



Coton Electrical

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS 7671: 2008

Part 1: Description

- Description of the minor works:
- Location and Address:
- Date completed:
- Departures from BS7671 (if any):

Part 2: Installation

- System earthing arrangement: TN-C-S TN-S TT Check Box 3
- Method of Fault Protection:
- Protective device for modified circuit: Type BS/EN Rating A Type C
- BS7671 requirements: Disconnection time s Max Z_s Ω
- Comments on the existing installation, including earthing and bonding (Reg 131.8):

Part 3: Tests

- Earth continuity: satisfactory
- Insulation resistance: Line/neutral MΩ
Line/earth MΩ or Line and neutral / earth MΩ
Neutral/earth MΩ
- Earth fault loop impedance: Ω
- Polarity: satisfactory
- RCD operation: Rated residual current I_{Δn} mA; operating time ms at I_{Δn} ms at 5I_{Δn}
- Multifunction meter

Part 4: Declaration

- I certify that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS7671:2008 (IEE Wiring Regulations), and that the said works, to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671 except as detailed in Part 1 of this certificate.
- Name: DAVID COTON (Principal) for and on behalf of COTON ELECTRICAL
Address:
- Signature:

Date:

GUIDANCE FOR RECIPIENTS

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed and inspected and tested in accordance with British Standard 7671, (the IEE Wiring Regulations).

You should have received an 'original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner.

A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

The Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the Certificate was issued.