



N:\CAD Data\Standard Dwg\Sanitary Sewer Details\SS-5.0\_AirVacuumRelVault\_A.dwg 3/28/2007 2:10:07 PM



HANSON PIPE & PRODUCTS, INC. CONCRETE VAULT 466-23, 6'-6" (L) X 4'-6" (W) X 6'-1" (D) OR APPROVED EQUAL. COVER NO. 23 WITH DUAL ACCESS DOORS, 3'-0" SQUARE, NON-SKID SURFACE, H2O RATED.



AIR VACUUM/RELEASE VAULT WITH ODOR CONTROL CANISTER

PLAN #



CITY OF BATTLE GROUND APPROVED

*San Adams* 3-28-07  
CITY ENGINEER DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	3/28/07	JMH	MCH

SS-5.0A