

# The Performance of Integrated Hydronic Heating Systems



---

**Dr. T. Butcher, Y. Celebi, and G. Wei**


**Aachener Ölwärme Kolloquium  
14. September 2006**

**Dr. Thomas A. Butcher**  
Building 526  
Brookhaven National Laboratory  
Upton, N.Y. 11973  
Tel. (631) 344 7916  
[butcher@bnl.gov](mailto:butcher@bnl.gov)



# Energy Cost Savings



?



?





# Objectives

---

- Compare annual fuel use of different combination systems
- Systems to include boilers, water heaters, storage tanks and control concepts. Oil and gas –fired.
- Impact of oversize decisions
- Consideration of jacket and near-boiler piping losses, location dependent
- Consideration of electric power
- Understanding sources of losses

# Units planned for tests


1. Cast iron, oil-fired boiler, severely oversized, fixed temperature, tankless coil
2. Cast iron, oil-fired boiler, slightly oversized, with indirect tank
3. Cast iron, oil-fired boiler, slightly oversized, with indirect tank, with outdoor reset control
4. Cast iron, oil-fired, well-insulated boiler with indirect tank
5. Steel, oil-fired, thermally purgable control with indirect tank
6. Water heater - dual use, oil-fired
7. Combi-system, oil-fired
8. Condensing oil boiler
9. Condensing, gas-fired with indirect tank
10. Cast iron, gas-fired with atmospheric burner, heat only, with outdoor reset
11. Cast iron, gas-fired with atmospheric burner, boiler and separate water heater

# End Products

---

- Basic performance curves for each unit
- Input / Output curves and idle loss
- Analysis of fuel use and electric power consumption when used in different applications
- Summary tables – stand alone communication tool
- Follow-on project planned for technology transfer

# Test Arrangement





IR-2

BROOKHAVEN NATIONAL LABORATORY


E=90  
142°F

07/28/05





## Daily distribution of hot water use (Gallons/hour)




# Units Tested to date


---

- Cast iron boiler with tankless coil
- Cast iron boiler with indirect DHW tank
- Steel boiler with indirect tank and purge control
- Condensing oil boiler
- Well insulated imported boiler with indirect


# CI boiler with tankless coil




# CI boiler with indirect




# Steel boiler



# Condensing oil boiler




# Evaluating Reset...







# Evaluating Reset



# Comparison of four systems



# Comparison of four systems



# Comparison of five systems

Unit	gph	Steady State Efficiency	Idle Loss (%)
1	1.46	83.7	1.2
2	.73	78.4	2.1
3	.78	86.5	.15
4	.55	92.0	1.5
5	.80	87.0	.6

## Inputs


Steady State Eff.	<input type="text" value="80.0"/>
Idle Loss	<input type="text" value="3.0"/>
Oversize	<input type="text" value="3.0"/>
Design Day Heat Load	<input type="text" value="40000"/>
Domestic Hot Water (gal/day)	<input type="text" value="64.3"/>
Oil Price (\$/gal)	<input type="text" value="2.50"/>
Inside / Isolated Location Factor	<input type="text" value="0"/>

Calculate

## Results

Seasonal Efficiency	<input type="text"/>
Annual Oil Used (gal)	<input type="text"/>
Annual Oil Cost (\$)	<input type="text"/>
Amount of oil wasted (gal)	<input type="text"/>
Cost of oil wasted (\$)	<input type="text"/>

End



## Inputs


Steady State Eff.	80.0
Idle Loss	3.0
Oversize	3.0
Design Day Heat Load	40000
Domestic Hot Water (gal/day)	64.3
Oil Price (\$/gal)	2.50
Inside / Isolated Location Factor	0

Calculate

## Results

Seasonal Efficiency	61
Annual Oil Used (gal)	1083
Annual Oil Cost (\$)	2709
Amount of oil wasted (gal)	422
Cost of oil wasted (\$)	1055

End



## Inputs


Steady State Eff.	88.0
Idle Loss	3.0
Overize	3.0
Design Day Heat Load	40000
Domestic Hot Water (gal/day)	64.3
Oil Price (\$/gal)	2.50
Inside / Isolated Location Factor	0

Calculate

## Results

Seasonal Efficiency	67.1
Annual Oil Used (gal)	985
Annual Oil Cost (\$)	2462
Amount of oil wasted (gal)	324
Cost of oil wasted (\$)	809

End





## Inputs


Steady State Eff.	88.0
Idle Loss	3.0
Overize	3.0
Design Day Heat Load	40000
Domestic Hot Water (gal/day)	64.3
Oil Price (\$/gal)	2.50
Inside / Isolated Location Factor	0

Calculate

## Results

Seasonal Efficiency	67.1
Annual Oil Used (gal)	985
Annual Oil Cost (\$)	2462
Amount of oil wasted (gal)	324
Cost of oil wasted (\$)	809

End



## Inputs


Steady State Eff.	88.0
Idle Loss	.15
Overize	3.0
Design Day Heat Load	40000
Domestic Hot Water (gal/day)	64.3
Oil Price (\$/gal)	2.50
Inside / Isolated Location Factor	0

Calculate

## Results

Seasonal Efficiency	86.7
Annual Oil Used (gal)	763
Annual Oil Cost (\$)	1908
Amount of oil wasted (gal)	102
Cost of oil wasted (\$)	255

End



## Inputs


Steady State Eff.	88.0
Idle Loss	.15
Oversize	3.0
Design Day Heat Load	40000
Domestic Hot Water (gal/day)	64.3
Oil Price (\$/gal)	2.50
Inside / Isolated Location Factor	0

Calculate

## Results


Seasonal Efficiency	86.7
Annual Oil Used (gal)	763
Annual Oil Cost (\$)	1908
Amount of oil wasted (gal)	102
Cost of oil wasted (\$)	255

End



	Steady State Efficiency	Idle Loss	Oversize Factor	Annual Efficiency	Annual Fuel Use	Reductio n from Baseline Case
	(%)	(%)	-	(%)	(gallons)	(%)
1- Baseline	82	3	2	68.7	855	0
2	88	3	2	73.7	797	6.8
3	92	1	2	86.4	680	20.5
4	88	.15	2	87.2	674	21.1
5	92	.15	2	91.1	645	24.6

# Oversizing



# Conclusions

---

- Linear input / output approach good for integrated systems
- Low load losses very big impact on annual fuel use
- As idle losses are reduced, impact of oversizing is reduced
- Opportunities for energy saving larger than steady state efficiency suggests

# Project Sponsors

---

- NORA
- New York State Energy Research and Development Authority