


Arsenic In NH


Cynthia M. Klevens, P.E. NH Department of Environmental Services Water Supply Engineering Bureau


SESSION IV: Making and Managing Arsenic Residuals from Drinking Water Supplies

> Arsenic and Landfills: Protecting Water Quality October 3-4, 2006, Boston, MA


NH PWS Arsenic Inventory (2005 - 2006)








A Closer Look : Detections < 20 ppb



Compliance Strategies



Treatment Technogies

Oxidation / Filtration	4	
POU - RO or Adsorption	5	
Anion Exchange	8	
Adsorption	95	
ArsenXnp		63
Adedge E-33		17
Activated Alumina		5
ATS Complex		5
Resintech		2
Isolux		1
ARM 200		1
ADI G2		1


NHDES Arsenic Studies

EPA Demonstration Projects – Adsorption / Iron Oxide Media - 3 sites, 2004 to present ♦ Borehole modification – 3 sites ♦ Total vs. Soluble ~25 sites to date ♦ As III speciation ~20 sites to date Actual Bedlife vs. Vendor Projections Backwash characterization ~12 sites, adsorption (2 medias), oxidation-filtration RSSCT setup (anticipated Nov-Dec 2006)

Rollinsford **Demo Project #1** ♦ Oct '04 to Mar '06 Adedge E33 media ♦ 27 CF/vessel x 2 S changeouts / abandoned technology! Oxid-Filtration 2-month trial Greensand piloting / install 4Q06


- Weekly Backwash, estim.
 2000 gal per event
- Backwash settling tanks / onsite sup't discharge





Bow, White Rock - Demo Project #2

 Oct 2004 to present ♦ ADI G2 media ♦ 85 CF/vessel x 2 First Changeout @ 6000 BV, TCLP<5 mg/L Backwash every 6 months, onsite infiltration ditch 1,700 gal backwash per vessel



NH Arsenic Residuals Policy

UIC Registrations all

- Backwash or salt regenerant sample for total arsenic
 - Backwash study 4Q06 to characterize total vs. filtered arsenic in onsite discharges

 Additional requirements depending on treatment technology

Discharge Requirements, cont'd

Adsorption

- Low backwash frequency
- Onsite discharge to drywell or infiltration ditch
- TCLP spent media prior to landfill
- Anion Exchange
 - Centralized leachfield or Sanitary Sewer
 - Same mass loading, all water returned to central septic or sewer
 - Weekly or biweekly regeneration cycle
- Oxidation / Filtration
 - Backwash settling tank or inline bag filter
 - Solids TCLP prior to landfill

Operational Problems...oh yeah!

Short bedlife adsorption medias

- 6,000 to 30,000 BV observed
- 50,000 to 250,000 BV promised
- Silica, Phosphate, pH, Manganese interferences
- Competition Installers / Operators
- Small Systems not used to process monitoring, sampling for compliance only
- Public Notice each O&M hiccup, schools in shock sending arsenic letters home!
- Need more Outreach, Funding, Field Data

Private Homes – No State Regulation

- Assume similar occurrence ~15%
- Central / Southern / Seacoast NH
- POU (one sink) vs. POE (whole house)
 - POU 30 to 70% depending on vendor, single contaminant target
 - POE if co-contaminants Iron, Manganese, Sulfide, Radon
- Liquid Residuals to home septic (salt, RO reject, filter backwash)
- Solid Residuals to regular trash



Visit us at www.des.state.nh.us

Water Supply Engineering Bureau <u>cklevens@des.state.nh.us</u> (603) 271-3108