

BASIN ELECTRIC POWER COOPERATIVE

**Site CS 5 Northern Border Waste Heat Recovery Generator
New Network Resource near:**

Killdeer, ND

(WAPA OASIS Request # 38131-03 GI-0404 and TSR Request # 841183)

**Prepared by:
Basin Electric Power Cooperative
Transmission Services Division
Bismarck, ND
May 15, 2008**

0.0 Executive Summary

The Upper Great Plains Region (UGPR) of the Western Area Power Administration (Western) received a generation interconnection request for an interconnection of a 7.5 MW waste heat generator to the Western/Heartland Consumers Power District/Basin Electric Power Cooperative Integrated System (IS) near Killdeer, North Dakota. This request is identified as Request GI-0404 on Western's Generation Interconnection Queue posted on its Open Access Same Time Information System (OASIS).

The Transmission Customer has submitted a Transmission Service Request #841183 in Western's OASIS Queue and the delivery of this requested new Designated Network Resource was also evaluated in this study.

The scope of this system impact study is limited to identifying and resolving possible criteria violations that may limit the ability of the generator to interconnect as well as the delivery of the unit as a baseload network resource. In accordance with WAPA system impact study practices, an interconnection request is required to mitigate stability impacts, short-circuit impacts and injection related steady state impacts (local area thermal and voltage impacts under system intact and contingency conditions). In addition, the delivery impacts of this unit have been evaluated through the 2016 time frame as the generation and delivery queue assumptions are the same.

These study results indicate the addition of the 7.5MW generator near Killdeer, ND will not degrade the reliability of the MAPP system and does not result in any unacceptable loading or voltage conditions in the area. No new constrained interfaces are required to accommodate the new generator. The generator improves the voltage profile in the areas studied and does not negatively impact the North Dakota export (NDEX) transient stability performance. The study results demonstrate that the Western Area Power Administration (Western)/ Basin Electric Power Cooperative (Basin)/ Heartland Consumers Power District Integrated System (IS) is capable of accommodating the new network resource request

Based upon these study results, the interconnection issues are confined to the local areas due to the relatively small size of the unit and amount of local load at the location that will consume the generation locally. Therefore, there is no increase in the transmission commitment for Basin Electric network load delivery across the NDEX constrained interface as a result of this new network resource approval.

Table of Contents

0.0 Executive Summary	2
1.0 Introduction	4
2.0 Study Methodology	5
2.1 Stability Analysis	5
2.2 Steady-State Analysis	5
2.2.1 System Intact Analysis.....	5
2.2.2 Contingency Analysis	6
2.3 Constrained Interface Analysis.....	6
3.0 Stability Analysis.....	7
3.1 Model Development - Summer Off-peak High Transfer Powerflow Models	7
4.0 Steady State Powerflow Analysis Procedure.....	9
4.1 Steady State Model Development.....	9
4.1.1 Summer Peak Model Development	9
4.1.2 Summer Off-peak High Transfer Model Development.....	9
4.2 2008 Summer Peak.....	10
4.2.1 System Intact.....	10
4.2.2 N-1 Conditions	10
4.3 2016 Summer Peak.....	10
4.3.1 System Intact.....	10
4.3.2 N-1 Conditions	10
4.4 2008 Summer off Peak Steady State Powerflow Analysis Results	11
4.4.1 System Intact.....	11
4.4.2 N-1 Conditions	11
4.5 Prior Outages	11
4.5.1 Antelope Valley – Charlie Creek 345 kV.....	11
5.0 Constrained Interface Analysis	12
6.0 Short-Circuit Analysis.....	17
6.1 Base Case Development.....	17
6.2 Short-Circuit Calculations	17
7.0 Conclusion	18
Appendix A – Case Descriptions	19
Appendix B – Maps and Onelines.....	20
Appendix C – Transient Stability Tables	21
Appendix D – Thermal and Voltage Analysis.....	22
Appendix E – Distribution Factor Analysis	23

1.0 Introduction

The purpose of this document is to provide information to the MAPP Design Review Subcommittee (DRS) regarding the addition of a new 7.5 MW waste heat recovery generator to be used as new network resource for BEPC. The new generator will be located on Basin Electric's member underlying distribution system. This site lies along the Northern Border Pipeline that runs through North and South Dakota. The generator associated with GI-0404 will be located at the Northern Border Pipeline pumping station CS-5. This generator will be fed into the bulk electric system via WAPA's Killdeer 115 kV substation. The geographic location of this substation can be seen in the following figure 1.1.



Figure 1.1 - Geographic location of Generation

2.0 Study Methodology

The PSS/E Power System Simulator for Engineers was used for this study. PTI PSS/ETM Rev 29.4 and Version 6.6B of the Digital FORTRAN Compiler was utilized to perform all aspects of the study work.

2.1 Stability Analysis

The purpose of the stability analysis is to determine whether the MAPP system would meet stability criteria following commissioning of the proposed GI-0404 plant. To that end, faults were simulated in Northern MAPP to assess the impact of the proposed project on transmission system stability. Preliminary solutions were identified and tested for faults that resulted in stability criteria violations.

2.2 Steady-State Analysis

The purpose of steady-state analysis is to analyze the impact of the proposed plant on transmission system facilities under steady-state conditions. It involves two distinct analyses: thermal analysis and voltage analysis.

2.2.1 System Intact Analysis

The incremental impact of the Killdeer plant on thermal loading of transmission facilities under system intact conditions was evaluated by comparing transmission system power flows with and without the proposed plant.

All transmission facilities rated 110 kV and above were monitored in the WAPA, OTP, GRE, MP, XEL and MH control areas. The criterion used to flag thermal overloads is 100% of continuous facility rating (Rate A in PSS/E). Significantly Affected Facilities (SAF) were identified based on the following criteria: All overloaded facilities that have a TDF (Transfer Distribution Factor) greater than 5% of the generation addition and an increase in flow of at least 1 MW (without plant vs. with plant) are flagged as significantly affected facilities.

Northern MAPP buses rated 110 kV and above were monitored for possible voltage violations. Voltages that were outside the values shown in Table 2.1 were flagged as violations. Those buses that have a voltage change of more than 0.01 p.u. (pre-project vs. post-project) are included in the SAF list.

System	Base kV	System Intact Conditions		N-1 Contingency Conditions	
		Max (pu)	Min (pu)	Max (pu)	Min (pu)
Northern MAPP	110-500 kV	1.05	0.95	1.10	0.90
MP (Area 608)	110-500 kV	1.05	1.00	1.05	0.95
MP Western Division (Area 610)	115-230 kV	1.05	0.96	1.05	0.92
OTP (Area 626)	230-345 kV	1.05	0.97	1.10	0.92
	115 kV	1.07	0.97	1.10	0.92

Figure 2.1 - Voltage Criteria for Steady-State Analysis

2.2.2 Contingency Analysis

Contingency analyses included single branch and selected multi-element contingencies on facilities rated 110 kV and above. Single branch as well as multi-terminal outages in WAPA, and single branch contingencies in GRE, MH, MP, OTP, and XEL were considered. Select multi-terminal outages were also considered in Northern MN. All facilities rated 110 kV and above were monitored in the WAPA, OTP, GRE, MP, XEL and MH control areas.

Contingencies were solved using activity ACCC of PSS/E, or some equivalent program (GRE's contingency program). Phase shifters and transformer taps were enabled. Thermal violations were flagged based on 100% of facility ratings (Rate A in PSS/E). Post-contingency power flows in excess of 100% of Rate A were recorded. Significantly Affected Facilities (SAF) were identified based on the following criteria: All overloaded facilities that have a TDF (Transfer Distribution Factor) greater than 3% of the generation addition and an increase in flow greater than 1 MW (pre-project vs. post-project) are flagged as significantly affected facilities.

If several contingencies overload a given transmission facility, only the worst fifteen contingencies are reported. Overloads on generator step up transformers are not reported.

As in the system intact analysis, Northern MAPP buses rated 110 kV and above were monitored for possible post-contingency voltage violations. Voltages that were outside the values shown in Table 2.1 were flagged as violations. Those buses that have a voltage change of more than 0.01 p.u. (pre-project vs. post-project) are included in the SAF list.

2.3 Constrained Interface Analysis

The purpose of the constrained interface analysis is to calculate the impact of the proposed project on specified interfaces in the MAPP transmission system. The MAPP DFCALC constrained interface analysis program was used for this purpose.

3.0 Stability Analysis

3.1 Model Development - Summer Off-peak High Transfer Powerflow Models

Cases used for dynamic stability analysis are taken from the NMORWG 2008 study package. The off-peak summer high transfer case (urg-so8aa.sav) with North Dakota coalfield generation at URGE output is used as a starting point for this study.

The following process was used to evaluate the differences of each option:

- Add a 60MVAR cap bank at the Groton 115 kV and at the 75 MVAR at the Watertown 230 kV buses to meet the requirements in the NDEX 2080 study.
- Document the transient stability performance of the existing system for the 2008 summer conditions at high simultaneous NDEX/MHEX/MWEX conditions of 2080/2175/1525 respectively.
- Document the stability performance of the resulting system with the generator online. Differences in power interfaces in the system were made to the swing bus and to loads, as the routine “setexports” requires.

The disturbances used to test the northern MAPP region included the ag1, ei2, and nmz disturbance files as well as the rest of the standard NMORWG disturbance files. These faults are defined as follows:

- **ag1** – Single line to ground fault on the Leland Olds to Fort Thompson 345 kV line with Leland Olds breaker stuck
- **ei2** – Permanent bipole fault on the Coal Creek DC line
- **nmz** – Three phase fault at Chisago, trip F601C, Cross trip D602F

Local faults were also developed to test the how the system and the cogen unit would react to faults in the area. Since the breakers are located at Charlie Creek and at Beulah, a fault on the 115 kV system will trip the entire 115 kV section of line as well as the cogen unit. The faults developed are as follows:

- **kb3** – Three Phase fault on the Killdeer to Halliday 115 kV line, Trip Charlie Creek to Beulah after 8 cycles

The fault files were used to check the transient response of the system with and without the generator online.

The following Table 3.1 shows that the addition of GI0404 does not change any of the transient voltages for the regional faults. Three critical buses that have been noted with low voltages in the past are compared.

	Groton 345 kV (PU) Transient Voltage Minimum			Wahpeton 115 kV (PU) Transient Voltage Minimum			Watertown 345 kV (PU) Transient Voltage Minimum		
	Disturbance			Disturbance			Disturbance		
	ag1	ei2	nmz	ag1	ei2	nmz	ag1	ei2	nmz
kc0-so08aa Base Case	0.83	0.81	0.71	0.95	0.85	0.80	0.92	0.87	0.76
kcg-so08aa GI0404 Added (7.5 MW)	0.83	0.81	0.71	0.95	0.85	0.80	0.92	0.87	0.76
Delta Impact	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Figure 3.1 - Transient Voltages at Critical Buses in MAPP Region

Figure 3.1 shows that the addition of the waste heat generator does not degrade the voltage performance during these regional disturbances. The corresponding stability summary tables for all the faults that were run can be found in Appendix C.

4.0 Steady State Powerflow Analysis Procedure

Steady state analysis was simulated in accordance with the MAPP DRS standards. Both single and multiple contingencies were run. To determine steady state results for each contingency, Contingency program developed by GRE was used. Single contingencies were created by the iplan for all areas within the MAPP region. Any cases that did not solve using this type of analysis were solved manually. The Contingency iplan monitors voltages and branch loading.

The Contingency analysis was run to flag any violations above 100% of Rate A, any voltage below 0.90 p.u, and any voltage and above 1.10 p.u during contingency scenarios. Any violations outside these limits were evaluated. A change in voltage of less than +/- 1% is considered a negligible effect. In addition, a loading increase of less than 1 MW is also considered a negligible effect.

4.1 Steady State Model Development

4.1.1 Summer Peak Model Development

The 2008 and 2016 cases were taken from the MAPP 2006 series models to serve as base cases for the GI0404 study. Existing and DRS approved area generation is energized at Pmax. Previously queued generation was also included in the 2008 and 2016 models according to the listed in-service dates.

The cases were created where the GI0404 generator was placed online and BEPC generation at Leland Olds unit 1 was scaled down by 7.5 MW to offset the increase in generation. The following Figure 4.2 lists the cases used for steady state analysis. To review the updates that were applied to these cases, please see the idevs located in [Appendix A](#).

MAPP 2006 series cases Summer Peak Load	GI0404	Comments
kc0-sp08aa.sav	0	Base Case GI0404 offline
kcg-sp08aa.sav	7.5	GI0404 online BEPC generation scaled down by 7.5 MW
kcl-sp08aa.sav	7.5	GI0404 online ND BEPC load scaled up by 7.5 MW
kc0-sp16aa.sav	0	Base Case GI0404 offline
kcg-sp16aa.sav	7.5	GI0404 online BEPC generation scaled down by 7.5 MW
kcl-sp16aa.sav	7.5	GI0404 online ND BEPC load scaled up by 7.5 MW

4.2 - Steady State Powerflow Models

The GI0404 waste heat cogenerator will be operated as a base load resource therefore a steady state power flow analysis is conducted with summer-peak conditions. The peak case will also demonstrate the heaviest loading for some local area lines.

4.1.2 Summer Off-peak High Transfer Model Development

Cases used for off peak high transfer thermal analysis are taken from the NMORWG 2008 study package. The off-peak summer high transfer case (urg-so8aa.sav) with North Dakota coalfield generation at URGE output is used as a starting point for this study.

There were several model changes and facility additions added to the model to properly model the prior queued generation. All changes made to these cases can be seen in Appendix A in PSSE format. The base case name was kc0-so08aa.sav.

The Northern Border cogen unit at Killdeer (gi0404) was added to the URGE base case. Unlike the dynamics cases where generation is turned off to get the worst case stability scenario, the thermal analysis includes all prior queued generation in the area online. The “setexports” routine was then used to maintain Manitoba Hydro Export (MHEX), North Dakota Export (NDEX), and Minnesota-Wisconsin Export (MWEX) at their maximum simultaneous limits in each of these cases. The following Figure 4.3 lists each case and its corresponding export levels.

2008 Summer Off-Peak Load Cases	NBCG4	NDEX	MHEX	MWEX	Comments
kc0-so08aa.sav	0	2080	2176	1525	Base Case NBCG4 offline
kcg-so08aa.sav	7.5	2080	2177	1525	NBCG4 online, exports reset

Figure 4.3 - High Transfer Steady State Models

4.2 2008 Summer Peak

4.2.1 System Intact

No facilities were significantly affected for system intact conditions during the 2008 summer peak season. All facilities were less than the 5% threshold required for system intact requirements. A complete listing of the 2008 system intact report can be seen in Appendix D.

4.2.2 N-1 Conditions

No facilities were significantly affected for contingency conditions during the 2008 summer peak season. All facilities were less than the 3% threshold required for contingency requirements. A complete listing of the 2008 contingency report can be seen in Appendix D.

4.3 2016 Summer Peak

4.3.1 System Intact

No facilities were significantly affected for system intact conditions during the 2016 summer peak season. All facilities were less than the 5% threshold required for system intact requirements. A complete listing of the 2016 system intact report can be seen in Appendix D.

4.3.2 N-1 Conditions

No facilities were significantly affected for N-1 contingency conditions during the 2016 summer peak season. However, there was one facility that was affected for an N-2 contingency situation during the 2016 summer peak season. The Belfield 345/230 kV transformer loads up to 108.6 % of its continuous rating for loss of both Leland Olds 345/230 kV transformers. This was an increase of 1.63 MVA from its base case loading at 108.1%. This double contingency is run due to the protection placed on the small transformer at Leland Olds to cross trip (if overloaded) for loss of the large transformer. The loading on the Belfield transformer is well below the 125% emergency limit of 390 MVA. Current operating procedures would monitor the generation at Leland Olds for loss of both of the transformers at that station.

4.4 2008 Summer off Peak Steady State Powerflow Analysis Results

4.4.1 System Intact

No facilities were significantly affected for system intact conditions during the 2008 summer off peak season. All facilities were less than the 5% threshold required for system intact requirements. A complete listing of the high transfer scenario system intact report can be seen in Appendix D.

4.4.2 N-1 Conditions

No facilities were significantly affected for contingency conditions during the 2008 summer off peak season. All facilities were less than the 3% threshold required for contingency requirements. A complete listing of the high transfer scenario contingency report can be seen in Appendix D.

4.5 Prior Outages

4.5.1 Antelope Valley – Charlie Creek 345 kV

The prior outage of the AVS to Charlie Creek 345 kV line has been determined to be the worst case prior outage for the area. Loss of this line creates a heavy through flow from Beulah to Charlie Creek. Loading and voltage on the 115 kV system has been a concern for this contingency especially with the increasing load in western North Dakota. The addition of the cogenerator unit at Killdeer has a beneficial impact for voltage support yet also increases the loading on the 115 kV segment from Killdeer to Charlie Creek. Loading on the Beulah to Charlie Creek line can be seen in the following figures 4.4 and 4.5

Line Segment	Rate A	System Intact Gen Off	System Intact Gen on	AVS – CC OS Gen Off	AVS – CC OS Gen on
Beulah – Haliday	120	14.5	12.1	84.8	82.1
Haliday - Killdeer	120	10.8	8.5	81.5	78.8
Killdeer – Charlie Creek	120	5.7	10.8	76.7	80.8

Figure 4.4 – SP08 Loading on 115 kV lines near Killdeer

Line Segment	Rate A	System Intact Gen Off	System Intact Gen on	AVS – CC OS Gen Off	AVS – CC OS Gen on
Beulah – Haliday	120	9.4	7.2	74.6	41.9
Haliday - Killdeer	120	5.2	3.0	71	68.3
Killdeer – Charlie Creek	120	1.2	4.7	65.9	70.2

Figure 4.5 – SP16 Loading on 115 kV lines near Killdeer

5.0 Constrained Interface Analysis

Constrained path analysis has been completed to assess the potential issues related to deliverability of the proposed generation. Analysis was completed using the 2008 and 2016 summer peak models that were used for steady state powerflow analysis. Both generation and load re-dispatch were considered. The analysis was completed using the DRS established “dfcalc.ipf” distribution factor calculation program, which measures the flows on all constrained interface ties, with and without the new generation. The net differences between the two cases are then compared to determine the total impact on each constrained interface. The net change in power flow across the interface is then divided by the new generation amount. This quantity equals the distribution factor. A distribution factor above 5% (for PTDF type flowgates) or 3% (for OTDF type flowgates) constitutes an impact on a constrained interface.

For the generation to load scenario, the Northern Border Waste heat recovery unit at pumping station 5 was added and BEPC’s load within the NDEX boundary was increased by 7.5 MW. For the generation-to-generation scenario, the generator was added and the Leland Olds Unit 1 was reduced by 7.5 MW. Results showed that the addition of the 7.5 MW generator at Killdeer does not create any unacceptable impacts on any MAPP or MISO constraints. All of the distribution factors (DF’s) are less than the cutoff thresholds 5% for the PTDF flowgates and 3% for the OTDF flowgates. The following Table 5.1 lists each of the interfaces and its corresponding distribution factor. The constrained interface reports can be seen in Appendix E.

PTDF				
Summer Peak 2008				
Constrained Interface	Load Dispatch		Generation Dispatch	
	(MW)	%	(MW)	%
COOPER_S	-0.10	-1.50%	0.00	0.49%
FTCAL_S	0.00	-0.56%	0.00	0.16%
GG5	-0.10	-1.74%	0.10	0.93%
GRIS_LNC	-0.10	-1.28%	0.00	0.44%
MNTSUMA_W	0.10	0.69%	0.00	-0.21%
NDEX	-0.40	-5.28%	0.10	1.57%
QUADCITY_W	0.10	0.70%	0.00	-0.23%
WNE_WKS	0.00	-0.65%	0.00	0.26%
MWEX	-0.10	-1.25%	0.00	0.50%
NDDC	0.00	0.00%	0.00	0.00%
MHEX_N+	0.10	0.86%	0.00	-0.38%
MHEX_S+	-0.10	-0.91%	0.00	0.38%
PRI-BYN	-0.10	-0.87%	0.00	0.38%
Y2DC	0.00	0.00%	0.00	0.00%
AHD_GPK	0.00	-0.50%	0.00	0.21%
EAUARP_XCEL	-0.10	-0.71%	0.00	0.27%
FORCHS_PTDF	-0.10	-1.63%	0.00	0.52%
LEECONELS	0.00	0.21%	0.00	-0.06%
MH_SPC_E+	-0.10	-1.12%	0.00	0.46%
MH_SPC_W+	0.10	1.14%	0.00	-0.47%

Figure 5.1 - 2008 PTDF Constrained Interface Analysis results

OTDF				
Summer Peak 2008				
Constrained Interface	Load Dispatch		Generation Dispatch	
	(MW)	%	(MW)	%
REASNOR_DPS	0.00	0.20%	0.00	-0.06%
S1226TEKAMAH	0.00	0.23%	0.00	-0.07%
S1226TEKAMAH	0.00	0.02%	0.00	-0.01%
HILLPAHILMON	0.00	0.16%	0.00	-0.05%
QUAD91CORD39	0.00	0.60%	0.00	-0.20%
CORD39QUAD91	0.00	0.52%	0.00	-0.17%
92HILLOUHILL	0.10	0.95%	0.00	-0.32%
PLYMSIOUXCTY	0.00	0.35%	0.00	-0.06%
ALBGARQUAST	0.00	-0.11%	0.00	0.04%
ARNVINARNHAZ	0.00	0.27%	0.00	-0.10%
BYCHEBYCHE	0.00	-0.25%	0.00	0.09%
DAVCALQUARCK	0.00	0.11%	0.00	-0.04%
HLSXFM TIFARN	0.00	0.20%	0.00	-0.08%
LACWGRLACSTI	0.00	0.52%	0.00	-0.17%
LEEBYREJNEL	0.00	-0.47%	0.00	0.15%
LKFFOXLKGWLM	0.00	0.01%	0.00	-0.03%
LORTRKWEMPAD	0.00	0.08%	0.00	-0.04%
PADXFMPADROE	0.00	0.00%	0.00	0.00%
POWREAMTZBON	0.00	0.27%	0.00	-0.08%
SALXFMQUADAV	0.00	0.20%	0.00	-0.07%
SALXFMWEMPAD	0.00	0.17%	0.00	-0.07%
SPETRILAKRAU	0.00	0.12%	0.00	-0.06%
SPHWMCSUMEMC	0.00	0.09%	0.00	-0.04%
CC-STN	-0.40	-4.72%	0.00	0.50%
STN-CC	0.40	4.76%	0.00	-0.50%
CC-CCT	-0.20	-2.68%	0.00	0.27%
CCT-CC	0.20	2.69%	0.00	-0.27%
CCTP-STN	-0.50	-7.03%	0.10	0.76%
STN-CCT	0.50	7.10%	-0.10	-0.77%

Figure 5.2 - 2008 OTDF Constrained Interface Analysis results

PTDF				
Summer Peak 2016				
Constrained Interface	Load Dispatch		Generation Dispatch	
	(MW)	%	(MW)	%
COOPER_S	-0.10	-1.01%	0.00	0.54%
FTCAL_S	0.00	-0.37%	0.00	0.19%
GG5	-0.10	-0.85%	0.10	0.92%
GRIS_LNC	0.00	-0.58%	0.00	0.36%
MNTSUMA_W	0.00	0.39%	0.00	-0.18%
NDEX	-0.20	-3.10%	0.00	0.14%
QUADCITY_W	0.00	0.28%	0.00	-0.22%
WNE_WKS	0.00	-0.36%	0.00	0.27%
MWEX	-0.10	-0.97%	0.10	0.74%
NDDC	0.00	-0.01%	0.00	0.00%
MHEX_N+	0.00	0.56%	-0.10	-1.49%
MHEX_S+	0.00	-0.58%	0.10	1.49%
PRI-BYN	0.00	0.00%	0.00	0.54%
Y2DC	0.00	0.00%	0.00	0.00%
AHD_GPK	0.00	-0.42%	0.00	0.32%
EAUARP_XCEL	0.00	-0.58%	0.00	0.40%
FORCHS_PTDF	-0.10	-1.77%	0.10	1.30%
LEECONELS	0.00	0.15%	0.00	-0.04%
MH_SPC_E+	-0.10	-1.59%	0.20	2.19%
MH_SPC_W+	0.10	1.62%	-0.20	-2.23%

Figure 5.3 - 2016 PTDF Constrained Interface Analysis results

OTDF				
Summer Peak 2016				
Constrained Interface	Load Dispatch		Generation Dispatch	
	(MW)	%	(MW)	%
REASNOR_DPS	0.00	0.11%	0.00	-0.04%
S1226TEKAMAH	0.00	0.13%	0.00	-0.08%
S1226TEKAMAH	0.00	0.01%	0.00	-0.01%
HILLPAHILMON	0.00	0.08%	0.00	-0.04%
QUAD91CORD39	0.00	0.24%	0.00	-0.19%
CORD39QUAD91	0.00	0.20%	0.00	-0.17%
92HILLOUHILL	0.00	0.50%	0.00	-0.35%
PLYMSIOUXCTY	0.00	0.19%	0.00	-0.03%
ALBGARQUAST	0.00	-0.08%	0.00	0.04%
ARNVINARNHAZ	0.00	0.15%	0.00	-0.13%
BYCHEBYCHE	0.00	-0.18%	0.00	0.09%
DAVCALQUARCK	0.00	0.12%	0.00	-0.06%
HLSXFMTIFARN	0.00	0.12%	0.00	-0.11%
LACWGRLACSTI	0.00	0.36%	0.00	-0.20%
LEEBYREJNEL	0.00	-0.33%	0.00	0.14%
LKFFOXLKGWLM	0.00	0.03%	0.00	-0.06%
LORTRKWEMPAD	0.00	0.07%	0.00	-0.05%
PADXFMPADROE	0.00	0.00%	0.00	0.00%
POWREAMTZBON	0.00	0.16%	0.00	-0.08%
SALXFMQUADAV	0.00	0.04%	0.00	-0.09%
SALXFMWEMPAD	0.00	0.04%	0.00	-0.08%
SPETRILAKRAU	0.00	0.11%	0.00	-0.09%
SPHWMCSUMEMC	0.00	0.05%	0.00	-0.04%
CC-STN	-0.30	-3.79%	0.10	0.88%
STN-CC	0.30	3.83%	-0.10	-0.89%
CC-CCT	-0.20	-2.21%	0.00	0.50%
CCT-CC	0.20	2.22%	0.00	-0.50%
CCTP-STN	-0.40	-5.80%	0.10	1.34%
STN-CCT	0.40	5.87%	-0.10	-1.36%

Figure 5.4 - 2016 OTDF Constrained Interface Analysis results

6.0 Short-Circuit Analysis

6.1 Base Case Development

The pre-project model required for this analysis is short-circuit case 01sc-062802.sav included in the 2008 NMORWG Study Package.

Starting from this case, a post-project case was developed by adding the proposed GI-0404 project and associated upgrades described in section 4. Suitable assumptions were made for the sequence data required for these additions.

6.2 Short-Circuit Calculations

Short-circuit calculations were performed to determine the impact of the proposed project on substation fault current levels. Three-phase and single-line-to-ground (SLG) symmetrical fault current levels were calculated at all study area buses rated 69 kV and above, both without and with the proposed project and the proposed network upgrades. In order to calculate fault current levels, classical fault assumptions were used with a pre-fault voltage of 1.0 p.u.

Figure 6.1 lists the three-phase and SLG fault current levels at the substations in the vicinity of GI-0404. The highest of these fault currents was compared against the lowest rated circuit breaker at each of these substations to determine whether or not the circuit breaker may be overstressed.

Lowest breaker ratings were not available for all of the area substations.

The comparison showed that the calculated fault current levels did not exceed the lowest breaker rating substations analyzed.

The calculated fault currents should be compared against the corresponding lowest breaker ratings when this information becomes available in order to determine whether existing breakers at these substations could become overstressed and whether mitigation may be required.

BUS			MIN. BREAKER RATING AMP	WITHOUT GI-0404 (1)		WITH GI-0404 (2)		CHANGE (2)-(1)	
NO.	NAME	kV		FAULT CURRENT (AMP)		FAULT CURRENT (AMP)		AMP	
				3-PH	SLG	3-PH	SLG	3-PH	SLG
67182	CHAR.CK7	115		9498	9586	9604	9657	106	71
66419	KILDEER7	115		4298	2943	4475	2998	177	55
66422	HALIDAY7	115		3764	2479	3829	2498	65	19
67205	BEULAH 7	115		8971	7722	9000	7736	29	14

Figure 6.1- GI-0404 Short Circuit comparison

7.0 Conclusion

The study results show that the addition of a GI0404 7.5MW Cogeneration unit to be fed into the bulk electric system through the Killdeer 115 kV bus does not degrade the reliability of the MAPP system. It provides minor steady state and contingency voltage support to the 115 kV transmission system from Charlie Creek to Beulah in west central North Dakota.

Summer Peak steady state analysis shows that the addition of the generator does not result in any voltage or loading violations for system intact and N-1 contingency scenarios. Contingency analysis showed that the addition of this unit increases the loading on an already overloaded facility at WAPA's Belfield station for an N-2 contingency situation. The Belfield transformer overloads above its continuous rating for loss of both Leland Olds 345/230 kV transformers but remains below its emergency rating.

The constrained interface analysis does not show any impacts to MAPP or MISO constrained interfaces.

Examination of stability analysis showed that all simulations are transiently stable and well damped. In addition, the stability analysis of the Northern MAPP region demonstrated that the addition of the unit did not degrade any transient voltages below criteria. The effect of the unit is negligible.

Appendix A – Case Descriptions

Appendix B – Maps and Onelines

Appendix C – Transient Stability Tables

Appendix D – Thermal and Voltage Analysis

Appendix E – Distribution Factor Analysis

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:56

KC0-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
 ND=318,MH=1283,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166

POWER FLOW SUMMARY

```

-----
NDEX:      318 MW      ECL-ARP:   228 MW
MHEX:     1283 MW     PRI-BYN:    94 MW
MWEX:      758 MW     AHD-SLK:   300 MW
KING-ECL:  457 MW     SLK-GPK:   147 MW
COOPER S:  200 MW     WNE-WKS:   299 MW
FTCAL S:   315 MW     GGS:      1366 MW
GRIS-LNC:  316 MW     QC WEST:   955 MW
    
```

LOAD LEVELS AS PERCENT OF 2008 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 3524.0 MW, 122.2% OF 2883.0 MW
 NSP (AREA 600) ***** MW, 100.2% OF 10581.0 MW
 MAN HYDRO (AREA 667) 2943.5 MW, 100.0% OF 2943.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	2943/ 290	MH total gross	4671	ATC West Import	496
Ont. total	23241/ 566	Wpg River	534	ATC SW Import	671
NW	0/ 0	7 Sisters	165	ATC SE Import	-190
Sask.	2952/ 99	OH total gross	23416	East Bias	114
MP	2074/ 188	northwest	0	SPC>WAPA (B10T)	166
NSP	10600/ 374	SPC total gross	3063	MH>SPC (3-230)	220
N. Dakota	3524/ 258	MP total gross	2186	MH>SPC (FALLS)	0
Manitoba	681 MVARs	ND Cfd AC gross	3089	OH>MH @Kenora	0
Ont. total	13540 MVARs	net	2918	OH>MP @Ft Fran	150
NW	0 MVARs	NSP East gross	2833	OH E>W @Wawa	-119
Sask.	699 MVARs	net	2698	OH>East USA	0
MP	11049 MVARs	West gross	2931	F601C @Forbes	798
NSP	1765 MVARs	net	2769	D602F @Dorsey	972
N. Dakota	782 MVARs	Total net	9409	L20D @Letell	265
ATC	14063/ 375	WAPA SD Hydro	1497	R50M @Richer	69
ATC	4266 MVARs	Pleasant Valley	422	G82R @Glenboro	-25
		LGS/Trimont	264		

SW MN Wind 1076
 N DAK WIND 221
 Swing Bus 1740

Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1 7-7	43/ 30%	Stinson	-1/ 109	CU (1,2)	1075
Wshell #2 7-7	43/ 30%	Boundary Dam	30/ 166	SQ BU (3,4)	450
Drayton#1 4-7	55/ 39%	Whiteshell	-42/ 0	MH Bipole 1	1476
Drayton#2 4-7	70/ 37%	Int Falls	-35/ 150	MH Bipole 2	1669
Dorsey #1 2-4	459/ 38%	St. Lawrence	17/ 0	MH (BP1+BP2)	3146
Dorsey #2 2-4	545/ 45%	Arrowhead	0/ 300	Miles City E>W	0
Forbes 2-4	89/ 13%			RCDC (15)	130
Stone Lk 3-5	150/ 50%			Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	383	600/ -330	Forbes 500	-10 400/ -450
SCE 1-3G	18.2	3	312	480/ -240	Fargo 13.2	-12 20/ -135
SCA 4-6G	18.2	3	312	480/ -240	Watertown 20.0	19 125/ -86
Total Margin		1008	1560/ -810	Series Caps	Num In Serv	
		552		Roseau 500	2 of 2	
				Chisago 500	1 of 1	

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	60	Arrowhead 230	80	Chisago T 9 34.5	25
Drayton 115	40	Blackberry 230	47	Chisago T 10 34.5	25
Drayton 13.8	0	Minntac 115	45	Forbes 230	0
Eau Claire(FS) 161	267	Riverton 230	47	Forbes 500	300
Kohlman Lake 115	160	Roseau Co.(FS) 230	30		0
Parkers Lk(FS) 115	0	Running (FS) 230	30	Fargo 115	27
Prairie (FS) 115	80	Running react 230	-20	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	0	Watertown 230	0
Red Rock 115	160		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	0
Split Rock(FS) 115	0	Laverendrye 110	98	Stone Lake 345	0
Sheyenne (FS) 115	120	Richer react 230	0	Stone Lk Reac 345	0

Wilton/Bemidji	115	43	St Vital	110	98	Stone Lake	161	0
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	100
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.022	Arrowhead	230 1.022	Whiteshell	110 119.1
Alexandria	115 1.014	Badoura	115 1.030	Kenora	220 249.3
Audubon	115 1.024	Blackberry	230 1.029	Dryden	220 252.8
Bemidji	115 1.021	Boise Cascade	13.8 1.033	Fort Frances	220 252.8
Byron	345 1.032	Boise Cascade	115 1.022	Mackenzie	220 253.6
Chisago Co.	345 1.034	ETCO	115 1.021	Lakehead	220 239.6
Chisago Co.	500 1.036	Forbes	230 1.038	Marathon	220 240.3
Drayton	230 1.022	Forbes	500 1.045	Wawa	220 237.3
Eau Claire	345 1.040	Hubbard	115 0.000	Mississagi	220 242.8
WEST FARIBAULT	115 1.006	Intl Falls	115 1.023	Fort Frances	118 120.7
LaPorte	115 1.015	Minntac	115 1.027	Lakehead	118 124.2
Maple River	230 1.034	Moranville	230 1.034	Birch	118 120.4
Marshall Tap	115 1.017	Riverton	230 1.023	Marathon	118 125.2
Owatonna	161 0.994	Running	230 1.028		0.000
Prairie	115 1.037	Shannon	230 1.027	Arrowhead	345 1.036
Prairie	230 1.028	Stinson MN	115 1.019	Stone Lake	345 1.043
Ramsey	230 1.014	Jamestown	345 0.985	Stone Lake	161 1.037
Roseau County	230 1.037	Groton	345 1.019	Gardner Park	345 1.020
Roseau County	500 1.076	Watertown	230 1.030	Weston	115 1.028
Sheyenne	230 1.037	Watertown	345 1.024	Arpin	345 1.031
Thief R Falls	115 1.019		0.000	Eau Claire	161 1.032
Tioga	230 1.030	Dorsey	230 1.045	Council Creek	161 0.999
Wahpeton	230 1.013	Dorsey	500 1.043	Hydro Lane	161 1.010
Winger	115 1.036		0.000	Wien	115 1.031
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

1)	B10T-Tioga (South)	GE OST	SLLP	334%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	688%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	1051%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	670%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	334%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	N/A	1996%	
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	742%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	1967%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:56

KCG-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
 ND=319,MH=1283,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166

POWER FLOW SUMMARY

```

-----
NDEX:      319 MW      ECL-ARP:   228 MW
MHEX:      1283 MW     PRI-BYN:    94 MW
MWEX:      758 MW     AHD-SLK:   300 MW
KING-ECL:  457 MW     SLK-GPK:   147 MW
COOPER S:  200 MW     WNE-WKS:   299 MW
FTCAL S:   315 MW     GGS:       1366 MW
GRIS-LNC:  316 MW     QC WEST:   955 MW
    
```

LOAD LEVELS AS PERCENT OF 2008 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 3524.0 MW, 122.2% OF 2883.0 MW
 NSP (AREA 600) ***** MW, 100.2% OF 10581.0 MW
 MAN HYDRO (AREA 667) 2943.5 MW, 100.0% OF 2943.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	2943/ 290	MH total gross	4671	ATC West Import	496
Ont. total	23241/ 566	Wpg River	534	ATC SW Import	671
NW	0/ 0	7 Sisters	165	ATC SE Import	-190
Sask.	2952/ 99	OH total gross	23416	East Bias	114
MP	2074/ 188	northwest	0	SPC>WAPA (B10T)	166
NSP	10600/ 374	SPC total gross	3063	MH>SPC (3-230)	220
N. Dakota	3524/ 258	MP total gross	2186	MH>SPC (FALLS)	0
Manitoba	681 MVARs	ND Cfd AC gross	3081	OH>MH @Kenora	0
Ont. total	13540 MVARs	net	2910	OH>MP @Ft Fran	150
NW	0 MVARs	NSP East gross	2833	OH E>W @Wawa	-119
Sask.	699 MVARs	net	2698	OH>East USA	0
MP	11049 MVARs	West gross	2931	F601C @Forbes	798
NSP	1765 MVARs	net	2769	D602F @Dorsey	973
N. Dakota	782 MVARs	Total net	9409	L20D @Letell	265
ATC	14063/ 375	WAPA SD Hydro	1497	R50M @Richer	69
ATC	4266 MVARs	Pleasant Valley	422	G82R @Glenboro	-25
		LGS/Trimont	264		

SW MN Wind 1076
 N DAK WIND 221
 Swing Bus 1740

Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1 7-7	43/ 30%	Stinson	-1/ 109	CU (1,2)	1075
Wshell #2 7-7	43/ 30%	Boundary Dam	30/ 166	SQ BU (3,4)	450
Drayton#1 4-7	55/ 39%	Whiteshell	-42/ 0	MH Bipole 1	1476
Drayton#2 4-7	70/ 37%	Int Falls	-35/ 150	MH Bipole 2	1669
Dorsey #1 2-4	459/ 38%	St. Lawrence	17/ 0	MH (BP1+BP2)	3146
Dorsey #2 2-4	545/ 45%	Arrowhead	0/ 300	Miles City E>W	0
Forbes 2-4	89/ 13%			RCDC (15)	130
Stone Lk 3-5	150/ 50%			Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	383	600/ -330	Forbes 500	-10 400/ -450
SCE 1-3G	18.2	3	312	480/ -240	Fargo 13.2	-12 20/ -135
SCA 4-6G	18.2	3	312	480/ -240	Watertown 20.0	19 125/ -86
Total Margin		1008	1560/ -810	Series Caps	Num In Serv	
		552		Roseau 500	2 of 2	
				Chisago 500	1 of 1	

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	60	Arrowhead 230	80	Chisago T 9 34.5	25
Drayton 115	40	Blackberry 230	47	Chisago T 10 34.5	25
Drayton 13.8	0	Minntac 115	45	Forbes 230	0
Eau Claire(FS) 161	267	Riverton 230	47	Forbes 500	300
Kohlman Lake 115	160	Roseau Co.(FS) 230	30		0
Parkers Lk(FS) 115	0	Running (FS) 230	30	Fargo 115	27
Prairie (FS) 115	80	Running react 230	-20	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	0	Watertown 230	0
Red Rock 115	160		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	0
Split Rock(FS) 115	0	Laverendrye 110	98	Stone Lake 345	0
Sheyenne (FS) 115	120	Richer react 230	0	Stone Lk Reac 345	0

Wilton/Bemidji	115	43	St Vital	110	98	Stone Lake	161	0
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	100
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.022	Arrowhead	230 1.022	Whiteshell	110 119.1
Alexandria	115 1.014	Badoura	115 1.030	Kenora	220 249.3
Audubon	115 1.024	Blackberry	230 1.029	Dryden	220 252.8
Bemidji	115 1.021	Boise Cascade	13.8 1.033	Fort Frances	220 252.8
Byron	345 1.032	Boise Cascade	115 1.022	Mackenzie	220 253.6
Chisago Co.	345 1.034	ETCO	115 1.021	Lakehead	220 239.6
Chisago Co.	500 1.036	Forbes	230 1.038	Marathon	220 240.3
Drayton	230 1.022	Forbes	500 1.045	Wawa	220 237.3
Eau Claire	345 1.040	Hubbard	115 0.000	Mississagi	220 242.8
WEST FARIBAULT	115 1.006	Intl Falls	115 1.023	Fort Frances	118 120.7
LaPorte	115 1.015	Minntac	115 1.027	Lakehead	118 124.2
Maple River	230 1.034	Moranville	230 1.034	Birch	118 120.4
Marshall Tap	115 1.017	Riverton	230 1.023	Marathon	118 125.2
Owatonna	161 0.994	Running	230 1.028		0.000
Prairie	115 1.037	Shannon	230 1.027	Arrowhead	345 1.036
Prairie	230 1.028	Stinson MN	115 1.019	Stone Lake	345 1.043
Ramsey	230 1.014	Jamestown	345 0.985	Stone Lake	161 1.037
Roseau County	230 1.037	Groton	345 1.019	Gardner Park	345 1.020
Roseau County	500 1.076	Watertown	230 1.030	Weston	115 1.028
Sheyenne	230 1.037	Watertown	345 1.024	Arpin	345 1.031
Thief R Falls	115 1.019		0.000	Eau Claire	161 1.032
Tioga	230 1.031	Dorsey	230 1.045	Council Creek	161 0.999
Wahpeton	230 1.013	Dorsey	500 1.043	Hydro Lane	161 1.010
Winger	115 1.036		0.000	Wien	115 1.031
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

1)	B10T-Tioga (South)	GE OST	SLLP	335%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	689%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	1051%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	669%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	334%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	N/A	1996%	
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	742%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	1967%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:56

KCL-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
 ND=318,MH=1282,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166

POWER FLOW SUMMARY

```

-----
NDEX:      318 MW      ECL-ARP:   228 MW
MHEX:      1282 MW     PRI-BYN:    94 MW
MWEX:      758 MW     AHD-SLK:   300 MW
KING-ECL:  457 MW     SLK-GPK:   147 MW
COOPER S:  200 MW     WNE-WKS:   299 MW
FTCAL S:   315 MW     GGS:       1366 MW
GRIS-LNC:  316 MW     QC WEST:   955 MW
    
```

LOAD LEVELS AS PERCENT OF 2008 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 3531.5 MW, 122.5% OF 2883.0 MW
 NSP (AREA 600) ***** MW, 100.2% OF 10581.0 MW
 MAN HYDRO (AREA 667) 2943.5 MW, 100.0% OF 2943.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	2943/ 290	MH total gross	4671	ATC West Import	496
Ont. total	23241/ 566	Wpg River	534	ATC SW Import	671
NW	0/ 0	7 Sisters	165	ATC SE Import	-190
Sask.	2952/ 99	OH total gross	23416	East Bias	114
MP	2074/ 188	northwest	0	SPC>WAPA (B10T)	166
NSP	10600/ 374	SPC total gross	3063	MH>SPC (3-230)	220
N. Dakota	3531/ 258	MP total gross	2186	MH>SPC (FALLS)	0
Manitoba	681 MVARs	ND Cfd AC gross	3089	OH>MH @Kenora	0
Ont. total	13540 MVARs	net	2918	OH>MP @Ft Fran	150
NW	0 MVARs	NSP East gross	2833	OH E>W @Wawa	-119
Sask.	699 MVARs	net	2698	OH>East USA	0
MP	11049 MVARs	West gross	2931	F601C @Forbes	798
NSP	1765 MVARs	net	2769	D602F @Dorsey	972
N. Dakota	782 MVARs	Total net	9409	L20D @Letell	265
ATC	14063/ 375	WAPA SD Hydro	1497	R50M @Richer	69
ATC	4266 MVARs	Pleasant Valley	422	G82R @Glenboro	-25
		LGS/Trimont	264		

SW MN Wind 1076
 N DAK WIND 221
 Swing Bus 1741

Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1 7-7	43/ 30%	Stinson	-1/ 109	CU (1,2)	1075
Wshell #2 7-7	43/ 30%	Boundary Dam	30/ 166	SQ BU (3,4)	450
Drayton#1 4-7	55/ 39%	Whiteshell	-42/ 0	MH Bipole 1	1475
Drayton#2 4-7	70/ 37%	Int Falls	-35/ 150	MH Bipole 2	1669
Dorsey #1 2-4	459/ 38%	St. Lawrence	17/ 0	MH (BP1+BP2)	3145
Dorsey #2 2-4	545/ 45%	Arrowhead	0/ 300	Miles City E>W	0
Forbes 2-4	89/ 13%			RCDC (15)	130
Stone Lk 3-5	150/ 50%			Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	383	600/ -330	Forbes 500	-10 400/ -450
SCE 1-3G	18.2	3	312	480/ -240	Fargo 13.2	-12 20/ -135
SCA 4-6G	18.2	3	312	480/ -240	Watertown 20.0	19 125/ -86
Total Margin		1008	1560/ -810	Series Caps	Num In Serv	
		552		Roseau 500	2 of 2	
				Chisago 500	1 of 1	

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	60	Arrowhead 230	80	Chisago T 9 34.5	25
Drayton 115	40	Blackberry 230	47	Chisago T 10 34.5	25
Drayton 13.8	0	Minntac 115	45	Forbes 230	0
Eau Claire(FS) 161	267	Riverton 230	47	Forbes 500	300
Kohlman Lake 115	160	Roseau Co.(FS) 230	30		0
Parkers Lk(FS) 115	0	Running (FS) 230	30	Fargo 115	27
Prairie (FS) 115	80	Running react 230	-20	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	0	Watertown 230	0
Red Rock 115	160		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	0
Split Rock(FS) 115	0	Laverendrye 110	98	Stone Lake 345	0
Sheyenne (FS) 115	120	Richer react 230	0	Stone Lk Reac 345	0

Wilton/Bemidji	115	43	St Vital	110	98	Stone Lake	161	0
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	100
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.022	Arrowhead	230 1.022	Whiteshell	110 119.1
Alexandria	115 1.014	Badoura	115 1.030	Kenora	220 249.3
Audubon	115 1.024	Blackberry	230 1.029	Dryden	220 252.8
Bemidji	115 1.021	Boise Cascade	13.8 1.033	Fort Frances	220 252.8
Byron	345 1.032	Boise Cascade	115 1.022	Mackenzie	220 253.6
Chisago Co.	345 1.034	ETCO	115 1.021	Lakehead	220 239.6
Chisago Co.	500 1.036	Forbes	230 1.038	Marathon	220 240.3
Drayton	230 1.022	Forbes	500 1.045	Wawa	220 237.3
Eau Claire	345 1.040	Hubbard	115 0.000	Mississagi	220 242.8
WEST FARIBAULT	115 1.006	Intl Falls	115 1.023	Fort Frances	118 120.7
LaPorte	115 1.015	Minntac	115 1.027	Lakehead	118 124.2
Maple River	230 1.034	Moranville	230 1.034	Birch	118 120.4
Marshall Tap	115 1.017	Riverton	230 1.023	Marathon	118 125.2
Owatonna	161 0.994	Running	230 1.028		0.000
Prairie	115 1.037	Shannon	230 1.027	Arrowhead	345 1.036
Prairie	230 1.028	Stinson MN	115 1.019	Stone Lake	345 1.043
Ramsey	230 1.014	Jamestown	345 0.985	Stone Lake	161 1.037
Roseau County	230 1.037	Groton	345 1.019	Gardner Park	345 1.020
Roseau County	500 1.076	Watertown	230 1.030	Weston	115 1.028
Sheyenne	230 1.037	Watertown	345 1.024	Arpin	345 1.031
Thief R Falls	115 1.018		0.000	Eau Claire	161 1.032
Tioga	230 1.030	Dorsey	230 1.045	Council Creek	161 0.999
Wahpeton	230 1.013	Dorsey	500 1.043	Hydro Lane	161 1.010
Winger	115 1.036		0.000	Wien	115 1.031
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

kcl-sp08.pfinfo

02/20/2008

1)	B10T-Tioga (South)	GE OST	SLLP	334%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	687%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	1051%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	670%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	334%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	N/A	1998%	
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	742%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	1967%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:57

KC0-SP16AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
 ND=9,MH=1056,MW=390,OHMH=3,OHMP=152,EWTW=-116,BD=169

P O W E R F L O W S U M M A R Y

```

-----
NDEX:      9 MW      ECL-ARP:  133 MW
MHEX:     843 MW     PRI-BYN:   -83 MW
MWEX:     390 MW     AHD-SLK:  125 MW
KING-ECL: 265 MW     SLK-GPK:   -6 MW
COOPER S:  75 MW     WNE-WKS:  247 MW
FTCAL S:  124 MW     GGS:      1308 MW
GRIS-LNC: 104 MW     QC WEST:  1133 MW
    
```

LOAD LEVELS AS PERCENT OF 2016 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 4544.3 MW, 122.5% OF 3710.2 MW
 NSP (AREA 600) ***** MW, 100.1% OF 11889.2 MW
 MAN HYDRO (AREA 667) 3076.3 MW, 100.0% OF 3076.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	3076/ 228	MH total gross	4305	ATC West Import	332
Ont. total	23241/ 563	Wpg River	476	ATC SW Import	1060
NW	0/ 0	7 Sisters	165	ATC SE Import	-590
Sask.	3239/ 114	OH total gross	23417	East Bias	108
MP	2376/ 213	northwest	0	SPC>WAPA (B10T)	169
NSP	11895/ 401	SPC total gross	3353	MH>SPC (3-230)	233
N. Dakota	4544/ 258	MP total gross	2269	MH>SPC (FALLS)	-62
Manitoba	715 MVARs	ND Cfd AC gross	2974	OH>MH @Kenora	3
Ont. total	13590 MVARs	net	2805	OH>MP @Ft Fran	152
NW	0 MVARs	NSP East gross	2396	OH E>W @Wawa	-116
Sask.	761 MVARs	net	2290	OH>East USA	0
MP	8309 MVARs	West gross	3062	F601C @Forbes	303
NSP	2046 MVARs	net	2900	D602F @Dorsey	0
N. Dakota	1080 MVARs	Total net	11567	L20D @Letell	219
ATC	16817/ 432	WAPA SD Hydro	0	R50M @Richer	51
ATC	5062 MVARs	Pleasant Valley	422	G82R @Glenboro	-26
		LGS/Trimont	264		

SW MN Wind 1076
 N DAK WIND 221
 Swing Bus 2129

Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1 7-7	41/ 29%	Stinson	-7/ 108	CU (1,2)	1104
Wshell #2 7-7	41/ 29%	Boundary Dam	16/ 170	SQ BU (3,4)	450
Drayton#1 4-7	52/ 37%	Whiteshell	-70/ -3	MH Bipole 1	1058
Drayton#2 4-7	66/ 35%	Int Falls	-61/ 151	MH Bipole 2	1198
Dorsey #1 2-4	276/ 23%	St. Lawrence	16/ 0	MH (BP1+BP2)	2256
Dorsey #2 2-4	357/ 29%	Arrowhead	0/ 125	Miles City E>W	0
Forbes 2-4	140/ 20%			RCDC (15)	130
Stone Lk 3-5	136/ 45%			Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	69 600/ -330	Forbes	500 -8	400/ -450
SCE 1-3G	18.2	3	56 480/ -240	Fargo	13.2 -4	20/ -135
SCA 4-6G	18.2	3	56 480/ -240	Watertown	20.0 27	125/ -86
Total Margin		183	1560/ -810	Series Caps		Num In Serv
		1377		Roseau	500	2 of 2
				Chisago	500	1 of 1

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	0	Arrowhead 230	120	Chisago T 9 34.5	25
Drayton 115	40	Blackberry 230	47	Chisago T 10 34.5	25
Drayton 13.8	0	Minntac 115	45	Forbes 230	0
Eau Claire(FS) 161	267	Riverton 230	47	Forbes 500	0
Kohlman Lake 115	240	Roseau Co.(FS) 230	0		0
Parkers Lk(FS) 115	0	Running (FS) 230	0	Fargo 115	54
Prairie (FS) 115	120	Running react 230	-20	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	36	Watertown 230	0
Red Rock 115	160		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	0
Split Rock(FS) 115	0	Laverendrye 110	98	Stone Lake 345	0
Sheyenne (FS) 115	120	Richer react 230	0	Stone Lk Reac 345	0

Wilton/Bemidji	115	43	St Vital	110	98	Stone Lake	161	0
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	50
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.014	Arrowhead	230 1.027	Whiteshell	110 119.1
Alexandria	115 1.020	Badoura	115 0.991	Kenora	220 251.2
Audubon	115 1.006	Blackberry	230 1.028	Dryden	220 254.7
Bemidji	115 1.015	Boise Cascade	13.8 1.045	Fort Frances	220 254.5
Byron	345 1.027	Boise Cascade	115 1.034	Mackenzie	220 254.1
Chisago Co.	345 1.034	ETCO	115 1.018	Lakehead	220 238.9
Chisago Co.	500 1.034	Forbes	230 1.026	Marathon	220 242.2
Drayton	230 1.031	Forbes	500 1.023	Wawa	220 240.6
Eau Claire	345 1.041	Hubbard	115 0.000	Mississagi	220 245.1
WEST FARIBAULT	115 1.006	Intl Falls	115 1.035	Fort Frances	118 121.7
LaPorte	115 0.993	Minntac	115 1.026	Lakehead	118 123.3
Maple River	230 1.025	Moranville	230 1.027	Birch	118 119.9
Marshall Tap	115 1.007	Riverton	230 1.002	Marathon	118 124.4
Owatonna	161 0.984	Running	230 1.018		0.000
Prairie	115 1.051	Shannon	230 1.031	Arrowhead	345 1.050
Prairie	230 1.035	Stinson MN	115 1.020	Stone Lake	345 1.053
Ramsey	230 1.001	Jamestown	345 0.986	Stone Lake	161 1.041
Roseau County	230 1.027	Groton	345 1.022	Gardner Park	345 1.020
Roseau County	500 1.048	Watertown	230 1.030	Weston	115 1.029
Sheyenne	230 1.029	Watertown	345 1.026	Arpin	345 1.024
Thief R Falls	115 1.018		0.000	Eau Claire	161 1.028
Tioga	230 1.024	Dorsey	230 1.045	Council Creek	161 0.960
Wahpeton	230 1.000	Dorsey	500 1.040	Hydro Lane	161 1.004
Winger	115 1.033		0.000	Wien	115 1.029
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

1)	B10T-Tioga (South)	GE OST	SLLP	315%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	652%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	999999%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	1170%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	339%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	N/A	1207%	
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	969%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	3164%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:58

KCG-SP16AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
 ND=9,MH=1056,MW=390,OHMH=3,OHMP=152,EWTW=-116,BD=169

P O W E R F L O W S U M M A R Y

```

-----
NDEX:          9 MW          ECL-ARP:  133 MW
MHEX:         843 MW         PRI-BYN:   -83 MW
MWEX:         390 MW         AHD-SLK:  125 MW
KING-ECL:     265 MW         SLK-GPK:   -6 MW
COOPER S:      75 MW         WNE-WKS:  247 MW
FTCAL S:     124 MW         GGS:      1308 MW
GRIS-LNC:     104 MW         QC WEST:  1133 MW
    
```

LOAD LEVELS AS PERCENT OF 2016 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 4544.3 MW, 122.5% OF 3710.2 MW
 NSP (AREA 600) ***** MW, 100.1% OF 11889.2 MW
 MAN HYDRO (AREA 667) 3076.3 MW, 100.0% OF 3076.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	3076/ 228	MH total gross	4305	ATC West Import	332
Ont. total	23241/ 563	Wpg River	476	ATC SW Import	1060
NW	0/ 0	7 Sisters	165	ATC SE Import	-590
Sask.	3239/ 114	OH total gross	23417	East Bias	108
MP	2376/ 213	northwest	0	SPC>WAPA (B10T)	169
NSP	11895/ 401	SPC total gross	3353	MH>SPC (3-230)	232
N. Dakota	4544/ 258	MP total gross	2269	MH>SPC (FALLS)	-62
Manitoba	715 MVARs	ND Cfd AC gross	2967	OH>MH @Kenora	3
Ont. total	13590 MVARs	net	2797	OH>MP @Ft Fran	152
NW	0 MVARs	NSP East gross	2396	OH E>W @Wawa	-116
Sask.	761 MVARs	net	2290	OH>East USA	0
MP	8309 MVARs	West gross	3062	F601C @Forbes	303
NSP	2046 MVARs	net	2900	D602F @Dorsey	0
N. Dakota	1080 MVARs	Total net	11567	L20D @Letell	219
ATC	16817/ 432	WAPA SD Hydro	0	R50M @Richer	51
ATC	5062 MVARs	Pleasant Valley	422	G82R @Glenboro	-25
		LGS/Trimont	264		

SW MN Wind 1076
 N DAK WIND 221
 Swing Bus 2129

Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1 7-7	41/ 29%	Stinson	-7/ 108	CU (1,2)	1103
Wshell #2 7-7	41/ 29%	Boundary Dam	16/ 170	SQ BU (3,4)	450
Drayton#1 4-7	52/ 37%	Whiteshell	-70/ -3	MH Bipole 1	1058
Drayton#2 4-7	66/ 35%	Int Falls	-61/ 151	MH Bipole 2	1198
Dorsey #1 2-4	276/ 23%	St. Lawrence	16/ 0	MH (BP1+BP2)	2256
Dorsey #2 2-4	357/ 29%	Arrowhead	0/ 125	Miles City E>W	0
Forbes 2-4	140/ 20%			RCDC (15)	130
Stone Lk 3-5	136/ 45%			Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	69	600/ -330	Forbes 500	-8 400/ -450
SCE 1-3G	18.2	3	56	480/ -240	Fargo 13.2	-4 20/ -135
SCA 4-6G	18.2	3	56	480/ -240	Watertown 20.0	27 125/ -86
Total Margin		183	1560/ -810	Series Caps	Num In Serv	
		1377		Roseau 500	2 of 2	
				Chisago 500	1 of 1	

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	0	Arrowhead 230	120	Chisago T 9 34.5	25
Drayton 115	40	Blackberry 230	47	Chisago T 10 34.5	25
Drayton 13.8	0	Minntac 115	45	Forbes 230	0
Eau Claire(FS) 161	267	Riverton 230	47	Forbes 500	0
Kohlman Lake 115	240	Roseau Co.(FS) 230	0		0
Parkers Lk(FS) 115	0	Running (FS) 230	0	Fargo 115	54
Prairie (FS) 115	120	Running react 230	-20	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	36	Watertown 230	0
Red Rock 115	160		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	0
Split Rock(FS) 115	0	Laverendrye 110	98	Stone Lake 345	0
Sheyenne (FS) 115	120	Richer react 230	0	Stone Lk Reac 345	0

Wilton/Bemidji	115	43	St Vital	110	98	Stone Lake	161	0
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	50
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.014	Arrowhead	230 1.027	Whiteshell	110 119.1
Alexandria	115 1.020	Badoura	115 0.991	Kenora	220 251.2
Audubon	115 1.006	Blackberry	230 1.028	Dryden	220 254.7
Bemidji	115 1.015	Boise Cascade	13.8 1.045	Fort Frances	220 254.5
Byron	345 1.027	Boise Cascade	115 1.034	Mackenzie	220 254.1
Chisago Co.	345 1.034	ETCO	115 1.018	Lakehead	220 238.9
Chisago Co.	500 1.034	Forbes	230 1.026	Marathon	220 242.2
Drayton	230 1.031	Forbes	500 1.023	Wawa	220 240.6
Eau Claire	345 1.041	Hubbard	115 0.000	Mississagi	220 245.1
WEST FARIBAULT	115 1.006	Intl Falls	115 1.035	Fort Frances	118 121.7
LaPorte	115 0.993	Minntac	115 1.026	Lakehead	118 123.3
Maple River	230 1.025	Moranville	230 1.027	Birch	118 119.9
Marshall Tap	115 1.007	Riverton	230 1.002	Marathon	118 124.4
Owatonna	161 0.984	Running	230 1.018		0.000
Prairie	115 1.051	Shannon	230 1.031	Arrowhead	345 1.050
Prairie	230 1.035	Stinson MN	115 1.020	Stone Lake	345 1.053
Ramsey	230 1.001	Jamestown	345 0.986	Stone Lake	161 1.041
Roseau County	230 1.027	Groton	345 1.022	Gardner Park	345 1.020
Roseau County	500 1.048	Watertown	230 1.030	Weston	115 1.029
Sheyenne	230 1.029	Watertown	345 1.026	Arpin	345 1.024
Thief R Falls	115 1.018		0.000	Eau Claire	161 1.028
Tioga	230 1.024	Dorsey	230 1.045	Council Creek	161 0.960
Wahpeton	230 1.000	Dorsey	500 1.040	Hydro Lane	161 1.004
Winger	115 1.033		0.000	Wien	115 1.029
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

kcg-sp16.pfinfo

02/20/2008

1)	B10T-Tioga (South)	GE OST	SLLP	316%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	653%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	999999%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	1169%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	339%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	N/A	1208%	
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	969%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	3163%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:58

KCL-SP16AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
 ND=4,MH=1057,MW=388,OHMH=0,OHMP=150,EWTW=-120,BD=165

POWER FLOW SUMMARY

```

-----
NDEX:      4 MW      ECL-ARP:  132 MW
MHEX:     845 MW     PRI-BYN:   -84 MW
MWEX:     388 MW     AHD-SLK:  124 MW
KING-ECL: 264 MW     SLK-GPK:   -7 MW
COOPER S:  74 MW     WNE-WKS:  246 MW
FTCAL S:  123 MW     GGS:      1308 MW
GRIS-LNC:  104 MW     QC WEST:  1134 MW
    
```

LOAD LEVELS AS PERCENT OF 2016 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 4551.8 MW, 122.7% OF 3710.2 MW
 NSP (AREA 600) ***** MW, 100.1% OF 11889.2 MW
 MAN HYDRO (AREA 667) 3076.3 MW, 100.0% OF 3076.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	3076/ 228	MH total gross	4305	ATC West Import	331
Ont. total	23241/ 564	Wpg River	476	ATC SW Import	1060
NW	0/ 0	7 Sisters	165	ATC SE Import	-590
Sask.	3239/ 114	OH total gross	23417	East Bias	108
MP	2376/ 213	northwest	0	SPC>WAPA (B10T)	165
NSP	11895/ 401	SPC total gross	3353	MH>SPC (3-230)	228
N. Dakota	4551/ 258	MP total gross	2269	MH>SPC (FALLS)	-62
Manitoba	715 MVARs	ND Cfd AC gross	2974	OH>MH @Kenora	0
Ont. total	13590 MVARs	net	2805	OH>MP @Ft Fran	150
NW	0 MVARs	NSP East gross	2396	OH E>W @Wawa	-120
Sask.	761 MVARs	net	2290	OH>East USA	0
MP	8310 MVARs	West gross	3062	F601C @Forbes	302
NSP	2046 MVARs	net	2900	D602F @Dorsey	0
N. Dakota	1080 MVARs	Total net	11567	L20D @Letell	219
ATC	16817/ 432	WAPA SD Hydro	0	R50M @Richer	51
ATC	5062 MVARs	Pleasant Valley	422	G82R @Glenboro	-25
		LGS/Trimont	264		

SW MN Wind 1076
 N DAK WIND 221
 Swing Bus 2131

Tfmrs	MVA/ Load	Ph Shifters	Deg/	MW	DC Lines	MW
Wshell #1	7-7 42/ 29%	Stinson	-7/	109	CU (1,2)	1103
Wshell #2	7-7 42/ 29%	Boundary Dam	15/	165	SQ BU (3,4)	450
Drayton#1	4-7 52/ 37%	Whiteshell	-72/	0	MH Bipole 1	1058
Drayton#2	4-7 67/ 35%	Int Falls	-63/	150	MH Bipole 2	1198
Dorsey #1	2-4 277/ 23%	St. Lawrence	16/	0	MH (BP1+BP2)	2256
Dorsey #2	2-4 357/ 29%	Arrowhead	0/	124	Miles City E>W	0
Forbes	2-4 140/ 20%				RCDC (15)	130
Stone Lk	3-5 134/ 44%				Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	69 600/ -330	Forbes	500	-8 400/ -450
SCE 1-3G	18.2	3	56 480/ -240	Fargo	13.2	-4 20/ -135
SCA 4-6G	18.2	3	56 480/ -240	Watertown	20.0	27 125/ -86
Total Margin		183	1560/ -810	Series Caps		Num In Serv
		1377		Roseau	500	2 of 2
				Chisago	500	1 of 1

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS)	230 0	Arrowhead	230 120	Chisago T 9	34.5 25
Drayton	115 40	Blackberry	230 47	Chisago T 10	34.5 25
Drayton	13.8 0	Minntac	115 45	Forbes	230 0
Eau Claire(FS)	161 267	Riverton	230 47	Forbes	500 0
Kohlman Lake	115 240	Roseau Co.(FS)	230 0		0
Parkers Lk(FS)	115 0	Running (FS)	230 0	Fargo	115 54
Prairie (FS)	115 120	Running react	230 -20	Watertown	20 20
Ramsey (FS)	230 0	Shannon	230 36	Watertown	230 0
Red Rock	115 160		0		0
Rugby	13.8 -25	Glenboro	230 0	Arrowhead	345 0
Split Rock(FS)	115 0	Laverendrye	110 98	Stone Lake	345 0
Sheyenne (FS)	115 120	Richer react	230 0	Stone Lk Reac	345 0

Wilton/Bemidji	115	43	St Vital	110	98	Stone Lake	161	0
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	50
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.014	Arrowhead	230 1.027	Whiteshell	110 119.1
Alexandria	115 1.020	Badoura	115 0.991	Kenora	220 251.3
Audubon	115 1.006	Blackberry	230 1.028	Dryden	220 254.7
Bemidji	115 1.015	Boise Cascade	13.8 1.046	Fort Frances	220 254.6
Byron	345 1.027	Boise Cascade	115 1.034	Mackenzie	220 254.1
Chisago Co.	345 1.034	ETCO	115 1.018	Lakehead	220 238.8
Chisago Co.	500 1.034	Forbes	230 1.026	Marathon	220 241.9
Drayton	230 1.031	Forbes	500 1.023	Wawa	220 240.4
Eau Claire	345 1.041	Hubbard	115 0.000	Mississagi	220 244.9
WEST FARIBAULT	115 1.006	Intl Falls	115 1.036	Fort Frances	118 121.8
LaPorte	115 0.993	Minntac	115 1.026	Lakehead	118 123.3
Maple River	230 1.025	Moranville	230 1.027	Birch	118 119.9
Marshall Tap	115 1.007	Riverton	230 1.002	Marathon	118 124.2
Owatonna	161 0.985	Running	230 1.019		0.000
Prairie	115 1.051	Shannon	230 1.031	Arrowhead	345 1.050
Prairie	230 1.035	Stinson MN	115 1.019	Stone Lake	345 1.053
Ramsey	230 1.001	Jamestown	345 0.986	Stone Lake	161 1.041
Roseau County	230 1.027	Groton	345 1.022	Gardner Park	345 1.020
Roseau County	500 1.048	Watertown	230 1.030	Weston	115 1.029
Sheyenne	230 1.029	Watertown	345 1.026	Arpin	345 1.024
Thief R Falls	115 1.018		0.000	Eau Claire	161 1.028
Tioga	230 1.024	Dorsey	230 1.045	Council Creek	161 0.960
Wahpeton	230 1.000	Dorsey	500 1.040	Hydro Lane	161 1.004
Winger	115 1.033		0.000	Wien	115 1.029
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

kcl-sp16.pfinfo

02/20/2008

1)	B10T-Tioga (South)	GE OST	SLLP	328%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	677%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	999999%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	1169%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	344%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	N/A	1208%	
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	966%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	3133%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:54

KC0-SO08AA.SAV;SUMMER;OP LD;SYSTEM INTACT :
 ND=2079,MH=2176,MW=1525,OHMH=-195,OHMP=151,EWTW=191,BD=164

P O W E R F L O W S U M M A R Y

```

-----
NDEX:      2079 MW      ECL-ARP:   551 MW
MHEX:      2176 MW      PRI-BYN:   882 MW
MWEX:      1525 MW      AHD-SLK:   638 MW
KING-ECL:   887 MW      SLK-GPK:   384 MW
COOPER S:   692 MW      WNE-WKS:   469 MW
FTCAL S:    587 MW      GGS:       1626 MW
GRIS-LNC:   756 MW      QC WEST:   193 MW
    
```

LOAD LEVELS AS PERCENT OF 2008 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 2010.2 MW, 69.7% OF 2883.0 MW
 NSP (AREA 600) 7883.8 MW, 74.5% OF 10581.0 MW
 MAN HYDRO (AREA 667) 2348.2 MW, 79.8% OF 2943.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	2348/ 288	MH total gross	5004	ATC West Import	1092
Ont. total	22150/ 478	Wpg River	568	ATC SW Import	455
NW	915/ 37	7 Sisters	170	ATC SE Import	-1030
Sask.	2150/ 82	OH total gross	21884	East Bias	247
MP	2021/ 132	northwest	717	SPC>WAPA (B10T)	164
NSP	7883/ 427	SPC total gross	2406	MH>SPC (3-230)	60
N. Dakota	2010/ 286	MP total gross	2161	MH>SPC (FALLS)	0
Manitoba	481 MVARs	ND Cfd AC gross	3237	OH>MH @Kenora	-195
Ont. total	13082 MVARs	net	3066	OH>MP @Ft Fran	151
NW	489 MVARs	NSP East gross	2334	OH E>W @Wawa	191
Sask.	502 MVARs	net	2232	OH>East USA	0
MP	540 MVARs	West gross	3033	F601C @Forbes	1452
NSP	1671 MVARs	net	2871	D602F @Dorsey	1727
N. Dakota	460 MVARs	Total net	6305	L20D @Letell	277
ATC	10359/ 310	WAPA SD Hydro	1497	R50M @Richer	142
ATC	3110 MVARs	Pleasant Valley	0	G82R @Glenboro	29
		LGS/Trimont	19		

SW MN Wind 193
 N DAK WIND 203
 Swing Bus 972

Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1 7-7	112/ 78%	Stinson	26/ 29	CU (1,2)	1104
Wshell #2 7-7	112/ 78%	Boundary Dam	5/ 165	SQ BU (3,4)	450
Drayton#1 4-7	47/ 33%	Whiteshell	81/ 199	MH Bipole 1	1523
Drayton#2 4-7	60/ 32%	Int Falls	100/ 150	MH Bipole 2	1724
Dorsey #1 2-4	814/ 67%	St. Lawrence	15/ 0	MH (BP1+BP2)	3247
Dorsey #2 2-4	924/ 77%	Arrowhead	0/ 638	Miles City E>W	-150
Forbes 2-4	94/ 14%			RCDC (15)	0
Stone Lk 3-5	240/ 71%			Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	462 600/ -330	Forbes	500 37	400/ -450
SCE 1-3G	18.2	3	377 480/ -240	Fargo	13.2 -30	20/ -135
SCA 4-6G	18.2	3	377 480/ -240	Watertown	20.0 39	125/ -86
Total Margin		1216	1560/ -810	Series Caps		Num In Serv
		344		Roseau	500	2 of 2
				Chisago	500	1 of 1

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	0	Arrowhead 230	160	Chisago T 9 34.5	51
Drayton 115	20	Blackberry 230	47	Chisago T 10 34.5	51
Drayton 13.8	0	Minntac 115	45	Forbes 230	70
Eau Claire(FS) 161	267	Riverton 230	47	Forbes 500	600
Kohlman Lake 115	240	Roseau Co.(FS) 230	0		0
Parkers Lk(FS) 115	0	Running (FS) 230	30	Fargo 115	54
Prairie (FS) 115	40	Running react 230	0	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	72	Watertown 230	76
Red Rock 115	240		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	150
Split Rock(FS) 115	80	Laverendrye 110	98	Stone Lake 345	0
Sheyenne (FS) 115	40	Richer react 230	0	Stone Lk Reac 345	0

Wilton/Bemidji	115	20	St Vital	110	98	Stone Lake	161	20
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	50
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 0.996	Arrowhead	230 1.023	Whiteshell	110 119.0
Alexandria	115 1.036	Badoura	115 1.043	Kenora	220 254.4
Audubon	115 1.048	Blackberry	230 1.036	Dryden	220 262.1
Bemidji	115 1.038	Boise Cascade	13.8 1.052	Fort Frances	220 259.8
Byron	345 1.007	Boise Cascade	115 1.020	Mackenzie	220 273.4
Chisago Co.	345 1.029	ETCO	115 1.019	Lakehead	220 273.6
Chisago Co.	500 1.027	Forbes	230 1.038	Marathon	220 269.1
Drayton	230 1.030	Forbes	500 1.035	Wawa	220 262.3
Eau Claire	345 1.008	Hubbard	115 1.031	Mississagi	220 252.4
WEST FARIBAULT	115 1.018	Intl Falls	115 1.021	Fort Frances	118 119.4
LaPorte	115 1.035	Minntac	115 1.028	Lakehead	118 122.8
Maple River	230 1.031	Moranville	230 1.030	Birch	118 120.3
Marshall Tap	115 1.030	Riverton	230 1.031	Marathon	118 127.5
Owatonna	161 0.998	Running	230 1.035		0.000
Prairie	115 1.043	Shannon	230 1.042	Arrowhead	345 1.046
Prairie	230 1.037	Stinson MN	115 1.029	Stone Lake	345 1.034
Ramsey	230 1.032	Jamestown	345 0.983	Stone Lake	161 1.038
Roseau County	230 1.029	Groton	345 0.992	Gardner Park	345 1.035
Roseau County	500 1.065	Watertown	230 1.030	Weston	115 1.035
Sheyenne	230 1.033	Watertown	345 1.021	Arpin	345 1.008
Thief R Falls	115 1.038		0.000	Eau Claire	161 1.029
Tioga	230 1.029	Dorsey	230 1.045	Council Creek	161 0.966
Wahpeton	230 1.024	Dorsey	500 1.038	Hydro Lane	161 1.011
Winger	115 1.052		0.000	Wien	115 1.033
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

1)	B10T-Tioga (South)	GE OST	SLLP	338%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	694%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	421%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	267%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	323%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	1797%	N/A	N/A
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	719%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	952%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

INITIATED AT LOAD FLOW ENTRY POINT ON WED, FEB 20 2008 13:55

KCG-SO08AA.SAV;SUMMER;OP LD;SYSTEM INTACT :
 ND=2079,MH=2176,MW=1525,OHMH=-195,OHMP=151,EWTW=191,BD=164

P O W E R F L O W S U M M A R Y

```

-----
NDEX:      2079 MW      ECL-ARP:   550 MW
MHEX:      2176 MW      PRI-BYN:   882 MW
MWEX:      1525 MW      AHD-SLK:   638 MW
KING-ECL:   886 MW      SLK-GPK:   384 MW
COOPER S:   691 MW      WNE-WKS:   469 MW
FTCAL S:    587 MW      GGS:       1626 MW
GRIS-LNC:   756 MW      QC WEST:   194 MW
    
```

LOAD LEVELS AS PERCENT OF 2008 SUMMER PEAK:
 NORTH DAKOTA (ZONE 90,990) 2016.8 MW, 70.0% OF 2883.0 MW
 NSP (AREA 600) 7886.1 MW, 74.5% OF 10581.0 MW
 MAN HYDRO (AREA 667) 2348.2 MW, 79.8% OF 2943.0 MW

Load/Losses	MW / MW	Generation	MW	Export	MW
Manitoba	2348/ 288	MH total gross	5003	ATC West Import	1091
Ont. total	22150/ 478	Wpg River	568	ATC SW Import	455
NW	915/ 37	7 Sisters	170	ATC SE Import	-1030
Sask.	2150/ 82	OH total gross	21884	East Bias	247
MP	2021/ 132	northwest	717	SPC>WAPA (B10T)	164
NSP	7886/ 427	SPC total gross	2406	MH>SPC (3-230)	60
N. Dakota	2016/ 286	MP total gross	2161	MH>SPC (FALLS)	0
Manitoba	481 MVARs	ND Cfd AC gross	3237	OH>MH @Kenora	-195
Ont. total	13082 MVARs	net	3066	OH>MP @Ft Fran	151
NW	489 MVARs	NSP East gross	2334	OH E>W @Wawa	191
Sask.	502 MVARs	net	2232	OH>East USA	0
MP	540 MVARs	West gross	3033	F601C @Forbes	1452
NSP	1671 MVARs	net	2871	D602F @Dorsey	1726
N. Dakota	462 MVARs	Total net	6305	L20D @Letell	277
ATC	10358/ 309	WAPA SD Hydro	1497	R50M @Richer	142
ATC	3110 MVARs	Pleasant Valley	0	G82R @Glenboro	29
		LGS/Trimont	19		

SW MN Wind 193
 N DAK WIND 203
 Swing Bus 972

Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1 7-7	112/ 78%	Stinson	26/ 29	CU (1,2)	1103
Wshell #2 7-7	112/ 78%	Boundary Dam	5/ 165	SQ BU (3,4)	450
Drayton#1 4-7	47/ 33%	Whiteshell	81/ 199	MH Bipole 1	1522
Drayton#2 4-7	60/ 32%	Int Falls	100/ 150	MH Bipole 2	1724
Dorsey #1 2-4	814/ 67%	St. Lawrence	15/ 0	MH (BP1+BP2)	3247
Dorsey #2 2-4	924/ 77%	Arrowhead	0/ 638	Miles City E>W	-150
Forbes 2-4	94/ 14%			RCDC (15)	0
Stone Lk 3-5	241/ 71%			Stegall (10)	0

Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	462	600/ -330	Forbes 500	37 400/ -450
SCE 1-3G	18.2	3	377	480/ -240	Fargo 13.2	-29 20/ -135
SCA 4-6G	18.2	3	377	480/ -240	Watertown 20.0	39 125/ -86
Total Margin		1216	1560/ -810	Series Caps	Num In Serv	
		344		Roseau 500	2 of 2	
				Chisago 500	1 of 1	

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	0	Arrowhead 230	160	Chisago T 9 34.5	51
Drayton 115	20	Blackberry 230	47	Chisago T 10 34.5	51
Drayton 13.8	0	Minntac 115	45	Forbes 230	70
Eau Claire(FS) 161	267	Riverton 230	47	Forbes 500	600
Kohlman Lake 115	240	Roseau Co.(FS) 230	0		0
Parkers Lk(FS) 115	0	Running (FS) 230	30	Fargo 115	54
Prairie (FS) 115	40	Running react 230	0	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	72	Watertown 230	76
Red Rock 115	240		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	150
Split Rock(FS) 115	80	Laverendrye 110	98	Stone Lake 345	0
Sheyenne (FS) 115	40	Richer react 230	0	Stone Lk Reac 345	0

Wilton/Bemidji	115	20	St Vital	110	98	Stone Lake	161	20
		0			0	Grdnr Pk Reac	345	0
		0			0	Grdnr Pk Caps	115	0
		0			0	Arpin Caps	138	50
		0			0	Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 0.996	Arrowhead	230 1.023	Whiteshell	110 119.0
Alexandria	115 1.036	Badoura	115 1.043	Kenora	220 254.4
Audubon	115 1.047	Blackberry	230 1.036	Dryden	220 262.1
Bemidji	115 1.038	Boise Cascade	13.8 1.052	Fort Frances	220 259.8
Byron	345 1.007	Boise Cascade	115 1.020	Mackenzie	220 273.4
Chisago Co.	345 1.029	ETCO	115 1.019	Lakehead	220 273.6
Chisago Co.	500 1.027	Forbes	230 1.038	Marathon	220 269.1
Drayton	230 1.030	Forbes	500 1.035	Wawa	220 262.3
Eau Claire	345 1.009	Hubbard	115 1.031	Mississagi	220 252.4
WEST FARIBAULT	115 1.018	Intl Falls	115 1.021	Fort Frances	118 119.4
LaPorte	115 1.035	Minntac	115 1.028	Lakehead	118 122.8
Maple River	230 1.031	Moranville	230 1.030	Birch	118 120.3
Marshall Tap	115 1.030	Riverton	230 1.031	Marathon	118 127.5
Owatonna	161 0.998	Running	230 1.035		0.000
Prairie	115 1.042	Shannon	230 1.042	Arrowhead	345 1.046
Prairie	230 1.037	Stinson MN	115 1.029	Stone Lake	345 1.034
Ramsey	230 1.031	Jamestown	345 0.983	Stone Lake	161 1.038
Roseau County	230 1.029	Groton	345 0.992	Gardner Park	345 1.035
Roseau County	500 1.065	Watertown	230 1.030	Weston	115 1.035
Sheyenne	230 1.032	Watertown	345 1.020	Arpin	345 1.008
Thief R Falls	115 1.037		0.000	Eau Claire	161 1.029
Tioga	230 1.029	Dorsey	230 1.045	Council Creek	161 0.966
Wahpeton	230 1.024	Dorsey	500 1.038	Hydro Lane	161 1.011
Winger	115 1.052		0.000	Wien	115 1.033
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)


Relay Location	Manuf/Type	PSS Model	South	North	Em North
----------------	------------	-----------	-------	-------	----------

1)	B10T-Tioga (South)	GE OST	SLLP	339%	N/A	N/A
2)	-Tioga (North)	GE OST	SLLP	696%	N/A	N/A
3)	-Tioga (Em North)	GE OST	SLLP		N/A	N/A
4)	D602F-Dorsey	ATP ???	SLINOS	421%	N/A	N/A
5)	-Forbes (Normal)	ATP ???	SLINOS	267%	N/A	N/A
6)	-Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A
8)	F3M-Intl Falls	APT S-PRO	SLINOS	323%	N/A	N/A
9)	G82R-Rugby	APT	SLINOS	1798%	N/A	N/A
10)	L20D-Drayton (Normal)	APT, ASEA	SLINOS	718%	N/A	N/A
11)	-Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A
12)	R50M-Moranville (Norm)	APT, West	SLINOS	952%	N/A	N/A
13)	-Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A

Project GI-0404

KC0-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT
 ND=318,MH=1283,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166
 FRI, MAY 16 2008 13:38


Bus - VOLTAGE (PU)
 Branch - MW/Mvar
 Equipment - MW/Mvar
 kV: <=41.600 <=115.000 <=230.000 <=345.000 <=500.000 >500.000



Project GI-0404

KCG-SP08AA_SAV_SUMMER-PK LD_SYSTEM INTACT
 ND=319,MH=1283,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166
 FRI, MAY 16 2008 13:35


Bus - VOLTAGE (PU)
 Branch - MW/Mvar
 Equipment - MW/Mvar
 kV: <=41.600 <=115.000 <=230.000 <=345.000 <=500.000 >500.000



Project GI-0404-SP16

KCO-SP16AA.SAV;SUMMER;PK LD.SYSTEM INTACT
 ND=171,MH=1067,MW=448,OHMH=0,OHMP=150,EWTW=120,BD=165
 FRI, MAY 16 2008 13:39


Bus - VOLTAGE (PU)
 Branch - MW/Mvar
 Equipment - MW/Mvar
 kV: <=41.600 <=115.000 <=230.000 <=345.000 <=500.000 >500.000



Project GI-0404-SP16

KCG-SP16AA.SAV:SUMMER.PK LD:SYSTEM INTACT
 ND=9,MH=1056,MW=390,OHMH=3,OHMP=152,EWTW=-116,BD=169
 FRI, MAY 16 2008 13:40

Bus - VOLTAGE (PU)
 Branch - MW/Mvar
 Equipment - MW/Mvar
 kV: <=41.600 <=115.000 <=230.000 <=345.000 <=500.000 >500.000



POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	1	2	3	4	5
Case Name	kc0-so08aa-ac1	kcg-so08aa-ac1	kc0-so08aa-ac3	kcg-so08aa-ac3	kc0-so08aa-ad1
Disturbance	ac1	ac1	ac3	ac3	ad1
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 10:24	FEB 05 2008 11:11	FEB 05 2008 10:26	FEB 05 2008 11:13	FEB 05 2008 10:28
Comments					
Steady State Flows					
NDEX / EAST BIAS	2079 / 296	2080 / 296	2079 / 296	2080 / 296	2079 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502
B10T / MH>SPC	165 / 61	165 / 60	165 / 61	165 / 60	165 / 61
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	11	10	11	10	11
Dorsey bipole / CU bipole	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103
Dorsey Reserve / Wtrtn SVC	321 / 33	322 / 34	321 / 33	322 / 34	321 / 33
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	338%	339%	338%	339%	338%
Min/MaxTransientVltg					
Arrowhd 230	0.99 1.03	0.99 1.03	0.98 1.03	0.98 1.03	1.00 1.04
Boise 115	0.99 1.03	0.99 1.03	0.99 1.03	0.99 1.03	1.00 1.03
Dorsey 230	1.02 1.06	1.02 1.06	1.02 1.06	1.02 1.06	1.03 1.06
Forbes 230	1.00 1.05	1.00 1.05	1.00 1.04	1.00 1.05	1.01 1.05
Riverton 230	0.97 1.06	0.98 1.06	0.97 1.05	0.97 1.05	0.99 1.06
Coal Creek 230	0.95 1.12	0.95 1.12	0.95 1.12	0.95 1.12	0.96 1.12
Stone Lake 345	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05	1.01 1.05
Drayton 230	0.98 1.09	0.98 1.09	0.99 1.09	0.99 1.10	0.99 1.08
Groton 345	0.83 1.01	0.83 1.02	0.83 1.02	0.83 1.02	0.87 1.04
Minong 161	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05
Wahpeton 115	0.94 1.09	0.95 1.09	0.94 1.09	0.94 1.09	0.97 1.10
Watertown 345	0.92 1.03	0.93 1.03	0.93 1.04	0.93 1.04	0.94 1.04
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	396%	396%	406%	405%	392%
K22W (max +dP @ t, d-ang)	10.6@(2.61665,2.2)	10.2@(2.60832,2.4)	13.2@(2.55832,0.9)	13.2@(2.55832,0.9)	15.3@(2.49166,-0.4)
K22W (max -dP @ t, d-ang)	24.9@(0.85000,6.8)	24.2@(0.85000,6.6)	23.7@(0.80833,6.9)	23.8@(0.80833,6.9)	16.1@(0.77500,4.0)
K22W (max d-ang @ t, dP)	9.6@(1.13333,-12.0)	9.3@(1.12500,-11.6)	9.3@(1.07500,-12.4)	9.3@(1.07500,-12.5)	5.9@(1.05000,-4.9)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	178% / 275%	179% / 277%	178% / 275%	178% / 275%	198% / 309%
B2R at Rugby/L20D at Drayton	999% / 621%	999% / 622%	999% / 616%	999% / 615%	999% / 633%
R50M / F3M	696% / 264%	700% / 264%	699% / 262%	699% / 262%	760% / 270%
B10T	190%	192%	184%	184%	190%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 1 0)	(0 1 0)	(0 1 0)	(0 1 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
Prairie 115 / Ramsey 230	(1 4 2) / (0 1 0)	(1 4 2) / (0 1 0)	(1 4 1) / (0 2 1)	(1 4 1) / (0 2 1)	(1 2 1) / (0 1 0)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 5 2) / (1 1 1)	(1 5 2) / (1 1 1)	(1 5 2) / (1 2 2)	(1 5 2) / (1 2 2)	(1 3 1) / (1 1 1)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	6	7	8	9	10
Case Name	kc0-so08aa-ad1	kc0-so08aa-ad3	kc0-so08aa-ad3	kc0-so08aa-af1	kc0-so08aa-af1
Disturbance	ad1	ad3	ad3	af1	af1
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 11:15	FEB 05 2008 10:30	FEB 05 2008 11:17	FEB 05 2008 10:31	FEB 05 2008 11:18
Comments					
Steady State Flows					
NDEX / EAST BIAS	2080 / 296	2079 / 296	2080 / 296	2079 / 296	2080 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502
B10T / MH>SPC	165 / 60	165 / 61	165 / 60	165 / 61	165 / 60
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	10	11	10	11	10
Dorsey bipole / CU bipole	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104
Dorsey Reserve / Wtrtn SVC	322 / 34	321 / 33	322 / 34	321 / 33	322 / 34
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	339%	338%	339%	338%	339%
Min/MaxTransientVltg					
Arrowhd 230	1.00 1.04	1.00 1.04	1.00 1.04	1.00 1.04	1.00 1.04
Boise 115	1.00 1.03	1.00 1.03	0.99 1.03	1.00 1.03	1.00 1.03
Dorsey 230	1.03 1.06	1.03 1.06	1.03 1.06	1.03 1.06	1.03 1.06
Forbes 230	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05
Riverton 230	0.99 1.06	0.99 1.06	0.99 1.06	0.99 1.06	0.99 1.06
Coal Creek 230	0.96 1.12	0.96 1.12	0.96 1.12	0.97 1.12	0.97 1.12
Stone Lake 345	1.01 1.05	1.01 1.05	1.01 1.06	1.01 1.06	1.01 1.06
Drayton 230	0.99 1.08	0.99 1.07	0.99 1.08	0.99 1.08	0.99 1.08
Groton 345	0.86 1.04	0.87 1.04	0.87 1.04	0.89 1.04	0.89 1.04
Minong 161	1.02 1.05	1.01 1.05	1.02 1.05	1.02 1.05	1.02 1.05
Wahpeton 115	0.97 1.10	0.97 1.10	0.97 1.10	0.98 1.10	0.98 1.10
Watertown 345	0.93 1.04	0.94 1.05	0.94 1.05	0.95 1.04	0.95 1.04
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	392%	391%	393%	396%	396%
K22W (max +dP @ t, d-ang)	15.4@(2.49166,-0.4)	18.0@(2.44166,-1.4)	17.9@(2.44166,-1.4)	13.7@(2.45832,-0.1)	13.7@(2.44999,0.0)
K22W (max -dP @ t, d-ang)	16.2@(0.77500,4.0)	16.5@(0.71666,4.3)	15.8@(0.71666,4.2)	15.0@(0.74166,3.6)	15.0@(0.74166,3.6)
K22W (max d-ang @ t, dP)	5.9@(1.05000,-5.0)	6.1@(0.97500,-6.7)	5.9@(0.97500,-6.0)	5.3@(1.00833,-4.2)	5.3@(1.00833,-4.2)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	198% / 309%	197% / 307%	197% / 307%	201% / 314%	201% / 314%
B2R at Rugby/L20D at Drayton	999% / 633%	999% / 621%	999% / 621%	999% / 635%	999% / 635%
R50M / F3M	760% / 269%	756% / 268%	757% / 267%	768% / 271%	768% / 271%
B10T	191%	181%	182%	198%	199%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)
Prairie 115 / Ramsey 230	(1 2 1)/(0 1 0)	(1 1 1)/(0 1 0)	(1 2 1)/(0 1 0)	(1 3 1)/(0 1 0)	(1 2 1)/(0 1 0)
Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
Shey 115 / Split Rock 115	(1 3 1)/(1 1 1)	(1 4 1)/(1 2 2)	(1 4 1)/(1 2 2)	(1 3 1)/(1 1 1)	(1 3 1)/(1 1 1)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	11	12	13	14	15
Case Name	kc0-so08aa-af3	kgc-so08aa-af3	kc0-so08aa-ag1	kgc-so08aa-ag1	kc0-so08aa-ag3
Disturbance	af3	af3	ag1	ag1	ag3
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 10:33	FEB 05 2008 11:20	FEB 05 2008 10:35	FEB 05 2008 11:22	FEB 05 2008 10:37
Comments					
Steady State Flows					
NDEX / EAST BIAS	2079 / 296	2080 / 296	2079 / 296	2080 / 296	2079 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502
B10T / MH>SPC	165 / 61	165 / 60	165 / 61	165 / 60	165 / 61
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	11	10	11	10	11
Dorsey bipole / CU bipole	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103
Dorsey Reserve / Wtrtn SVC	321 / 33	322 / 34	321 / 33	322 / 34	321 / 33
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	338%	339%	338%	339%	338%
Min/MaxTransientVltg					
Arrowhd 230	1.00 1.04	1.00 1.04	0.99 1.03	0.99 1.03	0.98 1.03
Boise 115	1.00 1.03	1.00 1.03	0.99 1.04	0.99 1.04	0.99 1.04
Dorsey 230	1.03 1.06	1.03 1.06	1.02 1.06	1.02 1.06	1.02 1.06
Forbes 230	1.01 1.05	1.01 1.05	1.00 1.05	1.00 1.05	1.00 1.04
Riverton 230	0.99 1.06	0.99 1.06	0.98 1.06	0.98 1.06	0.98 1.05
Coal Creek 230	0.97 1.12	0.97 1.12	0.95 1.12	0.95 1.12	0.96 1.12
Stone Lake 345	1.01 1.06	1.01 1.06	1.00 1.05	1.00 1.05	1.00 1.05
Drayton 230	0.99 1.07	0.99 1.08	0.98 1.09	0.98 1.09	0.98 1.10
Groton 345	0.89 1.05	0.89 1.05	0.83 1.03	0.83 1.03	0.83 1.03
Minong 161	1.01 1.05	1.02 1.05	1.01 1.05	1.01 1.05	1.01 1.05
Wahpeton 115	0.97 1.10	0.97 1.10	0.95 1.10	0.95 1.10	0.94 1.09
Watertown 345	0.95 1.05	0.95 1.05	0.92 1.04	0.92 1.04	0.92 1.04
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	394%	395%	389%	389%	386%
K22W (max +dP @ t, d-ang)	16.7@(2.42499,-1.2)	16.6@(2.41666,-1.1)	11.5@(2.55832,2.5)	11.5@(2.55832,2.5)	13.4@(2.51666,1.8)
K22W (max -dP @ t, d-ang)	16.1@(0.69166,4.0)	15.5@(0.69166,3.9)	24.4@(0.81666,6.6)	24.5@(0.81666,6.6)	24.4@(0.79166,7.5)
K22W (max d-ang @ t, dP)	5.8@(0.95833,-5.5)	5.6@(0.95000,-5.5)	9.5@(1.10000,-11.5)	9.5@(1.10000,-11.5)	9.8@(1.04166,-13.2)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	198% / 309%	198% / 310%	179% / 277%	179% / 277%	177% / 272%
B2R at Rugby/L20D at Drayton	999% / 619%	999% / 618%	999% / 609%	999% / 608%	999% / 599%
R50M / F3M	760% / 269%	761% / 268%	702% / 262%	702% / 262%	694% / 260%
B10T	185%	184%	179%	178%	170%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 0 0)	(0 1 0)	(0 1 0)	(0 1 0)
Eau Cl 345 / Park Lk 115	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)	(3 3 3)/(0 0 0)
Prairie 115 / Ramsey 230	(1 1 1)/(0 1 0)	(1 2 1)/(0 1 0)	(1 5 2)/(0 1 0)	(1 5 2)/(0 1 0)	(1 5 1)/(0 2 0)
Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
Shey 115 / Split Rock 115	(1 4 1)/(1 2 2)	(1 4 1)/(1 2 2)	(1 5 2)/(1 1 1)	(1 5 2)/(1 1 1)	(1 5 2)/(1 2 2)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	16	17	18	19	20
Case Name	kcg-so08aa-ag3	kc0-so08aa-ah1	kcg-so08aa-ah1	kc0-so08aa-ah3	kcg-so08aa-ah3
Disturbance	ag3	ah1	ah1	ah3	ah3
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 11:24	FEB 05 2008 10:39	FEB 05 2008 11:25	FEB 05 2008 10:41	FEB 05 2008 11:27
Comments					
Steady State Flows					
NDEX / EAST BIAS	2080 / 296	2079 / 296	2080 / 296	2079 / 296	2080 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502
B10T / MH>SPC	165 / 60	165 / 61	165 / 60	165 / 61	165 / 60
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	10	11	10	11	10
Dorsey bipole / CU bipole	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104
Dorsey Reserve / Wtrtn SVC	322 / 34	321 / 33	322 / 34	321 / 33	322 / 34
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	339%	338%	339%	338%	339%
Min/MaxTransientVltg					
Arrowhd 230	0.98 1.03	0.99 1.03	0.99 1.03	0.98 1.04	0.99 1.04
Boise 115	0.99 1.04	0.99 1.03	0.99 1.03	0.99 1.03	0.99 1.03
Dorsey 230	1.02 1.06	1.02 1.06	1.02 1.06	1.02 1.06	1.02 1.06
Forbes 230	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05
Riverton 230	0.97 1.05	0.98 1.06	0.98 1.06	0.98 1.05	0.98 1.06
Coal Creek 230	0.96 1.12	0.95 1.12	0.95 1.12	0.95 1.12	0.96 1.13
Stone Lake 345	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05
Drayton 230	0.98 1.10	0.98 1.09	0.98 1.09	0.98 1.10	0.98 1.08
Groton 345	0.83 1.03	0.94 1.04	0.94 1.04	0.94 1.04	0.94 1.04
Minong 161	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05
Wahpeton 115	0.94 1.09	0.95 1.09	0.95 1.09	0.94 1.09	0.94 1.09
Watertown 345	0.92 1.04	0.97 1.04	0.97 1.04	0.97 1.05	0.97 1.05
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	386%	400%	400%	399%	399%
K22W (max +dP @ t, d-ang)	13.4@(2.51666,1.8)	11.0@(2.60832,1.5)	11.0@(2.60832,1.5)	13.3@(2.54999,0.7)	13.2@(2.55832,0.6)
K22W (max -dP @ t, d-ang)	24.5@(0.80000,7.6)	22.9@(0.85000,6.3)	23.0@(0.85000,6.3)	23.0@(0.80833,6.9)	23.9@(0.80833,7.1)
K22W (max d-ang @ t, dP)	9.8@(1.04166,-13.2)	8.6@(1.11666,-11.3)	8.7@(1.11666,-11.3)	8.9@(1.05000,-12.9)	9.2@(1.06666,-12.0)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	177% / 272%	179% / 278%	179% / 278%	177% / 274%	177% / 273%
B2R at Rugby/L20D at Drayton	999% / 598%	999% / 620%	999% / 619%	999% / 606%	999% / 608%
R50M / F3M	694% / 260%	701% / 263%	701% / 263%	696% / 261%	694% / 262%
B10T	170%	202%	202%	191%	194%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 1 0)	(0 1 0)	(0 1 0)	(0 1 0)	(0 1 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
Prairie 115 / Ramsey 230	(1 5 1) / (0 2 0)	(1 6 2) / (0 1 0)	(1 6 2) / (0 1 0)	(1 5 2) / (0 2 0)	(1 4 2) / (0 1 0)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 5 2) / (1 2 2)	(1 5 2) / (1 1 1)	(1 5 2) / (1 1 1)	(1 5 3) / (1 2 2)	(1 5 3) / (1 2 2)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	21	22	23	24	25
Case Name	kc0-so08aa-ah4	kcg-so08aa-ah4	kc0-so08aa-ai1	kcg-so08aa-ai1	kc0-so08aa-ai3
Disturbance	ah4	ah4	ai1	ai1	ai3
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 10:43	FEB 05 2008 11:29	FEB 05 2008 10:44	FEB 05 2008 11:31	FEB 05 2008 10:46
Comments					
Steady State Flows					
NDEX / EAST BIAS	2079 / 296	2080 / 296	2079 / 296	2080 / 296	2079 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502
B10T / MH>SPC	165 / 61	165 / 60	165 / 61	165 / 60	165 / 61
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	11	10	11	10	11
Dorsey bipole / CU bipole	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103
Dorsey Reserve / Wtrtn SVC	321 / 33	322 / 34	321 / 33	322 / 34	321 / 33
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	338%	339%	338%	339%	338%
Min/MaxTransientVltg					
Arrowhd 230	0.99 1.03	0.99 1.03	0.99 1.04	0.99 1.04	0.99 1.04
Boise 115	0.99 1.03	0.99 1.03	0.99 1.03	0.99 1.03	0.99 1.04
Dorsey 230	1.02 1.06	1.02 1.06	1.02 1.06	1.02 1.06	1.03 1.06
Forbes 230	1.00 1.05	1.00 1.05	1.00 1.04	1.00 1.04	1.00 1.05
Riverton 230	0.98 1.06	0.98 1.06	0.99 1.05	0.99 1.05	0.99 1.06
Coal Creek 230	0.95 1.12	0.95 1.12	0.97 1.12	0.97 1.12	0.97 1.12
Stone Lake 345	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05	1.01 1.05
Drayton 230	0.98 1.09	0.98 1.09	0.98 1.09	0.98 1.09	0.99 1.08
Groton 345	0.94 1.04	0.94 1.04	0.95 1.04	0.95 1.04	0.89 1.05
Minong 161	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05	1.01 1.05
Wahpeton 115	0.95 1.09	0.95 1.09	0.97 1.09	0.96 1.08	0.98 1.09
Watertown 345	0.97 1.04	0.97 1.04	0.97 1.04	0.97 1.04	0.95 1.05
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	399%	398%	402%	403%	395%
K22W (max +dP @ t, d-ang)	10.6@(2.59999,1.6)	10.6@(2.59999,1.6)	11.1@(2.58332,1.2)	11.2@(2.58332,1.2)	17.2@(2.39999,-1.3)
K22W (max -dP @ t, d-ang)	22.9@(0.84166,6.2)	22.9@(0.84166,6.2)	21.4@(0.83333,5.7)	21.5@(0.83333,5.7)	16.4@(0.67500,4.2)
K22W (max d-ang @ t, dP)	8.6@(1.11666,-10.8)	8.6@(1.11666,-10.9)	8.2@(1.11666,-10.1)	8.2@(1.11666,-10.2)	6.1@(0.95000,-6.4)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	180% / 278%	180% / 278%	181% / 280%	181% / 280%	197% / 307%
B2R at Rugby/L20D at Drayton	999% / 620%	999% / 620%	999% / 621%	999% / 620%	999% / 617%
R50M / F3M	701% / 263%	701% / 263%	707% / 262%	707% / 262%	755% / 268%
B10T	202%	203%	205%	206%	181%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 1 0)	(0 1 0)	(0 2 0)	(0 2 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
Prairie 115 / Ramsey 230	(1 6 2) / (0 1 0)	(1 6 2) / (0 1 0)	(1 5 1) / (0 1 0)	(1 5 1) / (0 1 0)	(1 3 1) / (0 1 0)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 5 2) / (1 1 1)	(1 5 2) / (1 1 1)	(1 5 3) / (1 1 1)	(1 5 3) / (1 1 1)	(1 4 2) / (1 2 2)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	26	27	28	29	30
Case Name	kcg-so08aa-ai3	kc0-so08aa-am1	kcg-so08aa-am1	kc0-so08aa-am3	kcg-so08aa-am3
Disturbance	ai3	am1	am1	am3	am3
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 11:32	FEB 05 2008 10:48	FEB 05 2008 11:34	FEB 05 2008 10:50	FEB 05 2008 11:36
Comments					
Steady State Flows					
NDEX / EAST BIAS	2080 / 296	2079 / 296	2080 / 296	2079 / 296	2080 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502
B10T / MH>SPC	165 / 60	165 / 61	165 / 60	165 / 61	165 / 60
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	10	11	10	11	10
Dorsey bipole / CU bipole	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104
Dorsey Reserve / Wtrtn SVC	322 / 34	321 / 33	322 / 34	321 / 33	322 / 34
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	339%	338%	339%	338%	339%
Min/MaxTransientVltg					
Arrowhd 230	0.99 1.04	1.01 1.04	1.01 1.04	0.99 1.04	0.99 1.04
Boise 115	0.99 1.04	1.00 1.03	1.00 1.03	0.99 1.04	0.99 1.04
Dorsey 230	1.03 1.06	1.03 1.06	1.03 1.06	1.02 1.06	1.02 1.06
Forbes 230	1.00 1.05	1.01 1.04	1.01 1.04	1.00 1.05	1.00 1.05
Riverton 230	0.99 1.06	1.01 1.05	1.01 1.05	0.98 1.06	0.98 1.06
Coal Creek 230	0.97 1.12	0.98 1.10	0.98 1.10	0.96 1.12	0.96 1.12
Stone Lake 345	1.01 1.05	1.02 1.06	1.02 1.06	1.00 1.05	1.00 1.05
Drayton 230	0.99 1.08	1.00 1.08	1.00 1.08	0.98 1.09	0.98 1.09
Groton 345	0.89 1.05	0.86 1.08	0.86 1.08	0.85 1.05	0.85 1.05
Minong 161	1.01 1.05	1.02 1.06	1.02 1.06	1.01 1.05	1.01 1.05
Wahpeton 115	0.98 1.09	1.00 1.09	1.00 1.08	0.96 1.10	0.96 1.10
Watertown 345	0.95 1.05	0.93 1.07	0.93 1.07	0.93 1.05	0.93 1.05
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	395%	428%	429%	381%	381%
K22W (max +dP @ t, d-ang)	17.5@(2.39999,-1.5)	30.3@(2.68332,-6.6)	30.5@(2.68332,-6.6)	19.8@(2.45832,-1.4)	19.9@(2.45832,-1.4)
K22W (max -dP @ t, d-ang)	16.5@(0.67500,4.2)	7.4@(0.39166,0.7)	7.4@(0.39166,0.7)	19.9@(0.70833,5.4)	20.0@(0.70833,5.5)
K22W (max d-ang @ t, dP)	6.1@(0.95000,-6.4)	-9.4@(2.02500,13.8)	-9.4@(2.02500,13.8)	7.8@(0.99166,-10.2)	7.8@(0.99166,-10.3)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	197% / 307%	212% / 331%	212% / 331%	188% / 292%	188% / 292%
B2R at Rugby/L20D at Drayton	999% / 616%	999% / 615%	999% / 614%	999% / 590%	999% / 590%
R50M / F3M	755% / 268%	809% / 273%	809% / 273%	731% / 265%	731% / 265%
B10T	181%	203%	203%	170%	170%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 2 0)	(0 2 0)	(0 1 0)	(0 1 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
Prairie 115 / Ramsey 230	(1 3 1) / (0 1 0)	(1 4 1) / (0 1 0)	(1 4 1) / (0 1 0)	(1 3 1) / (0 1 0)	(1 3 1) / (0 1 0)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 5 2) / (1 2 2)	(1 3 2) / (1 1 1)	(1 3 2) / (1 1 1)	(1 5 2) / (1 2 2)	(1 5 2) / (1 2 2)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	31	32	33	34	35
Case Name	kc0-so08aa-aq3	kcg-so08aa-aq3	kc0-so08aa-ec1	kcg-so08aa-ec1	kc0-so08aa-ef1
Disturbance	aq3	aq3	ec1	ec1	ef1
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 10:52	FEB 05 2008 11:38	FEB 05 2008 10:53	FEB 05 2008 11:39	FEB 05 2008 10:55
Comments					
Steady State Flows					
NDEX / EAST BIAS	2079 / 296	2080 / 296	2079 / 296	2080 / 296	2079 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502
B10T / MH>SPC	165 / 61	165 / 60	165 / 61	165 / 60	165 / 61
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	11	10	11	10	11
Dorsey bipole / CU bipole	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103
Dorsey Reserve / Wtrtn SVC	321 / 33	322 / 34	321 / 33	322 / 34	321 / 33
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	338%	339%	338%	339%	338%
Min/MaxTransientVltg					
Arrowhd 230	1.01 1.02	1.01 1.02	0.98 1.04	0.98 1.04	1.00 1.04
Boise 115	1.01 1.02	1.01 1.02	1.00 1.04	1.00 1.04	1.01 1.03
Dorsey 230	1.04 1.05	1.04 1.05	1.03 1.07	1.03 1.07	1.03 1.06
Forbes 230	1.02 1.03	1.02 1.03	1.01 1.05	1.01 1.05	1.01 1.05
Riverton 230	1.01 1.02	1.01 1.02	0.98 1.06	0.98 1.06	1.00 1.05
Coal Creek 230	1.01 1.05	1.01 1.05	0.95 1.14	0.95 1.14	0.96 1.15
Stone Lake 345	1.02 1.04	1.02 1.04	1.00 1.06	1.00 1.06	1.01 1.05
Drayton 230	1.01 1.03	1.01 1.03	0.99 1.13	0.99 1.13	1.01 1.08
Groton 345	0.99 1.03	0.99 1.03	0.92 1.04	0.92 1.04	0.94 1.02
Minong 161	1.03 1.04	1.03 1.04	1.01 1.06	1.01 1.06	1.02 1.05
Wahpeton 115	1.01 1.03	1.01 1.03	0.96 1.11	0.95 1.11	1.00 1.07
Watertown 345	1.02 1.03	1.02 1.03	0.97 1.04	0.96 1.04	0.98 1.03
Dynamic Voltage Warnings					
	none	none			none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	486%	486%	419%	419%	421%
K22W (max +dP @ t, d-ang)	2.2@(2.36666,0.6)	2.2@(2.36666,0.7)	14.4@(2.54999,-0.3)	14.5@(2.54999,-0.3)	10.6@(2.56665,-1.7)
K22W (max -dP @ t, d-ang)	7.9@(0.65833,2.3)	7.9@(1.71666,0.6)	16.8@(0.70000,1.8)	16.8@(0.70000,1.8)	8.4@(0.64166,1.9)
K22W (max d-ang @ t, dP)	3.4@(0.96666,-5.2)	3.4@(0.96666,-5.2)	4.4@(1.04166,-3.8)	4.4@(1.04166,-3.9)	3.2@(1.00000,-5.0)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	218% / 342%	218% / 342%	208% / 326%	208% / 325%	226% / 354%
B2R at Rugby/L20D at Drayton	999% / 777%	999% / 776%	999% / 649%	999% / 648%	999% / 687%
R50M / F3M	812% / 300%	812% / 300%	736% / 271%	736% / 271%	830% / 296%
B10T	303%	304%	182%	183%	230%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 0 0)	(0 1 0)	(0 1 0)	(0 2 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
Prairie 115 / Ramsey 230	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)	(1 5 1) / (0 1 0)	(1 5 1) / (0 1 0)	(1 4 1) / (0 1 0)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 1 1) / (1 2 2)	(1 1 1) / (1 2 2)	(1 5 1) / (1 1 1)	(1 5 1) / (1 1 1)	(1 3 2) / (1 1 1)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	36	37	38	39	40
Case Name	kcg-so08aa-ef1	kc0-so08aa-ei2	kcg-so08aa-ei2	kc0-so08aa-eq1	kcg-so08aa-eq1
Disturbance	ef1	ei2	ei2	eq1	eq1
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 11:41	FEB 05 2008 10:57	FEB 05 2008 11:43	FEB 05 2008 10:59	FEB 05 2008 11:45
Comments					
Steady State Flows					
NDEX / EAST BIAS	2080 / 296	2079 / 296	2080 / 296	2079 / 296	2080 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502
B10T / MH>SPC	165 / 60	165 / 61	165 / 60	165 / 61	165 / 60
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	10	11	10	11	10
Dorsey bipole / CU bipole	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104
Dorsey Reserve / Wtrtn SVC	322 / 34	321 / 33	322 / 34	321 / 33	322 / 34
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	339%	338%	339%	338%	339%
Min/MaxTransientVltg					
Arrowhd 230	1.00 1.04	0.97 1.06	0.97 1.06	0.98 1.05	0.98 1.05
Boise 115	1.01 1.03	0.97 1.04	0.97 1.04	0.99 1.03	0.99 1.03
Dorsey 230	1.04 1.06	1.02 1.07	1.02 1.07	1.03 1.06	1.03 1.06
Forbes 230	1.02 1.05	0.97 1.04	0.97 1.04	1.00 1.05	1.00 1.05
Riverton 230	1.00 1.05	0.91 1.06	0.90 1.06	0.95 1.06	0.95 1.06
Coal Creek 230	0.96 1.15	1.00 1.13	1.00 1.13	0.97 1.17	0.97 1.17
Stone Lake 345	1.01 1.05	1.02 1.08	1.02 1.08	1.02 1.08	1.02 1.08
Drayton 230	1.01 1.08	0.94 1.11	0.94 1.11	1.00 1.10	1.00 1.10
Groton 345	0.94 1.02	0.81 1.08	0.81 1.08	0.85 1.07	0.85 1.07
Minong 161	1.02 1.05	1.01 1.08	1.01 1.08	1.02 1.07	1.02 1.07
Wahpeton 115	1.00 1.07	0.85 1.11	0.85 1.11	0.90 1.10	0.90 1.10
Watertown 345	0.98 1.03	0.87 1.08	0.87 1.08	0.91 1.07	0.90 1.08
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	421%	507%	507%	507%	507%
K22W (max +dP @ t, d-ang)	10.7@(2.56665,-1.7)	68.9@(2.76665,-27.6)	69.0@(2.77498,-27.5)	49.5@(2.49166,-19.0)	49.5@(2.49166,-19.0)
K22W (max -dP @ t, d-ang)	8.4@(0.64166,1.9)	6.9@(0.63333,0.7)	7.0@(0.63333,0.7)	8.5@(0.32500,0.7)	8.5@(0.32500,0.7)
K22W (max d-ang @ t, dP)	3.2@(1.00000,-5.1)	-32.9@(2.22499,56.3)	-33.0@(2.22499,56.2)	-21.0@(2.04166,38.8)	-21.0@(2.04166,38.8)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	226% / 354%	141% / 215%	141% / 215%	180% / 279%	180% / 279%
B2R at Rugby/L20D at Drayton	999% / 686%	999% / 485%	999% / 483%	999% / 548%	999% / 547%
R50M / F3M	830% / 296%	631% / 198%	631% / 198%	727% / 230%	727% / 229%
B10T	230%	81%	81%	106%	107%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 2 0)	(0 0 0)	(0 0 0)	(0 2 0)	(0 2 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 2) / (0 0 0)	(3 3 2) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
Prairie 115 / Ramsey 230	(1 4 1) / (0 1 0)	(1 7 1) / (0 2 0)	(1 7 1) / (0 2 0)	(1 4 1) / (0 1 0)	(1 4 1) / (0 1 0)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 1 0) / (1 2 1)	(0 1 0) / (1 2 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 3 2) / (1 1 1)	(1 5 0) / (1 2 2)	(1 5 0) / (1 2 2)	(1 5 1) / (1 2 2)	(1 5 1) / (1 2 2)
Damping Performance	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	41	42	43	44	45
Case Name	kc0-so08aa-er1	kcg-so08aa-er1	kc0-so08aa-evl	kcg-so08aa-evl	kc0-so08aa-fd1
Disturbance	er1	er1	evl	evl	fd1
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 11:01	FEB 05 2008 11:47	FEB 05 2008 11:02	FEB 05 2008 11:48	FEB 05 2008 11:04
Comments					
Steady State Flows					
NDEX / EAST BIAS	2079 / 296	2080 / 296	2079 / 296	2080 / 296	2079 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502
B10T / MH>SPC	165 / 61	165 / 60	165 / 61	165 / 60	165 / 61
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	11	10	11	10	11
Dorsey bipole / CU bipole	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103
Dorsey Reserve / Wtrtn SVC	321 / 33	322 / 34	321 / 33	322 / 34	321 / 33
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	338%	339%	338%	339%	338%
Min/MaxTransientVltg					
Arrowhd 230	0.98 1.05	0.98 1.05	1.02 1.07	1.02 1.07	1.00 1.05
Boise 115	0.99 1.03	0.99 1.03	0.99 1.03	0.99 1.03	0.99 1.03
Dorsey 230	1.03 1.06	1.03 1.06	1.03 1.06	1.03 1.06	1.02 1.06
Forbes 230	1.00 1.04	1.00 1.04	1.01 1.05	1.01 1.05	1.00 1.05
Riverton 230	0.95 1.06	0.95 1.06	0.99 1.07	0.99 1.07	0.95 1.07
Coal Creek 230	0.97 1.18	0.97 1.18	0.96 1.13	0.96 1.13	0.97 1.14
Stone Lake 345	1.02 1.08	1.02 1.08	1.04 1.08	1.04 1.08	1.02 1.07
Drayton 230	1.00 1.10	1.00 1.10	1.00 1.12	1.00 1.12	0.99 1.10
Groton 345	0.85 1.07	0.85 1.07	0.92 1.07	0.92 1.07	0.87 1.06
Minong 161	1.02 1.07	1.02 1.07	1.04 1.08	1.04 1.08	1.02 1.06
Wahpeton 115	0.90 1.09	0.90 1.09	0.97 1.10	0.97 1.10	0.89 1.11
Watertown 345	0.91 1.07	0.90 1.07	0.97 1.06	0.97 1.06	0.92 1.06
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVV / UdHold					
Forbes DC Red (DCAR)	507%	507%	471%	470%	360%
K22W (max +dP @ t, d-ang)	49.4@(2.48332,-19.4)	49.5@(2.48332,-19.4)	47.4@(2.34999,-15.7)	47.4@(2.34999,-15.7)	21.3@(2.67499,-1.4)
K22W (max -dP @ t, d-ang)	8.5@(0.32500,0.7)	8.5@(0.32500,0.7)	6.6@(0.34167,0.0)	6.6@(0.34167,0.0)	21.4@(0.87500,4.1)
K22W (max d-ang @ t, dP)	-21.0@(2.05833,39.3)	-21.1@(2.05833,39.3)	-17.1@(1.85833,30.6)	-17.1@(1.85833,30.6)	6.8@(1.15833,-8.4)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	180% / 279%	180% / 279%	206% / 321%	206% / 321%	183% / 284%
B2R at Rugby/L20D at Drayton	999% / 563%	999% / 561%	999% / 557%	999% / 557%	999% / 623%
R50M / F3M	726% / 228%	726% / 228%	736% / 240%	736% / 240%	715% / 254%
B10T	114%	114%	128%	128%	160%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 2 0)	(0 2 0)	(0 1 0)	(0 1 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
Prairie 115 / Ramsey 230	(1 4 1) / (0 1 0)	(1 4 1) / (0 1 0)	(1 5 1) / (0 1 0)	(1 5 1) / (0 1 0)	(1 5 1) / (0 1 0)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 5 1) / (1 2 2)	(1 5 1) / (1 2 2)	(1 4 0) / (1 1 1)	(1 4 0) / (1 1 1)	(1 5 1) / (1 2 2)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

Case No.	46	47	48	49	50
Case Name	kcg-so08aa-fd1	kc0-so08aa-fd3	kcg-so08aa-fd3	kc0-so08aa-pcs	kcg-so08aa-pcs
Disturbance	fd1	fd3	fd3	pcs	pcs
Prior Outage	None	None	None	None	None
Date/Time	FEB 05 2008 11:50	FEB 05 2008 11:06	FEB 05 2008 11:52	FEB 05 2008 11:08	FEB 05 2008 11:54
Comments					
Steady State Flows					
NDEX / EAST BIAS	2080 / 296	2079 / 296	2080 / 296	2079 / 296	2080 / 296
MHEX / L20D	2176 / 252	2176 / 252	2176 / 252	2176 / 252	2176 / 252
ECL-ARP / PRI-BYN	546 / 863	546 / 863	546 / 863	546 / 863	546 / 863
MWEX / AHD-SLK	1525 / 646	1525 / 646	1525 / 646	1525 / 646	1525 / 646
D602F / F601C	1766 / 1502	1767 / 1502	1766 / 1502	1767 / 1502	1766 / 1502
B10T / MH>SPC	165 / 60	165 / 61	165 / 60	165 / 61	165 / 60
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
R50M / OH>MP	146 / 151	146 / 151	146 / 151	146 / 151	146 / 151
G82R	10	11	10	11	10
Dorsey bipole / CU bipole	3200 / 1104	3201 / 1103	3200 / 1104	3201 / 1103	3200 / 1104
Dorsey Reserve / Wtrtn SVC	322 / 34	321 / 33	322 / 34	321 / 33	322 / 34
Forbes SVC / MSC	35 / 600	35 / 600	35 / 600	35 / 600	35 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000	1.045 / 0.000
Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025	1.063 / 1.025
Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009	1.019 / 1.009
Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031	1.020 / 1.031
Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000	1.024 / 0.000
SS OS Relay Margins					
D602F at Forbes/Dorsey	250% / 393%	250% / 393%	250% / 393%	250% / 393%	250% / 393%
B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%	999% / 809%	999% / 809%	999% / 809%
R50M/F3M	903% / 323%	903% / 323%	903% / 323%	903% / 323%	903% / 323%
B10T	339%	338%	339%	338%	339%
Min/MaxTransientVltg					
Arrowhd 230	1.00 1.05	0.95 1.04	0.95 1.04	0.85 1.00	0.85 1.00
Boise 115	0.99 1.03	0.99 1.04	0.99 1.04	0.98 1.05	0.98 1.05
Dorsey 230	1.02 1.06	1.02 1.06	1.02 1.06	1.01 1.10	1.01 1.10
Forbes 230	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05	1.00 1.05
Riverton 230	0.95 1.07	0.93 1.07	0.93 1.07	0.98 1.03	0.98 1.03
Coal Creek 230	0.97 1.14	0.95 1.15	0.95 1.15	0.96 1.07	0.96 1.07
Stone Lake 345	1.02 1.07	0.98 1.05	0.98 1.05	0.79 1.00	0.79 1.00
Drayton 230	0.99 1.10	0.98 1.12	0.98 1.12	0.99 1.06	0.99 1.06
Groton 345	0.87 1.06	0.83 1.08	0.83 1.07	0.93 1.01	0.93 1.01
Minong 161	1.02 1.06	0.99 1.05	0.99 1.05	0.82 1.01	0.82 1.01
Wahpeton 115	0.88 1.11	0.86 1.12	0.86 1.12	0.98 1.06	0.98 1.06
Watertown 345	0.92 1.06	0.89 1.07	0.89 1.07	0.97 1.03	0.97 1.03
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping					
Dorsey SUVP / UdHold		/ 0.166	/ 0.166		
Forbes DC Red (DCAR)	360%	356%	354%	107%	107%
K22W (max +dP @ t, d-ang)	21.4@(2.67499,-1.4)	27.0@(2.64165,-2.3)	27.1@(2.64165,-2.3)	8.4@(3.53331,0.7)	8.4@(3.53331,0.7)
K22W (max -dP @ t, d-ang)	21.5@(0.87500,4.1)	23.6@(0.88333,7.4)	23.8@(0.88333,7.4)	55.8@(1.65833,18.6)	55.8@(1.65833,18.6)
K22W (max d-ang @ t, dP)	6.8@(1.15833,-8.5)	9.8@(1.11666,-14.6)	9.8@(1.11666,-14.6)	29.0@(1.10833,-51.5)	29.0@(1.10833,-51.5)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	182% / 283%	184% / 286%	184% / 286%	171% / 261%	171% / 261%
B2R at Rugby/L20D at Drayton	999% / 620%	999% / 530%	999% / 529%	999% / 503%	999% / 502%
R50M / F3M	715% / 254%	730% / 265%	730% / 265%	581% / 323%	581% / 323%
B10T	160%	118%	117%	117%	117%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 1 0)	(0 1 0)	(0 0 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)	(3 4 3) / (0 3 3)	(3 4 3) / (0 3 3)
Prairie 115 / Ramsey 230	(1 5 1) / (0 1 0)	(1 5 1) / (0 2 1)	(1 5 1) / (0 2 1)	(1 2 2) / (0 1 1)	(1 2 2) / (0 1 1)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 1 1) / (1 1 1)	(0 1 1) / (1 1 1)
Shey 115 / Split Rock 115	(1 5 1) / (1 2 2)	(1 5 0) / (1 2 2)	(1 5 0) / (1 2 2)	(1 2 2) / (1 2 2)	(1 2 2) / (1 2 2)
Damping Performance					
	N/A	N/A	N/A	N/A	N/A

POWER FLOW AND STABILITY SUMMARY TABLE

1	Case No.	51	52
2	Case Name	kc0-so08aa-pyt	kcg-so08aa-pyt
3	Disturbance	pyt	pyt
4	Prior Outage	None	None
5	Date/Time	FEB 05 2008 11:10	FEB 05 2008 11:56
6	Comments		
7			
8	Steady State Flows		
9	NDEX / EAST BIAS	2079 / 296	2080 / 296
10	MHEX / L20D	2176 / 252	2176 / 252
11	ECL-ARP / PRI-BYN	546 / 863	546 / 863
12	MWEX / AHD-SLK	1525 / 646	1525 / 646
13	D602F / F601C	1767 / 1502	1766 / 1502
14	B10T / MH>SPC	165 / 61	165 / 60
15	OH E-W / OH>MH	190 / -196	190 / -196
16	R50M / OH>MP	146 / 151	146 / 151
17	G82R	11	10
18	Dorsey bipole / CU bipole	3201 / 1103	3200 / 1104
19	Dorsey Reserve / Wtrtn SVC	321 / 33	322 / 34
20	Forbes SVC / MSC	35 / 600	35 / 600
21	RCDC	0	0
22	Steady State Vltgs		
23	Dorsey 500/Dorsey 230	1.045 / 0.000	1.045 / 0.000
24	Roseau 500/Forbes 500	1.063 / 1.025	1.063 / 1.025
25	Chisago 500/EauClaire 345	1.019 / 1.009	1.019 / 1.009
26	Int Falls 115/Badoura 115	1.020 / 1.031	1.020 / 1.031
27	Drayton 230/Groton 345	1.024 / 0.000	1.024 / 0.000
28	SS OS Relay Margins		
29	D602F at Forbes/Dorsey	250% / 393%	250% / 393%
30	B2R at Rugby/L20D at Drayton	999% / 809%	999% / 809%
31	R50M/F3M	903% / 323%	903% / 323%
32	B10T	338%	339%
33	Min/MaxTransientVltg		
34	Arrowhd 230	0.99 1.02	0.99 1.02
35	Boise 115	1.02 1.04	1.02 1.04
36	Dorsey 230	1.04 1.05	1.04 1.05
37	Forbes 230	1.02 1.04	1.02 1.04
38	Riverton 230	1.02 1.04	1.02 1.04
39	Coal Creek 230	1.02 1.05	1.02 1.05
40	Stone Lake 345	0.99 1.02	0.99 1.02
41	Drayton 230	1.02 1.04	1.02 1.04
42	Groton 345	0.98 1.00	0.98 1.00
43	Minong 161	1.00 1.02	1.00 1.02
44	Wahpeton 115	1.03 1.05	1.03 1.05
45	Watertown 345	1.01 1.02	1.01 1.02
46	Dynamic Voltage Warnings		
47		none	none
48			
49			
50			
51			
52			
53			
54	Worst Case Angle Damping		
55	Dorsey SUVP / UdHold		
56	Forbes DC Red (DCAR)	330%	330%
57	K22W (max +dP @ t, d-ang)	0.0@(0.00000,0.0)	0.0@(0.00000,0.0)
58	K22W (max -dP @ t, d-ang)	28.5@(1.81666,11.1)	28.5@(1.81666,11.1)
59	K22W (max d-ang @ t, dP)	11.6@(2.10833,-26.9)	11.5@(2.10833,-26.8)
60	OS Rel Trip / Marg		
61	MH - OH		
62	D602F at Forbes/Dorsey	250% / 393%	250% / 393%
63	B2R at Rugby/L20D at Drayton	999% / 722%	999% / 721%
64	R50M / F3M	853% / 323%	854% / 323%
65	B10T	274%	275%
66	FSCAPS (SS/Unav/Final)		
67	Balta 230	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(3 3 3) / (0 0 0)	(3 3 3) / (0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)
70	Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1) / (1 1 1)	(1 1 1) / (1 1 1)
72	Damping Performance	N/A	N/A

Date: 05/16/2008 13:43
 Date of Run: FEB 12 2008 FEB 17 2008 FEB 18 2008
 Size of Plant 7.5 7.5
 Differential Impact Threshold 0.225 0.225
 Line Overload: System Intact 95.0% 100.0% 100.0%
 Contingency 95.0% 100.0% 100.0%
 Transformer Overload: System Intact 95.0% 100.0% 100.0%
 Contingency 95.0% 100.0% 100.0%
 Number of Violations Monitored: 10 10 10
 Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH		
#	NAME	#	NAME	MVA	%	MVA	%	MVA	MVA	%	MVA	MVA	FROM	TO	CKT	
34005	HRN LK 5 161 34007 LAKEFLD5 161 1	112		57.5	64.41	57.5	64.41						SYSTEM INTACT			
				104.4	116.97	104.4	116.97						34003 MAGNLIA5 161 60370 DAN JUHL 161 1			
				95.3	106.69								60128 SPLT RK5 161 60370 DAN JUHL 161 1			
34018	HAZLTON3 345 34019 HAZLTON5 161 1	224		51.2	114.74								SYSTEM INTACT			
				97.8	219.14								34018 HAZLTON3 345 34020 HAZL S 5 161 2			
34019	HAZLTON5 161 34440 HAZLTNN869.0 1	30		80	24.01	80	24.01						SYSTEM INTACT			
				137.6	41.27	137.6	41.27						34020 HAZL S 5 161 34439 HAZLTNS869.0 1			
34020	HAZL S 5 161 34439 HAZLTNS869.0 1	30		69	20.71	69	20.71						SYSTEM INTACT			
				135	40.51	135	40.51						34019 HAZLTON5 161 34440 HAZLTNN869.0 1			
34029	SALEM 3 345 34030 SALEM N5 161 1	336		89.7	301.46	89.7	301.45						SYSTEM INTACT			
				99.4	333.86								34035 ROCKCKW5 161 34037 ROCK CK5 161 1			SW769
				99.9	335.7								34036 ROCK CK3 345 34037 ROCK CK5 161 1			SW789
				98	329.34								34038 BVR CH 5 161 34044 ALBANY 5 161 1			
				98.1	329.65								34043 SAVANNA5 161 34046 YORK 5 161 1			
				99.4	334.07								34044 ALBANY 5 161 34046 YORK 5 161 1			
				100.5	337.66	100.5	337.65						60101 FORBES 2 500 60174 ROSEAUS2 500 1			SW501
				100.7	338.33	100.7	338.33						60101 FORBES 2 500 60198 CHIS-N 2 500 1			SW500
				100.5	337.66	100.5	337.65						60173 ROSEAUN2 500 60174 ROSEAUS2 500 1			SW501
				100.7	338.33	100.7	338.33						60197 CHIS CO2 500 60198 CHIS-N 2 500 1			SW500
				101.9	342.22	101.8	342.22						60202 COON CK3 345 63030 DICKNSN3 345 1			SW880
34038	BVR CH 5 161 34041 BEVCHN2869.0 2	74.7		59.2	44.2								SYSTEM INTACT			
				96.6	72.14								34040 BEVCHN1869.0 34042 BVR CH65 161 1			
34040	BEVCHN1869.0 34042 BVR CH65 161 1	150		55.6	83.42								SYSTEM INTACT			
				96	144.03								34038 BVR CH 5 161 34042 BVR CH65 161 1			
34043	SAVANNA5 161 34346 SAVNA S934.5 1	22.4		59.5	13.32	59.5	13.32						SYSTEM INTACT			
				123.5	27.67	123.5	27.67						34043 SAVANNA5 161 34347 SAVNA N934.5 1			
34043	SAVANNA5 161 34347 SAVNA N934.5 1	22.4		59.5	13.32	59.5	13.32						SYSTEM INTACT			
				122.7	27.49	122.7	27.49						34038 BVR CH 5 161 34044 ALBANY 5 161 1			SW789
				123.5	27.67	123.5	27.67						34043 SAVANNA5 161 34346 SAVNA S934.5 1			
34050	GU CTR 5 161 34167 GU CTR 934.5 1	24		109.7	26.32	109.7	26.32						SYSTEM INTACT			
				115.4	27.69	115.4	27.69						34047 ANTA TP5 161 34048 ANITA 5 161 1			
				110.5	26.53	110.5	26.53						34047 ANTA TP5 161 66560 CRESTON5 161 1			
				110.6	26.55	110.6	26.55						34047 ANTA TP5 161 66603 EXIRA 5 161 1			
				113.9	27.34	113.9	27.34						34048 ANITA 5 161 34050 GU CTR 5 161 1			
				110	26.41	110	26.41						34052 AMES 7 115 34076 BNE JCT7 115 1			SW787
				110.1	26.42	110.1	26.42						34059 BOONE E7 115 34076 BNE JCT7 115 1			
				110	26.4	110	26.4						34068 M-TOWN 5 161 34179 JASPER 5 161 1			
				110.1	26.43	110.1	26.43						34068 M-TOWN 5 161 34179 JASPER 5 161 1			SW771
				110	26.4	110	26.4						34189 OTTUMWA5 161 34192 LUCAS 5 161 1			
				110	26.4	110	26.4						34192 LUCAS 5 161 34202 LUCAS 869.0 1			

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH	
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	MVA	FROM	TO	CKT	
					95	12.67									
					96.5	12.87								34005 HRN LK 5 161 62709 BREWSTR5 161 1	
					97.2	12.95								60128 SPLT RK5 161 60129 SPLT RK7 115 6	
														60128 SPLT RK5 161 60370 DAN JUHL 161 1	
60009	HIBRD75G13.8	60214	HIBRDGE7 115 5	47	220.7	103.71	220.7	103.71		220.7	103.71			SYSTEM INTACT	
					228.5	107.38	228.5	107.38		228.5	107.38			60186 AS KING3 345 60221 KOLMNLK3 345 1	SW911
					231.2	108.67	231.2	108.67		231.2	108.67			60202 COON CK3 345 60221 KOLMNLK3 345 1	SW910
					244.9	115.12	244.9	115.12		244.9	115.12			60202 COON CK3 345 60251 TERMINL3 345 1	SW855
					231.2	108.64	231.2	108.64		231.2	108.64			60209 ELLOTPK7 115 60246 SO TOWN7 115 1	
					226.7	106.53	226.7	106.53		226.7	106.53			60218 INVRHLS7 115 60220 INVRGRV7 115 1	
					226.9	106.66	226.9	106.66		226.9	106.66			60221 KOLMNLK3 345 60251 TERMINL3 345 1	
					230	108.1	230	108.1		230	108.1			60221 KOLMNLK3 345 60251 TERMINL3 345 1	SW856
					227.7	107.03	227.7	107.03		227.7	107.03			60228 MERIMPK7 115 60275 PRIOR 7 115 1	
					230.5	108.32	230.5	108.32		230.5	108.32			60252 TERMINL7 115 60255 WESTERN7 115 1	
					231	108.58	231	108.58		231	108.58			60252 TERMINL7 115 60275 PRIOR 7 115 1	
60105	PR ISLD3 345	60106	PR ISLD5 161 10	224	67.6	151.43								SYSTEM INTACT	
					95.7	214.34								60105 PR ISLD3 345 60236 REDROCK3 345 1	SW800
60107	W FARIB7 115	60792	WFARBLT869.0 1	70	123.4	86.35	123.4	86.35		123.4	86.35			SYSTEM INTACT	
					140.8	98.55	140.8	98.55		140.8	98.55			60105 PR ISLD3 345 60106 PR ISLD5 161 10	
					140.8	98.55	140.8	98.55		140.8	98.55			60106 PR ISLD5 161 62224 RAVENNA5 161 1	
					142.4	99.69	142.4	99.69		142.4	99.69			60107 W FARIB7 115 60792 WFARBLT869.0 2	
					142.6	99.84	142.6	99.84		142.6	99.84			60107 W FARIB7 115 60792 WFARBLT869.0 3	
					139.9	97.95	139.9	97.95		139.9	97.95			60108 WILMART3 345 60192 BLUE LK3 345 1	
					140.2	98.11	140.2	98.11		140.2	98.11			60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
					139.9	97.91	139.9	97.91		139.9	97.91			60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
					134.9	94.42	134.9	94.42		134.9	94.42			60108 WILMART3 345 60365 FIELD_S3 345 1	
					156.8	109.75	156.8	109.75		156.8	109.75			60369 FEPTP 7 115 62234 LKMARN 7 115 1	
					140.8	98.55	140.8	98.55		140.8	98.55			62224 RAVENNA5 161 63071 SPRNGCK5 161 1	
60107	W FARIB7 115	60792	WFARBLT869.0 2	25	99.9	24.97	99.9	24.97		99.9	24.97			SYSTEM INTACT	
					112.5	28.13	112.5	28.13		112.5	28.13			60105 PR ISLD3 345 60106 PR ISLD5 161 10	
					112.5	28.13	112.5	28.13		112.5	28.13			60106 PR ISLD5 161 62224 RAVENNA5 161 1	
					196.2	49.04	196.2	49.04		196.2	49.04			60107 W FARIB7 115 60792 WFARBLT869.0 1	
					222.3	55.58	222.3	55.58		222.3	55.58			60107 W FARIB7 115 60792 WFARBLT869.0 1	SW822
					115.9	28.98	115.9	28.98		115.9	28.98			60107 W FARIB7 115 60792 WFARBLT869.0 3	
					112.8	28.19	112.8	28.19		112.8	28.19			60108 WILMART3 345 60192 BLUE LK3 345 1	
					113	28.24	113	28.24		113	28.24			60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
					112.7	28.18	112.7	28.18		112.7	28.18			60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
					128.1	32.03	128.1	32.03		128.1	32.03			60369 FEPTP 7 115 62234 LKMARN 7 115 1	
					112.5	28.13	112.5	28.13		112.5	28.13			62224 RAVENNA5 161 63071 SPRNGCK5 161 1	
60107	W FARIB7 115	60792	WFARBLT869.0 3	25	100.8	25.21	100.8	25.21		100.8	25.21			SYSTEM INTACT	
					113.6	28.4	113.6	28.4		113.6	28.4			60105 PR ISLD3 345 60106 PR ISLD5 161 10	
					113.6	28.4	113.6	28.4		113.6	28.4			60106 PR ISLD5 161 62224 RAVENNA5 161 1	
					198.1	49.52	198.1	49.52		198.1	49.52			60107 W FARIB7 115 60792 WFARBLT869.0 1	
					224.5	56.12	224.5	56.12		224.5	56.12			60107 W FARIB7 115 60792 WFARBLT869.0 1	SW822
					116.9	29.22	116.9	29.22		116.9	29.22			60107 W FARIB7 115 60792 WFARBLT869.0 2	
					113.9	28.46	113.9	28.46		113.9	28.46			60108 WILMART3 345 60192 BLUE LK3 345 1	
					114	28.51	114	28.51		114.1	28.51			60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
					113.8	28.45	113.8	28.45		113.8	28.46			60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
					129.4	32.34	129.4	32.34		129.4	32.34			60369 FEPTP 7 115 62234 LKMARN 7 115 1	
					113.6	28.4	113.6	28.4		113.6	28.4			62224 RAVENNA5 161 63071 SPRNGCK5 161 1	

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH		
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	MVA	FROM	TO	CKT		
60107	W FARIB7	115	62865 AIRTECH7	115	1	310	74.2	230.05	74.2	230.05		74.2	230.05		SYSTEM INTACT 60108 WILMART3 345 60365 FIELD_S3 345 1 60331 LKFLDXL3 345 60364 FIELD_N3 345 1 60364 FIELD_N3 345 60365 FIELD_S3 345 1 60369 FEPTP 7 115 62234 LKMARN 7 115 1	
60110	WILMART7	115	60650 WILMART869.0	1	70	113.2	79.21	113.2	79.21	113.2	79.21	113.2	79.21		SYSTEM INTACT 60107 W FARIB7 115 60792 WFARBLT869.0 1 60107 W FARIB7 115 60792 WFARBLT869.0 1 60107 W FARIB7 115 62865 AIRTECH7 115 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60110 WILMART7 115 60650 WILMART869.0 2 60110 WILMART7 115 60650 WILMART869.0 3 60276 AIRLAKE7 115 62234 LKMARN 7 115 1 60369 FEPTP 7 115 62865 AIRTECH7 115 1	SW822 SW812
60110	WILMART7	115	60650 WILMART869.0	2	70	113.8	79.66	113.8	79.66	113.8	79.66	113.8	79.66		SYSTEM INTACT 60107 W FARIB7 115 60792 WFARBLT869.0 1 60107 W FARIB7 115 60792 WFARBLT869.0 1 60107 W FARIB7 115 62865 AIRTECH7 115 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60110 WILMART7 115 60650 WILMART869.0 1 60110 WILMART7 115 60650 WILMART869.0 3 60276 AIRLAKE7 115 62234 LKMARN 7 115 1 60369 FEPTP 7 115 62865 AIRTECH7 115 1	SW822 SW812
60110	WILMART7	115	60650 WILMART869.0	3	70	113.2	79.21	113.2	79.21	113.2	79.21	113.2	79.21		SYSTEM INTACT 60107 W FARIB7 115 60792 WFARBLT869.0 1 60107 W FARIB7 115 60792 WFARBLT869.0 1 60107 W FARIB7 115 62865 AIRTECH7 115 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60108 WILMART3 345 60192 BLUE LK3 345 1 60110 WILMART7 115 60650 WILMART869.0 1 60110 WILMART7 115 60650 WILMART869.0 2 60276 AIRLAKE7 115 62234 LKMARN 7 115 1 60369 FEPTP 7 115 62865 AIRTECH7 115 1	SW822 SW812
60114	ELM CRK3	345	60115 ELMCRK	7	115	448	61.9	277.35	61.9	277.35		61.9	277.35		SYSTEM INTACT 60114 ELM CRK3 345 60233 PARKERS3 345 1	SW830
60122	LAWRENC7	115	60834 LAWRENC869.0	1	112	72.7	81.43	72.7	81.43	72.7	81.43	72.7	81.43		SYSTEM INTACT 60117 CHERRYC7 115 60129 SPLT RK7 115 1 60121 MINEHAH7 115 60122 LAWRENC7 115 1	SW756
60124	LINCNC07	115	60836 LINCLNC869.0	1	70	50.5	35.35	50.5	35.35	50.5	35.35	50.5	35.35		SYSTEM INTACT 60122 LAWRENC7 115 60834 LAWRENC869.0 1	
60132	WSX FLS7	115	60850 WSX FLS869.0	1	70	40.4	28.28	40.4	28.28	40.4	28.28	40.4	28.28		SYSTEM INTACT 60122 LAWRENC7 115 60834 LAWRENC869.0 1	
60140	MCHENRY7	115	63082 MCHENRY1.00	1	84	71.6	60.16	71.6	60.16	72	60.47	72	60.47		SYSTEM INTACT 60138 SOURIS 7 115 60139 MALLARD7 115 1	
							115.6	97.1	115.6	97.07	116.1	97.54	116.1	97.54	0.44	

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH	
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	MVA	FROM	TO	CKT	
					97	81.46									
					100.6	84.54	100.5	84.43		101.2	84.99				
60144	DGLASCO7 115 60749 DGLAS C869.0 1	47			72.7	34.18									
					96.4	45.32									
60145	FRANKLN7 115 60728 FRANKLN869.0 1	47			61.2	28.76									
					98.4	46.25									
60145	FRANKLN7 115 60728 FRANKLN869.0 2	47			61.2	28.76									
					98.4	46.25									
60148	MINVALY7 115 60357 MAYNARD7 115 1	78			53	41.33	53	41.33		53	41.33				
					96.4	75.2									
					112.1	87.48	112.1	87.47		112.2	87.48				
60151	MNTCELO3 345 60152 MNTCELO4 230 6	336			67.5	226.8	67.5	226.79		67.5	226.8				
					96.6	324.55									
					113.5	381.5	113.5	381.49		113.5	381.52				
					113.5	381.5	113.5	381.49		113.5	381.52				
60151	MNTCELO3 345 60153 MNTCELO7 115 10	336			73.2	245.95	73.2	245.94		73.2	245.95				
					108	362.91	108	362.91		108	362.91				
60154	SAUK RV7 115 60157 STCLOUD7 115 1	139			33.1	46.02	33.1	46.02		33.1	46.03				
					121.7	169.12	121.7	169.12		121.7	169.13				
					95.7	132.99									
60154	SAUK RV7 115 60163 WST CLD7 115 1	139			13	18.13									
					98.1	136.42									
60155	PULASKI7 115 60763 PULASKI869.0 1	70			127	88.88	127	88.88		127	88.88				
					129	90.29	129	90.29		129	90.29				
					129.2	90.42	129.2	90.42		129.2	90.42				
					131.9	92.3	131.9	92.3		131.9	92.3				
					131.9	92.3	131.9	92.3		131.9	92.3				
					128.9	90.24	128.9	90.24		128.9	90.24				
					128.3	89.78	128.3	89.78		128.3	89.78				
					128	89.58	128	89.58		128	89.58				
					131.9	92.31	131.9	92.31		131.9	92.31				
					127.9	89.54	127.9	89.54		127.9	89.54				
					127.9	89.54	127.9	89.54		127.9	89.54				
60156	PYNSVIL7 115 60702 PAYNES1934.5 1	17.9			245	43.85	245	43.85		245	43.85				
					247.1	44.23	247.1	44.23		247.1	44.23				
					247.1	44.23	247.1	44.23		247.1	44.23				
					251.1	44.95	251.1	44.95		251.1	44.95				
					247.3	44.26	247.3	44.26		247.3	44.26				
					247.5	44.3	247.5	44.3		247.5	44.3				
					254.8	45.6	254.8	45.6		254.8	45.6				
					246.5	44.13	246.5	44.13		246.5	44.13				
					254.8	45.62	254.8	45.62		254.8	45.62				
					247.5	44.3	247.5	44.3		247.5	44.3				
					258.7	46.3	258.7	46.3		258.7	46.3				
60156	PYNSVIL7 115 60760 PAYNES 869.0 1	47			66.3	31.16	66.3	31.16		66.3	31.16				
					111.2	52.24	111.1	52.24		111.2	52.24				
60156	PYNSVIL7 115 60760 PAYNES 869.0 2	47			65.6	30.83	65.6	30.83		65.6	30.84				
					110.8	52.06	110.8	52.06		110.8	52.06				
60158	STCLTP 7 115 60166 SALIDA 7 115 1	139			55.7	77.38	55.7	77.38		55.7	77.39				

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD CURRENT	OVRLD CURRENT	Diff	OVRLD CURRENT	Diff	CONTINGENCY			SWITCH	
# NAME	# NAME	MVA	% MVA	% MVA	MVA	% MVA	MVA	FROM	TO	CKT		
			136.5	189.78	136.5	189.77						
60163 WST CLD7 115 60732 WST CLD869.0 1		46.7	75.8	35.4				60143 BENTON 7 115 60146 GRANCTY7 115 1			SW757	
			98	45.79				SYSTEM INTACT				
			98.1	45.8				60156 PYNSVIL7 115 60356 PAYNES 4 230 6				
			99.3	46.4				60356 PAYNES 4 230 63050 WILLMAR4 230 1			SW928	
			96.8	45.21				62427 WILLMAR869.0 63050 WILLMAR4 230 1				
								63050 WILLMAR4 230 66550 GRANITF4 230 1				
60170 MARSHAL7 115 60171 LYON CO7 115 1		127	115.4	146.59	115.4	146.58	115.4	146.59	SYSTEM INTACT			
			124.3	157.84	124.3	157.84	124.3	157.85	60108 WILMART3 345 60365 FIELD_S3 345 1			
			126.5	160.64	126.5	160.64	126.5	160.64	60123 PIPESTN7 115 60125 PATHFDR7 115 1			
			126.5	160.64	126.5	160.64	126.5	160.65	60125 PATHFDR7 115 60129 SPLT RK7 115 1			
			151.1	191.92	151.1	191.92	151.1	191.93	60148 MINVALY7 115 60171 LYON CO7 115 1		SW812	
			126.6	160.81	126.6	160.8	126.6	160.81	60276 AIRLAKE7 115 62234 LKMARN 7 115 1			
			124.3	157.89	124.3	157.89	124.3	157.9	60331 LKFLDXL3 345 60364 FIELD_N3 345 1			
			139.1	176.68	139.1	176.68	139.1	176.69	60362 CHANRMB7 115 60384 FENTON 7 115 1			
			124.3	157.84	124.3	157.84	124.3	157.84	60364 FIELD_N3 345 60365 FIELD_S3 345 1			
			130.9	166.28	130.9	166.27	130.9	166.29	66503 BLAIR 4 230 66530 WATERTN4 230 1		SW896	
			135.6	172.22	135.6	172.22	135.6	172.23	66503 BLAIR 4 230 66550 GRANITF4 230 1		SW897	
60170 MARSHAL7 115 60373 SOUTH E7 115 1		127.9	19.8	25.27					SYSTEM INTACT			
			96.4	123.3					60170 MARSHAL7 115 60375 MMU_N7ST 115 1			
60170 MARSHAL7 115 60375 MMU_N7ST 115 1		127.9	91.1	116.49	91.1	116.49	91.1	116.49	SYSTEM INTACT			
			97.9	125.22					60125 PATHFDR7 115 60129 SPLT RK7 115 1			
			118.7	151.88	118.7	151.87	118.8	151.88	60148 MINVALY7 115 60171 LYON CO7 115 1			
			109.4	139.96	109.4	139.96	109.4	139.96	60170 MARSHAL7 115 60373 SOUTH E7 115 1			
			98.1	125.47					60276 AIRLAKE7 115 62234 LKMARN 7 115 1		SW812	
			108.9	139.25	108.9	139.24	108.9	139.25	60362 CHANRMB7 115 60384 FENTON 7 115 1			
			98.9	126.52					60371 ERIE RD7 115 60372 SARATOG7 115 1			
			109.8	140.45	109.8	140.44	109.8	140.45	60372 SARATOG7 115 67473 MMU SW 7 115 1			
			101.6	129.96	101.6	129.96	101.6	129.96	60373 SOUTH E7 115 67473 MMU SW 7 115 1			
			101.6	129.96	101.6	129.96	101.6	129.97	66503 BLAIR 4 230 66530 WATERTN4 230 1		SW896	
			106.1	135.65	106.1	135.64	106.1	135.65	66503 BLAIR 4 230 66550 GRANITF4 230 1		SW897	
60171 LYON CO7 115 60903 LYON CO869.0 1		70	31.5	22.05	31.5	22.05	31.5	22.05	SYSTEM INTACT			
			119.7	83.82	119.7	83.82	119.7	83.82	60119 LKYNKTN7 115 60171 LYON CO7 115 1		SW935	
60177 CHAMPLN7 115 60178 CHAMP T7 115 1		140	45.2	63.26	45.2	63.26	45.2	63.26	SYSTEM INTACT			
			100.3	140.41	100.3	140.42	100.3	140.41	60114 ELM CRK3 345 60233 PARKERS3 345 1		SW830	
60178 CHAMP T7 115 60205 CRKEDLK7 115 1		189	47.7	90.24	47.7	90.24	47.7	90.24	SYSTEM INTACT			
			111	209.73	111	209.73	111	209.81	60203 COON CK7 115 62090 PRKWOOD7 115 1			
			104.7	197.93	104.7	197.87	104.7	197.93	60203 COON CK7 115 62090 PRKWOOD7 115 1		SW970	
60184 APACHET7 115 60185 ARDNHLS7 115 1		229	46.2	105.9	46.2	105.9	46.2	105.9	SYSTEM INTACT			
			95.7	219.17					60212 GOOSELK7 115 60222 KOLMNLK7 115 1			
			119	272.43	119	272.43	119	272.43	60212 GOOSELK7 115 60222 KOLMNLK7 115 1		SW919	
60190 BLK DOG7 115 60258 WILSON 7 115 3		167	83.2	138.96	83.2	138.96	83.2	138.96	SYSTEM INTACT			
			99.1	165.47					60190 BLK DOG7 115 60242 SAVAGE 7 115 1			
			99.1	165.47					60190 BLK DOG7 115 60242 SAVAGE 7 115 1		SW885	
			143.2	239.08	143.2	239.08	143.2	239.08	60190 BLK DOG7 115 60258 WILSON 7 115 1			
			95.8	159.96					60208 EDINA 7 115 60263 EDEN PR7 115 1			
60208 EDINA 7 115 60263 EDEN PR7 115 1		310	73	226.26					SYSTEM INTACT			
			96	297.67					60234 PARKERS7 115 60259 BASCRK 7 115 1		SW838	
60212 GOOSELK7 115 62091 VADNSTP7 115 1		189	51.3	96.88	51.3	96.89	51.3	96.88	SYSTEM INTACT			
			106.3	200.81	106.3	200.81	106.2	200.73	60184 APACHET7 115 60185 ARDNHLS7 115 1			

Output File:

kc0-sp08-line

kcg-sp08-line

kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH
#	NAME	#	NAME	MVA	%	MVA	%	MVA	MVA	MVA	FROM	TO	CKT	
60224	LONG LK7 115 60230 OAKDALE7 115 1	239	56	133.88	56	133.88		56	133.87		SYSTEM INTACT			
			104	248.67	104	248.67		104	248.67		60179 AFTON 7 115 60238 REDROCK7 115 1			SW921
			103.9	248.37	103.9	248.37		103.9	248.37		60238 REDROCK7 115 60344 WOODBUR7 115 1			
60225	LXNGTON7 115 62091 VADNTP7 115 1	189	42.4	80.1							SYSTEM INTACT			
			97.1	183.55							60184 APACHET7 115 60185 ARDNHLS7 115 1			
60236	REDROCK3 345 60238 REDROCK7 115 9	448	67.4	301.86							SYSTEM INTACT			
			97	434.52							60236 REDROCK3 345 60238 REDROCK7 115 10			
60244	SCOTTCO7 115 60890 SCOTTCO869.0 1	70	60.9	42.62	60.9	42.62		60.9	42.62		SYSTEM INTACT			
			105.3	73.73	105.3	73.73		105.3	73.73		60244 SCOTTCO7 115 60890 SCOTTCO869.0 2			
60244	SCOTTCO7 115 60890 SCOTTCO869.0 2	70	59.4	41.58	59.4	41.58		59.4	41.58		SYSTEM INTACT			
			96.8	67.78							60108 WILMART3 345 60192 BLUE LK3 345 1			SW903
			99.6	69.74							60244 SCOTTCO7 115 60261 DEANLAK7 115 1			SW904
			104.7	73.3	104.7	73.3		104.7	73.3		60244 SCOTTCO7 115 60890 SCOTTCO869.0 1			
60250	TANRSLK7 115 60344 WOODBUR7 115 1	191	25.7	49.16	25.7	49.16		25.7	49.16		SYSTEM INTACT			
			110.6	211.32	110.6	211.32		110.6	211.32		60176 BAYTOWN7 115 60187 AS KING7 115 1			SW810
			98.1	187.3							60224 LONG LK7 115 60230 OAKDALE7 115 1			
60262	EDEN PR3 345 60263 EDEN PR7 115 10	448	60	268.98							SYSTEM INTACT			
			95.4	427.41							60262 EDEN PR3 345 60263 EDEN PR7 115 9			
60262	EDEN PR3 345 60263 EDEN PR7 115 9	448	64.6	289.31							SYSTEM INTACT			
			95.6	428.49							60233 PARKERS3 345 60262 EDEN PR3 345 1			SW988
			98.5	441.44							60262 EDEN PR3 345 60263 EDEN PR7 115 10			
60279	BUFFRID7 115 60616 BRI WND134.5 1	120	109.5	131.43	109.5	131.43		109.5	131.43		SYSTEM INTACT			
			110.4	132.47	110.4	132.47		110.4	132.47		60119 LKYNKTN7 115 60171 LYON CO7 115 1			SW935
			111.8	134.2	111.8	134.2		111.8	134.2		60119 LKYNKTN7 115 60279 BUFFRID7 115 1			
			109.7	131.69	109.7	131.69		109.7	131.69		60119 LKYNKTN7 115 62712 ELLSBOR7 115 1			
			110.2	132.18	110.2	132.18		110.2	132.18		60123 PIPESTN7 115 60279 BUFFRID7 115 1			
			109.8	131.8	109.8	131.8		109.8	131.8		60123 PIPESTN7 115 60362 CHANRMB7 115 1			
			222.5	266.97	222.5	266.97		222.5	266.97		60279 BUFFRID7 115 60617 BRI WND234.5 2			
			110.5	132.61	110.5	132.61		110.5	132.61		60362 CHANRMB7 115 60384 FENTON 7 115 1			
			109.8	131.7	109.8	131.7		109.8	131.7		60362 CHANRMB7 115 62712 ELLSBOR7 115 1			
			109.8	131.7	109.8	131.7		109.8	131.7		66504 BROOKNG7 115 66531 WATERTN7 115 1			SW898
			109.7	131.69	109.7	131.69		109.7	131.69		66529 WATERTN3 345 66537 WHITE 3 345 1			
60279	BUFFRID7 115 60617 BRI WND234.5 2	120	109.5	131.39	109.5	131.39		109.5	131.39		SYSTEM INTACT			
			110.4	132.43	110.4	132.43		110.4	132.43		60119 LKYNKTN7 115 60171 LYON CO7 115 1			SW935
			111.8	134.16	111.8	134.16		111.8	134.16		60119 LKYNKTN7 115 60279 BUFFRID7 115 1			
			109.7	131.66	109.7	131.66		109.7	131.66		60119 LKYNKTN7 115 62712 ELLSBOR7 115 1			
			110.1	132.14	110.1	132.14		110.1	132.14		60123 PIPESTN7 115 60279 BUFFRID7 115 1			
			109.8	131.76	109.8	131.76		109.8	131.76		60123 PIPESTN7 115 60362 CHANRMB7 115 1			
			222.5	266.97	222.5	266.97		222.5	266.97		60279 BUFFRID7 115 60616 BRI WND134.5 1			
			110.5	132.57	110.5	132.57		110.5	132.57		60362 CHANRMB7 115 60384 FENTON 7 115 1			
			109.7	131.66	109.7	131.66		109.7	131.66		60362 CHANRMB7 115 62712 ELLSBOR7 115 1			
			109.7	131.67	109.7	131.67		109.7	131.67		66504 BROOKNG7 115 66531 WATERTN7 115 1			SW898
			109.7	131.65	109.7	131.65		109.7	131.65		66529 WATERTN3 345 66537 WHITE 3 345 1			
60288	IRONWD 7 115 60289 HURLEY 7 115 1	60	85.7	51.44	85.7	51.44		85.7	51.43		SYSTEM INTACT			
			96.5	57.88							60282 REDCDR 5 161 60319 WHEATTP5 161 1			SW866
			96.2	57.7							60282 REDCDR 5 161 60319 WHEATTP5 161 1			SW870
			98.5	59.13							60285 EAGLEPT7 115 60321 HYDROLN7 115 1			SW865
			96.6	57.95							60296 SHELDNP7 115 60297 OSPREY 7 115 1			
			98.9	59.32							60296 SHELDNP7 115 60306 HOLCOMB7 115 1			

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD CURRENT	OVRLD CURRENT	Diff	OVRLD CURRENT	Diff	CONTINGENCY			SWITCH
# NAME	# NAME	MVA	% MVA	% MVA	MVA	% MVA	MVA	FROM	TO	CKT	
			100.8 60.49	100.8 60.49		100.8 60.48		60306 HOLCOMB7 115 60322 CORNELL7 115 1			SW872
			100.8 60.5	100.8 60.5		100.8 60.49		60306 HOLCOMB7 115 60322 CORNELL7 115 1			
			96.2 57.71					60319 WHEATTP5 161 60320 HYDROLN5 161 1			
			96.2 57.7					60320 HYDROLN5 161 60321 HYDROLN7 115 1			
			98.4 59.07					60321 HYDROLN7 115 60326 JIMFLS 7 115 1			
60290 ST LAKE5 161 60663 STONELK869.0 2		70	62 43.38					SYSTEM INTACT			
			98.4 68.88					60290 ST LAKE5 161 60293 FRMSINN5 161 1			
60293 FRMSINN5 161 60664 FRMRSIN869.0 1		50	61.9 30.94	61.9 30.94		61.9 30.94		SYSTEM INTACT			
			116.9 58.43	116.9 58.43		116.9 58.43		60290 ST LAKE5 161 60663 STONELK869.0 2			
60298 PARKFLS7 115 61101 PARKFLS934.5 1		28	60 16.8	60 16.8		60 16.8		SYSTEM INTACT			
			122.2 34.21	122.2 34.21		122.2 34.21		60298 PARKFLS7 115 61101 PARKFLS934.5 2			
60298 PARKFLS7 115 61101 PARKFLS934.5 2		28	60 16.8	60 16.8		60 16.8		SYSTEM INTACT			
			122.2 34.21	122.2 34.21		122.2 34.21		60298 PARKFLS7 115 61101 PARKFLS934.5 1			
60302 COULEE 5 161 60967 COULEE 869.0 1		70	62.5 43.77	62.5 43.77		62.5 43.77		SYSTEM INTACT			
			108 75.63	108 75.63		108 75.63		60302 COULEE 5 161 60308 LACROSS5 161 1			SW874
			114.4 80.1	114.4 80.1		114.4 80.1		60302 COULEE 5 161 60967 COULEE 869.0 2			
60302 COULEE 5 161 60967 COULEE 869.0 2		112	68 76.12	68 76.12		68 76.12		SYSTEM INTACT			
			117.4 131.54	117.4 131.53		117.4 131.54		60302 COULEE 5 161 60308 LACROSS5 161 1			SW874
60305 EAU CLA5 161 61001 EAUCLAI869.0 1		112	76.9 86.16	76.9 86.16		76.9 86.16		SYSTEM INTACT			
			95.8 107.27					60282 REDCDR 5 161 60319 WHEATTP5 161 1			SW866
			116.4 130.41	116.4 130.41		116.4 130.41		60305 EAU CLA5 161 61001 EAUCLAI869.0 2			
			103.5 115.89	103.5 115.89		103.5 115.89		60323 SEVN ML5 161 61071 SEVN ML869.0 1			
60305 EAU CLA5 161 61001 EAUCLAI869.0 2		112	84.3 94.41	84.3 94.41		84.3 94.41		SYSTEM INTACT			
			105 117.54	105 117.54		104.9 117.54		60282 REDCDR 5 161 60319 WHEATTP5 161 1			SW866
			99.9 111.85					60282 REDCDR 5 161 60319 WHEATTP5 161 1			SW870
			96.2 107.75					60305 EAU CLA5 161 60323 SEVN ML5 161 1			
			97.8 109.58					60305 EAU CLA5 161 60368 JEFRSRD5 161 1			
			122.1 136.76	122.1 136.76		122.1 136.76		60305 EAU CLA5 161 61001 EAUCLAI869.0 1			
			95.3 106.75					60318 WHT 56 5 161 60319 WHEATTP5 161 1			SW871
			95.3 106.76					60318 WHT 56 5 161 60319 WHEATTP5 161 1			
			98.6 110.41					60319 WHEATTP5 161 60320 HYDROLN5 161 1			
			98.6 110.39					60320 HYDROLN5 161 60321 HYDROLN7 115 1			
			113.4 126.99	113.4 126.99		113.4 126.99		60323 SEVN ML5 161 61071 SEVN ML869.0 1			
60305 EAU CLA5 161 61200 PRESTOT5 161 1		272	54.9 149.42					SYSTEM INTACT			
			95.3 259.32					60186 AS KING3 345 60304 EAU CL 3 345 1			SW400
60307 JACKSON5 161 60966 JACKCO 869.0 1		47	84.6 39.77	84.6 39.77		84.6 39.77		SYSTEM INTACT			
			99.1 46.58					60308 LACROSS5 161 60310 MONROCO5 161 1			
			99.1 46.58					60310 MONROCO5 161 60949 MONROCO869.0 1			
			103.4 48.61	103.4 48.62		103.4 48.61		60316 TREMVAL5 161 60979 TREMVAL869.0 1			
60308 LACROSS5 161 60973 LAX 869.0 1		70	70.4 49.29					SYSTEM INTACT			
			97.9 68.52					60308 LACROSS5 161 60973 LAX 869.0 2			
60308 LACROSS5 161 60973 LAX 869.0 2		70	70.7 49.52					SYSTEM INTACT			
			98.2 68.71					60308 LACROSS5 161 60973 LAX 869.0 1			
60310 MONROCO5 161 60949 MONROCO869.0 1		70	106.5 74.54	106.5 74.54		106.5 74.54		SYSTEM INTACT			
			108.1 75.66	108.1 75.66		108.1 75.66		34021 LANSINGW 161 34022 LANSING5 161 1			SW914
			110.1 77.06	110.1 77.06		110.1 77.06		60186 AS KING3 345 60221 KOLMNLK3 345 1			SW916
			109.2 76.41	109.2 76.41		109.2 76.41		60186 AS KING3 345 60236 REDROCK3 345 1			SW861
			110.4 77.25	110.4 77.25		110.4 77.25		60186 AS KING3 345 60304 EAU CL 3 345 1			
			110.7 77.48	110.7 77.48		110.7 77.48		60302 COULEE 5 161 60967 COULEE 869.0 2			

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: # NAME	CIRCUIT TO: # NAME	CTK	RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
				117.6	82.29	117.6	82.29		117.6	82.29		60307 JACKSON5 161 60316 TREMVAL5 161 1	
				117.6	82.29	117.6	82.29		117.6	82.29		60307 JACKSON5 161 60966 JACKCO 869.0 1	
				110.1	77.06	110.1	77.06		110.1	77.06		60308 LACROSS5 161 60311 MAYFAIR5 161 1	
				112.6	78.85	112.6	78.85		112.6	78.84		60308 LACROSS5 161 60973 LAX 869.0 1	
				112.7	78.87	112.7	78.87		112.7	78.87		60308 LACROSS5 161 60973 LAX 869.0 2	
60312 PINE LK5 161 60313 PINE LK7 115 3			112	41.9	46.97	41.9	46.97		41.9	46.97		SYSTEM INTACT	
				125.9	141.05	125.9	141.05		125.9	141.05		60187 AS KING7 115 60325 WILLOWRV7 115 1	
60315 T-CRNR5 115 60666 T CORNE869.0 1			62.5	47.4	29.64	47.4	29.64		47.4	29.64		SYSTEM INTACT	
				109.5	68.45	109.5	68.45		109.5	68.45		60315 T-CRNR5 115 60666 T CORNE869.0 2	
60317 WHT 14 5 161 61200 PRESTOT5 161 1			272	55.8	151.67							SYSTEM INTACT	
				96.6	262.65							60186 AS KING3 345 60304 EAU CL 3 345 1	SW400
60323 SEVN ML5 161 61071 SEVN ML869.0 1			112	80.8	90.54	80.8	90.54		80.8	90.54		SYSTEM INTACT	
				100	111.95							60305 EAU CLA5 161 61001 EAUCLA1869.0 1	
				102.8	115.18	102.8	115.18		102.8	115.18		60305 EAU CLA5 161 61001 EAUCLA1869.0 2	
60357 MAYNARD7 115 62005 KERKHOT7 115 1			78	50.4	39.34	50.4	39.33		50.4	39.34		SYSTEM INTACT	
				98.5	76.8							62427 WILLMAR869.0 63050 WILLMAR4 230 1	SW928
				118.9	92.76	118.9	92.76		118.9	92.77		63050 WILLMAR4 230 66550 GRANITF4 230 1	
60362 CHANRMB7 115 60614 CHB WND134.5 1			120	149.5	179.37	149.5	179.37		149.5	179.37		SYSTEM INTACT	
				150.6	180.78	150.6	180.78		150.6	180.78		60119 LKYNKTN7 115 60171 LYON CO7 115 1	SW935
				150.8	181.01	150.8	181.01		150.8	181.01		60119 LKYNKTN7 115 60279 BUFRID7 115 1	
				149.9	179.87	149.9	179.87		149.9	179.87		60123 PIPESTN7 115 60125 PATHFDR7 115 1	
				149.8	179.81	149.8	179.81		149.8	179.81		60125 PATHFDR7 115 60129 SPLT RK7 115 1	
				149.8	179.74	149.8	179.74		149.8	179.74		60126 SPLT RK3 345 60130 SPLTRTA3 345 1	
				149.8	179.79	149.8	179.79		149.8	179.79		60126 SPLT RK3 345 60130 SPLTRTA3 345 1	SW755
				149.8	179.78	149.8	179.78		149.8	179.78		60130 SPLTRTA3 345 66537 WHITE 3 345 1	
				149.7	179.62	149.7	179.62		149.7	179.62		60170 MARSHAL7 115 60171 LYON CO7 115 1	
				300.9	361.05	300.9	361.05		300.9	361.05		60362 CHANRMB7 115 60615 CHB WND234.5 2	
				149.7	179.59	149.7	179.59		149.7	179.59		60362 CHANRMB7 115 62712 ELLSBOR7 115 1	
60362 CHANRMB7 115 60615 CHB WND234.5 2			120	149.5	179.37	149.5	179.37		149.5	179.37		SYSTEM INTACT	
				150.6	180.78	150.6	180.78		150.6	180.78		60119 LKYNKTN7 115 60171 LYON CO7 115 1	SW935
				150.8	181.01	150.8	181.01		150.8	181.01		60119 LKYNKTN7 115 60279 BUFRID7 115 1	
				149.9	179.87	149.9	179.87		149.9	179.87		60123 PIPESTN7 115 60125 PATHFDR7 115 1	
				149.8	179.81	149.8	179.81		149.8	179.81		60125 PATHFDR7 115 60129 SPLT RK7 115 1	
				149.8	179.74	149.8	179.74		149.8	179.74		60126 SPLT RK3 345 60130 SPLTRTA3 345 1	
				149.8	179.79	149.8	179.79		149.8	179.79		60126 SPLT RK3 345 60130 SPLTRTA3 345 1	SW755
				149.8	179.78	149.8	179.78		149.8	179.78		60130 SPLTRTA3 345 66537 WHITE 3 345 1	
				149.7	179.62	149.7	179.62		149.7	179.62		60170 MARSHAL7 115 60171 LYON CO7 115 1	
				300.9	361.05	300.9	361.05		300.9	361.05		60362 CHANRMB7 115 60614 CHB WND134.5 1	
				149.7	179.59	149.7	179.59		149.7	179.59		60362 CHANRMB7 115 62712 ELLSBOR7 115 1	
60369 FEPTP 7 115 62234 LKMARN 7 115 1			310	83.2	257.83	83.2	257.82		83.2	257.83		SYSTEM INTACT	
				97.9	303.6							60101 FORBES 2 500 60198 CHIS-N 2 500 1	SW500
				112.8	349.54	112.8	349.54		112.8	349.54		60107 W FARIB7 115 62865 AIRTECH7 115 1	
				105.8	327.89	105.8	327.88		105.8	327.9		60108 WILMART3 345 60192 BLUE LK3 345 1	
				106.5	330.05	106.5	330.04		106.5	330.05		60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
				106.1	328.84	106.1	328.83		106.1	328.84		60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
				98.7	306.12							60108 WILMART3 345 60365 FIELD_S3 345 1	
				97.9	303.6							60197 CHIS CO2 500 60198 CHIS-N 2 500 1	SW500
				98.8	306.19							60331 LKFLDXL3 345 60364 FIELD_N3 345 1	
				98.7	306.09							60364 FIELD_N3 345 60365 FIELD_S3 345 1	

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY	SWITCH		
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	FROM	TO	CKT	SWITCH
					113.4	351.41	113.4	351.41						
60369	FEPTP 7 115 62865 AIRTECH7 115 1	310		75.7	234.57	75.7	234.57		75.7	234.57	60369	FEPTP 7 115 62865 AIRTECH7 115 1		
				99.2	307.41									
				99.2	307.57									
				99.2	307.44									
				110.1	341.18	110.1	341.17		110.1	341.17				
60372	SARATOG7 115 67473 MMU SW 7 115 1	127.9		19.4	24.79									
				95.7	122.34									
60382	BRKNGCO7 115 60383 BRKNGCO3 345 1	448		92.7	415.42	92.7	415.43		92.7	415.42				
				97.9	438.37									
				112.7	505.04	112.7	505.05		112.7	505.04				
				116.8	523.3	116.8	523.31		116.8	523.3				
				103.3	462.6	103.3	462.61		103.3	462.59				
				106	474.97	106	474.98		106	474.96				
				103.2	462.49	103.2	462.49		103.2	462.48				
				97.1	435.04									
				98.5	441.26									
				110	492.8	110	492.8		110	492.8				
				109.7	491.47	109.7	491.48		109.7	491.46				
62003	JOHNJCT7 115 63216 ORTONVL7 115 1	96.6		70.4	68	70.4	67.99		70.4	68				
				100.5	97.04	100.4	97.03		100.5	97.05				
				96.5	93.24									
				96.1	92.8									
				99.4	96.02									
62147	BNKRLK 869.0 63046 BUNKER 4 230 1	112		76.9	86.17									
				97.7	109.43									
62232	DKTAHGT7 115 62237 KENRICK7 115 1	144		66.8	96.24	66.8	96.24		66.8	96.24				
				108.4	156.13	108.4	156.13		108.4	156.13				
62234	LKMARN 7 115 62237 KENRICK7 115 1	144		71.3	102.66	71.3	102.66		71.3	102.66				
				113	162.76	113	162.75		113	162.76				
62234	LKMARN 7 115 62259 LKMARN 869.0 1	70		81.6	57.09	81.6	57.09		81.6	57.09				
				105.8	74.04	105.8	74.04		105.8	74.04				
				101.9	71.35	101.9	71.35		101.9	71.35				
				106.3	74.43	106.3	74.43		106.3	74.43				
				98.2	68.77									
				100	69.98									
62387	SPRNGCK869.0 63071 SPRNGCK5 161 1	70		71.7	50.18	71.7	50.18		71.7	50.18				
				107.7	75.37	107.7	75.38		107.7	75.37				
62387	SPRNGCK869.0 63071 SPRNGCK5 161 2	70		65.2	45.64	65.2	45.64		65.2	45.64				
				103.1	72.17	103.1	72.17		103.1	72.17				
62425	WILLMAR7 115 62427 WILLMAR869.0 1	92.4		33.4	30.82	33.4	30.83		33.4	30.82				
				106.6	98.46	106.6	98.47		106.6	98.46				
62666	GLNDALE7 115 62672 GLNDALE869.0 1	46.7		68.5	32.01	68.5	32.01		68.5	32.01				
				102.1	47.69	102.1	47.69		102.1	47.69				
62666	GLNDALE7 115 62672 GLNDALE869.0 2	46.7		68.5	32.01	68.5	32.01		68.5	32.01				
				99.8	46.6									
				102.1	47.69	102.1	47.69		102.1	47.69				
62667	ST BONI7 115 63021 ST BONI869.0 1	70		28.9	20.24	28.9	20.24		28.9	20.24				
				109.9	76.95	109.9	76.95		109.9	76.95				

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD CURRENT	OVRLD CURRENT	Diff	OVRLD CURRENT	Diff	CONTINGENCY			SWITCH
# NAME	# NAME	MVA	% MVA	% MVA	MVA	% MVA	MVA	FROM	TO	CKT	
			101.2	42.51	101.2	42.51					
66203 FARGO	869.0 66436 FARGO	42	28.2	11.82	28.2	11.82		65708 WLINC	7 115 65812 WLINC	A934.5 3	
			122.1	51.27	122.1	51.27		SYSTEM INTACT			
66203 FARGO	869.0 66436 FARGO	100	57.5	57.51	57.5	57.5		66203 FARGO	869.0 66436 FARGO	7 115 2	
			110.8	110.8	110.8	110.8		SYSTEM INTACT			
			110.8	110.8	110.8	110.8		60136 MAPLE	R7 115 66783 MAPLE	RT 115 1	
66303 SIOUXC1T	345 66564 SIOUXCY3	250	68.9	172.14	68.9	172.14		66783 MAPLE	RT 115 67000 MAPLE	R869.0 1	
			108.6	271.45	108.6	271.44		SYSTEM INTACT			
			108.6	271.45	108.6	271.44		66306 SIOUXC2T	345 66564 SIOUXCY3	345 1	
66303 SIOUXC1T	345 66565 SIOUXCY4	250	68.9	172.14	68.9	172.14		66306 SIOUXC2T	345 66565 SIOUXCY4	230 1	
			108.6	271.45	108.6	271.44		SYSTEM INTACT			
			108.6	271.45	108.6	271.44		66306 SIOUXC2T	345 66564 SIOUXCY3	345 1	
66306 SIOUXC2T	345 66564 SIOUXCY3	250	67.8	169.4	67.8	169.4		66306 SIOUXC2T	345 66565 SIOUXCY4	230 1	
			107.9	269.67	107.9	269.67		SYSTEM INTACT			
			107.9	269.67	107.9	269.67		66303 SIOUXC1T	345 66564 SIOUXCY3	345 1	
66306 SIOUXC2T	345 66565 SIOUXCY4	250	67.8	169.4	67.8	169.4		66303 SIOUXC1T	345 66565 SIOUXCY4	230 1	
			107.9	269.67	107.9	269.67		SYSTEM INTACT			
			107.9	269.67	107.9	269.67		66303 SIOUXC1T	345 66564 SIOUXCY3	345 1	
66401 CIRCLE	7 115 66404 DAWSONC7	40	25.7	10.29	25.7	10.29		66303 SIOUXC1T	345 66565 SIOUXCY4	230 1	
			133	53.22	133.1	53.23		SYSTEM INTACT			
66401 CIRCLE	7 115 66409 WOLFPT	40	47	18.79	47	18.8		66403 DAWSONC4	230 66405 FTPECK	4 230 1	
			153.7	61.49	153.8	61.51		SYSTEM INTACT			
66403 DAWSONC4	230 66411 MI CTYE4	200	89.7	179.38	89.7	179.48		66403 DAWSONC4	230 66405 FTPECK	4 230 1	
			105.9	211.76	105.9	211.84		SYSTEM INTACT			
			105.9	211.76	105.9	211.84		66210 DAWSONCT	230 66403 DAWSONC4	230 1	0.66
			101.1	202.26	101.2	202.37		66210 DAWSONCT	230 66404 DAWSONC7	115 1	0.66
			101.1	202.26	101.2	202.37		66216 MICTYE1T	230 66411 MI CTYE4	230 1	0.57
			104.3	208.55	104.3	208.67		66216 MICTYE1T	230 66412 MI CTYE7	115 1	0.57
			107.8	215.5	107.8	215.62		66404 DAWSONC7	115 66407 FALLON	7 115 1	
			100.6	201.11	100.6	201.23		66404 DAWSONC7	115 67332 GLENDCT7	115 1	0.78
			102.7	205.47	102.9	205.86	0.39	66407 FALLON	7 115 66412 MI CTYE7	115 1	0.58
			101.6	203.26	101.6	203.24		66470 BISON	4 230 66497 MAURINE4	230 1	0.79
			101.9	203.85	102	203.98		66470 BISON	4 230 67347 HETINGR4	230 1	0.74
66404 DAWSONC7	115 67356 LEWIS	80	44	35.21	44.2	35.34		67305 BAKER	7 115 67332 GLENDCT7	115 1	0.28
			120.5	96.42	120.7	96.56		SYSTEM INTACT			
			130.6	104.51	130.8	104.66		66403 DAWSONC4	230 66413 MEDORA	4 230 1	0.54
66405 FTPECK	4 230 66406 FTPECK	67	5.4	3.64	5.4	3.62		66413 MEDORA	4 230 66425 BELFELD4	230 1	0.92
			128.2	85.87	128.2	85.87		SYSTEM INTACT			
66408 WATFORD	7 115 67182 CHAR.CK7	80	84.4	67.55	84.8	67.85		66403 DAWSONC4	230 66405 FTPECK	4 230 1	
			108.5	86.79	109	87.17	0.38	SYSTEM INTACT			
			108.5	86.8	109	87.18	0.38	66220 BELFELDT	345 66424 BELFELD3	345 1	0.86
			123.9	99.12	124.3	99.42	0.3	66220 BELFELDT	345 66425 BELFELD4	230 1	0.86
			129.1	103.29	129.5	103.59	0.3	66403 DAWSONC4	230 66413 MEDORA	4 230 1	0.96
			108.8	87.04	109.3	87.41	0.37	66413 MEDORA	4 230 66425 BELFELD4	230 1	1.12
			106	84.76	106.2	84.99	0.23	66424 BELFELD3	345 67183 CHAR.CK3	345 1	0.85
			106.2	84.95	106.5	85.17		67104 TIOGA4	4 230 67108 LOGAN	4 230 1	0.77
			104.3	83.43	104.7	83.8	0.37	67104 TIOGA4	4 230 67385 TIOGA4	7 115 1	0.77
			104.3	83.47	104.8	83.84	0.37	67181 BICNTNL7	115 67184 R.RIDER7	115 1	0.89
			115.9	92.71	116.1	92.85		67182 CHAR.CK7	115 67184 R.RIDER7	115 1	0.89
								67385 TIOGA4	7 115 67386 TIOGA7	7 115 1	0.77

Output File: kc0-sp08-line kcg-sp08-line kcl-sp08-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH	
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	MVA	FROM	TO	CKT	
66417	DICKNSN4 230	66418	DKSN-ND7 115 1	100	69.2	69.22	69.2	69.24			69.6	69.56			
					110.9	110.93	111	110.96			111.5	111.55	0.62		SYSTEM INTACT
					115.4	115.41	115.4	115.44			116.2	116.19	0.78		66403 DAWSONC4 230 66413 MEDORA 4 230 1
					107.7	107.74	107.8	107.8			108.3	108.31	0.57		66413 MEDORA 4 230 66425 BELFELD4 230 1
					113	112.95	113	113.01			113.5	113.52	0.57		66418 DKSN-ND7 115 67320 DICKSWH7 115 1
66421	WILISTN7 115	67386	TIOGA7 7 115 1	79.7	40.1	31.91								67318 COYOTE 7 115 67320 DICKSWH7 115 1	
					100	79.69								SYSTEM INTACT	
66426	BISMARK4 230	66427	BISMARK7 115 1	100	68.4	68.42	68.3	68.29			68.6	68.6			67101 ANTELOP3 345 67183 CHAR.CK3 345 1
					109.8	109.8	109.6	109.59			110.1	110.09	0.29		SYSTEM INTACT
66426	BISMARK4 230	66427	BISMARK7 115 2	100	60.6	60.58	60.5	60.46			60.7	60.74			66426 BISMARK4 230 66427 BISMARK7 115 2
					105.5	105.47	105.3	105.27			105.8	105.76	0.29		SYSTEM INTACT
66451	RICHLND7 115	67356	LEWIS 7 115 1	79.7	23.2	18.48	23.3	18.57			23.6	18.79			66426 BISMARK4 230 66427 BISMARK7 115 1
					100.8	80.31	101	80.46			101.8	81.13	0.82		SYSTEM INTACT
					111.6	88.91	111.8	89.04			112.8	89.84	0.93		66403 DAWSONC4 230 66413 MEDORA 4 230 1
66486	PHILIP 4 230	66487	PHILIP 7 115 1	100	41.6	41.64								66413 MEDORA 4 230 66425 BELFELD4 230 1	
					97.4	97.37								SYSTEM INTACT	
66488	PHILTAP4 230	66519	OAHE 4 230 1	240	67.9	163.02	67.9	162.89						66484 NUNDRWD4 230 66488 PHILTAP4 230 1	
					114.6	275.09	114.5	274.91						SYSTEM INTACT	
					114.6	275.09	114.5	274.91						66573 STEGALL4 230 67206 STGXFMR4 230 1	SW4
					114.6	275.09	114.5	274.91						67135 STEGALL3 345 67207 STEGALTY 345 1	SW4
														67206 STGXFMR4 230 67207 STEGALTY 345 1	SW4
66502	BERSFRD7 115	66517	MANNING7 115 1	80	37.5	30.03	37.5	30.03			37.5	30.03			SYSTEM INTACT
					107.1	85.68	107.1	85.68			107.1	85.68			66511 GAVINS 7 115 66532 YANKTON7 115 1
					107.1	85.68	107.1	85.68			107.1	85.68			66532 YANKTON7 115 67121 SPIRITM7 115 1
66519	OAHE 4 230	66520	OAHE 7 115 1	107	43.4	46.4	43.3	46.35			43.4	46.48			SYSTEM INTACT
					100.5	107.56	100.4	107.45			100.7	107.74			66488 PHILTAP4 230 66519 OAHE 4 230 1
67104	TIOGA4 4 230	67385	TIOGA4 7 115 1	100	70	69.98	69.7	69.68			70.3	70.32			SYSTEM INTACT
					95.6	95.61									66413 MEDORA 4 230 66425 BELFELD4 230 1
					106.8	106.77	105.9	105.89			106.7	106.71			67101 ANTELOP3 345 67183 CHAR.CK3 345 1
67307	BISM NW7 115	67343	HESKETT7 115 1	119.5	45.4	54.29								SYSTEM INTACT	
					99.7	119.15									66427 BISMARK7 115 67329 ESTBMRK7 115 1
67318	COYOTE 7 115	67320	DICKSWH7 115 1	101.4	52.5	53.28								SYSTEM INTACT	
					95.7	97.09									66417 DICKNSN4 230 66418 DKSN-ND7 115 1
67335	GLENHAM7 115	67338	GLENHAM4 230 1	25	38.2	9.55	38.2	9.55			38.2	9.55			SYSTEM INTACT
					102.4	25.6	102.4	25.6			102.4	25.61			67335 GLENHAM7 115 67338 GLENHAM4 230 2
67342	HESKETT4 230	67343	HESKETT7 115 1	100	39.1	39.05	39	38.99			39.1	39.11			SYSTEM INTACT
					132.6	132.58	132.3	132.32			132.4	132.39			66427 BISMARK7 115 67329 ESTBMRK7 115 1
67385	TIOGA4 7 115	67386	TIOGA7 7 115 1	101.4	56.6	57.41	56.2	57.04			56.7	57.54			SYSTEM INTACT
					103.7	105.17	102.6	104.06			103.4	104.83			67101 ANTELOP3 345 67183 CHAR.CK3 345 1
					175.8	175.76	175.8	175.76			175.7	175.75			67396 G132 POI 230 67397 G132 CLC34.5 1

Date: 05/16/2008 13:45
Date of Run: FEB 12 2008 FEB 17 2008 FEB 18 2008
Size of Plant 7.5 7.5
Differential Impact Threshold 0.225 0.225
Line Overload: System Intact 95.0% 100.0% 100.0%
Contingency 95.0% 100.0% 100.0%
Transformer Overload: System Intact 95.0% 100.0% 100.0%
Contingency 95.0% 100.0% 100.0%
Number of Violations Monitored: 10 10 10
Output File: kc0-sp16-line kg-sp16-line kcl-sp16-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY	SWITCH	
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	FROM	TO	CKT
34016	EMERY	5 161	34912 EMERYST118.0	300	105.2	315.58	105.2	315.58	105.2	315.58	SYSTEM INTACT		
					105.2	315.74	105.2	315.74	105.2	315.74	34020 HAZL S 5 161 34135 DUNDEE 5 161 1		
					105.3	315.76	105.3	315.76	105.3	315.76	34075 ELDORA 7 115 34527 IAFINDT7 115 1		
34019	HAZLTON5	161 34440	HAZLTNN869.0	30	106.4	31.92	106.4	31.92	106.4	31.92	SYSTEM INTACT		
					108.2	32.45	108.2	32.45	108.2	32.45	34018 HAZLTON3 345 60102 ADAMS 3 345 1		
					108.4	32.53	108.4	32.53	108.5	32.54	34018 HAZLTON3 345 60102 ADAMS 3 345 1	SW815	
					113.7	34.1	113.7	34.1	113.7	34.1	34019 HAZLTON5 161 61930 WINDSOR5 161 1		
					180.6	54.19	180.6	54.19	180.6	54.19	34020 HAZL S 5 161 34439 HAZLTNS869.0 1		
					108.4	32.51	108.4	32.51	108.4	32.51	34021 LANSINGW 161 34022 LANSING5 161 1		
					108.4	32.51	108.4	32.51	108.4	32.51	34029 SALEM 3 345 34036 ROCK CK3 345 1		
					108.4	32.51	108.4	32.51	108.4	32.51	34030 SALEM N5 161 34508 JULIAN 5 161 1	SW763	
					108.9	32.67	108.9	32.67	108.9	32.67	34135 DUNDEE 5 161 34138 DUNDEE 869.0 1		
					117.8	35.34	117.8	35.34	117.8	35.34	34432 WINDSOR869.0 61930 WINDSOR5 161 1		
					109.2	32.75	109.2	32.75	109.2	32.75	60202 COON CK3 345 63030 DICKNSN3 345 1	SW880	
34020	HAZL S 5 161	34135 DUNDEE 5 161 1		167	51.3	85.74					SYSTEM INTACT		
					98.6	164.64					34030 SALEM N5 161 34508 JULIAN 5 161 1	SW763	
34020	HAZL S 5 161	34439 HAZLTNS869.0	1	30	91.8	27.53	91.8	27.53	91.8	27.53	SYSTEM INTACT		
					96.5	28.95					34019 HAZLTON5 161 34020 HAZL S 5 161 1		
					173.4	52.01	173.4	52.01	173.4	52.01	34019 HAZLTON5 161 34440 HAZLTNN869.0 1		
					98	29.41					34019 HAZLTON5 161 61930 WINDSOR5 161 1		
					101.6	30.48	101.6	30.48	101.6	30.48	34432 WINDSOR869.0 61930 WINDSOR5 161 1		
34027	CNTRGRV5	161 34508	JULIAN 5 161 1	326	56.7	184.75					SYSTEM INTACT		
					97.6	318.05					34031 SO.GVW.5 161 34034 SALEM S5 161 1		
34028	LORE 5 161	34908 KERPER 5 161 1		200	42.2	84.35	42.2	84.34	42.2	84.35	SYSTEM INTACT		
					101	202.06	101	202.05	101	202.07	34027 CNTRGRV5 161 34508 JULIAN 5 161 1		
					102.7	205.36	102.7	205.36	102.7	205.37	34030 SALEM N5 161 34508 JULIAN 5 161 1		
34029	SALEM 3 345	34030 SALEM N5 161 1		336	112	376.37	112	376.37	112	376.38	SYSTEM INTACT		
					119.7	402.06	119.7	402.05	119.7	402.07	34018 HAZLTON3 345 34093 ARNOLD 3 345 1		
					118.5	398.21	118.5	398.2	118.5	398.21	34020 HAZL S 5 161 34135 DUNDEE 5 161 1		
					118.4	397.85	118.4	397.85	118.4	397.86	34034 SALEM S5 161 34126 MQOKETA5 161 1		
					123.6	415.45	123.6	415.44	123.6	415.46	34035 ROCKCKW5 161 34037 ROCK CK5 161 1	SW769	
					124	416.79	124	416.79	124	416.8	34036 ROCK CK3 345 34037 ROCK CK5 161 1		
					123.9	416.29	123.9	416.28	123.9	416.3	34038 BVR CH 5 161 34044 ALBANY 5 161 1	SW789	
					123.8	415.86	123.8	415.85	123.8	415.87	34043 SAVANNA5 161 34046 YORK 5 161 1		
					125.4	421.25	125.4	421.25	125.4	421.27	34044 ALBANY 5 161 34046 YORK 5 161 1		
					119.9	402.88	119.9	402.87	119.9	402.89	34122 E CALMS5 161 34126 MQOKETA5 161 1		
					125.5	421.59	125.5	421.58	125.5	421.6	60202 COON CK3 345 63030 DICKNSN3 345 1	SW880	
34030	SALEM N5 161	34508 JULIAN 5 161 1		300	63.3	190.05	63.3	190.05	63.4	190.06	SYSTEM INTACT		
					97	290.95					34030 SALEM N5 161 34034 SALEM S5 161 1		
					101.9	305.81	101.9	305.8	101.9	305.82	34031 SO.GVW.5 161 34032 8TH ST.5 161 1		
					107.8	323.44	107.8	323.43	107.8	323.45	34031 SO.GVW.5 161 34034 SALEM S5 161 1		

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH	
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	MVA	FROM	TO	CKT	
34031	SO.GVW.5 161	34032	8TH ST.5 161	304	55.7	169.46	55.7	169.46			55.7	169.46			SYSTEM INTACT
					99.6	302.88									34027 CNTRGRV5 161 34508 JULIAN 5 161 1
					100.9	306.75	100.9	306.74			100.9	306.76			34030 SALEM N5 161 34508 JULIAN 5 161 1
34031	SO.GVW.5 161	34034	SALEM S5 161	306	63.6	194.66	63.6	194.66			63.6	194.67			SYSTEM INTACT
					101.6	311.03	101.6	311.03			101.6	311.04			34026 ASBURY 5 161 34027 CNTRGRV5 161 1
					100.9	308.9	100.9	308.89			101	308.91			34026 ASBURY 5 161 34028 LORE 5 161 1
					107.3	328.3	107.3	328.3			107.3	328.31			34027 CNTRGRV5 161 34508 JULIAN 5 161 1
					108.6	332.18	108.6	332.17			108.6	332.18			34030 SALEM N5 161 34508 JULIAN 5 161 1
34032	8TH ST.5 161	34908	KERPER 5 161	200	48.2	96.42	48.2	96.42			48.2	96.43			SYSTEM INTACT
					99.8	199.56									34026 ASBURY 5 161 34027 CNTRGRV5 161 1
					95.5	191.03					107.3	214.68			34026 ASBURY 5 161 34028 LORE 5 161 1
					107.3	214.67	107.3	214.67			107.3	214.68			34027 CNTRGRV5 161 34508 JULIAN 5 161 1
					109	218.04	109	218.03			109	218.05			34030 SALEM N5 161 34508 JULIAN 5 161 1
34038	BVR CH 5 161	34041	BEVCHN2869.0 1	74.7	65.7	49.06	65.7	49.06			65.7	49.06			SYSTEM INTACT
					106.1	79.23	106.1	79.23			106.1	79.23			34040 BEVCHN1869.0 34042 BVR CH65 161 1
34038	BVR CH 5 161	34041	BEVCHN2869.0 2	74.7	65.6	49.01	65.6	49.01			65.6	49.01			SYSTEM INTACT
					109.8	81.99	109.8	81.99			109.8	81.99			34040 BEVCHN1869.0 34042 BVR CH65 161 1
34039	BVRCH52G20.0	34042	BVR CH65 161	252	93.3	235.22									SYSTEM INTACT
					95.1	239.59									34029 SALEM 3 345 34030 SALEM N5 161 1
					95.2	239.81									34029 SALEM 3 345 34036 ROCK CK3 345 1
					96.4	242.91									34035 ROCKCKW5 161 34037 ROCK CK5 161 1
					98.1	247.26									34036 ROCK CK3 345 34037 ROCK CK5 161 1
34040	BEVCHN1869.0	34042	BVR CH65 161	150	62.1	93.16	62.1	93.16			62.1	93.16			SYSTEM INTACT
					109.1	163.61	109.1	163.61			109.1	163.61			34038 BVR CH 5 161 34042 BVR CH65 161 1
34043	SAVANNA5 161	34046	YORK 5 161	167	67	111.93	67	111.93			67	111.94			SYSTEM INTACT
					102.6	171.35	102.6	171.35			102.6	171.36			34029 SALEM 3 345 34030 SALEM N5 161 1
					102.6	171.33	102.6	171.33			102.6	171.34			34029 SALEM 3 345 34036 ROCK CK3 345 1
					117.1	195.52	117.1	195.51			117.1	195.52			34030 SALEM N5 161 34508 JULIAN 5 161 1
34043	SAVANNA5 161	34346	SAVNA S934.5 1	22.4	70	15.67	70	15.67			70	15.67			SYSTEM INTACT
					147.1	32.95	147.1	32.95			147.1	32.95			34043 SAVANNA5 161 34347 SAVNA N934.5 1
34043	SAVANNA5 161	34347	SAVNA N934.5 1	22.4	70	15.67	70	15.67			70	15.67			SYSTEM INTACT
					148.3	33.23	148.3	33.23			148.3	33.23			34038 BVR CH 5 161 34044 ALBANY 5 161 1
					147.1	32.95	147.1	32.95			147.1	32.95			34043 SAVANNA5 161 34346 SAVNA S934.5 1
34044	ALBANY 5 161	34046	YORK 5 161	200	61.3	122.63	61.3	122.62			61.3	122.63			SYSTEM INTACT
					104.2	208.31	104.2	208.31			104.2	208.32			34030 SALEM N5 161 34508 JULIAN 5 161 1
34061	BNE JCT5 161	34076	BNE JCT7 115	45	48.8	21.94									SYSTEM INTACT
					97.9	44.06									34061 BNE JCT5 161 34076 BNE JCT7 115 2
34066	M-TOWN 7 115	34159	M-TOWN 934.5 1	93	61.1	56.82	61.1	56.82			61.1	56.82			SYSTEM INTACT
					121.8	113.28	121.8	113.28			121.8	113.28			34066 M-TOWN 7 115 34159 M-TOWN 934.5 2
34066	M-TOWN 7 115	34159	M-TOWN 934.5 2	93	60.7	56.48	60.7	56.48			60.7	56.48			SYSTEM INTACT
					121.8	113.27	121.8	113.27			121.8	113.28			34066 M-TOWN 7 115 34159 M-TOWN 934.5 1
34083	BL.PLN.7 115	34095	STON PT7 115	77	26.5	20.39									SYSTEM INTACT
					96.9	74.62									34051 TOLEDO 7 115 34066 M-TOWN 7 115 1
34092	PR CRK1G34.5	34099	PRAR CK7 115	93	58.7	54.64	58.7	54.64			58.7	54.64			SYSTEM INTACT
					122.7	114.12	122.7	114.12			122.7	114.12			34092 PR CRK1G34.5 34099 PRAR CK7 115 2
34092	PR CRK1G34.5	34099	PRAR CK7 115	93	60.7	56.47	60.7	56.47			60.7	56.47			SYSTEM INTACT
					122.5	113.88	122.5	113.88			122.5	113.88			34092 PR CRK1G34.5 34099 PRAR CK7 115 1
34119	DUNDEE 934.5	34133	DUNDEE 7 115	12.5	74.1	9.26	74.1	9.26			74.1	9.26			SYSTEM INTACT
					150.7	18.84	150.7	18.84			150.7	18.84			34119 DUNDEE 934.5 34133 DUNDEE 7 115 2
34119	DUNDEE 934.5	34133	DUNDEE 7 115	12.5	73.3	9.16	73.3	9.16			73.3	9.16			SYSTEM INTACT

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY	SWITCH
				MVA	%	MVA	%	MVA	MVA	%	MVA	MVA	FROM TO CKT	
					150.8	18.85	150.8	18.85		150.8	18.85		34119 DUNDEE 934.5 34133 DUNDEE 7 115 1	
34122 E CALMS5 161	34126 MQOKETA5 161 1	176	49.3	86.71	49.3	86.71	49.3	86.71		49.3	86.72		SYSTEM INTACT	
			100.7	177.17	100.7	177.16	100.7	177.16		100.7	177.18		34029 SALEM 3 345 34030 SALEM N5 161 1	
			100.7	177.15	100.6	177.14	100.6	177.14		100.7	177.16		34029 SALEM 3 345 34036 ROCK CK3 345 1	
34133 DUNDEE 7 115	34135 DUNDEE 5 161 1	56	53.2	29.81									SYSTEM INTACT	
			99.3	55.62									34103 MARION 7 115 34170 SWAMPFX7 115 1	
34163 BOONE 934.5	34550 BOONE W7 115 2	47	57.1	26.84	57.1	26.84	57.1	26.84		57.1	26.84		SYSTEM INTACT	
			115.2	54.13	115.2	54.13	115.2	54.13		115.2	54.13		34059 BOONE E7 115 34163 BOONE 934.5 1	
34182 WAPELLO5 161	34206 WAPELLO869.0 1	131	62.4	81.75	62.4	81.75	62.4	81.75		62.4	81.75		SYSTEM INTACT	
			111.7	146.31	111.7	146.32	111.7	146.32		111.7	146.31		34182 WAPELLO5 161 34206 WAPELLO869.0 2	
34182 WAPELLO5 161	34206 WAPELLO869.0 2	131	62.4	81.75	62.4	81.75	62.4	81.75		62.4	81.75		SYSTEM INTACT	
			111.7	146.31	111.7	146.32	111.7	146.32		111.7	146.31		34182 WAPELLO5 161 34206 WAPELLO869.0 1	
34528 IAFINDP7 115	34532 IAFINDP869.0 1	31.2	87.8	27.43	87.8	27.43	87.8	27.43		87.8	27.43		SYSTEM INTACT	
			104	32.49	104	32.49	104	32.49		104	32.49		34075 ELDORA 7 115 34527 IAFINDT7 115 1	
			101.2	31.63	101.2	31.63	101.2	31.63		101.2	31.63		34527 IAFINDT7 115 34528 IAFINDP7 115 1	
60105 PR ISLD3 345	60106 PR ISLD5 161 10	224	65	145.7	65	145.7	65	145.7		65	145.7		SYSTEM INTACT	
			102.4	229.44	102.4	229.44	102.4	229.44		102.4	229.44		60105 PR ISLD3 345 60236 REDROCK3 345 1	SW800
60107 W FARIB7 115	60792 WFARBLT869.0 1	70	108.1	75.68	108.1	75.68	108.1	75.68		108.1	75.68		SYSTEM INTACT	
			121.2	84.82	121.2	84.82	121.2	84.82		121.2	84.82		60105 PR ISLD3 345 60106 PR ISLD5 161 10	
			121.2	84.82	121.2	84.82	121.2	84.82		121.2	84.82		60106 PR ISLD5 161 62224 RAVENNA5 161 1	
			124.9	87.45	124.9	87.44	124.9	87.45		124.9	87.45		60107 W FARIB7 115 60792 WFARBLT869.0 2	
			125.1	87.58	125.1	87.58	125.1	87.58		125.1	87.58		60107 W FARIB7 115 60792 WFARBLT869.0 3	
			123.8	86.65	123.8	86.65	123.8	86.65		123.8	86.66		60108 WILMART3 345 60192 BLUE LK3 345 1	
			124.2	86.95	124.2	86.94	124.2	86.95		124.2	86.95		60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
			123.8	86.64	123.8	86.63	123.8	86.64		123.8	86.64		60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
			118.3	82.83	118.3	82.83	118.3	82.83		118.3	82.83		60331 KFLDXL3 345 60364 FIELD_N3 345 1	
			143	100.08	143	100.08	143	100.08		143	100.08		60369 FEPTP 7 115 62234 LKMARN 7 115 1	
			121.2	84.82	121.2	84.82	121.2	84.82		121.2	84.83		62224 RAVENNA5 161 63071 SPRNGCK5 161 1	
60107 W FARIB7 115	60792 WFARBLT869.0 2	25	87.3	21.84	87.3	21.84	87.3	21.84		87.3	21.84		SYSTEM INTACT	
			98.4	24.6									60105 PR ISLD3 345 60106 PR ISLD5 161 10	
			98.4	24.6									60106 PR ISLD5 161 62224 RAVENNA5 161 1	
			165.4	41.34	165.4	41.34	165.4	41.34		165.4	41.34		60107 W FARIB7 115 60792 WFARBLT869.0 1	
			190.8	47.7	190.8	47.69	190.8	47.7		190.8	47.7		60107 W FARIB7 115 60792 WFARBLT869.0 1	SW822
			101.4	25.36	101.4	25.36	101.4	25.36		101.4	25.36		60107 W FARIB7 115 60792 WFARBLT869.0 3	
			101.1	25.28	101.1	25.27	101.1	25.28		101.1	25.28		60108 WILMART3 345 60192 BLUE LK3 345 1	
			101.5	25.37	101.5	25.37	101.5	25.37		101.5	25.37		60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
			101.1	25.28	101.1	25.28	101.1	25.28		101.1	25.28		60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
			116.1	29.02	116.1	29.02	116.1	29.02		116.1	29.02		60369 FEPTP 7 115 62234 LKMARN 7 115 1	
			98.4	24.6									62224 RAVENNA5 161 63071 SPRNGCK5 161 1	
60107 W FARIB7 115	60792 WFARBLT869.0 3	25	88.2	22.05	88.2	22.05	88.2	22.05		88.2	22.05		SYSTEM INTACT	
			99.3	24.84									60105 PR ISLD3 345 60106 PR ISLD5 161 10	
			99.3	24.84									60106 PR ISLD5 161 62224 RAVENNA5 161 1	
			167	41.74	167	41.74	167	41.74		167	41.74		60107 W FARIB7 115 60792 WFARBLT869.0 1	
			192.6	48.16	192.6	48.16	192.6	48.16		192.6	48.16		60107 W FARIB7 115 60792 WFARBLT869.0 1	SW822
			102.3	25.57	102.3	25.57	102.3	25.57		102.3	25.57		60107 W FARIB7 115 60792 WFARBLT869.0 2	
			102.1	25.52	102.1	25.52	102.1	25.52		102.1	25.52		60108 WILMART3 345 60192 BLUE LK3 345 1	
			102.5	25.62	102.5	25.62	102.5	25.62		102.5	25.62		60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
			102.1	25.52	102.1	25.52	102.1	25.52		102.1	25.52		60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
			117.2	29.3	117.2	29.3	117.2	29.3		117.2	29.3		60369 FEPTP 7 115 62234 LKMARN 7 115 1	
			99.3	24.84									62224 RAVENNA5 161 63071 SPRNGCK5 161 1	

CIRCUIT FROM: # NAME	CIRCUIT TO: CKT # NAME	RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
60107 W FARIB7 115 62865 AIRTECH7 115 1		310	64.8	201.02							SYSTEM INTACT 60369 FEPTP 7 115 62234 LKMARN 7 115 1	
60114 ELM CRK3 345 60115 ELMCRK 7 115 9		448	71.6	320.67	71.6	320.67		71.6	320.67		SYSTEM INTACT 60114 ELM CRK3 345 60233 PARKERS3 345 1	SW830
60119 LKYNKTN7 115 60279 BUFFRID7 115 1		292	60.3	175.99	60.3	175.99		60.3	176		SYSTEM INTACT 60381 YANKEE 7 115 60382 BRKNGCO7 115 1	
			123.9	361.66	123.9	361.66		123.9	361.67		60382 BRKNGCO7 115 60383 BRKNGCO3 345 1	
			123.2	359.85	123.2	359.85		123.2	359.86			
60120 BLUEETA5 161 61085 BLUEE 869.0 1		18	94	16.93							SYSTEM INTACT 34008 FOX LK 5 161 61932 RUTLAND5 161 1	SW889
			96.5	17.37							34008 FOX LK 5 161 61932 RUTLAND5 161 1	
			96.2	17.32							34009 WINBAGO5 161 34257 WBGOJ N869.0 1	
			95.1	17.11							34009 WINBAGO5 161 61932 RUTLAND5 161 1	
			96.2	17.32								
60122 LAWRENC7 115 60834 LAWRENC869.0 1		112	83.4	93.36	83.4	93.36		83.4	93.36		SYSTEM INTACT 60117 CHERRYC7 115 60129 SPLT RK7 115 1	SW756
			130.7	146.41	130.7	146.41		130.7	146.41		60121 MINEHAH7 115 60122 LAWRENC7 115 1	
			110.9	124.17	110.9	124.17		110.9	124.17		60121 MINEHAH7 115 60124 LINCNC07 115 1	
			103.4	115.83	103.4	115.83		103.4	115.83		60124 LINCNC07 115 60836 LINCLNC869.0 1	
			96.3	107.87							60129 SPLT RK7 115 60132 WSX FLS7 115 1	
			98	109.8								
60124 LINCNC07 115 60836 LINCLNC869.0 1		70	55.1	38.58	55.1	38.58		55.1	38.59		SYSTEM INTACT 60122 LAWRENC7 115 60834 LAWRENC869.0 1	
			109.7	76.79	109.7	76.79		109.7	76.79			
60132 WSX FLS7 115 60850 WSX FLS869.0 1		70	33.6	23.51	33.6	23.51		33.6	23.51		SYSTEM INTACT 60122 LAWRENC7 115 60834 LAWRENC869.0 1	
			106.4	74.49	106.4	74.49		106.4	74.49			
60138 SOURIS 7 115 60139 MALLARD7 115 1		112	76.4	85.59	76.4	85.59		76.5	85.7		SYSTEM INTACT 60140 MCHENRY7 115 63082 MCHENRY1.00 1	SW805
			96.6	108.23							63041 COAL CR4 230 63042 COAL TP4 230 1	
			118.1	132.25	118.1	132.25		118.3	132.44		63044 MCHENRY4 230 63082 MCHENRY1.00 1	
			98.1	109.9							66442 GARRISN7 115 67113 VOLTAIR7 115 1	
			96.1	107.61								
60140 MCHENRY7 115 63082 MCHENRY1.00 1		84	78	65.49	77.9	65.46		78.3	65.76		SYSTEM INTACT 60138 SOURIS 7 115 60139 MALLARD7 115 1	SW805
			135.8	114.05	135.7	114.02		136.2	114.42	0.37	60139 MALLARD7 115 67155 LOGAN 7 115 1	
			101.1	84.93	101.1	84.89		101.5	85.22	0.29	63041 COAL CR4 230 63042 COAL TP4 230 1	
			99.8	83.81							63044 MCHENRY4 230 63056 BALTA 4 230 1	
			100.1	84.09	100	84.04		100.5	84.38	0.29	66442 GARRISN7 115 67113 VOLTAIR7 115 1	
			104.2	87.56	104.2	87.53		104.7	87.96	0.4	67106 LELANDO4 230 67108 LOGAN 4 230 1	
			96.3	80.88							67108 LOGAN 4 230 67208 LOGAN TY 230 1	
			100.1	84.06	100	84		100.2	84.16		67155 LOGAN 7 115 67208 LOGAN TY 230 1	
			100.1	84.06	100	84		100.2	84.16			
60142 BENTON 3 345 63045 BENTON 4 230 1		336	75.3	253.06	75.3	253.06		75.3	253.07		SYSTEM INTACT 60142 BENTON 3 345 63045 BENTON 4 230 2	SW834
			117.1	393.6	117.1	393.59		117.1	393.61		60151 MNTCELO3 345 60160 SHERCO 3 345 1	SW878
			108	362.95	108	362.94		108	362.96			
			106.8	358.8	106.8	358.8		106.8	358.81			
60142 BENTON 3 345 63045 BENTON 4 230 2		336	72.8	244.46	72.8	244.46		72.8	244.47		SYSTEM INTACT 60142 BENTON 3 345 63045 BENTON 4 230 1	SW834
			115.4	387.82	115.4	387.8		115.4	387.83		60151 MNTCELO3 345 60160 SHERCO 3 345 1	SW878
			104.3	350.62	104.3	350.61		104.4	350.62			
			103.2	346.61	103.2	346.6		103.2	346.62			
60145 FRANKLN7 115 60728 FRANKLN869.0 1		47	65.1	30.61	65.1	30.61		65.1	30.61		SYSTEM INTACT 60145 FRANKLN7 115 60728 FRANKLN869.0 2	
			104.8	49.25	104.8	49.25		104.8	49.25			
60145 FRANKLN7 115 60728 FRANKLN869.0 2		47	65.1	30.61	65.1	30.61		65.1	30.61		SYSTEM INTACT 60145 FRANKLN7 115 60728 FRANKLN869.0 1	
			104.8	49.25	104.8	49.25		104.8	49.25			
60146 GRANCTY7 115 60164 XRDS 7 115 1		191	79.5	151.85	79.5	151.85		79.5	151.86		SYSTEM INTACT 60154 SAUK RV7 115 60157 STCLOUD7 115 1	
			105.7	201.87	105.7	201.87		105.7	201.88			

CIRCUIT FROM:		CIRCUIT TO:		CKT	RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH	
#	NAME	#	NAME		MVA	%	MVA	%	MVA	MVA	%	MVA	MVA	FROM	TO	CKT		
						98.5	188.23											60157 STCLOUD7 115 60348 BENCTP7 115 1
60148	MINVALY7 115 60357	MAYNARD7 115 1			78	56.7	44.22	56.7	44.22		56.7	44.22						SYSTEM INTACT
						95.7	74.64							62427 WILLMAR869.0 63050 WILLMAR4 230 1				SW928
						107.5	83.82	107.5	83.81		107.5	83.82		62427 WILLMAR869.0 63050 WILLMAR4 230 1				
						122.7	95.68	122.7	95.68		122.7	95.68		63050 WILLMAR4 230 66550 GRANITF4 230 1				
60151	MNTCELO3 345 60152	MNTCELO4 230 6			336	78.4	263.33	78.4	263.33		78.4	263.34						SYSTEM INTACT
						105.6	354.75	105.6	354.75		105.6	354.76		60114 ELM CRK3 345 60151 MNTCELO3 345 1				SW833
						137.4	461.82	137.4	461.81		137.5	461.83		60142 BENTON 3 345 60160 SHERCO 3 345 1				
						137.4	461.82	137.4	461.81		137.5	461.83		60142 BENTON 3 345 60160 SHERCO 3 345 1				SW979
						106	356.19	106	356.18		106	356.19		60160 SHERCO 3 345 63031 BUNKER 3 345 1				SW976
						98.5	331.01							60160 SHERCO 3 345 63031 BUNKER 3 345 1				SW977
						95.3	320.37							63031 BUNKER 3 345 63046 BUNKER 4 230 1				
60151	MNTCELO3 345 60153	MNTCELO7 115 10			336	87.6	294.46	87.6	294.46		87.6	294.47						SYSTEM INTACT
						119.9	403.01	119.9	403.01		119.9	403.01		60114 ELM CRK3 345 60151 MNTCELO3 345 1				SW833
						106.7	358.45	106.7	358.44		106.7	358.45		60142 BENTON 3 345 60160 SHERCO 3 345 1				
						106.7	358.45	106.7	358.44		106.7	358.45		60142 BENTON 3 345 60160 SHERCO 3 345 1				SW979
						110.9	372.77	110.9	372.77		110.9	372.77		60143 BENTON 7 115 60146 GRANCTY7 115 1				SW757
						110.1	369.93	110.1	369.93		110.1	369.93		60155 PULASKI7 115 62926 DCKSNSS7 115 1				
						110.1	369.93	110.1	369.92		110.1	369.93		60155 PULASKI7 115 62926 DCKSNSS7 115 1				SW982
						106	356.27	106	356.27		106	356.27		60202 COON CK3 345 63030 DICKNSN3 345 1				SW880
						110.3	370.47	110.3	370.47		110.3	370.47		62925 DICKNSN7 115 62926 DCKSNSS7 115 1				
						112.5	377.86	112.5	377.86		112.5	377.87		62925 DICKNSN7 115 63085 DICKSNSY1.00 1				
						112.5	377.86	112.5	377.86		112.5	377.87		63030 DICKNSN3 345 63085 DICKSNSY1.00 1				
60152	MNTCELO4 230 63045	BENTON 4 230 1			383.2	29.8	114.2	29.8	114.19		29.8	114.21						SYSTEM INTACT
						100.4	384.58	100.4	384.57		100.4	384.6		60142 BENTON 3 345 60160 SHERCO 3 345 1				
						100.4	384.58	100.4	384.57		100.4	384.6		60142 BENTON 3 345 60160 SHERCO 3 345 1				SW979
60153	MNTCELO7 115 62927	LKCONST7 115 1			191	36.5	69.62											SYSTEM INTACT
						97.5	186.24							60202 COON CK3 345 63030 DICKNSN3 345 1				SW880
						96.1	183.62							62925 DICKNSN7 115 63085 DICKSNSY1.00 1				
						96.1	183.62							63030 DICKNSN3 345 63085 DICKSNSY1.00 1				
60154	SAUK RV7 115 60157	STCLOUD7 115 1			139	44.8	62.31	44.8	62.3		44.8	62.31						SYSTEM INTACT
						129.1	179.46	129.1	179.45		129.1	179.46		60143 BENTON 7 115 60146 GRANCTY7 115 1				SW757
						131.7	183.08	131.7	183.07		131.7	183.08		60146 GRANCTY7 115 60164 XRDS 7 115 1				
						103.2	143.43	103.2	143.43		103.2	143.44		60164 XRDS 7 115 60165 MEI INT7 115 1				
60154	SAUK RV7 115 60163	WST CLD7 115 1			139	22.3	30.96	22.3	30.95		22.3	30.96						SYSTEM INTACT
						108.1	150.28	108.1	150.27		108.1	150.28		60143 BENTON 7 115 60146 GRANCTY7 115 1				SW757
						104.9	145.84	104.9	145.83		104.9	145.85		60146 GRANCTY7 115 60164 XRDS 7 115 1				
60155	PULASKI7 115 62926	DCKSNSS7 115 1			194	54	104.82	54	104.82		54	104.83						SYSTEM INTACT
						105.3	204.22	105.3	204.22		105.3	204.22		60151 MNTCELO3 345 60153 MNTCELO7 115 10				
60156	PYNSVIL7 115 60702	PAYNES1934.5 1			17.9	264.2	47.28	264.2	47.28		264.2	47.28						SYSTEM INTACT
						271.2	48.54	271.2	48.54		271.2	48.54		60143 BENTON 7 115 60146 GRANCTY7 115 1				SW757
						270.9	48.49	270.9	48.49		270.9	48.49		60144 DGLASCO7 115 60749 DGLAS C869.0 1				
						270.9	48.49	270.9	48.49		270.9	48.49		60144 DGLASCO7 115 60749 DGLAS C869.0 1				SW997
						273.1	48.89	273.1	48.89		273.1	48.89		60146 GRANCTY7 115 60164 XRDS 7 115 1				SW803
						275.9	49.39	275.9	49.39		275.9	49.39		60156 PYNSVIL7 115 60356 PAYNES 4 230 6				
						267.6	47.9	267.6	47.9		267.6	47.9		60159 STCTPW 7 115 60162 WAKEFLD7 115 1				
						272.1	48.7	272.1	48.7		272.1	48.7		60163 WST CLD7 115 60732 WST CLD869.0 1				
						275.9	49.39	275.9	49.39		275.9	49.39		60356 PAYNES 4 230 63050 WILLMAR4 230 1				
						269	48.14	269	48.14		269	48.14		62427 WILLMAR869.0 63050 WILLMAR4 230 1				SW928
						283.1	50.67	283.1	50.67		283.1	50.67		63050 WILLMAR4 230 66550 GRANITF4 230 1				

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH							
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	MVA	FROM	TO	CKT							
60156	PYNSVIL7	115	60760	PAYNES	869.0	1						SYSTEM INTACT									
		47			80.3	37.75	80.3	37.75				60146	GRANCTY7	115	60164	XRDS	7	115	1	SW803	
					98.1	46.12						60156	PYNSVIL7	115	60760	PAYNES	869.0	2			SW999
					133.5	62.72	133.4	62.72			133.5	62.73									
					99.5	46.76															
					101.6	47.77	101.6	47.77			101.6	47.77									
					95.8	45.04															
					99.2	46.62															
60156	PYNSVIL7	115	60760	PAYNES	869.0	2						SYSTEM INTACT									
		47			79.5	37.35	79.5	37.35				60146	GRANCTY7	115	60164	XRDS	7	115	1	SW803	
					97.1	45.63						60156	PYNSVIL7	115	60760	PAYNES	869.0	1			SW999
					133	62.5	133	62.5			133	62.5									
					98.4	46.27															
					100.6	47.26	100.6	47.26			100.6	47.27									
					98.1	46.13															
60158	STCLTP	7	115	60166	SALIDA	7	115	1				SYSTEM INTACT									
		139			68	94.57	68	94.57				60142	BENTON	3	345	60160	SHERCO	3	345	1	SW979
					112.6	156.58	112.6	156.58			112.7	156.59									
					112.6	156.58	112.6	156.58			112.7	156.59									
					153	212.7	153	212.7			153	212.71									
60162	WAKEFLD7	115	60717	WAKEFLD869.0	1							SYSTEM INTACT									
		70			77.2	54.01	77.2	54.01				60146	GRANCTY7	115	60164	XRDS	7	115	1	SW803	
					117.5	82.28	117.5	82.28			117.5	82.28									
					111.4	77.96	111.4	77.96			111.4	77.96									
60163	WST CLD7	115	60732	WST CLD869.0	1							SYSTEM INTACT									
		46.7			97.2	45.4	97.2	45.4				60144	DGLASCO7	115	60749	DGLAS	C869.0	1			SW997
					109.8	51.28	109.8	51.28			109.8	51.28									
					109.6	51.18	109.6	51.18			109.6	51.18									
					121.3	56.64	121.3	56.64			121.3	56.64									
					111.6	52.1	111.6	52.1			111.6	52.1									
					117.3	54.79	117.3	54.79			117.3	54.79									
					106.1	49.55	106.1	49.55			106.1	49.55									
					121.3	56.65	121.3	56.65			121.3	56.65									
					105.3	49.18	105.3	49.18			105.3	49.18									
					122.6	57.27	122.6	57.27			122.6	57.27									
					118.1	55.17	118.1	55.17			118.1	55.17									
60166	SALIDA	7	115	62137	BCKRNSP869.0	1						SYSTEM INTACT									
		112			65.9	73.83	65.9	73.83				60155	PULASKI7	115	60763	PULASKI869.0	1				SW68
					119.3	133.61	119.3	133.61			119.3	133.61									
60170	MARSHAL7	115	60171	LYON CO7	115	1						SYSTEM INTACT									
		127			108	137.12	108	137.12				60108	WILMART3	345	60365	FIELD_S3	345	1			SW812
					114.7	145.72	114.7	145.71			114.7	145.72									
					131.9	167.45	131.8	167.45			131.9	167.46									
					116.4	147.83	116.4	147.83			116.4	147.84									
					136.4	173.17	136.4	173.17			136.4	173.17									
					114.8	145.74	114.8	145.74			114.8	145.74									
					115.9	147.16	115.9	147.16			115.9	147.16									
					141.3	179.42	141.3	179.42			141.3	179.42									
					141.1	179.19	141.1	179.19			141.1	179.19									
					121.2	153.94	121.2	153.94			121.2	153.95									
					117.5	149.2	117.5	149.19			117.5	149.2									
60170	MARSHAL7	115	60375	MMU_N7ST	115	1						SYSTEM INTACT									
		127.9			80.8	103.39	80.8	103.39				60148	MINVALY7	115	60171	LYON CO7	115	1			SW896
					100.6	128.68	100.6	128.67			100.6	128.68									
					100.7	128.8	100.7	128.8			100.7	128.81									
					101	129.19	101	129.18			101	129.19									
					97.5	124.71															
					104.7	133.88	104.7	133.87			104.7	133.88									
												60372	SARATOG7	115	67473	MMU SW	7	115	1		SW897
												60381	YANKEE	7	115	60382	BRKNGCO7	115	1		

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
					104.7	133.87	104.7	133.87		104.7	133.88		60382 BRKNGCO7 115 60383 BRKNGCO3 345 1	
60171 LYON CO7 115 60903 LYON CO869.0 1		70	34.5	24.18	105.1	73.57	34.5	24.18		34.5	24.18		SYSTEM INTACT	
							105.1	73.57		105.1	73.57		60119 LKYNKTN7 115 60171 LYON CO7 115 1	SW935
60177 CHAMPLN7 115 60178 CHAMP T7 115 1		140	51	71.38									SYSTEM INTACT	
													60114 ELM CRK3 345 60233 PARKERS3 345 1	SW830
													60203 COON CK7 115 62090 PRKWOOD7 115 1	
60178 CHAMP T7 115 60205 CRKEDLK7 115 1		189	60.6	114.53	153.1	289.42	60.6	114.53		60.6	114.53		SYSTEM INTACT	
							153.1	289.42		153.1	289.42		60203 COON CK7 115 62090 PRKWOOD7 115 1	
							144.4	272.89		144.4	272.89		60203 COON CK7 115 62090 PRKWOOD7 115 1	SW970
60184 APACHET7 115 60185 ARDNHLS7 115 1		229	50.8	116.26	105.3	241.05	50.8	116.26		50.8	116.26		SYSTEM INTACT	
							105.3	241.05		105.3	241.05		60212 GOOSELK7 115 60222 KOLMNLK7 115 1	
							114.4	261.89		114.4	261.89		60212 GOOSELK7 115 60222 KOLMNLK7 115 1	SW919
60190 BLK DOG7 115 60258 WILSON 7 115 3		167	89.6	149.65			89.6	149.65		89.6	149.65		SYSTEM INTACT	
													60180 AIRPRT 7 115 60239 ROGRSLK7 115 1	
													60189 SHAKOPE7 115 62669 EAGLECK7 115 1	
										110.6	184.66		60190 BLK DOG7 115 60242 SAVAGE 7 115 1	
										110.6	184.66		60190 BLK DOG7 115 60242 SAVAGE 7 115 1	SW885
										110.6	184.66		60190 BLK DOG7 115 60258 WILSON 7 115 1	
										153.8	256.8		60192 BLUE LK3 345 60233 PARKERS3 345 1	SW985
										106	177.02		60193 BLUE LK7 115 60215 HYLNDLK7 115 1	
										106	177.02		60193 BLUE LK7 115 60215 HYLNDLK7 115 1	SW905
										101.9	170.18		60208 EDINA 7 115 60263 EDEN PR7 115 1	
										103.9	173.49		60242 SAVAGE 7 115 62669 EAGLECK7 115 1	
60194 CARVRCO7 115 60931 CARVRCO869.0 1		70	60	42.01	113.8	79.67	60	42.01		60	42.01		SYSTEM INTACT	
										113.8	79.67		60194 CARVRCO7 115 60931 CARVRCO869.0 2	
60194 CARVRCO7 115 60931 CARVRCO869.0 2		70	60	42.01	105.8	74.07	60	42.01		60	42.01		SYSTEM INTACT	
										105.8	74.07		60194 CARVRCO7 115 60243 SCOTTAP7 115 1	SW991
										107.6	75.29		60194 CARVRCO7 115 60931 CARVRCO869.0 1	SW76
60200 BLK DG27 115 62666 GLNDALE7 115 1		133	63.4	84.3									SYSTEM INTACT	
													60193 BLUE LK7 115 60215 HYLNDLK7 115 1	
													60256 WSTGATE7 115 60257 BLUFFCK7 115 1	SW900
60203 COON CK7 115 62090 PRKWOOD7 115 1		315.5	72.6	229.2	105.2	331.96	72.6	229.2		72.6	229.2		SYSTEM INTACT	
										105.2	331.96		60115 ELMCRK 7 115 60177 CHAMPLN7 115 1	SW836
										104.9	330.85		60115 ELMCRK 7 115 60177 CHAMPLN7 115 1	SW837
										105	331.16		60178 CHAMP T7 115 60205 CRKEDLK7 115 1	
60212 GOOSELK7 115 62091 VADNSTP7 115 1		189	37.3	70.52									SYSTEM INTACT	
													60184 APACHET7 115 60185 ARDNHLS7 115 1	
60214 HIBRDGE7 115 60228 MERIMPK7 115 1		194	63.2	122.53									SYSTEM INTACT	
													60214 HIBRDGE7 115 60239 ROGRSLK7 115 1	
60214 HIBRDGE7 115 60239 ROGRSLK7 115 1		200	85	169.96			85	169.97		85	169.95		SYSTEM INTACT	
													60114 ELM CRK3 345 60233 PARKERS3 345 1	SW827
													60176 BAYTOWN7 115 60187 AS KING7 115 1	SW810
													60195 CDRVALE7 115 60246 SO TOWN7 115 1	SW908
										112.9	225.89		60207 DYTBNLF7 115 60214 HIBRDGE7 115 1	
										112.4	224.82		60214 HIBRDGE7 115 60228 MERIMPK7 115 1	
										109.3	218.51		60214 HIBRDGE7 115 60245 SHEPARD7 115 1	
										110.2	220.48		60214 HIBRDGE7 115 60245 SHEPARD7 115 1	SW925
										102.7	205.4		60218 INVRHLS7 115 60220 INVRGRV7 115 1	
										110.2	220.48		60236 REDROCK3 345 60238 REDROCK7 115 9	
										101.9	203.86		60245 SHEPARD7 115 60246 SO TOWN7 115 1	
										101.9	203.87			

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
60215	HYLNDLK7 115 60261 DEANLAK7 115 1	194	81.7	158.53	81.7	158.53	81.7	158.53		81.7	158.53		SYSTEM INTACT	
			97.7	189.58									60190 BLK DOG7 115 60193 BLUE LK7 115 1	
			106.5	206.63	106.5	206.62	106.5	206.63		106.5	206.63		60192 BLUE LK3 345 60233 PARKERS3 345 1	SW985
			99	192.08									60256 WSTGATE7 115 60257 BLUFFCK7 115 1	
			106.4	206.46	106.4	206.46	106.4	206.46		106.4	206.46		60256 WSTGATE7 115 60257 BLUFFCK7 115 1	SW900
60218	INVRHLS7 115 60223 KOCHREF7 115 1	371	74.5	276.32									SYSTEM INTACT	
			97.3	360.9									60188 RIVERWD7 115 60200 BLK DG27 115 1	
			95.3	353.4									60218 INVRHLS7 115 60220 INVRGRV7 115 1	
			95.4	353.86									60276 AIRLAKE7 115 62234 LKMARN 7 115 1	SW812
60220	INVRGRV7 115 60914 INVERGR869.0 1	63	58	36.54	58	36.54	58	36.54		58	36.54		SYSTEM INTACT	
			117.4	73.98	117.4	73.98	117.4	73.98		117.4	73.98		60220 INVRGRV7 115 60914 INVERGR869.0 2	
60220	INVRGRV7 115 60914 INVERGR869.0 2	63	58	36.54	58	36.54	58	36.54		58	36.54		SYSTEM INTACT	
			117.4	73.98	117.4	73.98	117.4	73.98		117.4	73.98		60220 INVRGRV7 115 60914 INVERGR869.0 1	
60224	LONG LK7 115 60230 OAKDALE7 115 1	239	51.5	123.01	51.5	123.02	51.5	123.01		51.5	123.01		SYSTEM INTACT	
			119.8	286.22	119.8	286.22	119.8	286.22		119.8	286.22		60179 AFTON 7 115 60238 REDROCK7 115 1	SW921
			119.6	285.77	119.6	285.77	119.6	285.77		119.6	285.77		60238 REDROCK7 115 60344 WOODBUR7 115 1	
60233	PARKERS3 345 61489 PKLMID2Y 110 10	450	64.8	291.41									SYSTEM INTACT	
			95.9	431.6									60233 PARKERS3 345 61490 PKLMID1Y 110 9	
			95.9	431.6									60233 PARKERS3 345 61490 PKLMID1Y 110 9	SW829
			95.9	431.6									60234 PARKERS7 115 61490 PKLMID1Y 110 9	
60233	PARKERS3 345 61490 PKLMID1Y 110 9	450	64.2	288.93									SYSTEM INTACT	
			95.5	429.71									60233 PARKERS3 345 61489 PKLMID2Y 110 10	
			95.5	429.71									60234 PARKERS7 115 61489 PKLMID2Y 110 10	
60234	PARKERS7 115 61489 PKLMID2Y 110 10	450	64.8	291.41									SYSTEM INTACT	
			95.9	431.6									60233 PARKERS3 345 61490 PKLMID1Y 110 9	
			95.9	431.6									60233 PARKERS3 345 61490 PKLMID1Y 110 9	SW829
			95.9	431.6									60234 PARKERS7 115 61490 PKLMID1Y 110 9	
60234	PARKERS7 115 61490 PKLMID1Y 110 9	450	64.2	288.93									SYSTEM INTACT	
			95.5	429.71									60233 PARKERS3 345 61489 PKLMID2Y 110 10	
			95.5	429.71									60234 PARKERS7 115 61489 PKLMID2Y 110 10	
60238	REDROCK7 115 60344 WOODBUR7 115 1	310	49.6	153.88									SYSTEM INTACT	
			99.7	309.19									60176 BAYTOWN7 115 60187 AS KING7 115 1	SW810
60244	SCOTTCO7 115 60890 SCOTTCO869.0 1	70	69.9	48.92	69.9	48.92	69.9	48.92		69.9	48.92		SYSTEM INTACT	
			121.3	84.89	121.3	84.89	121.3	84.89		121.3	84.89		60244 SCOTTCO7 115 60890 SCOTTCO869.0 2	
60244	SCOTTCO7 115 60890 SCOTTCO869.0 2	70	68.2	47.72	68.2	47.72	68.2	47.72		68.2	47.72		SYSTEM INTACT	
			111.1	77.8	111.1	77.8	111.1	77.8		111.1	77.8		60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
			114.7	80.27	114.7	80.27	114.7	80.27		114.7	80.27		60244 SCOTTCO7 115 60261 DEANLAK7 115 1	SW904
			120.5	84.38	120.5	84.38	120.5	84.38		120.5	84.38		60244 SCOTTCO7 115 60890 SCOTTCO869.0 1	
60250	TANRSLK7 115 60344 WOODBUR7 115 1	191	37.3	71.24	37.3	71.23	37.3	71.24		37.3	71.24		SYSTEM INTACT	
			118	225.41	118	225.41	118	225.41		118	225.41		60176 BAYTOWN7 115 60187 AS KING7 115 1	SW810
			105.3	201.08	105.3	201.08	105.3	201.08		105.3	201.08		60224 LONG LK7 115 60230 OAKDALE7 115 1	
60256	WSTGATE7 115 60263 EDEN PR7 115 1	310	50.8	157.39									SYSTEM INTACT	
			97.4	301.96									60256 WSTGATE7 115 60263 EDEN PR7 115 2	
60256	WSTGATE7 115 60263 EDEN PR7 115 2	310	50.8	157.39									SYSTEM INTACT	
			97.4	301.96									60256 WSTGATE7 115 60263 EDEN PR7 115 1	
			96.6	299.43									60256 WSTGATE7 115 60263 EDEN PR7 115 1	SW901
60262	EDEN PR3 345 60263 EDEN PR7 115 10	448	64.1	287.14	64.1	287.14	64.1	287.14		64.1	287.14		SYSTEM INTACT	
			101.9	456.35	101.9	456.35	101.9	456.35		101.9	456.35		60262 EDEN PR3 345 60263 EDEN PR7 115 9	
60262	EDEN PR3 345 60263 EDEN PR7 115 9	448	68.9	308.85	68.9	308.85	68.9	308.85		68.9	308.85		SYSTEM INTACT	
			109.9	492.46	109.9	492.45	109.9	492.47		109.9	492.47		60192 BLUE LK3 345 60233 PARKERS3 345 1	SW986

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
					104.5	468.22	104.5	468.21		104.5	468.22		60233 PARKERS3 345 60262 EDEN PR3 345 1	SW988
					105.2	471.32	105.2	471.32		105.2	471.33		60262 EDEN PR3 345 60263 EDEN PR7 115 10	
60279	BUFFRID7 115 60708	BUFFRIDG34.5 1		120	57.1	68.48	57.1	68.48		57.1	68.48		SYSTEM INTACT	
					115	138.01	115	138.01		115	138.01		60279 BUFFRID7 115 60708 BUFFRIDG34.5 2	
60279	BUFFRID7 115 60708	BUFFRIDG34.5 2		120	57.1	68.48	57.1	68.48		57.1	68.48		SYSTEM INTACT	
					115	138.01	115	138.01		115	138.01		60279 BUFFRID7 115 60708 BUFFRIDG34.5 1	
60288	IRONWD 7 115 60289	HURLEY 7 115 1		60	84.4	50.65	84.4	50.65		84.4	50.65		SYSTEM INTACT	
					106.3	63.77	106.3	63.77		106.3	63.77		60285 EAGLEPT7 115 60321 HYDROLN7 115 1	SW865
					99.6	59.75							60296 SHELDNP7 115 60297 OSPREY 7 115 1	
					102	61.18	102	61.18		102	61.18		60296 SHELDNP7 115 60306 HOLCOMB7 115 1	
					100.8	60.47	100.8	60.47		100.8	60.47		60297 OSPREY 7 115 60298 PARKFLS7 115 1	SW867
					105.8	63.49	105.8	63.49		105.8	63.49		60306 HOLCOMB7 115 60322 CORNELL7 115 1	
					105.9	63.55	105.9	63.55		105.9	63.55		60306 HOLCOMB7 115 60322 CORNELL7 115 1	SW872
					99.2	59.51							60320 HYDROLN5 161 60321 HYDROLN7 115 1	
					106.5	63.87	106.5	63.87		106.4	63.87		60321 HYDROLN7 115 60326 JIMFLS 7 115 1	
					99.6	59.73							60322 CORNELL7 115 69157 ANDERSN7 115 1	
					100.6	60.37	100.6	60.37		100.6	60.37		60326 JIMFLS 7 115 69157 ANDERSN7 115 1	
60290	ST LAKE5 161 60663	STONELK869.0 2		70	66.2	46.33	66.2	46.33		66.2	46.33		SYSTEM INTACT	
					110.8	77.53	110.8	77.53		110.8	77.53		60290 ST LAKE5 161 60293 FRMSINN5 161 1	
					96.8	67.76							60293 FRMSINN5 161 60664 FRMRSIN869.0 1	
60293	FRMSINN5 161 60664	FRMRSIN869.0 1		50	68.6	34.28	68.6	34.28		68.6	34.28		SYSTEM INTACT	
					129.2	64.58	129.2	64.58		129.2	64.58		60290 ST LAKE5 161 60663 STONELK869.0 2	
60298	PARKFLS7 115 61101	PARKFLS934.5 1		28	64	17.91	64	17.91		64	17.91		SYSTEM INTACT	
					130.7	36.59	130.7	36.59		130.7	36.59		60298 PARKFLS7 115 61101 PARKFLS934.5 2	
60298	PARKFLS7 115 61101	PARKFLS934.5 2		28	64	17.91	64	17.91		64	17.91		SYSTEM INTACT	
					130.7	36.59	130.7	36.59		130.7	36.59		60298 PARKFLS7 115 61101 PARKFLS934.5 1	
60302	COULEE 5 161 60967	COULEE 869.0 2		112	51.6	57.8							SYSTEM INTACT	
					97.9	109.68							60302 COULEE 5 161 60308 LACROSS5 161 1	SW874
60305	EAU CLA5 161 61001	EAUCLAI869.0 1		112	92.4	103.5	92.4	103.5		92.4	103.5		SYSTEM INTACT	
					118.4	132.56	118.4	132.56		118.4	132.56		60282 REDCDR 5 161 60319 WHEATTP5 161 1	SW866
					113.3	126.94	113.3	126.94		113.3	126.94		60282 REDCDR 5 161 60319 WHEATTP5 161 1	SW870
					105.6	118.25	105.6	118.25		105.6	118.25		60305 EAU CLA5 161 60323 SEVN ML5 161 1	
					102.5	114.82	102.5	114.82		102.5	114.82		60305 EAU CLA5 161 60368 JEFERSRD5 161 1	
					140.2	157.06	140.2	157.06		140.2	157.06		60305 EAU CLA5 161 61001 EAUCLAI869.0 2	
					108.8	121.9	108.8	121.9		108.8	121.9		60318 WHT 56 5 161 60319 WHEATTP5 161 1	
					105.9	118.56	105.9	118.56		105.9	118.56		60318 WHT 56 5 161 60319 WHEATTP5 161 1	SW871
					110	123.24	110	123.24		110	123.24		60319 WHEATTP5 161 60320 HYDROLN5 161 1	
					110	123.24	110	123.24		110	123.24		60320 HYDROLN5 161 60321 HYDROLN7 115 1	
					124.5	139.43	124.5	139.43		124.5	139.43		60323 SEVN ML5 161 61071 SEVN ML869.0 1	
60305	EAU CLA5 161 61001	EAUCLAI869.0 2		112	101.3	113.41	101.3	113.41		101.3	113.41		SYSTEM INTACT	
					129.7	145.25	129.7	145.25		129.7	145.25		60282 REDCDR 5 161 60319 WHEATTP5 161 1	SW866
					124.2	139.1	124.2	139.1		124.2	139.1		60282 REDCDR 5 161 60319 WHEATTP5 161 1	SW870
					115.7	129.57	115.7	129.57		115.7	129.57		60305 EAU CLA5 161 60323 SEVN ML5 161 1	
					112.3	125.82	112.3	125.82		112.3	125.82		60305 EAU CLA5 161 60368 JEFERSRD5 161 1	
					147	164.62	147	164.62		147	164.62		60305 EAU CLA5 161 61001 EAUCLAI869.0 1	
					119.3	133.57	119.3	133.57		119.3	133.57		60318 WHT 56 5 161 60319 WHEATTP5 161 1	
					116	129.91	116	129.91		116	129.91		60318 WHT 56 5 161 60319 WHEATTP5 161 1	SW871
					120.6	135.04	120.6	135.04		120.6	135.04		60319 WHEATTP5 161 60320 HYDROLN5 161 1	
					120.6	135.04	120.6	135.04		120.6	135.04		60320 HYDROLN5 161 60321 HYDROLN7 115 1	
					136.4	152.78	136.4	152.78		136.4	152.78		60323 SEVN ML5 161 61071 SEVN ML869.0 1	

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
60305 EAU CLA5 161 61200 PRESTOT5 161 1				272	93.8	255.27	93.8	255.27		93.8	255.26		SYSTEM INTACT	
					98.5	267.98							60105 PR ISLD3 345 60236 REDROCK3 345 1	SW800
					111.3	302.8	111.3	302.81		111.3	302.8		60186 AS KING3 345 60221 KOLMNLK3 345 1	SW913
					111.7	303.71	111.7	303.72		111.7	303.71		60186 AS KING3 345 60221 KOLMNLK3 345 1	SW914
					111.8	304.04	111.8	304.05		111.8	304.04		60186 AS KING3 345 60236 REDROCK3 345 1	SW915
					112.1	304.8	112.1	304.8		112.1	304.79		60186 AS KING3 345 60236 REDROCK3 345 1	SW916
					123.1	334.9	123.1	334.9		123.1	334.9		60186 AS KING3 345 60304 EAU CL 3 345 1	SW400
					111.8	304.11	111.8	304.11		111.8	304.11		60186 AS KING3 345 60304 EAU CL 3 345 1	SW860
					112.1	304.85	112.1	304.85		112.1	304.84		60186 AS KING3 345 60304 EAU CL 3 345 1	SW861
					97	263.76							60304 EAU CL 3 345 60305 EAU CLA5 161 9	
					97.5	265.25							60316 TREMVAL5 161 60323 SEVN ML5 161 1	
60307 JACKSON5 161 60966 JACKCO 869.0 1				47	91.3	42.91	91.3	42.91		91.3	42.91		SYSTEM INTACT	
					95	44.67							60282 REDCDR 5 161 60319 WHEATTP5 161 1	SW866
					108.1	50.79	108.1	50.79		108.1	50.79		60308 LACROSS5 161 60310 MONROCO5 161 1	
					108.1	50.8	108.1	50.8		108.1	50.8		60310 MONROCO5 161 60949 MONROCO869.0 1	
					96.2	45.23							60316 TREMVAL5 161 60323 SEVN ML5 161 1	
					112.7	52.98	112.7	52.98		112.7	52.98		60316 TREMVAL5 161 60979 TREMVAL869.0 1	
					98	46.07							60323 SEVN ML5 161 61071 SEVN ML869.0 1	
60310 MONROCO5 161 60949 MONROCO869.0 1				70	119.6	83.69	119.6	83.69		119.6	83.69		SYSTEM INTACT	
					121.1	84.78	121.1	84.78		121.1	84.78		60186 AS KING3 345 60221 KOLMNLK3 345 1	SW914
					122	85.38	122	85.38		122	85.38		60302 COULEE 5 161 60967 COULEE 869.0 2	
					122	85.39	122	85.39		122	85.39		60305 EAU CLA5 161 61200 PRESTOT5 161 1	
					130.8	91.54	130.8	91.54		130.8	91.54		60307 JACKSON5 161 60316 TREMVAL5 161 1	
					130.8	91.55	130.8	91.55		130.8	91.55		60307 JACKSON5 161 60966 JACKCO 869.0 1	
					127.3	89.08	127.3	89.08		127.3	89.08		60308 LACROSS5 161 60311 MAYFAIR5 161 1	
					121.7	85.2	121.7	85.2		121.7	85.2		60308 LACROSS5 161 60973 LAX 869.0 1	
					121.7	85.21	121.7	85.21		121.7	85.2		60308 LACROSS5 161 60973 LAX 869.0 2	
					121.3	84.91	121.3	84.91		121.3	84.91		60316 TREMVAL5 161 60979 TREMVAL869.0 1	
					122	85.39	122	85.39		122	85.39		60317 WHT 14 5 161 61200 PRESTOT5 161 1	
60312 PINE LK5 161 60313 PINE LK7 115 3				112	66	73.95	66	73.95		66	73.95		SYSTEM INTACT	
					151.4	169.53	151.4	169.53		151.4	169.53		60187 AS KING7 115 60325 WILOWRV7 115 1	
					97.1	108.75							60187 AS KING7 115 60325 WILOWRV7 115 1	SW863
					96.7	108.28							60313 PINE LK7 115 60325 WILOWRV7 115 1	
60312 PINE LK5 161 60314 PINELKT5 161 1				165	44.8	73.95	44.8	73.95		44.8	73.95		SYSTEM INTACT	
					102.7	169.53	102.7	169.53		102.7	169.53		60187 AS KING7 115 60325 WILOWRV7 115 1	
60313 PINE LK7 115 61023 PINE LK869.0 1				112	53.4	59.86	53.4	59.86		53.4	59.86		SYSTEM INTACT	
					103.5	115.97	103.5	115.97		103.5	115.97		60313 PINE LK7 115 61023 PINE LK869.0 2	
60313 PINE LK7 115 61023 PINE LK869.0 2				112	52.9	59.25	52.9	59.25		52.9	59.25		SYSTEM INTACT	
					103.5	115.88	103.5	115.88		103.5	115.88		60313 PINE LK7 115 61023 PINE LK869.0 1	
60315 T-CRNRS7 115 60666 T CORNE869.0 1				62.5	56.3	35.16	56.3	35.16		56.3	35.17		SYSTEM INTACT	
					130	81.22	130	81.22		130	81.22		60315 T-CRNRS7 115 60666 T CORNE869.0 2	
60317 WHT 14 5 161 61200 PRESTOT5 161 1				272	94.3	256.36	94.3	256.36		94.3	256.36		SYSTEM INTACT	
					98.9	269.1							60105 PR ISLD3 345 60236 REDROCK3 345 1	SW800
					111.8	304.02	111.8	304.02		111.8	304.01		60186 AS KING3 345 60221 KOLMNLK3 345 1	SW913
					112.1	304.94	112.1	304.94		112.1	304.93		60186 AS KING3 345 60221 KOLMNLK3 345 1	SW914
					112.2	305.26	112.2	305.26		112.2	305.25		60186 AS KING3 345 60236 REDROCK3 345 1	SW915
					112.5	306.02	112.5	306.02		112.5	306.02		60186 AS KING3 345 60236 REDROCK3 345 1	SW916
					123.9	337.04	123.9	337.04		123.9	337.04		60186 AS KING3 345 60304 EAU CL 3 345 1	SW400
					112.3	305.32	112.3	305.32		112.3	305.32		60186 AS KING3 345 60304 EAU CL 3 345 1	SW860
					112.5	306.07	112.5	306.07		112.5	306.07		60186 AS KING3 345 60304 EAU CL 3 345 1	SW861

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
					97.4	264.93							60304 EAU CL 3 345 60305 EAU CLA5 161 9	
					97.9	266.37							60316 TREMVAL5 161 60323 SEVN ML5 161 1	
60323	SEVN ML5 161 61071	SEVN ML869.0 1		112	104.2	116.7	104.2	116.7		104.2	116.7		SYSTEM INTACT	
					118.1	132.22	118.1	132.22		118.1	132.22		60282 REDCDR 5 161 60319 WHEATTP5 161 1	SW866
					115.8	129.71	115.8	129.71		115.8	129.71		60282 REDCDR 5 161 60319 WHEATTP5 161 1	SW870
					126.4	141.53	126.4	141.53		126.4	141.53		60305 EAU CLA5 161 61001 EAUCLA1869.0 1	
					129.8	145.41	129.8	145.41		129.8	145.41		60305 EAU CLA5 161 61001 EAUCLA1869.0 2	
					107.7	120.62	107.7	120.62		107.7	120.62		60307 JACKSON5 161 60966 JACKCO 869.0 1	
					108.1	121.03	108.1	121.03		108.1	121.03		60316 TREMVAL5 161 60979 TREMVAL869.0 1	
					111.6	125.02	111.6	125.02		111.6	125.02		60318 WHT 56 5 161 60319 WHEATTP5 161 1	
					114.6	128.38	114.6	128.38		114.6	128.38		60319 WHEATTP5 161 60320 HYDROLN5 161 1	
					114.6	128.39	114.6	128.39		114.6	128.39		60320 HYDROLN5 161 60321 HYDROLN7 115 1	
					108.2	121.21	108.2	121.21		108.2	121.21		60321 HYDROLN7 115 61006 WISSOTAG69.0 1	
60343	WILLPIP7 115 62228	APPVLTW7 115 1		195.6	48.6	95							SYSTEM INTACT	
					99	193.55							60188 RIVERWD7 115 60200 BLK DG27 115 1	
60357	MAYNARD7 115 62005	KERKHOT7 115 1		78	52.7	41.14	52.7	41.14		52.8	41.15		SYSTEM INTACT	
					96.1	74.97							62427 WILLMAR869.0 63050 WILLMAR4 230 1	
					109.3	85.27	109.3	85.26		109.3	85.27		62427 WILLMAR869.0 63050 WILLMAR4 230 1	SW928
					127.2	99.18	127.2	99.18		127.2	99.19		63050 WILLMAR4 230 66550 GRANITF4 230 1	
60362	CHANRMB7 115 60715	CHANRMB934.5 1		120	67.2	80.64	67.2	80.64		67.2	80.64		SYSTEM INTACT	
					134.5	161.44	134.5	161.44		134.5	161.44		60362 CHANRMB7 115 60715 CHANRMB934.5 2	
60362	CHANRMB7 115 60715	CHANRMB934.5 2		120	67.2	80.64	67.2	80.64		67.2	80.64		SYSTEM INTACT	
					134.5	161.44	134.5	161.44		134.5	161.44		60362 CHANRMB7 115 60715 CHANRMB934.5 1	
60369	FEPTP 7 115 62234	LKMARN 7 115 1		310	85.8	266.04	85.8	266.03		85.8	266.05		SYSTEM INTACT	
					98.4	305.03							60107 W FARIB7 115 60792 WFARBLT869.0 1	SW822
					111.2	344.72	111.2	344.71		111.2	344.73		60107 W FARIB7 115 62865 AIRTECH7 115 1	
					112	347.12	112	347.11		112	347.13		60108 WILMART3 345 60192 BLUE LK3 345 1	
					113	350.16	113	350.15		113	350.17		60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
					112.3	348.19	112.3	348.18		112.3	348.2		60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
					100.9	312.87	100.9	312.87		100.9	312.88		60108 WILMART3 345 60365 FIELD_S3 345 1	
					100.3	310.97	100.3	310.96		100.3	310.97		60202 COON CK3 345 63030 DICKNSN3 345 1	SW880
					100.9	312.87	100.9	312.86		100.9	312.87		60331 LKFLDXL3 345 60364 FIELD_N3 345 1	
					100.9	312.84	100.9	312.83		100.9	312.84		60364 FIELD_N3 345 60365 FIELD_S3 345 1	
					112	347.1	112	347.09		112	347.11		60369 FEPTP 7 115 62865 AIRTECH7 115 1	
60369	FEPTP 7 115 62865	AIRTECH7 115 1		310	66.7	206.82	66.7	206.82		66.7	206.82		SYSTEM INTACT	
					101.4	314.47	101.4	314.46		101.4	314.47		60369 FEPTP 7 115 62234 LKMARN 7 115 1	
60382	BRKNGCO7 115 60383	BRKNGCO3 345 1		448	74.9	335.35	74.9	335.36		74.9	335.35		SYSTEM INTACT	
					95.2	426.46							60119 LKYNKTN7 115 60279 BUFFRID7 115 1	
					109.5	490.66	109.5	490.66		109.5	490.66		60279 BUFFRID7 115 60381 YANKEE 7 115 1	
60384	FENTON 7 115 60610	FTN WND134.5 1		120	89.4	107.23	89.4	107.23		89.4	107.23		SYSTEM INTACT	
					117.6	141.07	117.6	141.07		117.6	141.07		34003 MAGNLIA5 161 60128 SPLT RK5 161 1	SW806
					117.5	141.06	117.5	141.06		117.5	141.06		60067 FTN 20G.575 60370 DAN JUHL 161 1	
					117.5	141.06	117.5	141.06		117.5	141.06		60128 SPLT RK5 161 60370 DAN JUHL 161 1	
60742	PANTHER869.0 63054	PANTHER4 230 1		70	71.9	50.34							SYSTEM INTACT	
					96.1	67.24							60148 MINVALY7 115 61954 REDFLST7 115 1	
61910	MILACA 4 230 62301	MILACA 869.0 1		71.7	124.4	89.18	124.4	89.18		124.4	89.18		SYSTEM INTACT	
					137.8	98.8	137.8	98.8		137.8	98.8		60114 ELM CRK3 345 60151 MNTCELO3 345 1	SW833
					142.6	102.26	142.6	102.26		142.6	102.26		60143 BENTON 7 115 60146 GRANCTY7 115 1	SW757
					135.3	97.03	135.3	97.03		135.3	97.03		60151 MNTCELO3 345 60160 SHERCO 3 345 1	SW834
					134.7	96.58	134.7	96.58		134.7	96.58		60151 MNTCELO3 345 60160 SHERCO 3 345 1	SW878

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA MVA	OVRD %	CURRENT MVA	OVRD %	CURRENT MVA	Diff MVA	OVRD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
					135	96.82	135	96.82		135	96.82		60152 MNTCELO4 230 63043 ELK RIV4 230 1	
					138.9	99.62	138.9	99.62		138.9	99.62		60152 MNTCELO4 230 63043 ELK RIV4 230 1	SW975
					140	100.4	140	100.4		140	100.4		60160 SHERCO 3 345 63031 BUNKER 3 345 1	SW976
					133.5	95.74	133.5	95.74		133.5	95.74		60160 SHERCO 3 345 63031 BUNKER 3 345 1	SW977
					135.5	97.13	135.5	97.13		135.5	97.13		62293 RUSH CY869.0 63048 RUSH CY4 230 1	
					138.4	99.27	138.4	99.26		138.4	99.27		62297 BENTON 869.0 63045 BENTON 4 230 1	
62090 PRKWOOD7 115 62132 PRKWOOD869.0 1				140	69.7	97.65	69.7	97.65		69.7	97.65		SYSTEM INTACT	
					109.9	153.86	109.9	153.86		109.9	153.86		62090 PRKWOOD7 115 62132 PRKWOOD869.0 2	
62090 PRKWOOD7 115 62132 PRKWOOD869.0 2				140	69.7	97.65	69.7	97.65		69.7	97.65		SYSTEM INTACT	
					113.3	158.64	113.3	158.64		113.3	158.65		60205 CRKEDLK7 115 62090 PRKWOOD7 115 1	SW969
					109.9	153.86	109.9	153.86		109.9	153.86		62090 PRKWOOD7 115 62132 PRKWOOD869.0 1	
62128 BLAINE 869.0 63040 BLAINE 4 230 1				112	79.8	89.35	79.8	89.35		79.8	89.35		SYSTEM INTACT	
					95.1	106.51							60203 COON CK7 115 62090 PRKWOOD7 115 1	
					101.7	113.95	101.7	113.95		101.7	113.95		60203 COON CK7 115 62090 PRKWOOD7 115 1	SW970
					100	112.03	100	112.03		100	112.03		62140 MARTNTP869.0 63057 LINWOOD4 230 1	
					95.9	107.36							62147 BNKRLK 869.0 63046 BUNKER 4 230 1	
62134 ELKR14S869.0 63043 ELK RIV4 230 1				187	70.1	131.01	70.1	131.01		70.1	131.01		SYSTEM INTACT	
					107.2	200.51	107.2	200.51		107.2	200.51		62134 ELKR14S869.0 63043 ELK RIV4 230 2	
					117.8	220.24	117.8	220.24		117.8	220.24		62134 ELKR14S869.0 63043 ELK RIV4 230 2	SW974
62134 ELKR14S869.0 63043 ELK RIV4 230 2				187	70.1	131.01	70.1	131.01		70.1	131.01		SYSTEM INTACT	
					107.2	200.51	107.2	200.51		107.2	200.51		62134 ELKR14S869.0 63043 ELK RIV4 230 1	
62147 BNKRLK 869.0 63046 BUNKER 4 230 1				112	104.9	117.48	104.9	117.48		104.9	117.48		SYSTEM INTACT	
					116.7	130.75	116.7	130.75		116.7	130.75		60114 ELM CRK3 345 60151 MNTCELO3 345 1	SW833
					125.4	140.41	125.4	140.41		125.4	140.41		60203 COON CK7 115 62090 PRKWOOD7 115 1	
					132.8	148.69	132.8	148.69		132.8	148.69		60203 COON CK7 115 62090 PRKWOOD7 115 1	SW970
					116.7	130.69	116.7	130.69		116.7	130.69		60205 CRKEDLK7 115 62090 PRKWOOD7 115 1	SW969
					118.1	132.32	118.1	132.32		118.1	132.32		62090 PRKWOOD7 115 62132 PRKWOOD869.0 1	
					118.1	132.32	118.1	132.32		118.1	132.32		62090 PRKWOOD7 115 62132 PRKWOOD869.0 2	
					119.3	133.63	119.3	133.63		119.3	133.63		62128 BLAINE 869.0 63040 BLAINE 4 230 1	
					126.9	142.18	126.9	142.18		126.9	142.18		62128 BLAINE 869.0 63040 BLAINE 4 230 1	SW993
					115.1	128.93	115.1	128.93		115.1	128.93		62134 ELKR14S869.0 63043 ELK RIV4 230 1	
					122.1	136.73	122.1	136.73		122.1	136.73		63040 BLAINE 4 230 63046 BUNKER 4 230 1	
62225 BURNVIL7 115 62250 BURNVIL869.0 1				95.6	65.4	62.51	65.4	62.51		65.4	62.51		SYSTEM INTACT	
					112.4	107.41	112.4	107.41		112.4	107.41		62225 BURNVIL7 115 62250 BURNVIL869.0 2	
62232 DKTAHGT7 115 62237 KENRICK7 115 1				144	70.4	101.43	70.4	101.43		70.4	101.44		SYSTEM INTACT	
					97.6	140.61							60108 WILMART3 345 60192 BLUE LK3 345 1	
					99.1	142.71							60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
					98.3	141.51							60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
					95.8	137.9							60188 RIVERWD7 115 60200 BLK DG27 115 1	
					110.1	158.59	110.1	158.58		110.1	158.59		60276 AIRLAKE7 115 62234 LKMARN 7 115 1	
62234 LKMARN 7 115 62237 KENRICK7 115 1				144	76.5	110.2	76.5	110.2		76.5	110.21		SYSTEM INTACT	
					96.4	138.79							60107 W FARIB7 115 62865 AIRTECH7 115 1	
					103.4	148.91	103.4	148.91		103.4	148.92		60108 WILMART3 345 60192 BLUE LK3 345 1	
					104.9	151.05	104.9	151.05		104.9	151.06		60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
					104	149.82	104	149.81		104	149.82		60108 WILMART3 345 60192 BLUE LK3 345 1	SW903
					102.5	147.61	102.5	147.61		102.5	147.62		60188 RIVERWD7 115 60200 BLK DG27 115 1	
					97.7	140.7							60188 RIVERWD7 115 62225 BURNVIL7 115 1	
					116.3	167.52	116.3	167.51		116.3	167.52		60276 AIRLAKE7 115 62234 LKMARN 7 115 1	
					100.4	144.57	100.4	144.56		100.4	144.57		60343 WILLPIP7 115 62228 APPVLTW7 115 1	
					97	139.63							60369 FEPTP 7 115 62865 AIRTECH7 115 1	

CIRCUIT FROM: # NAME		CIRCUIT TO: # NAME		RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
					100.4	144.57	100.4	144.57		100.4	144.58		62227 JOHNSAK7 115 62228 APPVLTW7 115 1	
62234 LKMARN 7 115 62259 LKMARN 869.0 1				70	95.8	67.08	95.8	67.08		95.8	67.08		SYSTEM INTACT	
					105.1	73.58	105.1	73.57		105.1	73.58		60107 W FARIB7 115 60792 WFARBLT869.0 1	SW822
					114.8	80.33	114.8	80.33		114.8	80.33		60107 W FARIB7 115 62865 AIRTECH7 115 1	
					105	73.52	105	73.51		105	73.52		60108 WILMART3 345 60192 BLUE LK3 345 1	SW902
					105.7	74	105.7	74		105.7	74		60200 BLK DG27 115 62666 GLNDALE7 115 1	SW857
					104.4	73.1	104.4	73.1		104.4	73.1		60218 INVRHLS7 115 60220 INVRGRV7 115 1	
					113.9	79.76	113.9	79.76		113.9	79.76		60276 AIRLAKE7 115 62234 LKMARN 7 115 1	
					115.4	80.8	115.4	80.8		115.4	80.8		60369 FEPTP 7 115 62865 AIRTECH7 115 1	
					104.3	72.98	104.3	72.98		104.3	72.98		62225 BURNVIL7 115 62232 DKTAHGT7 115 1	
					112.5	78.73	112.5	78.72		112.5	78.73		62232 DKTAHGT7 115 62237 KENRICK7 115 1	
					114.7	80.29	114.7	80.29		114.7	80.29		62234 LKMARN 7 115 62237 KENRICK7 115 1	
62293 RUSH CY869.0 63048 RUSH CY4 230 1				84	87.9	73.87	87.9	73.87		87.9	73.87		SYSTEM INTACT	
					95.2	79.94							60142 BENTON 3 345 60160 SHERCO 3 345 1	
					95.2	79.94							60142 BENTON 3 345 60160 SHERCO 3 345 1	SW979
					100.4	84.31	100.4	84.31		100.4	84.31		61910 MILACA 4 230 62301 MILACA 869.0 1	
					100.4	84.32	100.4	84.32		100.4	84.32		61910 MILACA 4 230 63045 BENTON 4 230 1	
					102.2	85.83	102.2	85.83		102.2	85.83		61910 MILACA 4 230 63045 BENTON 4 230 1	SW971
					107	89.92	107	89.92		107	89.92		62140 MARTNTP869.0 63057 LINWOOD4 230 1	
62387 SPRNGCK869.0 63071 SPRNGCK5 161 1				70	63.7	44.58							SYSTEM INTACT	
					95.8	67.05							62387 SPRNGCK869.0 63071 SPRNGCK5 161 2	
62425 WILLMAR7 115 62427 WILLMAR869.0 1				92.4	36.5	33.72	36.5	33.72		36.5	33.72		SYSTEM INTACT	
					97.4	90.02							62427 WILLMAR869.0 63050 WILLMAR4 230 1	
					101	93.33	101	93.33		101	93.33		62427 WILLMAR869.0 63050 WILLMAR4 230 1	SW928
					123.5	114.13	123.5	114.13		123.5	114.13		63050 WILLMAR4 230 66550 GRANITF4 230 1	
62616 BIGSWAN7 115 62617 BIGSWAN869.0 1				46.7	84.7	39.56	84.7	39.56		84.7	39.56		SYSTEM INTACT	
					100.3	46.82	100.3	46.82		100.3	46.82		60206 CROWVR7 115 60652 CROWRV 869.0 1	
					102.5	47.86	102.5	47.86		102.5	47.86		62982 HUTCHMN7 115 62986 HUTCHMN869.0 1	
62666 GLNDALE7 115 62672 GLNDALE869.0 1				46.7	83.6	39.04	83.6	39.04		83.6	39.03		SYSTEM INTACT	
					115.2	53.79	115.2	53.79		115.2	53.78		60188 RIVERWD7 115 60200 BLK DG27 115 1	
					109.4	51.11	109.4	51.11		109.4	51.11		60188 RIVERWD7 115 62225 BURNVIL7 115 1	
					106.1	49.53	106.1	49.53		106.1	49.53		60276 AIRLAKE7 115 62234 LKMARN 7 115 1	SW812
					100.1	46.74	100.1	46.74		100.1	46.74		60369 FEPTP 7 115 62234 LKMARN 7 115 1	
					99.2	46.32							62225 BURNVIL7 115 62250 BURNVIL869.0 2	
					100.4	46.88	100.4	46.88		100.4	46.88		62234 LKMARN 7 115 62259 LKMARN 869.0 1	
					123.6	57.71	123.6	57.71		123.6	57.71		62666 GLNDALE7 115 62672 GLNDALE869.0 2	
62666 GLNDALE7 115 62672 GLNDALE869.0 2				46.7	83.6	39.04	83.6	39.04		83.6	39.03		SYSTEM INTACT	
					115.2	53.79	115.2	53.79		115.2	53.78		60188 RIVERWD7 115 60200 BLK DG27 115 1	
					109.4	51.11	109.4	51.11		109.4	51.11		60188 RIVERWD7 115 62225 BURNVIL7 115 1	
					127.3	59.43	127.3	59.43		127.3	59.43		60194 CARVRCO7 115 60243 SCOTTAP7 115 1	SW991
					106.1	49.53	106.1	49.53		106.1	49.53		60276 AIRLAKE7 115 62234 LKMARN 7 115 1	SW812
					100.1	46.74	100.1	46.74		100.1	46.74		60369 FEPTP 7 115 62234 LKMARN 7 115 1	
					99.2	46.32							62225 BURNVIL7 115 62250 BURNVIL869.0 2	
					100.4	46.88	100.4	46.88		100.4	46.88		62234 LKMARN 7 115 62259 LKMARN 869.0 1	
					123.6	57.71	123.6	57.71		123.6	57.71		62666 GLNDALE7 115 62672 GLNDALE869.0 1	
62667 ST BONI7 115 63021 ST BONI869.0 1				70	48	33.59	48	33.59		48	33.59		SYSTEM INTACT	
					159.6	111.69	159.6	111.69		159.6	111.69		60211 GLESNLK7 115 60887 GLESNLK869.0 1	
62925 DICKNSN7 115 62926 DCKSNSS7 115 1				195.6	54	105.65	54	105.64		54	105.65		SYSTEM INTACT	
					104.8	205.06	104.8	205.05		104.8	205.06		60151 MNTCELO3 345 60153 MNTCELO7 115 10	
62925 DICKNSN7 115 63085 DICKNSNY1.00 1				448	84.9	380.47	84.9	380.47		84.9	380.48		SYSTEM INTACT	

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM: # NAME	CIRCUIT TO: # NAME	CKT	RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
				106	475.08	106	475.08		106	475.08		60114 ELM CRK3 345 60233 PARKERS3 345 1	SW827
				101.5	454.62	101.5	454.62		101.5	454.62		60151 MNTCELO3 345 60153 MNTCELO7 115 10	
				102.1	457.25	102.1	457.25		102.1	457.26		60160 SHERCO 3 345 60202 COON CK3 345 1	SW881
				102.1	457.25	102.1	457.25		102.1	457.26		60160 SHERCO 3 345 60202 COON CK3 345 1	SW882
				102	456.98	102	456.98		102	456.99		60160 SHERCO 3 345 60272 MPLEGV23 345 1	SW835
				97.2	435.43							60202 COON CK3 345 63030 DICKNSN3 345 1	SW402
				105.5	472.45	105.5	472.45		105.5	472.45		60211 GLESNLK7 115 60234 PARKERS7 115 1	SW992
				101.8	456.21	101.8	456.21		101.8	456.21		60233 PARKERS3 345 60270 MPLEGV13 345 1	SW828
				101.8	456.21	101.8	456.21		101.8	456.21		60233 PARKERS3 345 60270 MPLEGV13 345 1	SW883
				96.8	433.48							60270 MPLEGV13 345 63030 DICKNSN3 345 1	SW402
63030 DICKNSN3 345	63085 DICKNSNY1.00 1		448	84.9	380.47	84.9	380.47		84.9	380.48		SYSTEM INTACT	
				106	475.08	106	475.08		106	475.08		60114 ELM CRK3 345 60233 PARKERS3 345 1	SW827
				101.5	454.62	101.5	454.62		101.5	454.62		60151 MNTCELO3 345 60153 MNTCELO7 115 10	
				102.1	457.25	102.1	457.25		102.1	457.26		60160 SHERCO 3 345 60202 COON CK3 345 1	SW881
				102.1	457.25	102.1	457.25		102.1	457.26		60160 SHERCO 3 345 60202 COON CK3 345 1	SW882
				102	456.98	102	456.98		102	456.99		60160 SHERCO 3 345 60272 MPLEGV23 345 1	SW835
				97.2	435.43							60202 COON CK3 345 63030 DICKNSN3 345 1	SW402
				105.5	472.45	105.5	472.45		105.5	472.45		60211 GLESNLK7 115 60234 PARKERS7 115 1	SW992
				101.8	456.21	101.8	456.21		101.8	456.21		60233 PARKERS3 345 60270 MPLEGV13 345 1	SW828
				101.8	456.21	101.8	456.21		101.8	456.21		60233 PARKERS3 345 60270 MPLEGV13 345 1	SW883
				96.8	433.48							60270 MPLEGV13 345 63030 DICKNSN3 345 1	SW402
63044 MCHENRY4 230	63082 MCHENRY1.00 1		84	89.9	75.51	89.9	75.48		90.2	75.75		SYSTEM INTACT	
				144.6	121.51	144.6	121.48		145.1	121.86	0.35	60138 SOURIS 7 115 60139 MALLARD7 115 1	
				110.4	92.77	110.4	92.73		110.8	93.04	0.27	60139 MALLARD7 115 67155 LOGAN 7 115 1	
				107.5	90.29	107.4	90.24		107.8	90.57	0.28	63044 MCHENRY4 230 63056 BALTA 4 230 1	
				101	84.86	101	84.83		101.3	85.13	0.27	63047 RAMSEY 4 230 63056 BALTA 4 230 1	
				101.5	85.27	101.5	85.23		101.8	85.53	0.26	63047 RAMSEY 4 230 66755 PRAIRIE4 230 1	SW739
				102.6	86.14	102.5	86.11		102.9	86.47	0.33	63185 RUGBY Y 230 63379 RUGBY 4 230 1	
				112.7	94.71	112.7	94.68		113.2	95.09	0.38	66442 GARRISN7 115 67113 VOLTAIR7 115 1	
				105.6	88.67	105.4	88.56		106	89.02	0.35	67106 LELAND04 230 67108 LOGAN 4 230 1	
				109.5	91.96	109.4	91.91		109.5	92.02		67108 LOGAN 4 230 67208 LOGAN TY 230 1	
				109.5	91.96	109.4	91.91		109.5	92.02		67155 LOGAN 7 115 67208 LOGAN TY 230 1	
63047 RAMSEY 4 230	63084 RAMSEY Y1.00 1		84	69.3	58.19	69.3	58.18		69.4	58.27		SYSTEM INTACT	
				107.8	90.55	107.8	90.54		107.9	90.61		63047 RAMSEY 4 230 66755 PRAIRIE4 230 1	
				96.7	81.19							63257 HENSEL 7 115 66705 DRAYTON7 115 1	
				101.3	85.13	101.3	85.13		101.5	85.25		66447 LEEDS 7 115 66452 RUGBY 7 115 1	
63084 RAMSEY Y1.00	63266 RAMSEY 7 115 1		84	69.3	58.18	69.3	58.18		69.4	58.27		SYSTEM INTACT	
				107.8	90.55	107.8	90.54		107.9	90.61		63047 RAMSEY 4 230 66755 PRAIRIE4 230 1	
				96.7	81.19							63257 HENSEL 7 115 66705 DRAYTON7 115 1	
				101.3	85.13	101.3	85.13		101.5	85.25		66447 LEEDS 7 115 66452 RUGBY 7 115 1	
63123 HOOT LK941.6	63223 HOOT LK7 115 1		27	96.7	26.11							SYSTEM INTACT	
				99.6	26.9							60133 SHEYNNE4 230 60134 SHEYNNE7 115 5	SW887
				98.3	26.53							60133 SHEYNNE4 230 63336 AUDUBON4 230 1	
				98.4	26.57							63129 WAHPETN941.6 63201 WAHPET2Y 230 1	SW960
				98.4	26.56							63198 BUFFALOY 345 63258 BUFFALO7 115 1	SW886
				98.6	26.63							63202 AUDUBONY 230 63236 AUDUBON7 115 1	
				97.6	26.34							63202 AUDUBONY 230 63336 AUDUBON4 230 1	
				97.9	26.44							63327 HANKSON4 230 63329 WAHPETN4 230 1	
				97.9	26.44							63358 BUFFALO3 345 63369 JAMESTN3 345 1	
				98.3	26.55							63358 BUFFALO3 345 66792 MAPLE R3 345 1	

CIRCUIT FROM: # NAME		CIRCUIT TO: CKT # NAME		RATEA MVA	OVRLD %	CURRENT MVA	OVRLD %	CURRENT MVA	Diff MVA	OVRLD %	CURRENT MVA	Diff MVA	CONTINGENCY FROM TO CKT	SWITCH
					97.6	26.35							63369 JAMESTN3 345 66791 CENTER 3 345 1	
63179 RUGBY T13.8 63185 RUGBY Y 230 1				25.3	97.7	24.71							SYSTEM INTACT	
					98.4	24.91							60202 COON CK3 345 63030 DICKNSN3 345 1	SW880
					98	24.79							63041 COAL CR4 230 63042 COAL TP4 230 1	SW804
					98	24.81							63047 RAMSEY 4 230 63056 BALTA 4 230 1	
					98.2	24.84							63056 BALTA 4 230 63290 HARVEY 4 230 1	
					98.2	24.85							63056 BALTA 4 230 63379 RUGBY 4 230 1	SW507
					98.9	25.02							63267 DEVIL J7 115 66431 DEVILSL7 115 1	SW732
					98.2	24.83							63290 HARVEY 4 230 63381 UNDERWD4 230 1	
					98.2	24.84							66437 GRNDFKS4 230 66759 PICKERT4 230 1	
					98.2	24.84							66437 GRNDFKS4 230 66759 PICKERT4 230 1	SW734
					98.2	24.84							67105 LELANDO3 345 67202 LELND2TY 345 1	SW3
63184 HENSEL2Y 115 66796 HENSELU869.0 P2				40	50.4	20.18	50.4	20.18		50.4	20.18		SYSTEM INTACT	
					109.2	43.69	109.2	43.69		109.2	43.69		63192 HENSEL Y 115 63257 HENSEL 7 115 1	
					101.6	40.63	101.6	40.63		101.6	40.63		63192 HENSEL Y 115 66796 HENSELU869.0 1	
63186 WILTON Y 230 63245 WILTON 7 115 1				140	60.4	84.57	60.4	84.57		60.4	84.57		SYSTEM INTACT	
					105.8	148.09	105.8	148.09		105.8	148.09		63245 WILTON 7 115 66798 WILTON2T 230 1	
					105.8	148.09	105.8	148.09		105.8	148.09		63345 WILTON 4 230 66798 WILTON2T 230 1	
63186 WILTON Y 230 63345 WILTON 4 230 1				140	60.4	84.57	60.4	84.57		60.4	84.57		SYSTEM INTACT	
					105.8	148.09	105.8	148.09		105.8	148.09		63245 WILTON 7 115 66798 WILTON2T 230 1	
					105.8	148.09	105.8	148.09		105.8	148.09		63345 WILTON 4 230 66798 WILTON2T 230 1	
63189 MAPLER1Y 345 66792 MAPLE R3 345 1				336	49.5	166.29							SYSTEM INTACT	
					95	319.37							63190 MAPLER2Y 345 66754 MAPLE R4 230 1	SW8
					95	319.37							63190 MAPLER2Y 345 66792 MAPLE R3 345 1	SW8
63190 MAPLER2Y 345 66792 MAPLE R3 345 1				336	49.5	166.29							SYSTEM INTACT	
					95	319.37							63189 MAPLER1Y 345 66754 MAPLE R4 230 1	SW7
					95	319.37							63189 MAPLER1Y 345 66792 MAPLE R3 345 1	SW7
63192 HENSEL Y 115 66796 HENSELU869.0 1				40	50.4	20.18	50.4	20.18		50.4	20.18		SYSTEM INTACT	
					109.2	43.69	109.2	43.69		109.2	43.69		63184 HENSEL2Y 115 63257 HENSEL 7 115 P2	
					101.6	40.63	101.6	40.63		101.6	40.63		63184 HENSEL2Y 115 66796 HENSELU869.0 P2	
63219 GRANTCO7 115 66555 MORRIS 7 115 1				96	96.5	92.66	96.5	92.65		96.5	92.67		SYSTEM INTACT	
					107.9	103.57	107.9	103.55		107.9	103.57		60133 SHEYNNE4 230 66435 FARGO 4 230 1	
					128.1	122.99	128.1	122.98		128.1	122.99		63129 WAHPETN941.6 63191 WAHPET1Y 230 1	SW959
					130	124.82	130	124.81		130	124.83		63129 WAHPETN941.6 63201 WAHPET2Y 230 1	SW960
					109.1	104.77	109.1	104.77		109.1	104.78		63219 GRANTCO7 115 63223 HOOT LK7 115 1	
					119.7	114.88	119.7	114.87		119.7	114.9		63314 BIGSTON4 230 63325 BROWNSV4 230 1	
					118.5	113.73	118.5	113.71		118.5	113.74		63314 BIGSTON4 230 63325 BROWNSV4 230 1	SW937
					117.1	112.42	117.1	112.41		117.1	112.43		63325 BROWNSV4 230 63327 HANKSON4 230 1	
					129.4	124.23	129.4	124.22		129.4	124.24		63327 HANKSON4 230 63329 WAHPETN4 230 1	
					124	119.04	124	119.03		124	119.04		63329 WAHPETN4 230 63331 FERGSFL4 230 1	
					112.9	108.41	112.9	108.39		112.9	108.42		66553 MOORHED4 230 66554 MORRIS 4 230 1	
63223 HOOT LK7 115 63233 EDGETAP7 115 1				96	82.9	79.58	82.9	79.57		82.9	79.58		SYSTEM INTACT	
					110.9	106.46	110.9	106.46		110.9	106.47		60133 SHEYNNE4 230 60134 SHEYNNE7 115 5	SW887
					102	97.88	102	97.88		102	97.88		60133 SHEYNNE4 230 63336 AUDUBON4 230 1	
					105.6	101.39	105.6	101.39		105.6	101.39		62531 INMAN 7 115 63052 INMAN 4 230 1	SW819
					102.5	98.44	102.5	98.43		102.5	98.44		63051 HENNING4 230 63052 INMAN 4 230 1	
					102.5	98.44	102.5	98.43		102.5	98.44		63051 HENNING4 230 63052 INMAN 4 230 1	SW818
					105.2	100.97	105.2	100.97		105.2	100.97		63051 HENNING4 230 63366 SILVRLK4 230 1	
					102.4	98.27	102.4	98.27		102.4	98.27		63202 AUDUBONY 230 63236 AUDUBON7 115 1	
					100.7	96.67	100.7	96.67		100.7	96.67		63219 GRANTCO7 115 63220 ELBOWLK7 115 1	

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM: CIRCUIT TO: CKT		RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH		
#	NAME	#	NAME	MVA	%	MVA	%	MVA	%	MVA	MVA	FROM	TO	CKT		
					99.2	95.19						63219	GRANTCO7	115 63220	ELBOWLK7 115 1	SW939
					105.2	100.98	105.2	100.98		105.2	100.98	63331	FERGSFL4	230 63366	SILVRLK4 230 1	
63223	HOOT LK7 115	63323	HOOTLK2G13.8 1	60	106.9	64.14	106.9	64.14		106.9	64.14	SYSTEM INTACT				
					111.4	66.82	111.4	66.82		111.4	66.82	60133	SHEYNNE4	230 60134	SHEYNNE7 115 5	SW887
					110	66.03	110	66.03		110.1	66.03	60133	SHEYNNE4	230 63336	AUDUBON4 230 1	
					110.2	66.12	110.2	66.12		110.2	66.12	63129	WAHPETN941.6	63201	WAHPET2Y 230 1	SW960
					110.2	66.1	110.2	66.1		110.2	66.11	63198	BUFFALOY	345 63258	BUFFALO7 115 1	SW886
					110.4	66.24	110.4	66.24		110.4	66.24	63202	AUDUBONY	230 63236	AUDUBON7 115 1	
					109.4	65.63	109.4	65.63		109.4	65.63	63202	AUDUBONY	230 63336	AUDUBON4 230 1	
					109.7	65.83	109.7	65.83		109.7	65.83	63327	HANKSON4	230 63329	WAHPETN4 230 1	
					109.7	65.84	109.7	65.84		109.7	65.85	63358	BUFFALO3	345 63369	JAMESTN3 345 1	
					110.1	66.07	110.1	66.07		110.1	66.08	63358	BUFFALO3	345 66792	MAPLE R3 345 1	
					109.4	65.66	109.4	65.66		109.4	65.66	63369	JAMESTN3	345 66791	CENTER 3 345 1	
63245	WILTON 7 115	63246	BEMIDJI7 115 1	120	106.8	128.17	106.8	128.17		106.8	128.17	SYSTEM INTACT				
					113.5	136.19	113.5	136.19		113.5	136.18	60101	FORBES 2	500 60198	CHIS-N 2 500 1	SW500
					116.4	139.73	116.4	139.73		116.4	139.72	60133	SHEYNNE4	230 60134	SHEYNNE7 115 5	SW887
					119.7	143.66	119.7	143.66		119.7	143.65	60133	SHEYNNE4	230 63336	AUDUBON4 230 1	
					113	135.57	113	135.57		113	135.57	60142	BENTON 3	345 60160	SHERCO 3 345 1	
					113	135.57	113	135.57		113	135.57	60142	BENTON 3	345 60160	SHERCO 3 345 1	SW979
					113.5	136.19	113.5	136.19		113.5	136.18	60197	CHIS CO2	500 60198	CHIS-N 2 500 1	SW500
					115.1	138.14	115.1	138.14		115.1	138.14	61910	MILACA 4	230 63045	BENTON 4 230 1	SW971
					112.2	134.67	112.2	134.67		112.2	134.67	63051	HENNING4	230 63366	SILVRLK4 230 1	
					113.3	135.97	113.3	135.97		113.3	135.97	63238	WINGER 7	115 63239	BAGLEY 7 115 1	SW943
					112.3	134.82	112.3	134.82		112.3	134.81	63243	SHEVLIN7	115 63285	SOLWAY 7 115 1	
63327	HANKSON4 230	63329	WAHPETN4 230 1	320	78.5	251.26						SYSTEM INTACT				
					96.6	308.97						63198	BUFFALOY	345 63258	BUFFALO7 115 1	SW886
					97.1	310.88						63358	BUFFALO3	345 63369	JAMESTN3 345 1	
					96.4	308.63						63358	BUFFALO3	345 66792	MAPLE R3 345 1	
					98.5	315.27						63369	JAMESTN3	345 66791	CENTER 3 345 1	
					99.2	317.55						66550	GRANITF4	230 66554	MORRIS 4 230 1	SW930
65738	20&PIO 7 115	65836	20&PI A913.2 1	28	104.5	29.27	104.5	29.27		104.5	29.27	SYSTEM INTACT				
					105	29.4	105	29.4		105	29.4	60202	COON CK3	345 63030	DICKNSN3 345 1	SW880
					104.8	29.35	104.8	29.35		104.8	29.35	65714	NW68HOL7	115 65716	SW27&F 7 115 1	
					104.9	29.36	104.9	29.36		104.9	29.36	65714-65720-65721	NW68HOL3	345/115/13 1		
					104.9	29.36	104.9	29.36		104.9	29.36	65714-65720-65722	NW68HOL3	345/115/13 2		
					104.8	29.34	104.8	29.34		104.8	29.34	65754	120&O	7 115 65771	81&OC 7 115 1	
					104.8	29.34	104.8	29.34		104.8	29.34	65754	120&O	7 115 65785	WAGENER7 115 1	
					105	29.39	105	29.39		105	29.39	65767	84&LEIG7	115 65785	WAGENER7 115 1	
					105	29.39	105	29.39		105	29.39	65785-65786-65787	WAGENER3	345/115/13 1		
					104.9	29.38	104.9	29.38		104.9	29.38	65785-65786-65788	WAGENER3	345/115/13 2		
					104.9	29.38	104.9	29.38		104.9	29.38	65786	WAGENER3	345 65789	103ROK 3 345 1	
66203	FARGO 869.0	66436	FARGO 7 115 1	42	31.9	13.4	31.9	13.4		31.9	13.4	SYSTEM INTACT				
					138.4	58.15	138.4	58.15		138.4	58.15	66203	FARGO 869.0	66436	FARGO 7 115 2	
66203	FARGO 869.0	66436	FARGO 7 115 2	100	67.5	67.52	67.5	67.51		67.5	67.52	SYSTEM INTACT				
					101.5	101.47	101.4	101.45		101.5	101.46	60133	SHEYNNE4	230 66435	FARGO 4 230 1	
					125.2	125.19	125.2	125.19		125.2	125.19	60136	MAPLE R7	115 66783	MAPLE RT 115 1	
					125.2	125.19	125.2	125.19		125.2	125.19	66783	MAPLE RT	115 67000	MAPLE R869.0 1	
66220	BELFELDT 345	66424	BELFELD3 345 1	312	81.5	254.35	81.8	255.12		82.1	256.08	SYSTEM INTACT				
					96.5	301.14						66426	BISMARK4	230 66456	WASHBRN4 230 1	SW893
					108.1	337.19	108.6	338.82	1.63	108.7	339.17	67105	LELANDO3	345 67202	LELND2TY 345 1	SW3
											1.98					

CIRCUIT FROM: # NAME	CIRCUIT TO: CKT # NAME	RATE MVA	OVRD %	CURRENT MVA	OVRD %	CURRENT MVA	Diff MVA	OVRD %	CURRENT MVA	Diff MVA	CONTINGENCY			SWITCH
											FROM	TO	CKT	
66220 BELFELDT 345	66425 BELFELD4 230 1	312	82.7	257.95	82.9	258.71	1.63	83.2	259.66	1.98	SYSTEM INTACT			
			97.8	305.04	108.6	338.82		108.7	339.17		66426 BISMARK4 230 66456 WASHBRN4 230 1	SW893		
			108.1	337.19							67105 LELAND03 345 67202 LELND2TY 345 1	SW3		
66231 SIOUXF1T 230	66523 SIOUXFL4 230 1	100	82.3	82.29	82.3	82.29	1.63	82.3	82.29	1.98	SYSTEM INTACT			
			140.5	140.48	140.5	140.48		140.5	140.48		66234 SIOUXF2T 230 66523 SIOUXFL4 230 1			
			140.5	140.48	140.5	140.48		140.5	140.48		66234 SIOUXF2T 230 66524 SIOUXFL7 115 1			
			96.7	96.74							66474 AURORA 7 115 66504 BROOKNG7 115 1			
			100.7	100.73	100.7	100.73		100.7	100.73		66502 BERSFRD7 115 66517 MANNING7 115 1			
			95.3	95.33							66504 BROOKNG7 115 66538 WHITE 7 115 1			
			103.3	103.33	103.3	103.33	103.3	103.33	66517 MANNING7 115 67121 SPIRITM7 115 1					
66231 SIOUXF1T 230	66524 SIOUXFL7 115 1	100	82.3	82.29	82.3	82.29	1.63	82.3	82.29	1.98	SYSTEM INTACT			
			140.5	140.48	140.5	140.48		140.5	140.48		66234 SIOUXF2T 230 66523 SIOUXFL4 230 1			
			140.5	140.48	140.5	140.48		140.5	140.48		66234 SIOUXF2T 230 66524 SIOUXFL7 115 1			
			96.7	96.74							66474 AURORA 7 115 66504 BROOKNG7 115 1			
			100.7	100.73	100.7	100.73		100.7	100.73		66502 BERSFRD7 115 66517 MANNING7 115 1			
			95.3	95.33							66504 BROOKNG7 115 66538 WHITE 7 115 1			
			103.3	103.33	103.3	103.33	103.3	103.33	66517 MANNING7 115 67121 SPIRITM7 115 1					
66234 SIOUXF2T 230	66523 SIOUXFL4 230 1	100	80.1	80.11	80.1	80.11	1.63	80.1	80.11	1.98	SYSTEM INTACT			
			139.4	139.44	139.4	139.44		139.4	139.44		66231 SIOUXF1T 230 66523 SIOUXFL4 230 1			
			139.4	139.44	139.4	139.44		139.4	139.44		66231 SIOUXF1T 230 66524 SIOUXFL7 115 1			
			98.1	98.05							66502 BERSFRD7 115 66517 MANNING7 115 1			
			100.6	100.57	100.6	100.57		100.6	100.57		66517 MANNING7 115 67121 SPIRITM7 115 1			
66234 SIOUXF2T 230	66524 SIOUXFL7 115 1	100	80.1	80.11	80.1	80.11	1.63	80.1	80.11	1.98	SYSTEM INTACT			
			139.4	139.44	139.4	139.44		139.4	139.44		66231 SIOUXF1T 230 66523 SIOUXFL4 230 1			
			139.4	139.44	139.4	139.44		139.4	139.44		66231 SIOUXF1T 230 66524 SIOUXFL7 115 1			
			98.1	98.05							66502 BERSFRD7 115 66517 MANNING7 115 1			
			100.6	100.57	100.6	100.57		100.6	100.57		66517 MANNING7 115 67121 SPIRITM7 115 1			
66303 SIOUXC1T 345	66564 SIOUXCY3 345 1	250	90.7	226.82	90.7	226.82	1.63	90.7	226.82	1.98	SYSTEM INTACT			
			95.4	238.5							34007 LAKEFLD5 161 34137 TRIBOJI5 161 1			
			95.3	238.15							60108 WILMART3 345 60365 FIELD_S3 345 1			
			103	257.59	103	257.59		103	257.6		60127 SPLT RK4 230 60129 SPLT RK7 115 7			
			103	257.59	103	257.59		103	257.6		60127 SPLT RK4 230 66523 SIOUXFL4 230 1			
			95.3	238.19							60331 LKFLDXL3 345 60364 FIELD_N3 345 1			
			143	357.47	143	357.47		143	357.48		66306 SIOUXC2T 345 66564 SIOUXCY3 345 1			
			143	357.47	143	357.47		143	357.48		66306 SIOUXC2T 345 66565 SIOUXCY4 230 1			
			96	239.91							66507 FTTHOMP4 230 66509 FTRANDL4 230 1	SW899		
			96.1	240.27							66509 FTRANDL4 230 66565 SIOUXCY4 230 1	SW747		
			95.7	239.34					66523 SIOUXFL4 230 66578 PAHOJA 4 230 1					
66303 SIOUXC1T 345	66565 SIOUXCY4 230 1	250	90.7	226.82	90.7	226.82	1.63	90.7	226.82	1.98	SYSTEM INTACT			
			95.4	238.5							34007 LAKEFLD5 161 34137 TRIBOJI5 161 1			
			95.3	238.15							60108 WILMART3 345 60365 FIELD_S3 345 1			
			103	257.59	103	257.59		103	257.6		60127 SPLT RK4 230 60129 SPLT RK7 115 7			
			103	257.59	103	257.59		103	257.6		60127 SPLT RK4 230 66523 SIOUXFL4 230 1			
			95.3	238.19							60331 LKFLDXL3 345 60364 FIELD_N3 345 1			
			143	357.47	143	357.47		143	357.48		66306 SIOUXC2T 345 66564 SIOUXCY3 345 1			
			143	357.47	143	357.47		143	357.48		66306 SIOUXC2T 345 66565 SIOUXCY4 230 1			
			96	239.91							66507 FTTHOMP4 230 66509 FTRANDL4 230 1	SW899		
			96.1	240.27							66509 FTRANDL4 230 66565 SIOUXCY4 230 1	SW747		
			95.7	239.34					66523 SIOUXFL4 230 66578 PAHOJA 4 230 1					
66306 SIOUXC2T 345	66564 SIOUXCY3 345 1	250	89.3	223.22	89.3	223.22	1.63	89.3	223.22	1.98	SYSTEM INTACT			

CIRCUIT FROM:		CIRCUIT TO:		CKT	RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY			SWITCH	
#	NAME	#	NAME		MVA	%	MVA	%	MVA	MVA	%	MVA	MVA	FROM	TO	CKT		
						101.4	253.5	101.4	253.5		101.4	253.51		60127	SPLT RK4 230	60129	SPLT RK7 115 7	
						101.4	253.5	101.4	253.5		101.4	253.51		60127	SPLT RK4 230	66523	SIOUXFL4 230 1	
						142.1	355.13	142.1	355.13		142.1	355.14		66303	SIOUXC1T 345	66564	SIOUXCY3 345 1	
						142.1	355.13	142.1	355.13		142.1	355.14		66303	SIOUXC1T 345	66565	SIOUXCY4 230 1	
66306	SIOUXC2T 345	66565	SIOUXCY4 230 1		250	89.3	223.22	89.3	223.22		89.3	223.22		SYSTEM INTACT				
						101.4	253.5	101.4	253.5		101.4	253.51		60127	SPLT RK4 230	60129	SPLT RK7 115 7	
						101.4	253.5	101.4	253.5		101.4	253.51		60127	SPLT RK4 230	66523	SIOUXFL4 230 1	
						142.1	355.13	142.1	355.13		142.1	355.14		66303	SIOUXC1T 345	66564	SIOUXCY3 345 1	
						142.1	355.13	142.1	355.13		142.1	355.14		66303	SIOUXC1T 345	66565	SIOUXCY4 230 1	
66403	DAWSONC4 230	66411	MI CTYE4 230 1		200	69.3	138.68							SYSTEM INTACT				
						97.1	194.17							66425	BELFELD4 230	67915	RHAME 4 230 1	
66426	BISMAR4 230	66427	BISMAR7 115 1		100	81.3	81.33	81.2	81.2		81.5	81.5	0.28	SYSTEM INTACT				
						131.3	131.29	131.1	131.08		131.6	131.57		66426	BISMAR4 230	66427	BISMAR7 115 2	
						96.2	96.2							67307	BISM NW7 115	67343	HESKETT7 115 1	
						99.6	99.57							67342	HESKETT4 230	67343	HESKETT7 115 1	
66426	BISMAR4 230	66427	BISMAR7 115 2		100	72	72	71.9	71.89		72.2	72.16	0.27	SYSTEM INTACT				
						126.3	126.29	126.1	126.09		126.6	126.56		66426	BISMAR4 230	66427	BISMAR7 115 1	
66432	EDGELEY7 115	66433	EDGELEY869.0 1		20	56.9	11.39	56.9	11.38		57.1	11.41		SYSTEM INTACT				
						104.4	20.88	104.4	20.88		104.5	20.91		66432	EDGELEY7 115	66445	JAMESTN7 115 1	
66435	FARGO 4 230	66440	FARGOM14 230 1		100	67.6	67.65	67.6	67.65		67.7	67.67		SYSTEM INTACT				
						104.5	104.48	104.5	104.48		104.5	104.51		66435	FARGO 4 230	66446	FARGOM24 230 1	
66435	FARGO 4 230	66446	FARGOM24 230 1		100	62.7	62.71	62.7	62.71		62.7	62.72		SYSTEM INTACT				
						102.4	102.35	102.4	102.35		102.4	102.37		66435	FARGO 4 230	66440	FARGOM14 230 1	
66436	FARGO 7 115	66440	FARGOM14 230 1		100	74.4	74.39	74.4	74.39		74.4	74.39		SYSTEM INTACT				
						100	100.05	100	100.03		100	100.04		60133	SHEYNNE4 230	66435	FARGO 4 230 1	
						99.1	99.05							60136	MAPLE R7 115	66783	MAPLE RT 115 1	
						109.3	109.29	109.3	109.29		109.3	109.3		66435	FARGO 4 230	66446	FARGOM24 230 1	
						110.5	110.46	110.5	110.46		110.5	110.46		66436	FARGO 7 115	66446	FARGOM24 230 1	
						99.1	99.05							66783	MAPLE RT 115	67000	MAPLE R869.0 1	
66436	FARGO 7 115	66446	FARGOM24 230 1		100	63.7	63.69	63.7	63.69		63.7	63.7		SYSTEM INTACT				
						103	102.97	103	102.98		103	102.99		66435	FARGO 4 230	66440	FARGOM14 230 1	
						109.5	109.52	109.5	109.52		109.5	109.53		66436	FARGO 7 115	66440	FARGOM14 230 1	
66502	BERSFRD7 115	66517	MANNING7 115 1		80	51.6	41.27	51.6	41.27		51.6	41.27		SYSTEM INTACT				
						106.4	85.11	106.4	85.11		106.4	85.11		66511	GAVINS 7 115	66532	YANKTON7 115 1	
						106.4	85.11	106.4	85.11		106.4	85.11		66532	YANKTON7 115	67121	SPIRITM7 115 1	
66515	HURON 7 115	67404	HURONWP7 115 1		120	48.6	58.37	48.6	58.37		48.6	58.37		SYSTEM INTACT				
						106.8	128.19	106.8	128.19		106.8	128.2		66515	HURON 7 115	67411	BTAP WP7 115 1	
66515	HURON 7 115	67411	BTAP WP7 115 1		120	71.8	86.16	71.8	86.16		71.8	86.16		SYSTEM INTACT				
						96.8	116.14							66512	GROTON 7 115	67402	ABDNSBT7 115 1	
						117	140.41	117	140.41		117	140.42		66515	HURON 7 115	67404	HURONWP7 115 1	
67101	ANTELOP3 345	67183	CHAR.CK3 345 1		538	71.2	383.21	70.6	379.74		70.9	381.52		SYSTEM INTACT				
						104.8	563.9	104.5	562.14		104.6	562.62		67105	LELANDO3 345	67202	LELND2TY 345 1	SW3
67265	LTLMISS4 230	67915	RHAME 4 230 1		216.1	84.1	181.78	84.1	181.68		84.5	182.69		SYSTEM INTACT				
						110.4	238.6	110.4	238.5		111	239.89	1.29	66403	DAWSONC4 230	66413	MEDORA 4 230 1	
						116.1	250.86	116	250.75		116.1	250.91		66413	MEDORA 4 230	66425	BELFELD4 230 1	
67307	BISM NW7 115	67343	HESKETT7 115 1		119.5	49	58.55	49.1	58.72		49.2	58.77		SYSTEM INTACT				
						116.7	139.45	116.7	139.45		116.9	139.73	0.28	66427	BISMAR7 115	67329	ESTBMRK7 115 1	
67316	COYOTE 3 345	67318	COYOTE 7 115 1		168	41.8	70.18							SYSTEM INTACT				
						96.6	162.25							63369	JAMESTN3 345	66791	CENTER 3 345 1	
67335	GLENHAM7 115	67338	GLENHAM4 230 1		25	41.5	10.38	41.5	10.38		41.5	10.38		SYSTEM INTACT				

Output File:

kc0-sp16-line

kcg-sp16-line

kcl-sp16-line

CIRCUIT FROM:		CIRCUIT TO:		CKT	RATEA	OVRLD	CURRENT	OVRLD	CURRENT	Diff	OVRLD	CURRENT	Diff	CONTINGENCY	SWITCH
#	NAME	#	NAME		MVA	%	MVA	%	MVA	MVA	%	MVA	MVA	FROM TO CKT	
						110.3	27.57	110.3	27.57		110.3	27.58		67335 GLENHAM7 115 67338 GLENHAM4 230 2	
67342	HESKETT4 230	67343	HESKETT7 115 1		100	39.4	39.38	39.3	39.3		39.4	39.43		SYSTEM INTACT	
						156.5	156.54	156.3	156.29		156.7	156.73		66427 BISMAR7 115 67329 ESTBMR7 115 1	
67343	HESKETT7 115	67367	MANDANW7 115 1		119.5	48.1	57.47							SYSTEM INTACT	
						96.4	115.17							66427 BISMAR7 115 67329 ESTBMR7 115 1	
						96.8	115.66							67309 BISEXP 7 115 67329 ESTBMR7 115 1	

***** BASE CASE:
KC0-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT
ND=318,MH=1283,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166

***** CHNG CASE:
KCG-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT
ND=319,MH=1283,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166

***** BASE TRANSACTION AMOUNT FOR DF CALCULATION: 7.500

PTFD INTERFACES

64786 COOPER 3 - 59393 ST JOE 3 BASE: 95.0 CHNG: 95.0 DIFF: 0.0%
64786 COOPER 3 - 96039 7FAIRPT BASE: 105.8 CHNG: 105.8 DIFF: 0.0%

SUBTOTALS FOR: COOPER_S BASE: 200.7 CHNG: 200.8 DIFF: 0.0%
DIFF: 0.0 DF: 0.5%

65351 S3451 3 - 65354 S3454 3 BASE: 101.3 CHNG: 101.3 DIFF: 0.0%
65351 S3451 3 - 65359 S3459 3 BASE: 143.9 CHNG: 144.0 DIFF: 0.0%
65451 S1251 5 - 65497 S1297 5 BASE: 70.6 CHNG: 70.6 DIFF: 0.0%

SUBTOTALS FOR: FTCAL_S BASE: 315.9 CHNG: 315.9 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%

64832 GENTLMN4 - 64909 N.PLATT4 BASE: 153.8 CHNG: 153.8 DIFF: 0.0%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 154.3 CHNG: 154.3 DIFF: 0.0%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 157.7 CHNG: 157.7 DIFF: 0.0%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 272.6 CHNG: 272.6 DIFF: 0.0%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 328.5 CHNG: 328.6 DIFF: 0.0%
64831 GENTLMN3 - 64943 REDWILO3 BASE: 299.7 CHNG: 299.7 DIFF: 0.0%

SUBTOTALS FOR: GGS BASE: 1366.6 CHNG: 1366.6 DIFF: 0.0%
DIFF: 0.1 DF: 0.9%

64933 PAULINE3 - 64902 MOORE 3 BASE: 63.6 CHNG: 63.6 DIFF: 0.0%
64839 GR ISLD4 - 64780 COLMB.W4 BASE: 115.7 CHNG: 115.7 DIFF: 0.0%
66571 GR ISLD3 - 64896 MCCOOL 3 BASE: 137.6 CHNG: 137.6 DIFF: 0.0%

SUBTOTALS FOR: GRIS_LNC BASE: 316.8 CHNG: 316.9 DIFF: 0.0%
DIFF: 0.0 DF: 0.4%

64095 MNTZUMA3 - 64064 BONDRNT3 BASE: 137.8 CHNG: 137.8 DIFF: 0.0%

SUBTOTALS FOR: MNTZUMA_W BASE: 137.8 CHNG: 137.8 DIFF: 0.0%
DIFF: 0.0 DF: -0.2%

67105 LELANDO3 - 66506 FTTHOMP3 BASE: 153.7 CHNG: 153.5 DIFF: -0.1%
67105 LELANDO3 - 67160 GROTON 3 BASE: 201.7 CHNG: 201.6 DIFF: -0.1%
67101 ANTELOP3 - 67120 BRDLAND3 BASE: 187.0 CHNG: 187.0 DIFF: 0.0%
63314 BIGSTON4 - 66503 BLAIR 4 BASE: 127.8 CHNG: 127.8 DIFF: 0.0%
66554 MORRIS 4 - 66550 GRANITF4 BASE: -48.5 CHNG: -48.5 DIFF: -0.1%
63336 AUDUBON4 - 63053 HUBBARD4 BASE: 60.3 CHNG: 60.4 DIFF: 0.0%
66521 SULLYBT4 - 66519 OAHE 4 BASE: -55.4 CHNG: -55.4 DIFF: 0.0%
63052 INMAN 4 - 61611 WINGRIV4 BASE: 54.6 CHNG: 54.6 DIFF: 0.0%
66470 BISON 4 - 66497 MAURINE4 BASE: -63.0 CHNG: -62.8 DIFF: -0.4%
66716 LAPORTE7 - 61638 AKELEY7 BASE: -22.5 CHNG: -22.5 DIFF: 0.0%
63222 ALEXAND7 - 60144 DGLASCO7 BASE: 18.8 CHNG: 18.8 DIFF: 0.0%
67327 ELLENDL7 - 67401 ABDNJCT7 BASE: 13.6 CHNG: 13.7 DIFF: 0.2%

66432	EDGELEY7	-	66534	ORDWAY 7	BASE:	-7.6	CHNG:	-7.6	DIFF:	-0.2%
66438	FORMAN 7	-	66522	SUMMIT-7	BASE:	-11.9	CHNG:	-11.9	DIFF:	-0.1%
63211	CANBY 7	-	66551	GRANITF7	BASE:	8.5	CHNG:	8.5	DIFF:	0.0%
62006	KERKHO 7	-	62005	KERKHOT7	BASE:	-7.5	CHNG:	-7.5	DIFF:	-0.1%
66752	DRAYTON4	-	67557	LETELER4	BASE:	-265.9	CHNG:	-265.9	DIFF:	0.0%
63379	RUGBY 4	-	67523	GLENBOR4	BASE:	25.4	CHNG:	25.4	DIFF:	0.0%

SUBTOTALS FOR: NDEX					BASE:	368.9	CHNG:	369.0	DIFF:	0.0%
							DIFF:	0.1	DF:	1.6%

36382	QUAD ;	-	64405	SUB 91 3	BASE:	559.9	CHNG:	559.9	DIFF:	0.0%
64400	MECCORD3	-	64403	E MOLIN3	BASE:	395.7	CHNG:	395.7	DIFF:	0.0%

SUBTOTALS FOR: QUADCITY_W					BASE:	955.6	CHNG:	955.5	DIFF:	0.0%
							DIFF:	0.0	DF:	-0.2%

64831	GENTLMN3	-	64943	REDWILO3	BASE:	299.7	CHNG:	299.7	DIFF:	0.0%
-------	----------	---	-------	----------	-------	-------	-------	-------	-------	------

SUBTOTALS FOR: WNE_WKS					BASE:	299.7	CHNG:	299.7	DIFF:	0.0%
							DIFF:	0.0	DF:	0.3%

61615	ARROWHD4	-	39448	AWHD PST	BASE:	300.6	CHNG:	300.6	DIFF:	0.0%
60186	AS KING3	-	60304	EAU CL 3	BASE:	457.8	CHNG:	457.8	DIFF:	0.0%

SUBTOTALS FOR: MWEX					BASE:	758.4	CHNG:	758.4	DIFF:	0.0%
							DIFF:	0.0	DF:	0.5%

66756	SQBUTTE4	-	63049	STANTON4	BASE:	-64.9	CHNG:	-64.1	DIFF:	-1.3%
66756	SQBUTTE4	-	66751	CENTER 4	BASE:	-57.0	CHNG:	-57.0	DIFF:	0.0%
66756	SQBUTTE4	-	66791	CENTER 3	BASE:	70.6	CHNG:	69.8	DIFF:	-1.1%
63041	COAL CR4	-	63042	COAL TP4	BASE:	-9.7	CHNG:	-9.7	DIFF:	0.0%
63041	COAL CR4	-	63049	STANTON4	BASE:	-116.0	CHNG:	-116.0	DIFF:	0.0%
63041	COAL CR4	-	63381	UNDERWD4	BASE:	123.7	CHNG:	123.6	DIFF:	0.0%

SUBTOTALS FOR: NDDC					BASE:	-53.4	CHNG:	-53.4	DIFF:	0.0%
							DIFF:	0.0	DF:	0.0%

60175	ROSEAU 4	-	67576	RICHER 4	BASE:	-68.9	CHNG:	-68.9	DIFF:	0.0%
60173	ROSEAU2	-	67564	DORSEY 2	BASE:	-961.0	CHNG:	-961.0	DIFF:	0.0%
66752	DRAYTON4	-	67557	LETELER4	BASE:	-260.4	CHNG:	-260.4	DIFF:	0.0%
63379	RUGBY 4	-	67523	GLENBOR4	BASE:	25.5	CHNG:	25.5	DIFF:	0.0%

SUBTOTALS FOR: MHEX_N+					BASE:	-1264.8	CHNG:	-1264.9	DIFF:	0.0%
							DIFF:	0.0	DF:	-0.4%

67576	RICHER 4	-	60175	ROSEAU 4	BASE:	69.5	CHNG:	69.5	DIFF:	0.0%
67564	DORSEY 2	-	60173	ROSEAU2	BASE:	973.0	CHNG:	973.0	DIFF:	0.0%
67557	LETELER4	-	66752	DRAYTON4	BASE:	265.9	CHNG:	265.9	DIFF:	0.0%
67523	GLENBOR4	-	63379	RUGBY 4	BASE:	-25.4	CHNG:	-25.4	DIFF:	0.0%

SUBTOTALS FOR: MHEX_S+					BASE:	1283.0	CHNG:	1283.1	DIFF:	0.0%
							DIFF:	0.0	DF:	0.4%

60105	PR ISLD3	-	61950	BYRON 3	BASE:	94.2	CHNG:	94.2	DIFF:	0.0%
-------	----------	---	-------	---------	-------	------	-------	------	-------	------

SUBTOTALS FOR: PR_ISL_BYRON					BASE:	94.2	CHNG:	94.2	DIFF:	0.0%
							DIFF:	0.0	DF:	0.4%

66756	SQBUTTE4	-	63049	STANTON4	BASE:	-64.9	CHNG:	-64.1	DIFF:	-1.3%
-------	----------	---	-------	----------	-------	-------	-------	-------	-------	-------

66756	SQBUTTE4	-	66751	CENTER	4	BASE:	-57.0	CHNG:	-57.0	DIFF:	0.0%
66756	SQBUTTE4	-	66791	CENTER	3	BASE:	70.6	CHNG:	69.8	DIFF:	-1.1%
SUBTOTALS FOR: Y2DC						BASE:	-51.3	CHNG:	-51.3	DIFF:	0.0%
								DIFF:	0.0	DF:	0.0%

61615	ARROWHD4	-	39448	AWHD	PST	BASE:	300.6	CHNG:	300.6	DIFF:	0.0%
SUBTOTALS FOR: AHD_GPK						BASE:	300.6	CHNG:	300.6	DIFF:	0.0%
								DIFF:	0.0	DF:	0.2%

60304	EAU CL 3	-	39244	ARP	345	BASE:	228.9	CHNG:	228.9	DIFF:	0.0%
SUBTOTALS FOR: EAUARP_XCEL						BASE:	228.9	CHNG:	228.9	DIFF:	0.0%
								DIFF:	0.0	DF:	0.3%

60101	FORBES 2	-	60198	CHIS-N	2	BASE:	798.6	CHNG:	798.6	DIFF:	0.0%
SUBTOTALS FOR: FORCHS_PTDF						BASE:	798.6	CHNG:	798.6	DIFF:	0.0%
								DIFF:	0.0	DF:	0.5%

37632	LEECO;BP	-	36362	NELSO;	B	BASE:	403.0	CHNG:	403.0	DIFF:	0.0%
SUBTOTALS FOR: LEECONELS						BASE:	403.0	CHNG:	403.0	DIFF:	0.0%
								DIFF:	0.0	DF:	-0.1%

68613	AUBURN4	-	67525	RESTON	4	BASE:	-10.3	CHNG:	-10.3	DIFF:	-0.2%
68615	YORKTON4	-	67514	ROBLIN	4	BASE:	-116.8	CHNG:	-116.8	DIFF:	0.0%
68630	EBCAMPB4	-	67515	RALL	4	BASE:	-89.8	CHNG:	-89.8	DIFF:	0.0%
SUBTOTALS FOR: MH_SPC_E+						BASE:	-216.9	CHNG:	-216.9	DIFF:	0.0%
								DIFF:	0.0	DF:	0.5%

67525	RESTON 4	-	68613	AUBURN4		BASE:	10.4	CHNG:	10.4	DIFF:	-0.2%
67514	ROBLIN 4	-	68615	YORKTON4		BASE:	118.2	CHNG:	118.2	DIFF:	0.0%
67515	RALL 4	-	68630	EBCAMPB4		BASE:	92.0	CHNG:	92.0	DIFF:	0.0%
SUBTOTALS FOR: MH_SPC_W+						BASE:	220.6	CHNG:	220.5	DIFF:	0.0%
								DIFF:	0.0	DF:	-0.5%

OTDF INTERFACES

64095	MNTZUMA3	-	64064	BONDRNT3		*CONTINGENCY*	BASE:	0.0	CHNG:	0.0		

34191	REASNOR5	-	64062	DMOINES5			BASE:	13.7	CHNG:	13.7	DIFF:	0.0%
SUBTOTALS FOR: REASNOR_DPS						BASE:	13.7	CHNG:	13.7	DIFF:	0.0%	
								DIFF:	0.0	DF:	-0.1%	

65351	S3451	3	-	63875	RAUN	3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	

65426	S1226	5	-	64987	TEKAMAH5		BASE:	35.4	CHNG:	35.4	DIFF:	0.0%
SUBTOTALS FOR: S1226TEKAMAH						BASE:	35.4	CHNG:	35.4	DIFF:	0.0%	
								DIFF:	0.0	DF:	-0.1%	

```

65351 S3451 3 - 63875 RAUN 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
57374 SPHILPJ3 - 57438 WMCIPHER3 BASE: -18.5 CHNG: -18.5 DIFF: 0.0%
SUBTOTALS FOR: S1226TEKAMAH BASE: -18.5 CHNG: -18.5 DIFF: 0.0%
DIFF: 0.0 DF: 0.0%
*****
64350 HILLS 3 - 64095 MNTZUMA3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64351 HILLS 5 - 34084 PARNEL 5 BASE: 48.1 CHNG: 48.1 DIFF: 0.0%
SUBTOTALS FOR: HILLPAHILMON BASE: 48.1 CHNG: 48.1 DIFF: 0.0%
DIFF: 0.0 DF: 0.0%
*****

***** ERROR: OTDF # 5 BASE CONTINGENT LINE NOT FOUND OR ALREADY STATUS=0 64403 TO 64680 CKT
***** ERROR: OTDF # 5 CHNG CONTINGENT LINE NOT FOUND OR ALREADY STATUS=0 64403 TO 64680 CKT
64400 MECCORD3 - 64403 E MOLIN3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64403 E MOLIN3 - 64680 ***** *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64403 E MOLIN3 - 64418 E MOLINE *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
36382 QUAD ; - 64405 SUB 91 3 BASE: 798.8 CHNG: 798.8 DIFF: 0.0%
SUBTOTALS FOR: QUAD91CORD39 BASE: 798.8 CHNG: 798.8 DIFF: 0.0%
DIFF: 0.0 DF: -0.2%
*****

36382 QUAD ; - 64405 SUB 91 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64405 SUB 91 3 - 64438 SB 91 5 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64400 MECCORD3 - 64403 E MOLIN3 BASE: 731.6 CHNG: 731.6 DIFF: 0.0%
SUBTOTALS FOR: CORD39QUAD91 BASE: 731.6 CHNG: 731.6 DIFF: 0.0%
DIFF: 0.0 DF: -0.2%
*****

64402 LOUISA 3 - 64408 SUB T 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64408 SUB T 3 - 64350 HILLS 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64406 SUB 92 3 - 64350 HILLS 3 BASE: 544.8 CHNG: 544.8 DIFF: 0.0%
SUBTOTALS FOR: 92HILLOUHILL BASE: 544.8 CHNG: 544.8 DIFF: 0.0%
DIFF: 0.0 DF: -0.3%
*****

63875 RAUN 3 - 66564 SIOUXCY3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63889 PLYMOTH5 - 66566 SIOUXCY5 BASE: -51.3 CHNG: -51.3 DIFF: 0.0%
SUBTOTALS FOR: PLYMSIOUXCTY BASE: -51.3 CHNG: -51.3 DIFF: 0.0%
DIFF: 0.0 DF: -0.1%
*****

36382 QUAD ; - 36368 H471 ; *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34045 ALBANY 6 - 36773 GARDE; BASE: 42.8 CHNG: 42.8 DIFF: 0.0%
SUBTOTALS FOR: ALBGARQUAST BASE: 42.8 CHNG: 42.8 DIFF: 0.0%
DIFF: 0.0 DF: 0.0%
*****

34093 ARNOLD 3 - 34018 HAZLTON3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34091 ARNOLD 5 - 34089 VINTON 5 BASE: 127.6 CHNG: 127.6 DIFF: 0.0%
SUBTOTALS FOR: ARNVINARNHAZ BASE: 127.6 CHNG: 127.6 DIFF: 0.0%

```

				DIFF:	0.0	DF:	-0.1%

36280	BYRON; B	- 36288	CHERR; B	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

36281	BYRON; R	- 36289	CHERR; R		BASE:	1362.4	CHNG: 1362.4 DIFF: 0.0%
SUBTOTALS FOR: BYCHEBYCHE					BASE:	1362.4	CHNG: 1362.4 DIFF: 0.0%
					DIFF:	0.0	DF: 0.1%

36382	QUAD ;	- 34036	ROCK CK3	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

64425	DAVNPR5	- 34909	E CAL T5		BASE:	202.9	CHNG: 202.9 DIFF: 0.0%
SUBTOTALS FOR: DAVCALQUARCK					BASE:	202.9	CHNG: 202.9 DIFF: 0.0%
					DIFF:	0.0	DF: 0.0%

64352	TIFFIN 3	- 34093	ARNOLD 3	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

64350	HILLS 3	- 34110	HILLSIE5		BASE:	115.1	CHNG: 115.1 DIFF: 0.0%
SUBTOTALS FOR: HLSXFMTIFARN					BASE:	115.1	CHNG: 115.1 DIFF: 0.0%
					DIFF:	0.0	DF: -0.1%

57981	LACYGNE7	- 57968	STILWEL7	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

57981	LACYGNE7	- 57965	W.GRDNR7		BASE:	1041.2	CHNG: 1041.2 DIFF: 0.0%
SUBTOTALS FOR: LACWGRLACSTI					BASE:	1041.2	CHNG: 1041.2 DIFF: 0.0%
					DIFF:	0.0	DF: -0.2%

36310	ELECT; B	- 36362	NELSO; B	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

37632	LEECO;BP	- 36280	BYRON; B		BASE:	542.6	CHNG: 542.6 DIFF: 0.0%
SUBTOTALS FOR: LEEBYREJNEL					BASE:	542.6	CHNG: 542.6 DIFF: 0.0%
					DIFF:	0.0	DF: 0.2%

60331	LKFLDXL3	- 34006	LAKEFLD3	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

34007	LAKEFLD5	- 34008	FOX LK 5		BASE:	46.4	CHNG: 46.3 DIFF: 0.0%
SUBTOTALS FOR: LKFFOXLKGWLM					BASE:	46.4	CHNG: 46.3 DIFF: 0.0%
					DIFF:	0.0	DF: 0.0%

36407	WEMPL; R	- 39058	PAD 345	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

34028	LORE 5	- 34033	TRK RIV5		BASE:	82.1	CHNG: 82.1 DIFF: 0.0%
SUBTOTALS FOR: LORTRKWEMPAD					BASE:	82.1	CHNG: 82.1 DIFF: 0.0%
					DIFF:	0.0	DF: 0.0%

39058	PAD 345	- 36407	WEMPL; R	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0
36407	WEMPL; R	- 36406	WEMPL; B	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0
36406	WEMPL; B	- 39119	ROE 345	*CONTINGENCY*	BASE:	0.0	CHNG: 0.0

39058	PAD 345	- 39059	PAD 138		BASE:	0.0	CHNG: 0.0 DIFF: -763.4%
SUBTOTALS FOR: PADXFMPADROE					BASE:	0.0	CHNG: 0.0 DIFF: -763.4%
					DIFF:	0.0	DF: 0.0%

```

*****
64095 MNTZUMA3 - 64064 BONDRNT3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34185 POWESHK5 - 34191 REASNOR5 BASE: 61.2 CHNG: 61.2 DIFF: 0.0%
SUBTOTALS FOR: POWREAMTZBON BASE: 61.2 CHNG: 61.2 DIFF: 0.0%
DIFF: 0.0 DF: -0.1%
*****

36382 QUAD ; - 64405 SUB 91 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34029 SALEM 3 - 34030 SALEM N5 BASE: 299.7 CHNG: 299.7 DIFF: 0.0%
SUBTOTALS FOR: SALXFMQUADAV BASE: 299.7 CHNG: 299.7 DIFF: 0.0%
DIFF: 0.0 DF: -0.1%
*****

36407 WEMPL; R - 39058 PAD 345 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34029 SALEM 3 - 34030 SALEM N5 BASE: 268.1 CHNG: 268.1 DIFF: 0.0%
SUBTOTALS FOR: SALXFMWEMPAD BASE: 268.1 CHNG: 268.1 DIFF: 0.0%
DIFF: 0.0 DF: -0.1%
*****

63875 RAUN 3 - 34006 LAKEFLD3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
66563 SPENCER5 - 34137 TRIBOJI5 BASE: -79.8 CHNG: -79.8 DIFF: 0.0%
SUBTOTALS FOR: SPETRILAKRAU BASE: -79.8 CHNG: -79.8 DIFF: 0.0%
DIFF: 0.0 DF: -0.1%
*****

56873 SUMMIT 6 - 56872 EMCIPHER6 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
57374 SPHILPJ3 - 57438 WMCIPHER3 BASE: -4.9 CHNG: -4.9 DIFF: 0.0%
57374 SPHILPJ3 - 57438 WMCIPHER3 BASE: -5.3 CHNG: -5.3 DIFF: 0.0%
SUBTOTALS FOR: SPHWMCSUMEMC BASE: -10.3 CHNG: -10.3 DIFF: 0.0%
DIFF: 0.0 DF: 0.0%
*****

63041 COAL CR4 - 63042 COAL TP4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63044 MCHENRY4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63041 COAL CR4 - 63049 STANTON4 BASE: -174.5 CHNG: -174.5 DIFF: 0.0%
SUBTOTALS FOR: CC-STN BASE: -174.5 CHNG: -174.5 DIFF: 0.0%
DIFF: 0.0 DF: 0.5%
*****

63041 COAL CR4 - 63042 COAL TP4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63044 MCHENRY4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63049 STANTON4 - 63041 COAL CR4 BASE: 175.3 CHNG: 175.2 DIFF: 0.0%
SUBTOTALS FOR: STN-CC BASE: 175.3 CHNG: 175.2 DIFF: 0.0%
DIFF: 0.0 DF: -0.5%
*****

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63041 COAL CR4 - 63042 COAL TP4 BASE: -118.6 CHNG: -118.5 DIFF: 0.0%

```

SUBTOTALS FOR: CC-CCT		BASE:	-118.6	CHNG:	-118.5	DIFF:	0.0%
				DIFF:	0.0	DF:	0.3%

63041	COAL CR4 - 63049 STANTON4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	

63042	COAL TP4 - 63041 COAL CR4		BASE:	118.7	CHNG:	118.7	DIFF: 0.0%
SUBTOTALS FOR: CCT-CC		BASE:	118.7	CHNG:	118.7	DIFF:	0.0%
				DIFF:	0.0	DF:	-0.3%

63041	COAL CR4 - 63049 STANTON4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	

63042	COAL TP4 - 63049 STANTON4		BASE:	-239.1	CHNG:	-239.0	DIFF: 0.0%
SUBTOTALS FOR: CCTP-STN		BASE:	-239.1	CHNG:	-239.0	DIFF:	0.0%
				DIFF:	0.1	DF:	0.8%

63041	COAL CR4 - 63049 STANTON4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	

63049	STANTON4 - 63042 COAL TP4		BASE:	240.2	CHNG:	240.2	DIFF: 0.0%
SUBTOTALS FOR: STN-CCT		BASE:	240.2	CHNG:	240.2	DIFF:	0.0%
				DIFF:	-0.1	DF:	-0.8%

***** BASE CASE:
KC0-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT
ND=318,MH=1283,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166

***** CHNG CASE:
KCL-SP08AA.SAV;SUMMER;PK LD;SYSTEM INTACT
ND=318,MH=1282,MW=758,OHMH=0,OHMP=150,EWTW=-119,BD=166

***** BASE TRANSACTION AMOUNT FOR DF CALCULATION: 7.500

PTDF INTERFACES

64786 COOPER 3 - 59393 ST JOE 3 BASE: 95.0 CHNG: 94.9 DIFF: -0.1%
64786 COOPER 3 - 96039 7FAIRPT BASE: 105.8 CHNG: 105.7 DIFF: 0.0%

SUBTOTALS FOR: COOPER_S BASE: 200.7 CHNG: 200.6 DIFF: -0.1%
DIFF: -0.1 DF: -1.5%

65351 S3451 3 - 65354 S3454 3 BASE: 101.3 CHNG: 101.3 DIFF: 0.0%
65351 S3451 3 - 65359 S3459 3 BASE: 143.9 CHNG: 143.9 DIFF: 0.0%
65451 S1251 5 - 65497 S1297 5 BASE: 70.6 CHNG: 70.6 DIFF: 0.0%

SUBTOTALS FOR: FTCAL_S BASE: 315.9 CHNG: 315.8 DIFF: 0.0%
DIFF: 0.0 DF: -0.6%

64832 GENTLMN4 - 64909 N.PLATT4 BASE: 153.8 CHNG: 153.8 DIFF: 0.0%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 154.3 CHNG: 154.3 DIFF: 0.0%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 157.7 CHNG: 157.7 DIFF: 0.0%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 272.6 CHNG: 272.5 DIFF: 0.0%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 328.5 CHNG: 328.5 DIFF: 0.0%
64831 GENTLMN3 - 64943 REDWILO3 BASE: 299.7 CHNG: 299.6 DIFF: 0.0%

SUBTOTALS FOR: GGS BASE: 1366.6 CHNG: 1366.4 DIFF: 0.0%
DIFF: -0.1 DF: -1.7%

64933 PAULINE3 - 64902 MOORE 3 BASE: 63.6 CHNG: 63.6 DIFF: -0.1%
64839 GR ISLD4 - 64780 COLMB.W4 BASE: 115.7 CHNG: 115.6 DIFF: 0.0%
66571 GR ISLD3 - 64896 MCCOOL 3 BASE: 137.6 CHNG: 137.5 DIFF: 0.0%

SUBTOTALS FOR: GRIS_LNC BASE: 316.8 CHNG: 316.7 DIFF: 0.0%
DIFF: -0.1 DF: -1.3%

64095 MNTZUMA3 - 64064 BONDRNT3 BASE: 137.8 CHNG: 137.9 DIFF: 0.0%

SUBTOTALS FOR: MNTZUMA_W BASE: 137.8 CHNG: 137.9 DIFF: 0.0%
DIFF: 0.1 DF: 0.7%

67105 LELANDO3 - 66506 FTTHOMP3 BASE: 153.7 CHNG: 153.9 DIFF: 0.1%
67105 LELANDO3 - 67160 GROTON 3 BASE: 201.7 CHNG: 201.9 DIFF: 0.1%
67101 ANTELOP3 - 67120 BRDLAND3 BASE: 187.0 CHNG: 187.3 DIFF: 0.1%
63314 BIGSTON4 - 66503 BLAIR 4 BASE: 127.8 CHNG: 127.7 DIFF: 0.0%
66554 MORRIS 4 - 66550 GRANITF4 BASE: -48.5 CHNG: -48.5 DIFF: 0.1%
63336 AUDUBON4 - 63053 HUBBARD4 BASE: 60.3 CHNG: 60.3 DIFF: 0.0%
66521 SULLYBT4 - 66519 OAHE 4 BASE: -55.4 CHNG: -55.7 DIFF: 0.4%
63052 INMAN 4 - 61611 WINGRIV4 BASE: 54.6 CHNG: 54.6 DIFF: 0.0%
66470 BISON 4 - 66497 MAURINE4 BASE: -63.0 CHNG: -63.5 DIFF: 0.7%
66716 LAPORTE7 - 61638 AKELEY7 BASE: -22.5 CHNG: -22.6 DIFF: 0.1%
63222 ALEXAND7 - 60144 DGLASCO7 BASE: 18.8 CHNG: 18.8 DIFF: 0.0%
67327 ELLENDL7 - 67401 ABDNJCT7 BASE: 13.6 CHNG: 13.6 DIFF: -0.2%

66432	EDGELEY7	-	66534	ORDWAY 7	BASE:	-7.6	CHNG:	-7.7	DIFF:	0.6%
66438	FORMAN 7	-	66522	SUMMIT-7	BASE:	-11.9	CHNG:	-12.0	DIFF:	0.2%
63211	CANBY 7	-	66551	GRANITF7	BASE:	8.5	CHNG:	8.5	DIFF:	-0.1%
62006	KERKHO 7	-	62005	KERKHOT7	BASE:	-7.5	CHNG:	-7.5	DIFF:	0.1%
66752	DRAYTON4	-	67557	LETELER4	BASE:	-265.9	CHNG:	-265.9	DIFF:	0.0%
63379	RUGBY 4	-	67523	GLENBOR4	BASE:	25.4	CHNG:	25.3	DIFF:	-0.3%

SUBTOTALS FOR: NDEX					BASE:	368.9	CHNG:	368.5	DIFF:	-0.1%
							DIFF:	-0.4	DF:	-5.3%

36382	QUAD ;	-	64405	SUB 91 3	BASE:	559.9	CHNG:	559.9	DIFF:	0.0%
64400	MECCORD3	-	64403	E MOLIN3	BASE:	395.7	CHNG:	395.7	DIFF:	0.0%

SUBTOTALS FOR: QUADCITY_W					BASE:	955.6	CHNG:	955.6	DIFF:	0.0%
							DIFF:	0.1	DF:	0.7%

64831	GENTLMN3	-	64943	REDWILO3	BASE:	299.7	CHNG:	299.6	DIFF:	0.0%
-------	----------	---	-------	----------	-------	-------	-------	-------	-------	------

SUBTOTALS FOR: WNE_WKS					BASE:	299.7	CHNG:	299.6	DIFF:	0.0%
							DIFF:	0.0	DF:	-0.7%

61615	ARROWHD4	-	39448	AWHD PST	BASE:	300.6	CHNG:	300.6	DIFF:	0.0%
60186	AS KING3	-	60304	EAU CL 3	BASE:	457.8	CHNG:	457.7	DIFF:	0.0%

SUBTOTALS FOR: MWEX					BASE:	758.4	CHNG:	758.3	DIFF:	0.0%
							DIFF:	-0.1	DF:	-1.2%

66756	SQBUTTE4	-	63049	STANTON4	BASE:	-64.9	CHNG:	-64.6	DIFF:	-0.5%
66756	SQBUTTE4	-	66751	CENTER 4	BASE:	-57.0	CHNG:	-56.8	DIFF:	-0.4%
66756	SQBUTTE4	-	66791	CENTER 3	BASE:	70.6	CHNG:	70.1	DIFF:	-0.8%
63041	COAL CR4	-	63042	COAL TP4	BASE:	-9.7	CHNG:	-9.7	DIFF:	-0.3%
63041	COAL CR4	-	63049	STANTON4	BASE:	-116.0	CHNG:	-116.3	DIFF:	0.2%
63041	COAL CR4	-	63381	UNDERWD4	BASE:	123.7	CHNG:	123.9	DIFF:	0.2%

SUBTOTALS FOR: NDDC					BASE:	-53.4	CHNG:	-53.4	DIFF:	0.0%
							DIFF:	0.0	DF:	0.0%

60175	ROSEAU 4	-	67576	RICHER 4	BASE:	-68.9	CHNG:	-68.9	DIFF:	0.0%
60173	ROSEAU2	-	67564	DORSEY 2	BASE:	-961.0	CHNG:	-960.8	DIFF:	0.0%
66752	DRAYTON4	-	67557	LETELER4	BASE:	-260.4	CHNG:	-260.5	DIFF:	0.0%
63379	RUGBY 4	-	67523	GLENBOR4	BASE:	25.5	CHNG:	25.4	DIFF:	-0.3%

SUBTOTALS FOR: MHEX_N+					BASE:	-1264.8	CHNG:	-1264.8	DIFF:	0.0%
							DIFF:	0.1	DF:	0.9%

67576	RICHER 4	-	60175	ROSEAU 4	BASE:	69.5	CHNG:	69.5	DIFF:	0.0%
67564	DORSEY 2	-	60173	ROSEAU2	BASE:	973.0	CHNG:	972.8	DIFF:	0.0%
67557	LETELER4	-	66752	DRAYTON4	BASE:	265.9	CHNG:	265.9	DIFF:	0.0%
67523	GLENBOR4	-	63379	RUGBY 4	BASE:	-25.4	CHNG:	-25.3	DIFF:	-0.3%

SUBTOTALS FOR: MHEX_S+					BASE:	1283.0	CHNG:	1283.0	DIFF:	0.0%
							DIFF:	-0.1	DF:	-0.9%

60105	PR ISLD3	-	61950	BYRON 3	BASE:	94.2	CHNG:	94.1	DIFF:	-0.1%
-------	----------	---	-------	---------	-------	------	-------	------	-------	-------

SUBTOTALS FOR: PR_ISL_BYRON					BASE:	94.2	CHNG:	94.1	DIFF:	-0.1%
							DIFF:	-0.1	DF:	-0.9%

66756	SQBUTTE4	-	63049	STANTON4	BASE:	-64.9	CHNG:	-64.6	DIFF:	-0.5%
-------	----------	---	-------	----------	-------	-------	-------	-------	-------	-------

66756	SQBUTTE4	-	66751	CENTER	4	BASE:	-57.0	CHNG:	-56.8	DIFF:	-0.4%
66756	SQBUTTE4	-	66791	CENTER	3	BASE:	70.6	CHNG:	70.1	DIFF:	-0.8%
SUBTOTALS FOR: Y2DC						BASE:	-51.3	CHNG:	-51.3	DIFF:	0.0%
								DIFF:	0.0	DF:	0.0%

61615	ARROWHD4	-	39448	AWHD	PST	BASE:	300.6	CHNG:	300.6	DIFF:	0.0%
SUBTOTALS FOR: AHD_GPK						BASE:	300.6	CHNG:	300.6	DIFF:	0.0%
								DIFF:	0.0	DF:	-0.5%

60304	EAU CL 3	-	39244	ARP	345	BASE:	228.9	CHNG:	228.9	DIFF:	0.0%
SUBTOTALS FOR: EAUARP_XCEL						BASE:	228.9	CHNG:	228.9	DIFF:	0.0%
								DIFF:	-0.1	DF:	-0.7%

60101	FORBES 2	-	60198	CHIS-N	2	BASE:	798.6	CHNG:	798.5	DIFF:	0.0%
SUBTOTALS FOR: FORCHS_PTDF						BASE:	798.6	CHNG:	798.5	DIFF:	0.0%
								DIFF:	-0.1	DF:	-1.6%

37632	LEECO;BP	-	36362	NELSO;	B	BASE:	403.0	CHNG:	403.1	DIFF:	0.0%
SUBTOTALS FOR: LEECONELS						BASE:	403.0	CHNG:	403.1	DIFF:	0.0%
								DIFF:	0.0	DF:	0.2%

68613	AUBURN4	-	67525	RESTON	4	BASE:	-10.3	CHNG:	-10.4	DIFF:	0.4%
68615	YORKTON4	-	67514	ROBLIN	4	BASE:	-116.8	CHNG:	-116.8	DIFF:	0.0%
68630	EBCAMPB4	-	67515	RALL	4	BASE:	-89.8	CHNG:	-89.8	DIFF:	0.0%
SUBTOTALS FOR: MH_SPC_E+						BASE:	-216.9	CHNG:	-217.0	DIFF:	0.0%
								DIFF:	-0.1	DF:	-1.1%

67525	RESTON 4	-	68613	AUBURN4		BASE:	10.4	CHNG:	10.4	DIFF:	0.4%
67514	ROBLIN 4	-	68615	YORKTON4		BASE:	118.2	CHNG:	118.2	DIFF:	0.0%
67515	RALL 4	-	68630	EBCAMPB4		BASE:	92.0	CHNG:	92.0	DIFF:	0.0%
SUBTOTALS FOR: MH_SPC_W+						BASE:	220.6	CHNG:	220.7	DIFF:	0.0%
								DIFF:	0.1	DF:	1.1%

OTDF INTERFACES

64095	MNTZUMA3	-	64064	BONDRNT3		*CONTINGENCY*	BASE:	0.0	CHNG:	0.0		

34191	REASNOR5	-	64062	DMOINES5			BASE:	13.7	CHNG:	13.7	DIFF:	0.1%
SUBTOTALS FOR: REASNOR_DPS						BASE:	13.7	CHNG:	13.7	DIFF:	0.1%	
								DIFF:	0.0	DF:	0.2%	

65351	S3451	3	-	63875	RAUN	3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	

65426	S1226	5	-	64987	TEKAMAH5		BASE:	35.4	CHNG:	35.5	DIFF:	0.0%
SUBTOTALS FOR: S1226TEKAMAH						BASE:	35.4	CHNG:	35.5	DIFF:	0.0%	
								DIFF:	0.0	DF:	0.2%	

```

65351 S3451 3 - 63875 RAUN 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
57374 SPHILPJ3 - 57438 WMCpher3 BASE: -18.5 CHNG: -18.5 DIFF: 0.0%
SUBTOTALS FOR: S1226TEKAMAH BASE: -18.5 CHNG: -18.5 DIFF: 0.0%
DIFF: 0.0 DF: 0.0%
*****
64350 HILLS 3 - 64095 MNTZUMA3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64351 HILLS 5 - 34084 PARNEL 5 BASE: 48.1 CHNG: 48.1 DIFF: 0.0%
SUBTOTALS FOR: HILLPAHILMON BASE: 48.1 CHNG: 48.1 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%
*****

***** ERROR: OTDF # 5 BASE CONTINGENT LINE NOT FOUND OR ALREADY STATUS=0 64403 TO 64680 CKT
***** ERROR: OTDF # 5 CHNG CONTINGENT LINE NOT FOUND OR ALREADY STATUS=0 64403 TO 64680 CKT
64400 MECCORD3 - 64403 E MOLIN3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64403 E MOLIN3 - 64680 ***** *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64403 E MOLIN3 - 64418 E MOLINE *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
36382 QUAD ; - 64405 SUB 91 3 BASE: 798.8 CHNG: 798.9 DIFF: 0.0%
SUBTOTALS FOR: QUAD91CORD39 BASE: 798.8 CHNG: 798.9 DIFF: 0.0%
DIFF: 0.0 DF: 0.6%
*****

36382 QUAD ; - 64405 SUB 91 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64405 SUB 91 3 - 64438 SB 91 5 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64400 MECCORD3 - 64403 E MOLIN3 BASE: 731.6 CHNG: 731.7 DIFF: 0.0%
SUBTOTALS FOR: CORD39QUAD91 BASE: 731.6 CHNG: 731.7 DIFF: 0.0%
DIFF: 0.0 DF: 0.5%
*****

64402 LOUISA 3 - 64408 SUB T 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
64408 SUB T 3 - 64350 HILLS 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64406 SUB 92 3 - 64350 HILLS 3 BASE: 544.8 CHNG: 544.9 DIFF: 0.0%
SUBTOTALS FOR: 92HILLOUHILL BASE: 544.8 CHNG: 544.9 DIFF: 0.0%
DIFF: 0.1 DF: 0.9%
*****

63875 RAUN 3 - 66564 SIOUXCY3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63889 PLYMOTH5 - 66566 SIOUXCY5 BASE: -51.3 CHNG: -51.3 DIFF: -0.1%
SUBTOTALS FOR: PLYMSIOUXCTY BASE: -51.3 CHNG: -51.3 DIFF: -0.1%
DIFF: 0.0 DF: 0.3%
*****

36382 QUAD ; - 36368 H471 ; *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34045 ALBANY 6 - 36773 GARDE; BASE: 42.8 CHNG: 42.8 DIFF: 0.0%
SUBTOTALS FOR: ALBGARQUAST BASE: 42.8 CHNG: 42.8 DIFF: 0.0%
DIFF: 0.0 DF: -0.1%
*****

34093 ARNOLD 3 - 34018 HAZLTON3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34091 ARNOLD 5 - 34089 VINTON 5 BASE: 127.6 CHNG: 127.6 DIFF: 0.0%
SUBTOTALS FOR: ARNVINARNHAZ BASE: 127.6 CHNG: 127.6 DIFF: 0.0%

```

		DIFF:	0.0	DF:	0.3%

36280	BYRON; B - 36288 CHERR; B	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

36281	BYRON; R - 36289 CHERR; R		BASE: 1362.4	CHNG: 1362.3	DIFF: 0.0%
SUBTOTALS FOR: BYCHEBYCHE					
			BASE: 1362.4	CHNG: 1362.3	DIFF: 0.0%
			DIFF: 0.0	DF: -0.2%	

36382	QUAD ; - 34036 ROCK CK3	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

64425	DAVNPR5 - 34909 E CAL T5		BASE: 202.9	CHNG: 202.9	DIFF: 0.0%
SUBTOTALS FOR: DAVCALQUARCK					
			BASE: 202.9	CHNG: 202.9	DIFF: 0.0%
			DIFF: 0.0	DF: 0.1%	

64352	TIFFIN 3 - 34093 ARNOLD 3	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

64350	HILLS 3 - 34110 HILLSIE5		BASE: 115.1	CHNG: 115.2	DIFF: 0.0%
SUBTOTALS FOR: HLSXFMTIFARN					
			BASE: 115.1	CHNG: 115.2	DIFF: 0.0%
			DIFF: 0.0	DF: 0.2%	

57981	LACYGNE7 - 57968 STILWEL7	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

57981	LACYGNE7 - 57965 W.GRDNR7		BASE: 1041.2	CHNG: 1041.3	DIFF: 0.0%
SUBTOTALS FOR: LACWGRLACSTI					
			BASE: 1041.2	CHNG: 1041.3	DIFF: 0.0%
			DIFF: 0.0	DF: 0.5%	

36310	ELECT; B - 36362 NELSO; B	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

37632	LEECO;BP - 36280 BYRON; B		BASE: 542.6	CHNG: 542.5	DIFF: 0.0%
SUBTOTALS FOR: LEEBYREJNEL					
			BASE: 542.6	CHNG: 542.5	DIFF: 0.0%
			DIFF: 0.0	DF: -0.5%	

60331	LKFLDXL3 - 34006 LAKEFLD3	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

34007	LAKEFLD5 - 34008 FOX LK 5		BASE: 46.4	CHNG: 46.4	DIFF: 0.0%
SUBTOTALS FOR: LKFFOXLKGWLM					
			BASE: 46.4	CHNG: 46.4	DIFF: 0.0%
			DIFF: 0.0	DF: 0.0%	

36407	WEMPL; R - 39058 PAD 345	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

34028	LORE 5 - 34033 TRK RIV5		BASE: 82.1	CHNG: 82.1	DIFF: 0.0%
SUBTOTALS FOR: LORTRKWEMPAD					
			BASE: 82.1	CHNG: 82.1	DIFF: 0.0%
			DIFF: 0.0	DF: 0.1%	

39058	PAD 345 - 36407 WEMPL; R	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0
36407	WEMPL; R - 36406 WEMPL; B	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0
36406	WEMPL; B - 39119 ROE 345	*CONTINGENCY*	BASE: 0.0	CHNG:	0.0

39058	PAD 345 - 39059 PAD 138		BASE: 0.0	CHNG: 0.0	DIFF: 382.3%
SUBTOTALS FOR: PADXFMPADROE					
			BASE: 0.0	CHNG: 0.0	DIFF: 382.3%
			DIFF: 0.0	DF: 0.0%	

```

*****
64095 MNTZUMA3 - 64064 BONDRNT3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34185 POWESHK5 - 34191 REASNOR5 BASE: 61.2 CHNG: 61.2 DIFF: 0.0%
SUBTOTALS FOR: POWREAMTZBON BASE: 61.2 CHNG: 61.2 DIFF: 0.0%
DIFF: 0.0 DF: 0.3%
*****

36382 QUAD ; - 64405 SUB 91 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34029 SALEM 3 - 34030 SALEM N5 BASE: 299.7 CHNG: 299.7 DIFF: 0.0%
SUBTOTALS FOR: SALXFMQUADAV BASE: 299.7 CHNG: 299.7 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%
*****

36407 WEMPL; R - 39058 PAD 345 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34029 SALEM 3 - 34030 SALEM N5 BASE: 268.1 CHNG: 268.2 DIFF: 0.0%
SUBTOTALS FOR: SALXFMWEMPAD BASE: 268.1 CHNG: 268.2 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%
*****

63875 RAUN 3 - 34006 LAKEFLD3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
66563 SPENCER5 - 34137 TRIBOJI5 BASE: -79.8 CHNG: -79.8 DIFF: 0.0%
SUBTOTALS FOR: SPETRILAKRAU BASE: -79.8 CHNG: -79.8 DIFF: 0.0%
DIFF: 0.0 DF: 0.1%
*****

56873 SUMMIT 6 - 56872 EMCIPHER6 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
57374 SPHILPJ3 - 57438 WMCIPHER3 BASE: -4.9 CHNG: -4.9 DIFF: -0.1%
57374 SPHILPJ3 - 57438 WMCIPHER3 BASE: -5.3 CHNG: -5.3 DIFF: -0.1%
SUBTOTALS FOR: SPHWMCSUMEMC BASE: -10.3 CHNG: -10.3 DIFF: -0.1%
DIFF: 0.0 DF: 0.1%
*****

63041 COAL CR4 - 63042 COAL TP4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63044 MCHENRY4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63041 COAL CR4 - 63049 STANTON4 BASE: -174.5 CHNG: -174.9 DIFF: 0.2%
SUBTOTALS FOR: CC-STN BASE: -174.5 CHNG: -174.9 DIFF: 0.2%
DIFF: -0.4 DF: -4.7%
*****

63041 COAL CR4 - 63042 COAL TP4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
63042 COAL TP4 - 63044 MCHENRY4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63049 STANTON4 - 63041 COAL CR4 BASE: 175.3 CHNG: 175.6 DIFF: 0.2%
SUBTOTALS FOR: STN-CC BASE: 175.3 CHNG: 175.6 DIFF: 0.2%
DIFF: 0.4 DF: 4.8%
*****

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
63041 COAL CR4 - 63042 COAL TP4 BASE: -118.6 CHNG: -118.8 DIFF: 0.2%

```


***** BASE CASE:
KC0-SP16AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
ND=171,MH=1067,MW=448,OHMH=0,OHMP=150,EWTW=-120,BD=165

***** ERROR: GETTING LINE FLOW 60105 TO 61950 CKT 1 IERR= 2

***** CHNG CASE:
KCG-SP16AA.SAV;SUMMER;PK LD;SYSTEM INTACT :
ND=9,MH=1056,MW=390,OHMH=3,OHMP=152,EWTW=-116,BD=169

***** BASE TRANSACTION AMOUNT FOR DF CALCULATION: 7.500

PTDF INTERFACES

64786 COOPER 3 - 59393 ST JOE 3 BASE: 25.9 CHNG: 20.8 DIFF: -20.0%
64786 COOPER 3 - 96039 7FAIRPT BASE: 57.9 CHNG: 54.4 DIFF: -6.1%

SUBTOTALS FOR: COOPER_S(MAP BASE: 83.8 CHNG: 75.1 DIFF: -10.4%
DIFF: -8.7 DF: -116.2%

65351 S3451 3 - 65354 S3454 3 BASE: 31.3 CHNG: 37.1 DIFF: 18.7%
65351 S3451 3 - 65359 S3459 3 BASE: 21.6 CHNG: 27.2 DIFF: 26.0%
65451 S1251 5 - 65497 S1297 5 BASE: 32.7 CHNG: 59.9 DIFF: 83.0%

SUBTOTALS FOR: FTICAL_S(MAPP BASE: 85.6 CHNG: 124.3 DIFF: 45.1%
DIFF: 38.6 DF: 515.2%

64832 GENTLMN4 - 64909 N.PLATT4 BASE: 176.1 CHNG: 167.0 DIFF: -5.2%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 176.7 CHNG: 167.6 DIFF: -5.1%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 180.6 CHNG: 171.2 DIFF: -5.2%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 253.6 CHNG: 251.9 DIFF: -0.7%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 305.9 CHNG: 303.9 DIFF: -0.7%
64831 GENTLMN3 - 64943 REDWILO3 BASE: 253.6 CHNG: 247.1 DIFF: -2.6%

SUBTOTALS FOR: GGS(MAPP) BASE: 1346.5 CHNG: 1308.6 DIFF: -2.8%
DIFF: -37.8 DF: -504.3%

64933 PAULINE3 - 64902 MOORE 3 BASE: 33.7 CHNG: -11.2 DIFF: -133.3%
64839 GR ISLD4 - 64780 COLMB.W4 BASE: 82.9 CHNG: 143.1 DIFF: 72.6%
66571 GR ISLD3 - 64896 MCCOOL 3 BASE: 82.7 CHNG: -27.1 DIFF: -132.8%

SUBTOTALS FOR: GRIS_LNC(MAP) BASE: 199.4 CHNG: 104.8 DIFF: -47.5%
DIFF: -94.7 DF: -999.0%

64095 MNTZUMA3 - 64064 BONDRNT3 BASE: 144.9 CHNG: 138.6 DIFF: -4.3%

SUBTOTALS FOR: MNTZUMA_W(MA) BASE: 144.9 CHNG: 138.6 DIFF: -4.3%
DIFF: -6.2 DF: -83.2%

67105 LELANDO3 - 66506 FTTHOMP3 BASE: 109.9 CHNG: 86.8 DIFF: -21.1%
67105 LELANDO3 - 67160 GROTON 3 BASE: 141.6 CHNG: 145.2 DIFF: 2.5%
67101 ANTELOP3 - 67120 BRDLAND3 BASE: 140.7 CHNG: 138.6 DIFF: -1.5%
63314 BIGSTON4 - 66503 BLAIR 4 BASE: 89.0 CHNG: 40.9 DIFF: -54.0%
66554 MORRIS 4 - 66550 GRANITF4 BASE: -11.1 CHNG: -33.8 DIFF: 204.4%
63336 AUDUBON4 - 63053 HUBBARD4 BASE: 64.4 CHNG: 56.0 DIFF: -13.1%
66521 SULLYBT4 - 66519 OAHE 4 BASE: -86.9 CHNG: -99.4 DIFF: 14.5%
63052 INMAN 4 - 61611 WINGRIV4 BASE: 86.8 CHNG: 52.3 DIFF: -39.7%
66470 BISON 4 - 66497 MAURINE4 BASE: -24.0 CHNG: -46.2 DIFF: 92.4%
66716 LAPORTE7 - 61638 AKELEY7 BASE: 4.8 CHNG: 10.0 DIFF: 106.4%
63222 ALEXAND7 - 60144 DGLASCO7 BASE: 70.4 CHNG: 19.7 DIFF: -72.0%

67327	ELLENDL7	-	67401	ABDNJCT7	BASE:	8.4	CHNG:	12.8	DIFF:	51.6%
66432	EDGELEY7	-	66534	ORDWAY 7	BASE:	-19.4	CHNG:	-15.7	DIFF:	-19.0%
66438	FORMAN 7	-	66522	SUMMIT-7	BASE:	-24.6	CHNG:	-27.7	DIFF:	12.7%
62006	KERKHO 7	-	62005	KERKHOT7	BASE:	0.6	CHNG:	-6.9	DIFF:	-999.0%
66752	DRAYTON4	-	67557	LETELER4	BASE:	-201.3	CHNG:	-219.3	DIFF:	8.9%
63379	RUGBY 4	-	67523	GLENBOR4	BASE:	32.0	CHNG:	26.0	DIFF:	-18.8%
63400	*****	-	60507	*****	BASE:	206.5	CHNG:	0.0	DIFF:	-100.0%
67010	*****	-	60389	*****	BASE:	-122.3	CHNG:	0.0	DIFF:	-100.0%
67452	ALEXSS 7	-	99950	CARPNT4	BASE:	20.1	CHNG:	0.0	DIFF:	-100.0%
63212	BURR 7	-	63210	TORONTO7	BASE:	-56.2	CHNG:	2.6	DIFF:	-104.6%
63345	WILTON 4	-	61626	BOSWELL4	BASE:	-180.3	CHNG:	-200.4	DIFF:	11.1%

SUBTOTALS FOR: NDEX (MAPP)					BASE:	249.1	CHNG:	-58.6	DIFF:	-123.5%
								DIFF:	-307.8	DF: -999.0%

36382	QUAD ;	-	64405	SUB 91 3	BASE:	601.6	CHNG:	657.3	DIFF:	9.3%
64400	MECCORD3	-	64403	E MOLIN3	BASE:	436.1	CHNG:	476.5	DIFF:	9.2%

SUBTOTALS FOR: QUADCITY_W(M					BASE:	1037.7	CHNG:	1133.7	DIFF:	9.3%
								DIFF:	96.0	DF: 999.0%

64831	GENTLMN3	-	64943	REDWILO3	BASE:	253.6	CHNG:	247.1	DIFF:	-2.6%
-------	----------	---	-------	----------	-------	-------	-------	-------	-------	-------

SUBTOTALS FOR: WNE_WKS (MAPP					BASE:	253.6	CHNG:	247.1	DIFF:	-2.6%
								DIFF:	-6.5	DF: -86.9%

61615	ARROWHD4	-	39448	AWHD PST	BASE:	156.7	CHNG:	125.6	DIFF:	-19.9%
60186	AS KING3	-	60304	EAU CL 3	BASE:	291.5	CHNG:	265.2	DIFF:	-9.0%

SUBTOTALS FOR: MWEX (NEW)					BASE:	448.2	CHNG:	390.8	DIFF:	-12.8%
								DIFF:	-57.4	DF: -765.1%

66756	SQBUTTE4	-	63049	STANTON4	BASE:	23.3	CHNG:	3.1	DIFF:	-86.9%
66756	SQBUTTE4	-	66751	CENTER 4	BASE:	-54.0	CHNG:	-39.3	DIFF:	-27.2%
66756	SQBUTTE4	-	66791	CENTER 3	BASE:	34.0	CHNG:	39.6	DIFF:	16.2%
63041	COAL CR4	-	63042	COAL TP4	BASE:	-9.1	CHNG:	-8.1	DIFF:	-10.9%
63041	COAL CR4	-	63049	STANTON4	BASE:	-139.3	CHNG:	-128.6	DIFF:	-7.7%
63041	COAL CR4	-	63381	UNDERWD4	BASE:	146.1	CHNG:	134.4	DIFF:	-8.0%

SUBTOTALS FOR: NDDC (INFO)					BASE:	1.0	CHNG:	1.0	DIFF:	0.4%
								DIFF:	0.0	DF: 0.0%

60175	ROSEAU 4	-	67576	RICHER 4	BASE:	-50.7	CHNG:	-50.9	DIFF:	0.5%
67621	RIEL 2	-	67564	DORSEY 2	BASE:	-554.1	CHNG:	-545.1	DIFF:	-1.6%
66752	DRAYTON4	-	67557	LETELER4	BASE:	-198.3	CHNG:	-215.6	DIFF:	8.8%
63379	RUGBY 4	-	67523	GLENBOR4	BASE:	32.3	CHNG:	26.2	DIFF:	-18.9%

SUBTOTALS FOR: MHEX_N+ (INFO					BASE:	-770.8	CHNG:	-785.5	DIFF:	1.9%
								DIFF:	-14.7	DF: -195.3%

67576	RICHER 4	-	60175	ROSEAU 4	BASE:	51.0	CHNG:	51.3	DIFF:	0.5%
67564	DORSEY 2	-	67621	RIEL 2	BASE:	555.9	CHNG:	546.5	DIFF:	-1.7%
67557	LETELER4	-	66752	DRAYTON4	BASE:	201.3	CHNG:	219.3	DIFF:	8.9%
67523	GLENBOR4	-	63379	RUGBY 4	BASE:	-32.0	CHNG:	-26.0	DIFF:	-18.8%

SUBTOTALS FOR: MHEX_S+ (INFO					BASE:	776.2	CHNG:	791.0	DIFF:	1.9%
								DIFF:	14.8	DF: 197.6%

60105	PR ISLD3	-	61950	BYRON 3	BASE:	0.0	CHNG:	-83.7	DIFF:	999.0%
-------	----------	---	-------	---------	-------	-----	-------	-------	-------	--------

34093	ARNOLD 3	-	34018	HAZLTON3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
34091	ARNOLD 5	-	34089	VINTON 5		BASE:	125.6	CHNG:	164.1
						DIFF:	38.5	DF:	513.0%
SUBTOTALS FOR: ARNVINARNHAZ						BASE:	125.6	CHNG:	164.1
						DIFF:	38.5	DF:	513.0%

36280	BYRON; B	-	36288	CHERR; B	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
36281	BYRON; R	-	36289	CHERR; R		BASE:	1523.1	CHNG:	1526.5
SUBTOTALS FOR: BYCHEBYCHE						BASE:	1523.1	CHNG:	1526.5
						DIFF:	3.4	DF:	45.2%

36382	QUAD ;	-	34036	ROCK CK3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
64425	DAVNPR5	-	34909	E CAL T5		BASE:	207.9	CHNG:	238.5
SUBTOTALS FOR: DAVCALQUARCK						BASE:	207.9	CHNG:	238.5
						DIFF:	30.6	DF:	408.6%

64352	TIFFIN 3	-	34093	ARNOLD 3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
64350	HILLS 3	-	34110	HILLSIE5		BASE:	102.6	CHNG:	139.1
SUBTOTALS FOR: HLSXFMTIFARN						BASE:	102.6	CHNG:	139.1
						DIFF:	36.4	DF:	486.0%

57981	LACYGNE7	-	57968	STILWEL7	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
57981	LACYGNE7	-	57965	W.GRDNR7		BASE:	1080.7	CHNG:	1090.2
SUBTOTALS FOR: LACWGRLACSTI						BASE:	1080.7	CHNG:	1090.2
						DIFF:	9.5	DF:	126.6%

36310	ELECT; B	-	36362	NELSO; B	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
37632	LEECO;BP	-	36280	BYRON; B		BASE:	1054.6	CHNG:	1088.8
SUBTOTALS FOR: LEEBYREJNEL						BASE:	1054.6	CHNG:	1088.8
						DIFF:	34.2	DF:	456.0%

60331	LKFLDXL3	-	34006	LAKEFLD3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
34007	LAKEFLD5	-	34008	FOX LK 5		BASE:	31.8	CHNG:	43.1
SUBTOTALS FOR: LKFFOXLKGWLM						BASE:	31.8	CHNG:	43.1
						DIFF:	11.3	DF:	150.6%

36407	WEMPL; R	-	39058	PAD 345	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
34028	LORE 5	-	34033	TRK RIV5		BASE:	175.8	CHNG:	146.8
SUBTOTALS FOR: LORTRKWEMPAD						BASE:	175.8	CHNG:	146.8
						DIFF:	-29.0	DF:	-387.2%

39058	PAD 345	-	36407	WEMPL; R	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
36407	WEMPL; R	-	36406	WEMPL; B	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0
36406	WEMPL; B	-	39119	ROE 345	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0

39058 PAD 345	-	39059 PAD 138	BASE:	0.0	CHNG:	0.0	DIFF:	-182.2%
SUBTOTALS FOR: PADXFMPADROE			BASE:	0.0	CHNG:	0.0	DIFF:	-182.2%
					DIFF:	0.0	DF:	0.0%

64095 MNTZUMA3	-	64064 BONDRNT3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
SUBTOTALS FOR: POWREAMTZBON			BASE:	68.3	CHNG:	71.1	DIFF:	4.0%
					DIFF:	2.8	DF:	36.7%

36382 QUAD ;	-	64405 SUB 91 3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
34029 SALEM 3	-	34030 SALEM N5	BASE:	240.5	CHNG:	370.8	DIFF:	54.1%
SUBTOTALS FOR: SALXFMQUADAV			BASE:	240.5	CHNG:	370.8	DIFF:	54.1%
					DIFF:	130.2	DF:	999.0%

36407 WEMPL; R	-	39058 PAD 345	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
34029 SALEM 3	-	34030 SALEM N5	BASE:	219.3	CHNG:	336.9	DIFF:	53.6%
SUBTOTALS FOR: SALXFMWEMPAD			BASE:	219.3	CHNG:	336.9	DIFF:	53.6%
					DIFF:	117.5	DF:	999.0%

63875 RAUN 3	-	34006 LAKEFLD3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
66563 SPENCER5	-	34137 TRIBOJI5	BASE:	-53.7	CHNG:	-36.3	DIFF:	-32.4%
SUBTOTALS FOR: SPETRILAKRAU			BASE:	-53.7	CHNG:	-36.3	DIFF:	-32.4%
					DIFF:	17.4	DF:	232.0%

56873 SUMMIT 6	-	56872 EMCIPHER6	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
57374 SPHILPJ3	-	57438 WMCIPHER3	BASE:	-1.0	CHNG:	0.7	DIFF:	-167.3%
57374 SPHILPJ3	-	57438 WMCIPHER3	BASE:	-0.6	CHNG:	1.3	DIFF:	-304.9%
SUBTOTALS FOR: SPHWMCSUMEMC			BASE:	-1.6	CHNG:	2.0	DIFF:	-222.5%
					DIFF:	3.6	DF:	47.8%

63041 COAL CR4	-	63042 COAL TP4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63049 STANTON4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63044 MCHENRY4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63041 COAL CR4	-	63049 STANTON4	BASE:	-206.4	CHNG:	-191.4	DIFF:	-7.3%
SUBTOTALS FOR: CC-STN			BASE:	-206.4	CHNG:	-191.4	DIFF:	-7.3%
					DIFF:	15.0	DF:	200.2%

63041 COAL CR4	-	63042 COAL TP4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63049 STANTON4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63044 MCHENRY4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63049 STANTON4	-	63041 COAL CR4	BASE:	207.4	CHNG:	192.3	DIFF:	-7.3%
SUBTOTALS FOR: STN-CC			BASE:	207.4	CHNG:	192.3	DIFF:	-7.3%
					DIFF:	-15.2	DF:	-202.2%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63041 COAL CR4 - 63042 COAL TP4 BASE: -139.9 CHNG: -128.9 DIFF: -7.9%

SUBTOTALS FOR: CC-CCT BASE: -139.9 CHNG: -128.9 DIFF: -7.9%
 DIFF: 11.0 DF: 146.9%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63042 COAL TP4 - 63041 COAL CR4 BASE: 140.1 CHNG: 129.0 DIFF: -7.9%

SUBTOTALS FOR: CCT-CC BASE: 140.1 CHNG: 129.0 DIFF: -7.9%
 DIFF: -11.0 DF: -147.2%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63042 COAL TP4 - 63049 STANTON4 BASE: -288.0 CHNG: -266.0 DIFF: -7.6%

SUBTOTALS FOR: CCTP-STN BASE: -288.0 CHNG: -266.0 DIFF: -7.6%
 DIFF: 21.9 DF: 292.6%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63049 STANTON4 - 63042 COAL TP4 BASE: 289.7 CHNG: 267.5 DIFF: -7.7%

SUBTOTALS FOR: STN-CCT BASE: 289.7 CHNG: 267.5 DIFF: -7.7%
 DIFF: -22.2 DF: -296.0%

***** BASE CASE:
KC0-SP16AA.SAV;SUMMER;PK LD;SYSTEM INTACT
ND=171,MH=1067,MW=448,OHMH=0,OHMP=150,EWTW=-120,BD=165

***** ERROR: GETTING LINE FLOW 60105 TO 61950 CKT 1 IERR= 2

***** CHNG CASE:
KCL-SP16AA.SAV;SUMMER;PK LD;SYSTEM INTACT
ND=171,MH=1067,MW=448,OHMH=0,OHMP=150,EWTW=-120,BD=165

***** BASE TRANSACTION AMOUNT FOR DF CALCULATION: 7.500

PTDF INTERFACES

64786 COOPER 3 - 59393 ST JOE 3 BASE: 25.9 CHNG: 25.9 DIFF: -0.2%
64786 COOPER 3 - 96039 7FAIRPT BASE: 57.9 CHNG: 57.9 DIFF: -0.1%

SUBTOTALS FOR: COOPER_S(MAP BASE: 83.8 CHNG: 83.8 DIFF: -0.1%
DIFF: -0.1 DF: -1.0%

65351 S3451 3 - 65354 S3454 3 BASE: 31.3 CHNG: 31.3 DIFF: 0.0%
65351 S3451 3 - 65359 S3459 3 BASE: 21.6 CHNG: 21.6 DIFF: -0.1%
65451 S1251 5 - 65497 S1297 5 BASE: 32.7 CHNG: 32.7 DIFF: 0.0%

SUBTOTALS FOR: FTICAL_S(MAPP BASE: 85.6 CHNG: 85.6 DIFF: 0.0%
DIFF: 0.0 DF: -0.4%

64832 GENTLMN4 - 64909 N.PLATT4 BASE: 176.1 CHNG: 176.1 DIFF: 0.0%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 176.7 CHNG: 176.7 DIFF: 0.0%
64832 GENTLMN4 - 64909 N.PLATT4 BASE: 180.6 CHNG: 180.6 DIFF: 0.0%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 253.6 CHNG: 253.6 DIFF: 0.0%
64831 GENTLMN3 - 64984 SWEET W3 BASE: 305.9 CHNG: 305.9 DIFF: 0.0%
64831 GENTLMN3 - 64943 REDWILO3 BASE: 253.6 CHNG: 253.6 DIFF: 0.0%

SUBTOTALS FOR: GGS(MAPP) BASE: 1346.5 CHNG: 1346.4 DIFF: 0.0%
DIFF: -0.1 DF: -0.8%

64933 PAULINE3 - 64902 MOORE 3 BASE: 33.7 CHNG: 33.7 DIFF: -0.1%
64839 GR ISLD4 - 64780 COLMB.W4 BASE: 82.9 CHNG: 82.9 DIFF: 0.0%
66571 GR ISLD3 - 64896 MCCOOL 3 BASE: 82.7 CHNG: 82.7 DIFF: 0.0%

SUBTOTALS FOR: GRIS_LNC(MAP BASE: 199.4 CHNG: 199.4 DIFF: 0.0%
DIFF: 0.0 DF: -0.6%

64095 MNTZUMA3 - 64064 BONDRNT3 BASE: 144.9 CHNG: 144.9 DIFF: 0.0%

SUBTOTALS FOR: MNTZUMA_W(MA BASE: 144.9 CHNG: 144.9 DIFF: 0.0%
DIFF: 0.0 DF: 0.4%

67105 LELANDO3 - 66506 FTTHOMP3 BASE: 109.9 CHNG: 110.1 DIFF: 0.1%
67105 LELANDO3 - 67160 GROTON 3 BASE: 141.6 CHNG: 141.7 DIFF: 0.1%
67101 ANTELOP3 - 67120 BRDLAND3 BASE: 140.7 CHNG: 140.9 DIFF: 0.1%
63314 BIGSTON4 - 66503 BLAIR 4 BASE: 89.0 CHNG: 88.9 DIFF: 0.0%
66554 MORRIS 4 - 66550 GRANITF4 BASE: -11.1 CHNG: -11.1 DIFF: 0.2%
63336 AUDUBON4 - 63053 HUBBARD4 BASE: 64.4 CHNG: 64.4 DIFF: 0.0%
66521 SULLYBT4 - 66519 OAHE 4 BASE: -86.9 CHNG: -87.1 DIFF: 0.2%
63052 INMAN 4 - 61611 WINGRIV4 BASE: 86.8 CHNG: 86.8 DIFF: 0.0%
66470 BISON 4 - 66497 MAURINE4 BASE: -24.0 CHNG: -24.2 DIFF: 0.8%
66716 LAPORTE7 - 61638 AKELEY7 BASE: 4.8 CHNG: 4.8 DIFF: -0.1%
63222 ALEXAND7 - 60144 DGLASCO7 BASE: 70.4 CHNG: 70.4 DIFF: 0.0%

SUBTOTALS FOR: S1226TEKAMAH BASE: 23.0 CHNG: 23.0 DIFF: 0.0%
DIFF: 0.0 DF: 0.1%

65351 S3451 3 - 63875 RAUN 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

57374 SPHILPJ3 - 57438 WMCIPHER3 BASE: -16.7 CHNG: -16.7 DIFF: 0.0%

SUBTOTALS FOR: S1226TEKAMAH BASE: -16.7 CHNG: -16.7 DIFF: 0.0%
DIFF: 0.0 DF: 0.0%

64350 HILLS 3 - 64095 MNTZUMA3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

64351 HILLS 5 - 34084 PARNEL 5 BASE: 33.8 CHNG: 33.8 DIFF: 0.0%

SUBTOTALS FOR: HILLPAHILMON BASE: 33.8 CHNG: 33.8 DIFF: 0.0%
DIFF: 0.0 DF: 0.1%

***** ERROR: OTDF # 5 BASE CONTINGENT LINE NOT FOUND OR ALREADY STATUS=0 64403 TO 64680 CKT
***** ERROR: OTDF # 5 CHNG CONTINGENT LINE NOT FOUND OR ALREADY STATUS=0 64403 TO 64680 CKT

64400 MECCORD3 - 64403 E MOLIN3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

64403 E MOLIN3 - 64680 ***** *CONTINGENCY* BASE: 0.0 CHNG: 0.0

64403 E MOLIN3 - 64418 E MOLINE *CONTINGENCY* BASE: 0.0 CHNG: 0.0

36382 QUAD ; - 64405 SUB 91 3 BASE: 853.6 CHNG: 853.6 DIFF: 0.0%

SUBTOTALS FOR: QUAD91CORD39 BASE: 853.6 CHNG: 853.6 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%

36382 QUAD ; - 64405 SUB 91 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

64405 SUB 91 3 - 64438 SB 91 5 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

64400 MECCORD3 - 64403 E MOLIN3 BASE: 775.9 CHNG: 775.9 DIFF: 0.0%

SUBTOTALS FOR: CORD39QUAD91 BASE: 775.9 CHNG: 775.9 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%

64402 LOUISA 3 - 64408 SUB T 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

64408 SUB T 3 - 64350 HILLS 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

64406 SUB 92 3 - 64350 HILLS 3 BASE: 557.9 CHNG: 558.0 DIFF: 0.0%

SUBTOTALS FOR: 92HILLOUHILL BASE: 557.9 CHNG: 558.0 DIFF: 0.0%
DIFF: 0.0 DF: 0.5%

63875 RAUN 3 - 66564 SIOUXCY3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

63889 PLYMOTH5 - 66566 SIOUXCY5 BASE: -32.4 CHNG: -32.3 DIFF: 0.0%

SUBTOTALS FOR: PLYMSIOUXCTY BASE: -32.4 CHNG: -32.3 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%

36382 QUAD ; - 36368 H471 ; *CONTINGENCY* BASE: 0.0 CHNG: 0.0

34045 ALBANY 6 - 36773 GARDE; BASE: 26.5 CHNG: 26.5 DIFF: 0.0%

SUBTOTALS FOR: ALBGARQUAST BASE: 26.5 CHNG: 26.5 DIFF: 0.0%
DIFF: 0.0 DF: -0.1%

```

34093 ARNOLD 3 - 34018 HAZLTON3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34091 ARNOLD 5 - 34089 VINTON 5 BASE: 125.6 CHNG: 125.6 DIFF: 0.0%
SUBTOTALS FOR: ARNVINARNHAZ BASE: 125.6 CHNG: 125.6 DIFF: 0.0%
DIFF: 0.0 DF: 0.2%
*****

36280 BYRON; B - 36288 CHERR; B *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
36281 BYRON; R - 36289 CHERR; R BASE: 1523.1 CHNG: 1523.1 DIFF: 0.0%
SUBTOTALS FOR: BYCHEBYCHE BASE: 1523.1 CHNG: 1523.1 DIFF: 0.0%
DIFF: 0.0 DF: -0.2%
*****

36382 QUAD ; - 34036 ROCK CK3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64425 DAVNPRT5 - 34909 E CAL T5 BASE: 207.9 CHNG: 207.9 DIFF: 0.0%
SUBTOTALS FOR: DAVCALQUARCK BASE: 207.9 CHNG: 207.9 DIFF: 0.0%
DIFF: 0.0 DF: 0.1%
*****

64352 TIFFIN 3 - 34093 ARNOLD 3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
64350 HILLS 3 - 34110 HILLSIE5 BASE: 102.6 CHNG: 102.6 DIFF: 0.0%
SUBTOTALS FOR: HLSXFMTIFARN BASE: 102.6 CHNG: 102.6 DIFF: 0.0%
DIFF: 0.0 DF: 0.1%
*****

57981 LACYGNE7 - 57968 STILWEL7 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
57981 LACYGNE7 - 57965 W.GRDNR7 BASE: 1080.7 CHNG: 1080.8 DIFF: 0.0%
SUBTOTALS FOR: LACWGRLACSTI BASE: 1080.7 CHNG: 1080.8 DIFF: 0.0%
DIFF: 0.0 DF: 0.4%
*****

36310 ELECT; B - 36362 NELSO; B *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
37632 LEECO;BP - 36280 BYRON; B BASE: 1054.6 CHNG: 1054.6 DIFF: 0.0%
SUBTOTALS FOR: LEEBYREJNEL BASE: 1054.6 CHNG: 1054.6 DIFF: 0.0%
DIFF: 0.0 DF: -0.3%
*****

60331 LKFLDXL3 - 34006 LAKEFLD3 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34007 LAKEFLD5 - 34008 FOX LK 5 BASE: 31.8 CHNG: 31.8 DIFF: 0.0%
SUBTOTALS FOR: LKFFOXLKGWLM BASE: 31.8 CHNG: 31.8 DIFF: 0.0%
DIFF: 0.0 DF: 0.0%
*****

36407 WEMPL; R - 39058 PAD 345 *CONTINGENCY* BASE: 0.0 CHNG: 0.0
-----
34028 LORE 5 - 34033 TRK RIV5 BASE: 175.8 CHNG: 175.8 DIFF: 0.0%
SUBTOTALS FOR: LORTRKWEMPAD BASE: 175.8 CHNG: 175.8 DIFF: 0.0%
DIFF: 0.0 DF: 0.1%
*****

39058 PAD 345 - 36407 WEMPL; R *CONTINGENCY* BASE: 0.0 CHNG: 0.0
36407 WEMPL; R - 36406 WEMPL; B *CONTINGENCY* BASE: 0.0 CHNG: 0.0
36406 WEMPL; B - 39119 ROE 345 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

```


39058 PAD 345	-	39059 PAD 138	BASE:	0.0	CHNG:	0.0	DIFF:	-104.5%
SUBTOTALS FOR: PADXFMPADROE			BASE:	0.0	CHNG:	0.0	DIFF:	-104.5%
					DIFF:	0.0	DF:	0.0%

64095 MNTZUMA3	-	64064 BONDRNT3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
SUBTOTALS FOR: POWREAMTZBON			BASE:	68.3	CHNG:	68.3	DIFF:	0.0%
					DIFF:	0.0	DF:	0.2%

34185 POWESHK5	-	34191 REASNOR5	BASE:	68.3	CHNG:	68.3	DIFF:	0.0%
SUBTOTALS FOR: SALXFMQUADAV			BASE:	240.5	CHNG:	240.5	DIFF:	0.0%
					DIFF:	0.0	DF:	0.0%

36382 QUAD ;	-	64405 SUB 91 3	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
34029 SALEM 3	-	34030 SALEM N5	BASE:	240.5	CHNG:	240.5	DIFF:	0.0%
SUBTOTALS FOR: SALXFMWEMPAD			BASE:	219.3	CHNG:	219.3	DIFF:	0.0%
					DIFF:	0.0	DF:	0.0%

36407 WEMPL; R	-	39058 PAD 345	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
34029 SALEM 3	-	34030 SALEM N5	BASE:	219.3	CHNG:	219.3	DIFF:	0.0%
SUBTOTALS FOR: SPETRILAKRAU			BASE:	-53.7	CHNG:	-53.7	DIFF:	0.0%
					DIFF:	0.0	DF:	0.1%

56873 SUMMIT 6	-	56872 EMCIPHER6	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
57374 SPHILPJ3	-	57438 WMCIPHER3	BASE:	-1.0	CHNG:	-1.0	DIFF:	-0.2%
57374 SPHILPJ3	-	57438 WMCIPHER3	BASE:	-0.6	CHNG:	-0.6	DIFF:	-0.3%
SUBTOTALS FOR: SPHWMCSUMEMC			BASE:	-1.6	CHNG:	-1.6	DIFF:	-0.2%
					DIFF:	0.0	DF:	0.0%

63041 COAL CR4	-	63042 COAL TP4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63049 STANTON4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63044 MCHENRY4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63041 COAL CR4	-	63049 STANTON4	BASE:	-206.4	CHNG:	-206.7	DIFF:	0.1%
SUBTOTALS FOR: CC-STN			BASE:	-206.4	CHNG:	-206.7	DIFF:	0.1%
					DIFF:	-0.3	DF:	-3.8%

63041 COAL CR4	-	63042 COAL TP4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63049 STANTON4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63042 COAL TP4	-	63044 MCHENRY4	*CONTINGENCY*	BASE:	0.0	CHNG:	0.0	
63049 STANTON4	-	63041 COAL CR4	BASE:	207.4	CHNG:	207.7	DIFF:	0.1%
SUBTOTALS FOR: STN-CC			BASE:	207.4	CHNG:	207.7	DIFF:	0.1%
					DIFF:	0.3	DF:	3.8%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63041 COAL CR4 - 63042 COAL TP4 BASE: -139.9 CHNG: -140.0 DIFF: 0.1%

SUBTOTALS FOR: CC-CCT BASE: -139.9 CHNG: -140.0 DIFF: 0.1%
 DIFF: -0.2 DF: -2.2%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63042 COAL TP4 - 63041 COAL CR4 BASE: 140.1 CHNG: 140.2 DIFF: 0.1%

SUBTOTALS FOR: CCT-CC BASE: 140.1 CHNG: 140.2 DIFF: 0.1%
 DIFF: 0.2 DF: 2.2%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63042 COAL TP4 - 63049 STANTON4 BASE: -288.0 CHNG: -288.4 DIFF: 0.2%

SUBTOTALS FOR: CCTP-STN BASE: -288.0 CHNG: -288.4 DIFF: 0.2%
 DIFF: -0.4 DF: -5.8%

63041 COAL CR4 - 63049 STANTON4 *CONTINGENCY* BASE: 0.0 CHNG: 0.0

 63049 STANTON4 - 63042 COAL TP4 BASE: 289.7 CHNG: 290.2 DIFF: 0.2%

SUBTOTALS FOR: STN-CCT BASE: 289.7 CHNG: 290.2 DIFF: 0.2%
 DIFF: 0.4 DF: 5.9%
