



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

999 18th STREET – SUITE 300
DENVER, COLORADO 80202-2466

Phone 800-227-8917

<http://www.epa.gov/region08>

July 25, 2006

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Honorable Jim McKinney, Mayor
Town of Encampment
POB 5
Encampment, WY 82325

Re: Administrative Order Addendum
Docket No. SDWA-08-2005-0026
PWS ID # 5600060

Dear Mayor McKinney:

This addendum to the Amended Administrative Order issued March 20, 2006 to the Town of Encampment conditionally approves the plan submitted to EPA on January 27, 2006 and revised on April 3, 2006 and June 8, 2006. Two notations on the monitoring plan still need correcting: source water monitoring needs to be added under the Lead/Copper Rule frequency column and in the row titled SWTR the word “end” needs to be changed to “entrance” where disinfectant residual at the distribution system must be 0.2 mg/L or greater.

This letter constitutes the written approval by EPA of the Town’s modifications according to the following schedule (condensed from the plan submitted by the Town). The plan is hereby incorporated into the Amended Administrative Order.

<u>Action</u>	<u>Start Date</u>	<u>Complete Date</u>
Burns & McDonnell Engineering preliminary recommendations		January 2006
Water treatment plant optimization for SWTR compliance (detailed steps involved included in plan)	October 2005	April 26, 2006
Install bag and cartridge filters downstream of existing filters if WTP optimization does not achieve SWTR compliance		July 27, 2006
Implement use of ground water or upgrade/replace existing facility with microfiltration/ultrafiltration membranes to meet future regulations		TBD
Add soda ash for lead exceedance		October 2005
Lower tank operating levels to minimize stagnant water in tanks		January 2006
Initiate quarterly flushing program	February 2006	on-going
If lead continues to exceed action levels, implement use of a corrosion inhibitor. Implement public education	April 15, 2006	as needed

If continued lead exceedance, ID all galvanized piping in Town distribution system and replace with PVC

June 13, 2006

as needed

2

Please contact Kathelene Brainich, Environmental Specialist, at (303) 312-6481 if you have any questions concerning this Addendum.

Sincerely,

SIGNED

Diane L. Sipe, Director
Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice

SIGNED

David J. Janik, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: Burns & McDonnell Engineering (via email)
Wyoming DEQ (via email)
Wyoming DOH (via email)

**THIS DOCUMENT WAS FILED IN THE REGIONAL HEARING CLERK'S OFFICE ON
JULY 25, 2006.**