

# Action-Oriented Benchmarking

*Using CEUS Data to Identify and Prioritize Efficiency Opportunities in California Commercial Buildings*




**Paul A. Mathew, Ph.D.**

Lawrence Berkeley National Laboratory  
Berkeley California


# *Content*

- Introduction to action-oriented benchmarking
- Using the CEUS database for AOB
- AOB Vignettes – schools and offices
- Limits of AOB
- Outlook

# Many Applications for Energy Benchmarking



# Action Oriented Benchmarking



# Action-oriented Benchmarking Complements Other Assessment Tools

## Whole Building Energy Benchmarking




Screen facilities for overall potential

0.5-2 day FTE

Minimal data requirements  
(utility bills, building features)

## Action-oriented Energy Benchmarking



Identifies and prioritizes specific opportunities

2-10 day FTE

Requires sub-metered end-use data ; may require additional data logging

Highly applicable for RCx and CCx

## Investment-Grade Energy Audit



Estimates savings and cost for specific opportunities

10-20 day FTE

Requires detailed data collection, cost estimation, financial analysis

Necessary for retrofits with capital investments

# ***CEUS Database***

- Commercial End Use Survey
  - Territories: PG&E, SCE, SDG&E, SMUD
- Survey of 2800 premises
  - Stratified random sampling based on utility region, climate zone, building type, size (consumption)
  - On-site survey of building characteristics, features
  - Monthly utility bill data
  - Short term data logging and/or interval metering at some sites


## HVAC – Single Zone Systems

tblSINGLZONE

Component ID	ShellCmpID		
Single-Zone Item Ltr	Item	Ltr	Ltr
HVAC Schedule # from Form 10	HVACSchdNum	#	#
<b>Activity Areas/Thermal Zones Served:</b>			
Enter Area ID #(s) or A for all areas	AreaID1-8		
Floor type served ( <i>Circle all that apply</i> )	FlrTyp_B_G_M_T	B G M T	B G M T
If perimeter/core, enter zones served ( <i>Circle all that apply</i> )	ZoneServed_P_C	P C	P C
<b>Distribution System Type:</b>	DistType	SZ PSZ SSZ PTU UV 2PFC 4PFC BR ASHP GSHP WLHP	SZ PSZ SSZ PTU UV 2PFC 4PFC BR ASHP GSHP WLHP
<b>Number of units of this type</b>	DistUnit		
Average Age (years) -7	AvgAge		
Temperature control type:	TempControl	M A T E P	M A T E P
Optimal start/stop? (Y / N)	OptStart	Y N	Y N
<b>Indoor/Supply fan (hp/unit)</b>	SpHPUnit	[Missing FanonBefore FanonAfter (See Form 10c)]	
-- Motor Eff.: (Nom. %) OR (S=Std. H=HiEff P=Premium)	SpMtrEffStr		
-- Quantity of Indoor Fans	SpFanQty		
-- Supply air rate (CFM/fan) -7	SuppCFM		
<b>Return air path:</b> DI=Direct DU=Ducted P=Plenum -7	RtAirPath	DI DU P	DI DU P
<b>% Outside air (minimum)</b>	PctOA		
<b>Economizer Type:</b> Other <u>EconoTypeOther</u>	EconoType	N ( T E ) O	N T E O
<b>Return fan motor (hp/unit)</b>	RtHPUnit		
-- Motor Eff.: (Nom. %) OR (S=Std. H=HiEff P=Premium)	RtMtrEffStr		
-- Quantity of Return Fans	RtFanQty		
-- Return air rate (CFM) -7	RtCFM		
<b>Cooling Equipment Type:</b>	CoolType	N D C E P	N D C E P
-- If cooling type <b>D</b> and not air-cooled: water (W) or evap (E) cooled?	EvapType	W E	W E
-- If cooling type = C, enter chilled water loop # and skip to heating equip.	ChWLNum	CWL #	CWL #
Compressor rating: volts / amps (RLA) / phase ( <i>circle one</i> )	CompVolt	CompAmps	CompPhase
Number of compressors per unit	NumComp	[Purchased Cool & Heat]	
Capacity output (nominal tons per unit)	CoolTons		
Equipment manufacturer/brand:	Make		
-- Model number for unitary or split-system outdoor unit -7	Model		
-- Model number for split-system coil -7	Model_Coil		
Efficiency: <b>EER</b> -7	CoolEER		

# ***CEUS Calibrated Simulations***

- Energy intensities derived from calibrated simulations
  - Simulation models generated from survey data
  - Calibrated with utility data, data logging, interval metering





# ***CEUS End Uses***

- HVAC
  - Space Heating
  - Space Cooling
  - Ventilation
- Lighting
  - Interior Lighting
  - Exterior Lighting
- Other
  - Water Heating
  - Office Equipment
  - Cooking
  - Miscellaneous Equipment
  - Refrigeration
  - Air Compressors
  - Motors (non-HVAC)
  - Process Equipment

# *Using CEUS to Infer Actions*

## *End-Use Benchmarking*

- End-Use Intensity
- End-Use Breakout



*Identify and Prioritize Systems*

## *Building Features*

- Presence/absence
- Component efficiency



*Identify Potential Actions*


## *Correlate Energy Intensities & Building Features*



*Estimate Potential Savings*

# Whole Building Energy Intensity


→ Overall Efficiency Potential



# Whole Building Energy Intensity → Overall Efficiency Potential


## Large Office > Total Source Energy Intensity

244 datapoints




# Whole Building Energy Intensity

## → Overall Efficiency Potential by Vintage




# Whole Building Energy Intensity

## → Overall Efficiency Potential by Climate




# End-Use Energy Intensity

## → System Efficiency Potential



## End-Use Breakout


→ System Efficiency Potential and Prioritization





# End-Use Breakout


→ System Efficiency Potential and Prioritization




# Building Features Benchmarking

→ Identify Potential Actions by Presence/Absence

Large Office > Multi-zone AHU > Temp Control Type  
Aggregated by # Systems; N=178 sites, 1676 records




Schools > Single-zone AHU > Temp Control Type  
Aggregated by # Systems; N=125 sites, 2395 systems




# Building Features Benchmarking

→ Identify Potential Actions by Presence/Absence

Large Office > Ballast Type (% of total kW for 292 sites)




Large Office > Lighting Control (% of total kW for 292 sites)




## Building Features Benchmarking

→ Identify Potential Actions by Presence/Absence

Large Office > Multi-zone AHU > Supply Fan Motor Efficiency  
Aggregated by # Motors; N=176 sites, 1911 motors




Schools > Single-zone AHU > Supply Fan Motor Efficiency  
Aggregated by # Motors; N=123 sites, 2490 motors



## Building Features Benchmarking


→ Identify Potential Actions by System Efficiency



# Correlating Building Features and Energy Intensity

→ Estimate Potential Savings (sort of)

## Large Office > Impact of Lighting Controls and Lighting Power on Lighting Energy Intensity



# *Limits of AOB*


- **NOT “audit in a box”**
  - Only identifies potential actions from predefined list
  - Only crude savings estimates (range)
- Effectiveness is driven by database density
  - Many gaps in CEUS survey data
- Ability to identify actions proportional to user ability to input data

***AOB helps identify potential actions and prioritize areas for more detailed analysis and audits***

# Outlook

- Continued analysis of CEUS
  - Opportunities and limits for AOB
- Development of action inference methodology
  - Mapping list of actions to benchmarking metrics
- Prototype tool currently under development
  - Extensive user surveys to determine features
  - Expected April 2008





Action-oriented energy benchmarking for non-residential buildings

## Benchmark

## Actions

### V Building type

- All
- Small Office
- Large Office**
- Restaurant
- Retail
- Food Store
- Warehouse
- School
- College
- Healthcare
- Lodging
- Public Assembly
- Laboratory
- Cleanroom
- Datacenter
- Mixed Use
- More choices...

- > [Location](#)
- > [Vintage](#)


Or, enter all information in [Project Profile](#)

### To Compare Your Building, Enter:

Conditioned floor area (sf):   
 Total energy use  
 ➤ Electricity (MWh):   
 ➤ Fuel (MBTU):   
 ➤ Other (MBTU):

Energy, or...	Characteristics & Operations, or	Combinations	Indicators	Views
<input checked="" type="checkbox"/> Total energy	<input type="checkbox"/> Lighting		<input checked="" type="checkbox"/> Quantity	<input type="checkbox"/> Summary
<input type="checkbox"/> Electricity	<input type="checkbox"/> Envelope		<input type="checkbox"/> Cost	<input type="checkbox"/> End Uses
<input type="checkbox"/> Peak power	<input type="checkbox"/> Air Handling		<input type="checkbox"/> Emissions	<input checked="" type="checkbox"/> Distribution
<input type="checkbox"/> Fuel	<input type="checkbox"/> Chillers			
<input type="checkbox"/> Thermal	<input type="checkbox"/> Boilers			
	<input type="checkbox"/> Hot Water			
	<input type="checkbox"/> Plug/Process			

**Results:** Typical large office buildings use 191 kBtu/ft<sup>2</sup>-year. Enter your own building information at the left to see how yours compares.



**This View:** California > large office > total energy > all end uses > **quintiles**  
**Project Profile:** Large Office, California, 100ksf, Electric+Fuel

# Questions?



Paul Mathew  
MS 90-3111  
Lawrence Berkeley National Laboratory  
1 Cyclotron Road, Berkeley CA 94720

(510) 486-5116    [pamathew@lbl.gov](mailto:pamathew@lbl.gov)