

78675

FACSIMILE LEAD SHEET

12429-N
#36851

REPORT TRANSPORTING: RSPA-00-6973-3

00 MAY -2 11:12:54

Pages: Lead + 21

Date 4/14/00

Sensitive: Yes No



The Boeing Company
P.O. Box 21233
Kennedy Space Center, FL 32815

To:	<u>CHERYL FREEMAN</u>	Phone No.	<u>202 366-6808</u>	Fax No.	<u>202 366-3753</u>
From:	<u>FRED LONG</u>	Phone No.	<u>321 867-5634</u>	Fax No.	<u>321 867-6580</u>

Remarks...

CHERYL:
 HERE IS THE DATA CONCERNING THE
 PRESSURIZATION OF THE PFE.
 IF YOU HAVE ANY ADDITIONAL QUESTIONS
 PLEASE FEEL FREE TO CALL

THANKS

FRED
2

FRED LONG

321-867-5634



Consolidated Laboratories, Inc.

732 Arrow Grand Circle
Covina, California 91722
(818) 915-8991

REPORT NO. 6608 # 36851
PAGE 132 *Aditt'l Info.*
919165

LAB DATA SHEET

Part No. 84482 S/N 001 Sample 1 Job 6608
Description Portable Fire Extinguisher Co. Arde
Page 2.0

TEST:	THERMAL CYCLE	Start	To Cont.	Cptd
To Spec:	QA 10060, Paras. 5.13 & 5.14	Date <u>5-12-96</u>		<u>5-16-96</u>
		Test By <u>[Signature]</u>		<u>[Signature]</u>
		Photo <u>[check]</u>		

Photo Req'd. YES

CAUTION: Use clean nylon, polyvinyl or cotton gloves in handling the test unit. Protect the unit by placing it, in a polyethylene bag, in its Arde supplied crate when not in use.

- Fill the specimen with gas and pressurize per Arde procedure ME 10009, except only 5.5 to 5.6 lb of CO₂. Install the pressurized test sample in a temperature chamber with the nozzle unattached at ambient conditions. Connect a thermocouple to the unit at the point which has the longest thermal lag in order to determine unit temperature stabilization. Record the temperature and pressure of the unit below and on the Arde Data Sheet.

Pressure?? 660 PSIG Temperature?? 63°F

- Decrease the chamber temperature to 20°F. Monitor the unit temperature and, after unit temperature stabilization, maintain the chamber at temperature for a period of 1 hour, minimum.
- At the end of the 1 hour hold, record the temperature and pressure of the unit below and on the Arde Data Sheet. Then connect the nozzle assembly to the PF2 port, pull the pin while pressing the button and squeeze the trigger to discharge the CO₂ until the tank is empty.

Pressure?? 420 PSIG Temperature?? 22°F

Did the unit discharge properly?? YES

- Re-fill the specimen with gas and pressurize per Arde procedure ME 10009, except only 5.5 to 5.6 lb of CO₂. Re-install the pressurized test sample in the temperature chamber with the nozzle unattached at ambient conditions and re-connect the thermocouple to the unit. Record the temperature and pressure of the unit below and on the Arde Data sheet.

Pressure?? 700 PSIG Temperature?? 68°F

- Increase the chamber temperature to 129°F. Monitor the unit temperature and, after unit temperature stabilization, maintain the chamber at that temperature for a period of 1 hour, minimum.

- At the end of the 1 hour hold, record the temperature and pressure of the unit below and on the Arde Data Sheet. Then connect the nozzle assembly to the PF2 port; pull the pin while pressing the button and squeeze the trigger to discharge the CO₂ until the tank is empty.

Pressure?? 950 PSIG Temperature?? 127°F

Did the unit discharge properly?? YES

(Continued on next page.)



Consolidated Laboratories, Inc.

732 Arrow Grand Circle
Covina, California 91722
(818) 915-8991

REPORT NO. 6608

PAGE 133

TW
9/5/95

LAB DATA SHEET

Part No. E4A S/N 001 Sample 1 Job 6608
Description: Fire Extinguisher Co. Arde
Page 33

TEST: THERMAL CYCLING (continued)
To Spec.: QA 1006 Paragraphs 5.13 & 5.14

7. Re-fill the unit with gas and pressurize per Arde procedure ME 10009, except only 5.5 to 5. Re-install the pressurized test sample in the temperature chamber with the nozzle unattached at ambient conditions and re-connect the sample to the unit. Record the temperature and pressure of the unit below on the Arde Data Sheet.

Pressure?? 730 PSIG Temperature?? 73°F

8. Repeat the procedure Steps 2 through 6 for a total of 21 cycles, except perform the Cycle only during the last cycle.

Start Date/Time	Finish Date/Time
<u>5-13-95 1130</u>	<u>5-16-95 1320</u>

After last 20 cycles Pressure?? 410 PSIG Temperature?? 20°F

Before last cycle Pressure?? 700 PSIG Temperature?? 57°F

After last cycle Pressure?? 1060 PSIG Temperature?? 128°F

Did the unit operate properly on every occasion?? YES

9. With the unit at ambient conditions, visually inspect for damage.

Any visible evidence of damage?? NO

10. Fill the specimen with gas and pressurize per Arde procedure ME 10009. Record the total weight and pressure gauge reading and compare the pressure with the specification of QA 10060. Record results below and on the Arde QA 10060 data sheet.

Weight?? 6.0 Pressure?? 700 PSIG

Is the pressure within specifications for its temperature?? NO

DUE TO
NOT
ACHIEVING
TEMP
STABILIZATION

11. Perform the Internal Leakage and Functional Tests of QA 10060. See Consolidated Lab Data Sheet for procedures. Record results below and on the Arde QA 10060 data sheet.

Internal Leakage 1 sec/hr (1.35 sec/hr, Max.)

Did the unit operate without any unusual resistance?? YES

Sub
6/5/95

Any visible evidence of damage?? NO

12. List test equipment used on test Equipment List, attached.



LAB DATA SHEET

Part No. E4482 S/N 001 Sample 1 Job 6608
 Description Portable Fire Extinguisher Co. Arde
 Page 3.1

TEST: THERMAL CYCLING (Continued)

To Spec.: QA 10060, Paragraphs 5.13 & 5.14

7. Re-fill the specimen with gas and **pressurize per Arde procedure NE 10009**, except only 5.5 to 5.6 lb of CO₂. Re-install the pressurized test sample in the temperature chamber with the nozzle unattached at ambient conditions and re-connect the thermocouple to the unit. Record the temperature and pressure of the unit below and on the Arde Data Sheet.

Pressure?? 730 PSIG Temperature?? 73°F

8. Repeat the procedures of Steps 2 through 6 for a total of 21 cycles. except perform the CO₂ discharge only during the Last cycle.

Start Date/Time	Finish Date/Time
<u>5-13-95 1130</u>	<u>5-16-95 1320</u>

After last 20°F hold: Pressure?? 410 PSIG Temperature?? 20°F
 Before last 129°F hold: Pressure?? 700 PSIG Temperature?? 59°F
 After last 129°F hold: Pressure?? 1060 PSIG Temperature?? 128°F
 Did the unit discharge properly on every occasion?? YES

9. With the unit at room ambient conditions, visually inspect for damage.

Any visible evidence of damage?? NO

10. Fill the specimen with CO₂ gas and pressurize per Arde procedure ME 10009. Record the total filled weight and pressure gauge reading and compare the pressure with Table 5.7-1 of QA 10060. Record results below and on the Arde QA 10060 data sheet.

Weight?? 6.04 Pressure?? 700 PSIG

Is the pressure reading within specifications for its temperature?? NO

11. Perform the Internal Leakage and Functional Tests of QA 10060. See Consolidated tab Data Sheet, Page 0.0, for procedures. Record results below and on the Arde QA 10060 data sheet.


Internal Leakage?? 0.1 scc/hr (1.35 scc/hr, Max.)

Did the unit discharge without any unusual resistance..? YES

Any visible evidence of damage?? NO

12. List test equipment used on Test: Equipment List, attached-

12



TW 9/5/95

TEST REPORT

BOTTLE FILLING DATA



Before During or After (circle one) Which Test?? THERMAL CYCLE

Date/Time?? 5-12-95 1 1624

PFF Tare Dry Weight (Step c)?? 8.59

PPR Installed Tare Weight (Step j)?? 8.58

PFE Filled Weight (Step m)?? 14.52

PFR Pressure?? 650 PSIG and Temperature?? 60.6 °F (Step o)


PFE Filled Weight (Step r)?? 13.87

Calculated CO₂ Weight (Step r)?? 5.28

Pressure Gauge Reading (Step s)?? 650 PSIG



MRR 49000-033
 USE AS IS.
 VER # HR02353



Consolidated Laboratories, Inc.
732 Arrow Grand Circle
Covina, California 91722
(818) 915-8991

REPORT NO. 6608

PAGE 135

95195

TEST REPORT

BOTTLE FILLING DATA



Before, (During) or After (circle one) Which Test?? THERMAL CYCLE
(AFTER FIRST COLD CYCLE)

Date/Time?? 5-13-95 1 0845

PFE Tare Dry Weight (Step c)?? 8.63

PFE Installed Tare Weight (Step j)?? 9.22

PFE Filled Weight (Step m)?? 14.22

PFE Pressure?? 700 PSIG and Temperature?? 66.5°F (Step o)

PFE Filled Weight (Step r)?? 13.63

Calculated CO₂ Weight (Step r)?? 5.0

Pressure Gauge Reading (Step s)?? 700 PSIG



MRL 49000-033
USE AS IS.
VER # HR02353



TEST REPORT

BOTTLE FILLING DATA



Before, During or After (circle one) Which Test?? THERMAL CYCLE
(AFTER FIRST HOT CYCLE)

Date/Time?? 5-13-95 1100

PFE Tare Dry Weight (Step c)?? 8.60

PFE Installed Tare Weight (Step j)?? 9.25

PFE Filled Weight (Step m)?? 14.30

PFE Pressure?? 700 PSIG and Temperature?? 67.8°F (Step o)

PFE Filled Weight (Step r)?? 13.62

Calculated CO₂ Weight (Step r)?? 5.02

Pressure Gauge Reading (Step s)?? 720 PSIG



MAR 49000-033
 USE AS IS.
 UER # HR 02353



Consolidated Laboratories, Inc.

732 Arrow Grand Circle
Covina, California 91722
(818) 915-8991

REPORT NO. 6608

PAGE 137 *PLW*

TEST REPORT

9/5/95

BOTTLE FILLING DATA

OLT
18

Before (During) or After (circle one) Which Test?? THERMAL CYCLE
(AFTER LAST COLD CYCLE)

Time?? 5-16-95 1000

Tare Dry Weight (Step c)?? 9.62

Installed Tare Weight (Step j)?? 9.35

Filled Weight (Step m)?? 15.00

Pressure?? 680 PSIG and Temperature?? 58.8°F (Step o)

Filled Weight (Step r)?? 14.15

Related CO₂ Weight (Step t)?? 5.53



Pressure Gauge Reading (Step s)?? 700 PSIG



TEST REPORT

OLE
18

BOTTLE FILLING DATA

Before, During or After (circle one) Which Test?? THERMAL CYCLE

Date/Time?? 5-16-95 1500

PFE Tare Dry Weight (Step c)?? 3.60

PFE Installed Tare Weight (Step j)?? 9.38

PFE Filled Weight [Step m]?? 15.82

PFE Pressure?? 700 PSIG and Temperature?? 64°F (Step o)

PFE Filled Weight (Step r)?? 14.64

Calculated CO₂ Weight (Step r)?? 6.04 

Pressure Gauge Reading (Step a)?? 700 PSIG




TEST REPORT

CHART RECORDING OF TYPICAL THERMAL CYCLES

Trace is Chamber Temperature

(5-13-95 through 5-16-95)

CLT
&
INSP





Consolidated Laboratories, Inc.

732 Arrow Grand circle
Covina, California 91722
(818) 915-8991

TEST REPORT

P.11


REPORT NO. 6608

PAGE 141

PHOTO 10

THERMAL CYCLE TEST SETUP

(Unit Close-Up)





LAB DATA SHEET

Part No. E4482 S/N 001 Sample 1 Job 6608
Description Portable Fire Extinguisher Co. Arde
Page 4.0

TEST:	HUMIDITY	Start	To Opt.	Cptd
To Spec:	QA 10060, Para. 5.15	Date <u>5-26-95</u>		<u>5-26-95</u>
		Test By <u>[Signature]</u>		<u>[Signature]</u>
		Photo <u>[Signature]</u>		

Photo Req'd YES

CLI
A
INSP
CLI
2
INSP

CAUTION: Use clean nylon, polyvinyl or cotton gloves in handling the test unit. Protect the unit by placing it, in a polyethylene bag, in its **Arde** supplied crate when not in use.

1. Fill the specimen with CO₂ gas and pressurize per **Arde procedure ME 10009**. Place the pressurized specimen **into** a humidity chamber, with the nozzle unattached at ambient conditions, on non-corrosive supports. Use distilled, demineralized or deionized water with pH between **6.0 and 7.2** to obtain the required humidity. Air velocity throughout the exposure area must not exceed **150 FPM**.
2. Cycle 1
 - a) Increase the chamber temperature to **95°F** over a one (1) hour period and then increase the relative humidity to **not less than 95%** over a one (1) hour period.
 - b) Maintain these conditions for two (2) hours.
 - c) Reduce the chamber temperature to **36°F** over a two (2) hour period with relative humidity maintained at **95%** or greater.
 - d) Maintain these conditions for two (2) hours.
3. Cycle 2
 - a) Increase the chamber temperature to **95°F** over a two (2) hour period with no moisture being added to the chamber until **95°F** is reached.
 - b) Maintain these conditions (**95°F & 95%**) for two (2) hours.
 - c) Reduce the chamber temperature to **36°F** over a two (2) hour period with relative humidity maintained at **95%** or greater.
 - d) Maintain these conditions for two (2) hours.
4. Cycle 3
 - a) Dry the unit at room temperature and **50% maximum** relative humidity by blowing air through the chamber, at a rate of 1 - 3 times the chamber volume per minute, for six (6) hours.



new
9/15/95

LAB DATA SHEET

Part No. E4482 S/N 001 Sample 1 Job 6608
Description Portable Fire Extinguisher Co. Arde
Page 4.1


TEST: HUMIDITY (Continued)

To Spec.: QA 10060, Paragraph 5.15

4. Cycle 3 (Continued)

b) Within two (2) hours after completing this cycle, record the temperature and pressure of the unit below and on the Arde Data Sheet. Then connect the nozzle assembly to the PFE port, pull the pin while pressing the button and squeeze the trigger to discharge the CO₂ for 45 seconds. Weigh the units to determine the amount of CO₂ discharged in 45 seconds, then squeeze the trigger until the tank is empty.

Pressure?? 857 PSIG Temperature?? 70°F



Weight after 45 seconds?? 9.132 lb [CO₂ discharged?? 5.538 lb (91.24%)]



5. Re-fill the specimen with CO₂ gas and, pressurize per Arde procedure ME 10009. Re-install the pressurized test sample in the humidity chamber with the nozzle unattached at ambient conditions.

6. Cycle 4

a) Increase the chamber temperature to 95°F and the relative humidity to 90% over a one (1) hour period.

b) Maintain these conditions for at least one (1) hour.

c) At the end of the one (1) hour period, record the temperature and pressure of the unit below and on the Arde Data Sheet. Then connect the nozzle assembly to the PFE port, pull the pin while pressing the button and squeeze the trigger to discharge the CO₂ for 45 seconds. Weigh the unit to determine the amount of CO₂ discharged in 45 seconds, then squeeze the trigger until the tank is empty.

Pressure?? 960 PSIG Temperature?? 95°F



Weight after 45 seconds?? 8.858 lb [CO₂ discharged?? 5.742 lb (95.7%)]



d) Re-fill the specimen with CO₂ gas and pressurize per Arde procedure ME 10009. Re-install the pressurized test sample in the humidity chamber with the nozzle unattached at ambient conditions.

e) Reduce the chamber temperature to 36°F over a one (1) hour period with relative humidity maintained at 90%.

f) Maintain these conditions for at least one (1) hour:



Consolidated Laboratories, Inc.

732 Arrow Grand Circle
Covina, California 91722
(818) 915-8991

62223663703

P.14

REPORT NO. 6608
PAGE 144
mt 9/15/85

LAB DATA SHEET

Part No. E4482 S/N 001 Sample 1 Job 6608
Description Portable Fire Extinguisher co. Arde
Page 4.2

TEST: HUMIDITY (Continued)

To Spec.: QA 10060, Paragraph 5.15

6. Cycle 4 (Continued)

g) At the end of the one (1) hour period, record the temperature and pressure of the unit below and on the Arde Data Sheet. Then connect the nozzle assembly to the PPE port, pull the pin while pressing the button and squeeze the trigger to discharge the CO₂ for 45 seconds. Weigh the unit to determine the amount of CO₂ discharged in 45 seconds, then squeeze the trigger until the tank is empty.

Pressure?? 600 PSIG Temperature?? 36°F

NO REAT FOR COLD CASE SAMP

Weight after 45 seconds?? 9.922 lb [CO₂ discharged?? 4.688 lb (78 %)]

GLT 22

GLT 2 INCLP

7. Following completion of the fourth cycle, dry the unit as described in Cycle 3, Step 4, above. Remove the unit from the test chamber and visually examine for evidence of deterioration or damage.

Any visible evidence of deterioration or damage?? NO

GLT 1

8. List test equipment used on Test Equipment List, attached.



TEST REPORT

BOTTLE FILLING DATA

Before During or After (circle one) Which Test?? HUMIDITY

Date/Time?? 5-24-95 1 1030


PFE Tare Dry Weight (Step c)?? 8.60

PFE Installed Tare Weight (Step j)?? 9.94

PFE Filled Weight (Step m)?? 15.21

PFE Pressure?? 830 PSIG and Temperature?? 74°F (Step o)

PFE Filled Weight (Step r)?? 14.67

Calculated CO₂ Weight (Step r)?? 6.07 

Pressure Gauge Reading (Step s)?? 825 PSIG



TEST REPORT

BOTTLE FILLING DATA

Before, During or After (circle one) Which Test?? HUMIDITY
(AFTER CYCLE 3)

Date/Time?? 5-25-95 1035


PFE Tare Dry Weight (Step c)?? 8.60

PFE Installed Tare Weight (Step j)?? 9.09

PFE Filled Weight (Step m)?? 15.09

PFE Pressure?? 850 PSIG and Temperature?? 78°F (Step o)

PFE Filled Weight (Step r)?? 14.60

Calculated CO₂ Weight (Step r)?? 6.00 

Pressure Gauge Reading (Step s)?? 850 PSIG



TW 9/5/95

TEST REPORT

BOTTLE FILLING DATA

Before, During or After (circle one) Which Test?? HUMIDITY

(AFTER 1 HR @ 95°F + 90%)

Date/Time?? 5-25-95, 1330

PFE Tare Dry Weight (Step c)?? 8.60

PFE Installed Tare Weight (Step j)?? 9.11


PFE Filled Weight (Step m)?? 15.12

PFE Pressure??... 850 PSIG and Temperature?? 79°F (Step o)

PFE Filled Weight (Step r)?? 14.61

Calculated CO₂ Weight (Step r)?? 6.01

Pressure Gauge Reading (Step s)?? 870 PSIG



TEST REPORT


CHART RECORDING HUMIDITY TEST

Trace Number 1 (Inside) is Chamber Temperature

Trace Number 2 (Outside) is Chamber Humidity

(5/24/95 through 5/25/95)

CLI
6
INS





TEST REPORT


CHART RECORD& OF HUMIDITY TEST

Trace Number 1 (Inside) is Chamber Temperature

Trace Number 2 (Outside) is Chamber Humidity

(5/25/95 through 5/26/95)

CLI
 3
 INSP





CONSULTANT LABORATORIES, INC.
732 Arrow Grand Circle
Covina, California 91722
(818) 915-8991

62223663753

P.20


REPORT NO. 6608

PAGE 150

PHOTO 11

TEST REPORT

HUMIDITY TEST SETUP



Data Sheet

PN : E4482

Date : 5-17-95

SN : 001

Temperature : 65°F

Qualification Test per QA10060, Rev. A

Humidity : 60%

para. 5.11 Thermal Vacuum Test

Requirements : Actual Inspector

a) CO2 mass fill
 5.50 to 5.60 lbm
 Pressure psig
 Temperature °F

5.54
770 PSIG
72°F

CLT
 12

b) Thermal vacuum cycle

Warning: Chamber temperature and PFE skin temperature shall not exceed 132°F. The PFE assembly may explode if high temperature limits are violated.

Cycle No. 1

Start time 5-17-95 @ 2000

20°F temp.

Start End
20°F 20°F

Chamber Pressure (1×10^{-5} torr)
 Hold time (12 hrs min)

$< 1 \times 10^{-5}$ $< 1 \times 10^{-5}$
12 HRS

129°F temp.

Start End
129°F 129°F

Chamber Pressure (1×10^{-5} torr)
 PFE Pressure
 Hold time (12 hrs min)

$< 1 \times 10^{-5}$ $< 1 \times 10^{-5}$
650 PSIG 1050 PSIG
15.5 HRS

Cycle No. 2

Start time 5-19-95 @ 0830

20°F temp.

Start End
20°F 20°F

Chamber Pressure (1×10^{-5} torr)
 Hold time (1 hr min)

$< 1 \times 10^{-5}$ $< 1 \times 10^{-5}$
1 HR

129°F temp.

Start End
129°F 129°F

Chamber Pressure (1×10^{-5} torr)
 Hold time (1 hr min)

$< 1 \times 10^{-5}$ $< 1 \times 10^{-5}$
1.5 HR

A-13 SMB 5/5/95