

Transmission Plan Based on Economic Studies

Paper 08TD0721 Slides

Dale Osborn, Zheng Zhou


Midwest ISO

April, 2008


dosborn@midwestiso.org

Zzhou@midwestiso.org


Power System Conceptual Design




Future Capacity Requirements 2008-2027




Full Constrained Case Annual Gen Weighted LMP




Potential Congestion Relief \$M/yr




Generation Difference: Full Copper Sheet and Full Constrained Cases




West to East Interface Flows OH-PA



West to East Flow with HVDC




Transmission and Substation Costs per Mw-mile by Transmission Voltage And Type of Construction




Final Skeleton – EI Overlay


MTEP08
October 5, 2007
Overlay for
Step 4 Analysis




Potential Benefits from Expansion \$M/yr




Remaining Congestion With Transmission Expansion



Full Constrained Case with EI Annual Gen Weighted LMP



Full Constrained Case Annual Gen Weighted LMP



Cost and Benefit Comparison (All in 2021 \$) EI Overlay

	10 year NPV costs (M\$)	EI APC 10 year NPV Savings (M\$)	B/C Ratio
Reference	34,102	40,167	1.18
Renewable	51,039	56,280	1.10
Environmental	36,441	32,094	0.88
Fuel	37,086	60,525	1.63

Top Binding Constraints – EI Overlay

Top 10 Binding Constraints outside of MISO					Total Binding	Total Shadow	Area	
					Hours	Price (k\$/MW)		
01DOUBS	20459	01AQUEDT	20456	330	4881	3043.8	PJM	
01DOUBS	20105	01DOUBS	20459	1	1354	2581.14	PJM	
NEWROAD6	50403	6W.NROAD	98414	1	4866	2214.78	SPP	
PLAT T#1	79593	WILLIS E	79595	1	8035	1556.87	NYISO	
MED-LDG3	58773	MED-LDG4	58774	1	3305	1522.73	SPP	
WHITPAIN	15	WHITPAN3	4601	1	2026	1454.97	PJM	
MANOR	3071	MILLWOOD	3104	363	1132	1259.23	PJM	
NIAGAR2W	79592	PA27 REG	81516	1	4538	1057.59	NYISO-IMO	
CRAIGJT4	54015	ASHWEST4	53226	19	4956	957.17	SPP	
INTERFACE ISONE - CAPITAL				10	1	8435	861.17	ISONE

Top 10 Binding Constraints in MISO					Total Binding	Total Shadow	Area
					Hours	Price (k\$/MW)	
MT VRNON	32328	ASHLEY	32334	216	1861	873.72	IP
CENTER 3	66791	JAMESTN3	63369	1	1451	494.92	OTP
PR ISLD3	60105	REDROCK3	60236	209	5783	445.83	NSP
08WHITST	25380	16GUION	27821	255	2026	362.59	PSI-IPL
CENTER 4	66751	HESKETT4	67342	1	910	288.29	OTP-MDU
QUAD ;	36382	ROCK CK3	34036	1	2384	222.66	ALTW-COED
QUAD ;	36382	ROCK CK3	34036	273	3251	195.78	ALTW-COED
EASTDALE	33307	E SPFLD	33158	197	687	142.32	AMREN
DUCK CRK	33161	IPAVAL	30788	1	755	119.53	AMREN
MNVLTAP4	60150	GRANITF4	66550	1	279	113.52	NSP-WAPA


Conclusion

- A process has been implemented that produces transmission expansion conceptual plans that appear to be economically supportable from benefits derived from the existing energy markets.
- A transmission system for a 20% wind energy for the MISO footprint was developed.


Four Modes of Wind Energy Cost Considerations

- Wind penetration less than 10%-local-local- business as usual
 - Local Wind generation delivering to local load
 - Local utility pays for the capital costs and the transmission
 - Generation is curtailed for constraints
- Wind penetration between 10% and 13%
 - Local generation to mandates and transmission to obtain ancillary services to control the load- MISO is entering this stage.
- Wind level greater than 13% with mandates
 - Transmission is built to export the surplus to the highest priced markets
 - This is the JCSP work
- Wind levels beyond local mandates for the supply area- 20% nationally
 - Remote generation, delivered by transmission under contract
 - Receiver pays for the
 - Capital cost of wind generation
 - Transmission to deliver
 - About an 11% (30% vs 41%) capacity factor difference will pay for the transmission from South Dakota to New Jersey.


20% Wind Full Constrained Case Annual Gen Weighted LMP



20% Wind Generation Difference: Full Copper Sheet and Full Constrained Cases



20% Wind Interface Contour: Annual Energy Difference Full Copper Sheet to Full Constrained Case




20% Wind Top 25 Interfaces with biggest Energy Difference

Top	INTERFACE	Total Positive	Total Negative	Average	80% CAP
		Energy	Energy	Energy	
		(TWh)	(TWh)	(GWh)	(MW)
1	AMRN - IN	235	0	27	26878
2	IN - OH	177	0	20	19334
3	OH - WPENN	129	0	15	13942
4	SPP - EES	107	0	12	12567
5	AMRN - IOWA	0	-106	-12	12204
6	WPENN - PJM	111	0	13	11891
7	ISONE - NYISO	0	-88	-10	10331
8	TVA - EES	0	-75	-9	9472
9	SOUTHERN - TVA	0	-82	-9	8860
10	IESO - NYISO	69	0	8	8678
11	NYISO - PJM	5	-55	-6	8430
12	ATC - AMRN	69	0	8	8068


20% Wind Annual Economic Information

	Net Generation Revenue	Adj. Production	Load Cost
	Increase(M\$)	Cost Saving (M\$)	Saving (M\$)
Whole EI	-12,905	24,045	52,402
MISO	4,623	269	-4,987
PJM	-14,967	5,585	27,446
MRO	5,186	-2,136	-7,659
NYISO	-746	4,459	8,903
SERC	-13,848	8,096	27,586
SPP	6,703	-2,930	-11,698
ISONE	-2,653	3,518	7,893
TVA	-3,926	1,481	5,248
E_CAN	4,795	4,470	752
IMO	1,927	1,235	-1,082


20% Wind Forecasted Units




20% Wind Future DC Tie Design for ISONE and NYISO



20% Wind Scenario – Current Overlay



Reference Scenario – Current Overlay



Line Miles and Transmission Cost Assumptions in 2024\$



Cost per Mile Assumption							
	345 KV	(2) - 345 kv	500 KV	(2) - 500 kv	765 KV	DC - 400 kv	DC - 800 kv
2024\$	2,250,000	3,750,000	2,875,000	4,792,000	5,125,000	3,800,000	6,000,000


Estimated Line Mileage Summary (Miles)								
	345 KV	(2) - 345 kv	500 KV	(2) - 500 kv	765 KV	DC - 400 kv	DC - 800 kv	Total
Reference	3,329	292	508	946	3,118	282	2,400	10,875
20% Wind	2,042	193	864	279	3,977	0	7,582	14,937

Estimated Cost Summary (Millions of 2024\$)								
	345 KV	(2) - 345 kv	500 KV	(2) - 500 kv	765 KV	DC - 400 kv	DC - 800 kv	Total
Reference	9,363	1,371	1,825	5,668	19,975	1,698	14,400	54,298
20% Wind	5,742	905	3,106	1,671	25,478	0	45,492	82,394




Cost Perspective

Reference Future Cumulative
Costs through 2024



20% Wind Future Cumulative
Costs through 2024



B/C Ratio – Transmission Overlays

Cost and Benefit Comparison (2024\$)			
	2024 Annual Transmission Cost	2024 Adjusted Production Cost Savings	2024 Benefit/Cost Ratio
Reference	8,145	10,029	1.23
20% Wind	12,359	11,082	0.9

Note:

1. Cost includes 25% additional cost to account for the transformer and substation costs, HVDC cost includes terminals, communications, and line costs.
2. Annual cost in 2024\$ is calculated using 15% fixed charge rate.
3. APC (Adjusted production cost) savings is calculated by taking difference between overlay case and constrained case for whole East Interconnect footprint.
4. Adjusted Production Cost = Production Cost + Import * Load Weighted LMP (or) – Export * Generation Weighted LMP
5. Each value represents year **2024 only**.


2024 Binding Constraints

Relief of Binding Constraints: Overlay case versus Constrained Case


Binding Constraints	Reference Future		Wind Future	
	Numbers/ Hours Decrease	Shadow Price Decrease (k\$/MW)	Numbers/ Hours Decrease	Shadow Price Decrease (k\$/MW)
Total	74,893 (Hrs)	8,833	120,103 (Hrs)	164,149
Removed Binding Constraints	95	4,533	65	19,609
Improved Binding Constraints	187	11,662	231	175,508
New Binding Constraints	49	-1,896	50	-254
Worsened Binding Constraints	111	-5,466	138	-30,714

Estimated CO2 Implications by Defined Scenario

2008-2024 Cumulative CO2 Output



Note: Information provided from the Midwest ISO Transmission Expansion Plan Process




Reference Scenario - Top 20 Interfaces with Largest Annual Energy Difference

INTERFACE (From Area-To Area)	Coppersheet Minus Constrained (Pre-Overlay)			Coppersheet Minus Constrained (Overlay)		
	Total Positive Energy (TWh)	Total Negative Energy (TWh)	Additional Transfer Needed to Deliver 80% Energy (MW)	Total Positive Energy (TWh)	Total Negative Energy (TWh)	Additional Transfer Needed to Deliver 80% Energy (MW)
OH-E_PJM	115	0	12,031	61	-1	7,956
AMRN - IN	75	-1	9,434	41	-6	6,790
ISONE - NYISO	0	-71	9,158	2	-19	5,508
NYISO - E_PJM	2	-74	8,661	7	-31	5,239
IN - OH	69	0	8,143	31	-4	4,921
IESO - NYISO	42	-1	6,027	27	-5	4,664
IESO - HQ	8	-32	5,412	12	-32	5,422
SOUTHERN - TVA	0	-30	4,501	0	-20	3,993
MICH - IESO	19	-5	4,284	10	-11	3,340
PJM - CPL	0	-27	3,754	0	-9	1,780
AMRN - IOWA	0	-18	2,693	2	-5	1,403
ATC - AMRN	18	0	2,631	10	-1	1,786
SPP - EES	17	0	2,585	13	0	2,219
TVA - EES	2	-12	2,341	1	-7	1,606
TVA - KY	3	-8	2,158	1	-5	1,111
SOUTHERN - DUK	0	-6	2,054	0	-4	1,521
MICH - IN	2	-12	2,032	4	-9	1,906
ISONE - HQ	1	0	1,986	1	0	1,637
NYISO - HQ	0	-11	1,888	0	-9	1,688
OH - KY	1	-11	1,805	1	-6	1,221


1

Reference Interface Contour: Annual Energy Difference Copper Sheet to Constrained Case




3

Reference Interface Contour: Annual Energy Difference Copper Sheet to Overlay Constrained Case with One West to East DC Line



4

Reference Interface Contour: Annual Energy Difference Copper Sheet to Overlay Constrained Case with Two West to East DC Lines



B/C Ratio – Reference Transmission Overlays

Cost Summary Million (\$)								
Reference	345kV	345kV (2)	500kV	500kV (2)	765kV	DC-400kV	DC-800kV	Total
Workshop	9,363	1,371	1,825	3,001	16,299	0	13,903	45,761
1st Round Changes	9,363	1,371	1,825	5,668	19,975	1,698	7,333	47,231
2nd Round Changes	9,363	1,371	1,825	5,668	19,975	1,698	14,400	54,298
3rd Round: Next workshop Inputs	TBD	TBD	TBD	TBD	TBD	TBD	TBD	TBD

Cost and Benefit Comparison (2024 M\$)			
Reference	2024 Annual Transmission Cost	2024 Adjusted Production Cost Savings	2024 B/C ratio
Workshop	6,864	7,138	1.04
1st Round Changes	7,085	8,285	1.17
2nd Round Changes	8,145	10,029	1.23
3rd Round: Next workshop Inputs	TBD	TBD	TBD

Note:

1. Cost includes 25% additional cost to account for the transformer and substation costs, HVDC cost includes terminals, communications, and line costs.
2. Annual cost in 2024\$ is calculated using 15% FCR
3. APC (Adjusted production cost) savings is calculated by taking difference between overlay case and constrained case for whole East Interconnect footprint.
4. Adjusted Production Cost = Production Cost + Import * Load Weighted LMP (cr) – Export * Generation Weighted LMP
5. Each value represents year 2024 only.