## DO NOT CHANGE WITHOUT PERMISSION FROM MSHA

### DRAWING No 37556A

#### **ELECTRICAL SYSTEM PERMISSIBILITY CHECKLIST**

Listed below are the items and functions that must be maintained for the electrical system to be considered permissible. For a complete equipment permissibility evaluation, this checklist must be used in conjunction with a machine checklist and a power system checklist.

#### ALL INSPECTIONS AND TESTS SHALL BE PERFORMED IN FRESH AIR.

- A. All electrical enclosures must meet the following provisions. (Refer to Table I.) These inspections must be performed weekly to comply with 30 CFR 751914(F)(I).
  - 1. All electrical enclosures are intact (not cracked or broken); the headlight lenses are not loose.
  - 2. All electrical enclosures have an MSHA plate attached that is clearly stamped with an MSHA certification (X/P) number.
  - 3. Use feeler gauges of the appropriate size to insure the clearances listed in Table I.
  - 4. All electrical components are securely mounted; headlights are guarded by position.
  - 5. Lockwashers or equivalent devices are provided for. all bolts, screws, and studs that secure parts of the explosion-proof enclosures.
  - 6. None of the fasteners used for joints on the explosion-proof enclosures are used for attaching non-essential parts or for making electrical connections.
  - 7. All lead entrances (packing glands) are assembled so that a %-inch minimum clearance remains between the packing nut and the stuffing box.
  - 8. All packing nuts and stuffing boxes are secured from loosening by a locking screw, wire, or other means. All unused lead entrances are closed with metal plugs that are secured in place by spot welding, brazing, or equivalent.

NEXT ASSEMBLY: GA465-1

REVISIONS:

(A) ECN 3319 1 1/15/96 (B) ECN 3369 09/22/97

CONFIDENTIAL • PROPERTY OF

CONSOL Inc<sub>®</sub>

MAINTENANCE ENGINEERING DEPARTMENT

200 HIDDEN VALLEY ROAD McMURRAY, PA. 15317 ELECTRICAL SYSTEM
PERMISSIBILITY CHECKLIST
DIESEL/ELECTRIC SHUTTLE CAR

DRAWING No 37556A

05/26/95 PAGE 1 of 5

### **TABLE I**

ltem	Description	Intact	Certification NO (2)	Max. Clearance (3)	Securely Mounted (4)	Lockwashers (5)	Joint Fasteners (6)	1/6" Packing Gland Clearance (7)	Packing Glands Secured from Loosening (8)
В	Generator	( )	X/P-951 ( )	Lid to Conduit Box.004"( )	( )	( )	( )	( )	( )
С	Controller	( )	X/P-2605-0 ( )	Lid to Enclosure.004"( )	( )	( )	( )	( )	( )
D	Circuit Breaker	( )	X/P-2081 <b>-15</b> ( )	Lid to Enclosure.004" ( )	( )	( )	( )	( )	( )
F	Tram Motor	( )	X/P-1455-42 ( )	Hand hold cover to Frame .004" ( )	( )	( )	( )	( )	( )
Alt. F1	Tram Motor	( )	X/P-1455-13 ( )	Hand hold cover to Frame.004"( )	( )	( )	( )	( )	( )
G	Convevor Motor	( )	X/P-I 455-42 ( )	Hand hold cover to Frame .004" ( )	( )	( )	( )	( )	( )
Alt. G1	Conveyor Motor	( )	x/P-1455-13 ( )	Hand hold cover to Frame .004" ( )	( )	( )	( )	( )	( )
н	Master Station	( )	X/P-2393-0 ( )	Lid to Enclosure.008"( )	( )	( )	( )	( )	( )
J	Foot Switch	( )	X/P-2398-1 ( )	Lid to Enclosure.oo8" ( )	( )	( )	( )	( )	( )
к	Panic Switch	( )	x/P-2405-0( )	Lid to Enclosure.008" ( )	( )	( )	( )	( )	( )
L	Headlight	( )	X/P-3221-0 ()	Lid to Enclosure.004"( )	( )	( )	( )	( )	( )
MDiagnostic P a n e I		( )	X/P-I 275-2 ( )	N/A	( )	( )	( )	( )	( )
NVoltmeter Optional		( )	X/P-1275-2( )	N/A	( )	( )	( )	( )	( ')

\*Optional

NEXT ASSEMBLY: GA465-1

**REVISIONS:** 

(A) ECN 3319 11/15/96

(B) ECN 3369 09/22/97

CONFIDENTIAL • PROPERTY OF

C O N S O L I n c  $_{\circledR}$ 

MAINTENANCE ENGINEERING DEPARTMENT 200 HIDDEN VALLEY ROAD McMURRAY , PA. 15317 ELECTRICAL SYSTEM
PERMISSIBILITY CHECKLIST
DIESEL/ELECTRIC SHUTTLE CAR

DRAWING Nº 37556A

05126195 PAGE 2 of 5

#### DO NOT CHANGE WITHOUT PERMISSION FROM MSHA

## DRAWING N<sup>o</sup> 37556A

B.	The following inspections are to be performed weekly; however, portions of cables or conduits enclosed in troughs or requiring							
	the	disas	semb	ly of guards need only to be inspected when the cable is repaired or replaced.				
	1.	(	)	All cables/conduits are clamped in place to prevent undue movement.				
	2.	(	)	All cables are protected from mechanical damage by position, flame-resistant hose conduit, metal tubing, or troughs. Note:				

3. ( ) All cables are not subject to abrasion from sharp corners or edges.

Flexible or threaded rigid metal conduit is not acceptable.

- **4**. ( ) All cables are isolated from hydraulic lines and components.
- 5. ( ) All cables are isolated from fuel lines.
- 6. ( ) All cables are flame-resistant if not enclosed in hose conduit. This is indicated by "MSHA" markings on the cable.
- 7. ( ) All hose conduit is securely clamped at both ends and MSHA markings are present and appear as *Flame-Resistant*, **US** *MSHA*, *US MESA*, or *USBM*.
- C. Whenever the controller is disassembled, the following items in the enclosure should be checked:
  - Circuit breaker ratings.
    - ( ) Main breaker 2CB 400 A max. instantaneous
    - ( ) Control breaker 3CB 10 A max.
    - ( ) Lighting breaker 4CB 10 A max.
  - 2. Overload relay settings. (Refer to Table II.)
    - ( ) OL1
    - ( ) OL2
    - ( ) OL3

NEXT ASSEMBLY: GA465-1 REVISIONS:

(A) ECN 3319 11/15/96

(B) ECN 3369 09/22/97

CONFIDENTIAL • PROPERTY OF



200 HIDDEN VALLEY ROAD McMURRAY, PA. 15317 ELECTRICAL SYSTEM
PERMISSIBILITY CHECKLIST
DIESEL/ELECTRIC SHUTTLE CAR

DRAWING N<sup>o</sup> 37556A

05/26/95 PAGE 3 of 5

문유 S

Motor	Mfg./Type	Heater	Range	Max. Adj.	Ult. Trip	
30 Hp	OL1, OL2	FH91	111-122	108	150 A	
Tram Motor	Westinghouse AA31XX	FH92	<b>123</b> - 129	97		
		FH93	<b>130</b> - 133	92		
<b>30 H</b> p	OL3	FH91	111 - 122	108		
Conveyor Motor	Westinghouse AA31XX	FH92	123 - 129	97	150A	
		FH93	<b>130</b> - 133	92		

- 3. Fuse ratings
  - ( ) FU1, FU2, Tram Motor N<sup>O</sup> 1; 200 A max., 300 V min.
  - ( ) FU3, FU4, Tram Motor  $N^{\circ}$  2; 200 A max., 300 V min.
  - ( ) FU5, FU6, Conveyor Motor; 200 A max., 300 V min.
  - ( ) FU7, FU8, FU9, Control Circuit; 15 A max., 300 V min.
  - ( ) FU10, FU11, FU12, FU13, Control Circuit; 2 A max., 50 V min.
  - ( ) FU14, FU15, Shunt Field; 15 A max., 300 V min.
- 4. ( ) Controller lid switch operates freely. Ohmmeter verifies the function of lid switch.
- D. Whenever the circuit breaker (Item D) is disassembled, the circuit breaker rating should be checked.

**NEXT ASSEMBLY: GA465-1 REVISIONS:** 

(A) ECN 3319 11/15/96 (B) ECN 3369 09/22/97 CONFIDENTIAL . PROPERTY OF

# CONSOL Inc®

MAINTENANCE ENGINEERING DEPARTMENT

200 HIDDEN VALLEY ROAD McMURRAY , PA. 15317 ELECTRICAL SYSTEM
PERMISSIBILITY CHECKLIST
DIESEL/ELECTRIC SHUTTLE CAR

DRAWING No 37556A

05/26/95 PAGE 4 of 5

DO N	от сі	HANC	SE WIT	THOUT PERMISSION FROM MSHA	DRAWING N <sup>o</sup> 37556A
	1.	(	)	Generator Breaker 1 CB; 500 A max. instantaneous, 250 A max. thermal.	
E.	Wh	enev	er any	electrical enclosure is disassembled, the following items should be checked	d:
	1.	(	)	All lead entrances (packing glands) are assembled so that the cable jacket pene	trates into the enclosure.
	2.			All joints forming the flame-arresting path are smooth and free from rust, corrosic	on or pitting.
	3.	(	)	Use feeler gauge of the appropriate size to insure the clearances listed in Table I	l.

NEXT ASSEMBLY: GA465-1 REVISIONS:

(A) ECN 3319 11/15/96 (B) ECN 3369 09/22/97 CONFIDENTIAL • PROPERTY OF

CONSOL Inc<sub>®</sub>
MAINTENANCE ENGINEERING DEPARTMENT

200 HIDDEN VALLEY ROAD McMURRAY , PA. 15317 ELECTRICAL SYSTEM
PERMISSIBILITY CHECKLIST
DIESEL/ELECTRIC SHUTTLE CAR

DRAWING N<sup>o</sup> 37556A

05/26/95 PAGE 5 of 5