



August 8, 2006

To: Administrator Stephen Johnson
U.S. Environmental Protection Agency
1200 Pennsylvania Avenue, NW, MC0001
Washington, DC 20460-0001

Subject: Federal Facilities UST Compliance Act Report
USPS Underground Storage Tank Inventory and Compliance Strategy Report

Dear Mr. Johnson,

Thank you for the opportunity to submit the enclosed Underground Storage Tank Inventory and Compliance Strategy Report on behalf of the United States Postal Service (USPS). We are pleased to provide this agency report containing the complete list and compliance status of all USPS owned or operated federally regulated underground storage tanks in fulfillment of the requirements of The Energy Policy Act of 2005, Title XV, Subtitle B Sec. 1528(b)(1). Please direct any questions concerning this report to Casey Cole Huron at (202) 268-5073.

Thank You,

A handwritten signature in blue ink that reads "Michael J. Fanning".

Michael J. Fanning
Manager, Environmental Policy and Programs
United States Postal Service
475 L'Enfant Plaza, SW Room 1P830
Washington, DC 20260-0830
Phone: 202.268.3364
Fax: 202.268.6016

CC: Committee on Energy and Commerce US House of Representatives
Committee on Environment & Public Works US Senate
Director Cliff Rothenstein, USEPA OSWER/OUST (Electronic copy)
Director Dave Kling, USEPA OECA/FFEO (Electronic copy)
Melanie Garvey, USEPA OECA/FFEO (Electronic copy)
Steven McNeely, USEPA OSWER/OUST (Electronic copy)
Sam Pulcrano, Director, Safety and Environmental Performance Management
Casey Cole Huron, USPS EPP Storage Tank Management Program



August 8, 2006

To: Committee on Energy and Commerce
U.S. House of Representatives
2125 Rayburn House Office Building
Washington, DC 20515-6115

Subject: Federal Facilities UST Compliance Act Report
USPS Underground Storage Tank Inventory and Compliance Strategy Report

Dear Committee Members,

Thank you for the opportunity to submit the enclosed Underground Storage Tank Inventory and Compliance Strategy Report on behalf of the United States Postal Service (USPS). We are pleased to provide this agency report containing the complete list and compliance status of all USPS owned or operated federally regulated underground storage tanks in fulfillment of the requirements of The Energy Policy Act of 2005, Title XV, Subtitle B Sec. 1528(b)(1). Please direct any questions concerning this report to Casey Cole Huron at (202) 268-5073.

Thank You,

A handwritten signature in blue ink, appearing to read "Michael J. Fanning".

Michael J. Fanning
Manager, Environmental Policy and Programs
United States Postal Service
475 L'Enfant Plaza, SW Room 1P830
Washington, DC 20260-0830
Phone: 202.268.3364
Fax: 202.268.6016

CC: Committee on Environment & Public Works US Senate
Administrator Stephen Johnson, USEPA
Director Cliff Rothenstein, USEPA OSWER/OUST (Electronic copy)
Director Dave Kling, USEPA OECA/FFEO (Electronic copy)
Melanie Garvey, USEPA OECA/FFEO (Electronic copy)
Steven McNeely, USEPA OSWER/OUST (Electronic copy)
Sam Pulcrano, Director, Safety and Environmental Performance Management
Casey Cole Huron, USPS EPP Storage Tank Management Program



August 8, 2006

To: Committee on Environment & Public Works
U.S. Senate
SD-410
Dirksen Senate Office Building
Washington, DC 20510-6175

Subject: Federal Facilities UST Compliance Act Report
USPS Underground Storage Tank Inventory and Compliance Strategy Report

Dear Committee Members,

Thank you for the opportunity to submit the enclosed Underground Storage Tank Inventory and Compliance Strategy Report on behalf of the United States Postal Service (USPS). We are pleased to provide this agency report containing the complete list and compliance status of all USPS owned or operated federally regulated underground storage tanks in fulfillment of the requirements of The Energy Policy Act of 2005, Title XV, Subtitle B Sec. 1528(b)(1). Please direct any questions concerning this report to Casey Cole Huron at (202) 268-5073.

Thank You,

A handwritten signature in blue ink that reads "Michael J. Fanning".

Michael J. Fanning
Manager, Environmental Policy and Programs
United States Postal Service
475 L'Enfant Plaza, SW Room 1P830
Washington, DC 20260-0830
Phone: 202.268.3364
Fax: 202.268.6016

CC: Committee on Energy and Commerce US House of Representatives
Administrator Stephen Johnson, USEPA
Director Cliff Rothenstein, USEPA OSWER/OUST (Electronic copy)
Director Dave Kling, USEPA OECA/FFEO (Electronic copy)
Melanie Garvey, USEPA OECA/FFEO (Electronic copy)
Steven McNeely, USEPA OSWER/OUST (Electronic copy)
Sam Pulcrano, Director, Safety and Environmental Performance Management
Casey Cole Huron, USPS EPP Storage Tank Management Program

ENVIRONMENTAL POLICY AND PROGRAMS

475 L'ENFANT PLAZA SW

WASHINGTON DC 20260-2810

FAX: 202-268-6016

U.S. POSTAL SERVICE



Underground Storage Tank Inventory and Compliance Strategy Report

August 2006

Underground Storage Tank Inventory and Compliance Strategy Report

Fulfilling the requirements of:

The Energy Policy Act of 2005, Title XV, Subtitle B Sec.1528(b)(1)

Submitted to:

**Committee on Energy and Commerce
US House of Representatives**

2125 Rayburn House Office Building

Washington, DC 20515-6115

RE: Federal Facilities UST Compliance Act Report

Committee on Environment & Public Works

US Senate, SD-410

Dirksen Senate Office Building

Washington, DC 20510-6175

RE: Federal Facilities UST Compliance Act Report

Administrator Stephen Johnson

U.S. Environmental Protection Agency

1200 Pennsylvania Avenue, NW, MC0001

Washington, DC 20460-0001

RE: Federal Facilities UST Compliance Act Report

Electronic carbon copies to:

Director Cliff Rothenstein, OSWER/OUST, rothenstein.cliff@epa.gov

Director Dave Kling, OECA/FFEO, kling.dave@epa.gov

Melanie Garvey, OECA/FFEO, garvey.melanie@epa.gov

Steven McNeely, OSWER/OUST, mcneely.steven@epa.gov

Submitted by:



Office of Environmental
Policy and Programs
475 L'Enfant Plaza SW
Washington, DC 20260-2810

August 2006

Table of Contents

1. Introduction	2
2. Scope and Purpose.....	4
3. Methodology	5
4. Asset Characterization	7
4.1 National Summary.....	7
4.2 Regional Characteristics by Area	8
5. Compliance Profile.....	10
5.1 UST-Related Training.....	11
6. Compliance Strategy.....	13
6.1 Environmental Management System.....	13
6.2 Environmental Compliance Reviews	14

TABLES

- Table 1: UST Database Data Field Descriptions
- Table 2: UST Quantities by USPS Geographic Areas

FIGURES

- Figure 1: Geographic Coverage of USPS Areas
- Figure 2: National UST Capacities (Gallons)
- Figure 3: National UST Contents
- Figure 4: UST Capacities by USPS Areas (Gallons)
- Figure 5: UST Contents by USPS Areas
- Figure 6: National UST Compliance Status
- Figure 7: UST Compliance Status by USPS Area
- Figure 8: National UST Operator Training Status
- Figure 9: UST Operator Training Compliance Status by USPS Area

APPENDIX

- Appendix A: UST Database

1. Introduction

The United States Postal Service (“USPS” or “Postal Service”) has a complex interconnected delivery system that is dependant on over 200,000 motorized vehicles, one of the largest fleets in the world. To ensure that the USPS can operate efficiently and carry out its mission of delivering the mail, the Postal Service must provide adequate fuel supplies and maintenance facilities for its large fleet. Many USPS facilities use underground storage tanks (USTs) to provide fuel storage for vehicles; liquids storage for vehicle maintenance facilities, facility operations, and backup and emergency power generators; as well as waste storage for facility and vehicle maintenance operations liquid wastes. These storage tanks must be properly managed to ensure that their contents are contained and that stored fuel is available to service the USPS fleet.


The Postal Service manages and maintains its inventory of storage tank systems in accordance with applicable USPS Management Instructions and federal, state, and local laws and regulations. In December 1998, all existing USTs were required to be upgraded, replaced, or properly removed from service to meet Environmental Protection Agency (EPA) mandates. The USPS fully complied with the 1998 requirement by removing underutilized tanks, upgrading antiquated systems where necessary, assessing and replacing leaking USTs, implementing a facility manager training program that includes UST management, and updating Spill Prevention Countermeasure and Control (SPCC) Plans. Additionally, fuel management systems were implemented at many vehicle maintenance facilities.

The USPS continues to pursue initiatives to improve its tank systems and to reduce releases into the environment. For example, the Operations, Maintenance and Management (OMM) plan was created to document and describe the roles and responsibilities of USPS personnel relative to maintaining and complying with regulatory requirements, as well as to record standard operating procedures for the UST system. Additionally, the Postal Service’s Storage Tank (ST) program is now implementing and continually improving a life-cycle management approach to ST management.

The operational structure of the Postal Service consists of Headquarter level management operations, including the Office of Environmental Policy and Programs (EPP) with nine operational areas nationwide. The areas are divided geographically and are tied to USPS operations, population density, mail distribution requirements, and other elements. The areas are responsible for all components of mail delivery operations, including regulatory compliance for all facilities within that geographic area. The geographic breakdown for each area is illustrated in Figure 1 (Page 3).

To ensure that USPS employees and facilities comply with all applicable environmental laws and regulations, roles and responsibilities regarding environmental regulatory compliance have been identified in the USPS Document, *Employee Labor Relations Manual*, Chapter 8, Safety, Health and Environment, and instituted at all operational levels. Each area has a Manager of Environmental Programs (MEP), who implements and supports environmental initiatives, policy and compliance activities at USPS facilities in his/her respective area. Environmental Specialists (ESs) support the MEPs and provide technical expertise, implement area activities and provide support to district managers, installation heads, middle level managers and supervisors. The ESs are also responsible for responding to inquiries regarding procedures and training mandated by federal, state, and local environmental laws and regulations. With the support of these area environmental professionals, UST daily operations, inspections, installation/closure, and training are implemented through installation heads, mid-level operational managers and supervisors, and ultimately by operating employees.

Figure 1: Geographic Coverage of USPS Areas



2. Scope and Purpose

The Energy Policy Act of 2005, Title XV, Subtitle B – or the Underground Storage Tank Compliance Act of 2005 – affects federal and state UST programs by aiming to reduce accidental releases or spills from USTs to the environment. This Act also includes new requirements impacting operator training, inspections, and delivery prohibitions related to storage tanks. *Sec. 1528 (b)(1)* of this Act requires all Federal agencies that own or operate USTs to submit a compliance strategy report to the EPA Administrator and Congress. To fulfill this requirement, the USPS is submitting this Underground Storage Tank Inventory and Compliance Strategy Report. The purpose of this report includes the following:

- To list the location and owner of every USPS underground storage tank;
- To list all USPS tanks that are not in compliance with the above Act;
- To specify the date, if any, of State or Federal inspections of each USPS tank system;
- To list each violation respecting any USPS UST system;
- To describe the operator training that has been provided to the operators and management responsible for each USPS UST system; and,
- To describe the actions that have been, and will be taken, to ensure compliance for each USPS UST system.

Note: This report contains information on federally regulated USTs that are owned and/or operated by the USPS and/or located on USPS owned or leased lands. USTs that contain heating oil and/or have capacities less than 110 gallons are not considered federally regulated and are not included in this report. All tanks contained within this report are operated solely by the USPS on lands either owned or leased by USPS. No coordination with other agencies was required to ensure that UST identification numbers were not duplicated.

3. Methodology

To maintain an accurate and complete list of all federally regulated USTs that are owned, operated, or managed by the Postal Service, a national Environmental Management Information System (EMIS) that includes an inventory of all USPS storage tank systems was developed and implemented in 1997. Although the system has undergone various revisions to account for operational and technology changes (e.g., capabilities of the internet), it continues to serve as the Postal Service's primary tool in maintaining an inventory of all storage tanks, including USTs. The current version of the web-based EMIS (WebEMIS) system provides centralized information that is entered and maintained by each of the operational areas identified in Section 1. Using the most recent data available from WebEMIS, a pre-populated spreadsheet with data categories aligning with the requirements of the UST Compliance Act of 2005 was developed and sent to each area for review, verification, and, if necessary, updating. This methodology ensured that the latest available information (e.g., inspections, compliance status) for each UST system was accounted for. As such, all UST data referred to or presented in this report have been verified by responsible staff from each area as of June 2006.

The data fields in this database fall into two main categories: 1) physical asset information and 2) regulatory compliance information. Physical asset information is used by the USPS for operational purposes and includes internal identifications of facilities and tanks, locations, utilization status, tank size, construction materials, and capacity. Regulatory compliance information has been collected to fully address the sixteen specific data fields in the "Guidance for Underground Storage Tank Compliance Act 2005 Federal Facility Compliance Reporting" issued by EPA on February 1, 2006.

The regulatory compliance data fields have been incorporated as Appendix A of this report. Since the USPS has compiled this data from its internal WebEMIS system and is not utilizing FedCenter to report this data, the data fields in Appendix A have not been reformatted to address additional guidance as provided by EPA on July 11, 2006. By maintaining the existing data field formats, the USPS has made every effort to avoid potential data conflicts and maintain the integrity of the verified data. Appendix A data utilizes the data fields identified in Table 1 below:

Table 1: UST Database Data Field Descriptions

Data Field	Field Description
1) Facility Name:	Lists the name of the USPS facility on which the UST is located. If the UST is not located at a USPS facility, the name of the facility or property on which the UST is located has been provided.
2) Agency:	Identifies the agency responsible for reporting this UST. The USPS is responsible for reporting all USTs contained in this report. There is no cross agency ownership or operation for any USPS tank.
3) Point of Contact:	Provides the point of contact responsible for overseeing the UST(s). The point of contact's name, email address, mailing address, and phone number have been included.
4) Tank #:	Identifies the UST using an existing identification number (such as the tank serial number or UST registration number used by the manufacturing company or the state) or a unique identification number assigned by the USPS facility. If a number such as the tank serial number or UST registration number cannot be found for a tank located on USPS land, and the tank is not owned or operated by the USPS, a unique tank identification number has been assigned to the tank. The source of the number being used has been identified in the narrative field.

Data Field	Field Description
5) UST Location Information:	Lists the UST's physical address. Information including the building name or number, street address, city, county, state and zip code has been provided.
6) Federal Ownership:	"Yes" or "No" has been used to indicate ownership of the UST by the USPS. If "No" is selected, then the "narrative" field lists the owner(s) of the UST.
7) Federal Operator:	"Yes" or "No" has been used to indicate the operator of the UST by USPS. If "No" is selected, then the "narrative" field lists the operator(s) of the UST.
8) UST on Federally Managed Lands:	"Yes" or "No" has been used to indicate a non-USPS owned or operated UST on USPS land. "Yes" indicates the UST is located on USPS managed land, but is neither owned nor operated by the USPS.
9) UST Operator Training:	Indicates whether operator training has been provided for the operator and other persons having daily on-site management responsibilities for the operation of the UST. If no training was provided, the field has been left blank. If training was provided, the field indicates all types of training provided, including: Release Prevention; Release Detection; Release Response and Corrective Action; State Required UST training; or Other.
10) Inspection Data / Inspection Organization:	Identifies the date of last inspection of the UST by a regulator and the type of regulator who performed the last inspection (e.g. federal, state, or local) in each respective field. If the UST has never been inspected, then "Never Inspected" has been entered.
11) Status of UST:	Indicates whether the UST was determined to be non-compliant when last inspected based on, at a minimum, written information from the most recent regulatory inspection of the UST. If the UST has never been inspected by a regulator, "Never Inspected" has been entered.
12) Determination of Non-compliant UST:	Indicates whether non-compliance for the UST has been determined by federal, state, or local regulator inspection (recommended minimum), internal agency or facility auditor (optional), or other (optional).
13) UST Violation Information:	Lists all the UST violations as determined from the last inspection. Violation types include: UST System Requirements; Design, Construction, Installation and Notification (Subpart B); General Operating Requirements (Subpart C); Release Detection (Subpart D); Release Reporting, Investigation and Confirmation (Subpart E); Release Response and Corrective Action (Subpart F); Out of Service UST Systems and Closure (Subpart G); and Other. If "Other" is listed, the violation has been described in more detail in the narrative field.
14) Status of UST Violation(s):	Indicates the current status, with a "Y" for Yes, if actions address violations identified for the UST, which include: Corrective Action in Progress; Corrective Action Completed; Corrective Action Complete – waiting on Regulatory Concurrence; Corrective Action Not Started or Other. If "Other" is listed, an explanation has been provided in the comments section.
15) Status of UST Compliance Strategy:	Describes the compliance actions that have been taken or have been planned for the non-compliant federally owned or operated UST.
16) Comments (optional):	Provides comments as desired on information provided in other fields.
17) Narrative:	Provides information relating to fields 2, 4, 6, 7 and any other fields which require extra information to be provided.

4. Asset Characterization

This section characterizes the UST assets that the USPS owns, operates, and/or manages.

4.1 National Summary

The Postal Service owns, operates, and/or manages 433 federally regulated UST systems. As identified in Section 1. Introduction, the USPS utilizes UST systems for providing fuel storage for vehicles; liquids storage for vehicle maintenance facilities, facility operations, backup and emergency power generators; and waste storage for facility and vehicle maintenance operations.

Figure 2 presents a summary view of all USPS UST Systems by capacity. As shown below, nearly half of the UST systems are in the 5,501 to 10,500 gallon capacity range.

Figure 2: National UST Capacities (Gallons)





Figure 3 identifies the same UST systems by contents. According to Figure 3, 84% contain vehicle or emergency generator fuel (gasoline and diesel). Virgin Oil includes motor oil and lubricating oils such as automatic transmission fluid (ATF).

Figure 3: National UST Contents



4.2 Regional Characteristics by Area

The nine areas individually operate and manage the underground storage tanks in their respective geographic regions. Refer to Section 1, Figure 1 for a map of these areas and more information regarding USPS regional operations. The associated number of tanks for each area are identified in the table below:

Table 2: UST Quantities by USPS Geographic Areas

USPS Area	Geographic Range	Quantity of USTs
Pacific	CA, HI and Guam, Marianas, American Samoa and Palau	22
Southwest	AR, LA, NM, OK and TX	3
Capital Metro	DC, MD, NC, SC and portions of VA	61
Western	AK, AR, CO, ID, IA, KS, MN, MT, NE, NV, ND, OR, SD, UT, WA, WY and portions of WI and MO	44
Eastern	DE, KY, OH, PA, WV and portions of IN, NJ, and VA	103
New York Metro	Puerto Rico US Virgin Islands and portions of NY and NJ	47
Southeast	AL, GA, FL, MS and TN	24
Great Lakes	IL, MI and portions of IN, WI and MO. (Note: No regulated USTs are located in MI)	60
Northeast	CT, MA, ME, NH, RI, VT and portions of NY	69
Total UST Systems Nationwide		433

Figures 4 and 5 below present the breakdown of UST systems in each USPS area by capacity and contents respectively. The total of all area information equals the distribution provided in Figures 2 and 3 above for the national breakdown.

Figure 4: UST Capacities by USPS Areas (Gallons)





Figure 5: UST Contents by USPS Areas



5. Compliance Profile

The following section identifies the overall compliance status of USPS UST systems based on the latest available data regarding state and federal regulator inspections and any subsequent corrective actions taken by the Postal Service as of June 2006.

As identified in Figure 6 below, 66% of USPS UST systems have been inspected nationally by regulators and 3% are currently identified as non-compliant. As of August 2006, the non-compliant UST systems are either in the process of implementing the appropriate corrective actions or are no longer in service and scheduled to be closed. Due to the USPS's proactive compliance policy and diligent maintenance and operation of all of its UST systems, it is likely that the total number of non-compliant systems would not increase if regulator inspections were performed on the remaining 34% of UST systems.

Figure 6: National UST Compliance Status





Figure 7 breaks down the national UST compliance information by each of the nine USPS areas. It should be noted that inspection in specific states in the Northeast Area, including Maine, New Hampshire and Massachusetts are conducted by state certified private tank inspection companies on behalf of federal or state employed regulators. Refer to Section 1, Figure 1 for a map of USPS areas and more information regarding USPS regional operations.

Figure 7: UST Compliance Status by USPS Area



5.1 UST-Related Training

The Postal Service maintains national training programs for a multitude of environmental compliance topics, including national training courses for SPCC plan implementation, Tank Management, and RCRA Underground Storage Tank requirements. However, given the site-specific needs of operator training, system variations, and employee relocation or turnover, the majority of UST operator training is tailored to each specific installation and performed on site by qualified contractors and USPS area environmental professionals. Training sessions are conducted in accordance with USPS Management Instruction AS-550-95-9, *Underground Storage Tank Management*, to ensure consistent, quality training at all installations. Training sessions are also designed to address an installation's individual and unique OMM Plan.

The OMM Plan is a site-specific procedural document describing an employee's roles and responsibilities for maintaining compliance with regulatory requirements and the methods to execute those responsibilities. The three-part document includes procedures for operating and maintaining the UST system, for recordkeeping, for emergency situations, and for responses to leaks or spills. Part I lists the tasks that must be performed to comply with regulatory requirements for monitoring and maintaining USTs. It also contains the Emergency Response Plan (required by USPS policy) and SPCC Plan. Part II presents site-specific information, including tank specifications and installation date, monitoring data, and tank closure records, where applicable. Part III is a compilation of federal and state regulations, USPS standard operating procedures, environmental handbooks, and industry standards.

Individual types of training identified in Appendix A vary according to the needs of each installation. Courses provided at various installations are categorized as follows: Release Prevention; Release Detection; Release Response & Corrective Action; UST Operation and Monitoring; Inspection Procedures; Emergency Response Plan Review; Emergency Response Equipment; Spill Prevention and Countermeasures; Waste Handling Procedures; Inspection Procedures; Designated UST Operator Training (DUSTO); State-required Stage II Vapor Recovery System Operator Training; and UST Control OMM Plan Training. As previously discussed, each of these courses has been designed to meet or exceed the state and/or federal training requirements for various levels of installation employees, from managers to operators.

The USPS has a 100% compliance goal for employee UST training. Training is an ongoing process and sessions are implemented as soon as possible following system and/or staff changes. The following bar and pie charts identify the percentage of staff that have completed documented, site-specific training for the systems they are currently operating. It should be noted that these figures and the data in Appendix A present only a snapshot of conditions as of June 2006. The small percentage of staff that are identified as not adequately trained can be attributed to recent system modifications, staff changes, or other administrative issues and staff will be scheduled to receive training at the earliest possible opportunity.

Figure 8 identifies the percentage of staff nationally that have completed documented, site-specific training for the systems they are currently operating.

Figure 8: National UST Operator Training Status





Figure 9 identifies the staff within each USPS area that have completed documented, site-specific UST training for the systems they are currently operating.

Figure 9: UST Operator Training Compliance Status by USPS Area



6. Compliance Strategy

The Postal Service is dedicated to integrating environmental considerations into its business planning, operations, and decision-making processes to provide its customers, employees, suppliers, and communities with a safe and healthy environment. As a result, the USPS manages and maintains its inventory of storage tanks and containers in accordance with all applicable USPS policy and federal, state, and local laws and regulations. The USPS will continue to maintain efficiently utilized storage tank systems and will manage these systems using practical and innovative best management practices.

USPS programs, guidance and tools currently exist, or are being developed, to identify potential non-compliance issues, implement corrective actions and innovative solutions, and review the success of implemented actions to provide further improvements. Some of these tools have been integral to gathering and verifying the Appendix A data. WebEMIS (Section 3) is just a portion of the IT infrastructure that is utilized to not only maintain compliance, but also identify USTs during catastrophic events and natural disasters to help avoid major releases. Continuous improvements are being made to integrate environmental information systems with other existing databases to create a robust knowledge management system that will support better management decisions and facilitate easier employee access to useful resources. The re-organization of programs, such as the current integration of EPP into the Safety Performance Management organization, has provided an opportunity to further improve national training programs (Section 5.1) and develop more effective training delivery mechanisms. Other tools, such as the OMM Plans (Section 5.1), are developed to meet each site and UST system's specific requirements, clarifying the administrative and operational functions for operators and facility management to help ensure consistent operations and maintained compliance over time.

The key to continued USPS compliance for USTs, and all environmental issues, relies on the ability to communicate facility needs and management decisions, regularly evaluate the impact of actions based on those decisions and provide a mechanism to modify programs and improve performance. The USPS has implemented programs across the organization that are developed from the best available practices of public and private industries worldwide. Its Environmental Management System (EMS) and Environmental Compliance Review (ECR) programs as described below help ensure that USPS environmental programs, including UST compliance, will continue to evolve and improve long into the future.

6.1 *Environmental Management System*

In order to continually meet or exceed compliance obligations, the USPS has developed an Environmental Management System (EMS) framework for each level of the organization including Headquarters, Areas, and appropriate facilities. In April 2006, the USPS began updating and streamlining the EMS and all environmental program components to integrate it with the Safety Performance Management organization. The EMS framework includes a national Storage Tank Management Program. This program identifies, develops, and implements the policies and procedures to ensure that all storage tank systems are managed to protect human health and the environment, are compliant with applicable regulations, and are dependant on sound business-case decisions regarding operational costs and liability.

The Storage Tank Management Program is currently in the process of developing a revised Management Instruction (Policy), scheduled to be completed by the end of 2006, which will ensure a consistent national approach to tank management that aligns with recent regulatory developments and USPS operational changes. Corresponding tools and standard operating procedures will be developed in 2007 to support the implementation of this Management Instruction and will address the management of all types of storage tanks. These tools will not only resolve issues creating non-compliance, but also pro-actively incorporate all aspects of a tank system, from installation to closure.

6.2 Environmental Compliance Reviews

The Postal Service Environmental Compliance Review (ECR) Program currently assesses environmental compliance at Plants and Vehicle Maintenance Facilities at least every five years through third-party multi-media reviews. USPS staff perform more frequent internal ECRs in the interim. As part of the integration of environmental considerations with business operations, the USPS regularly reevaluates the effectiveness of ECR components and the efficiency with which corrective actions are implemented. During this evaluation, the USPS will modify components of the ECR process, if necessary, to better address for UST management and operation (updating of protocols) and reduce the potential for any issues, administrative or physical, to occur.

Appendix

Appendix A: UST Database

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
EMBARCADERO POSTAL CTR	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	005563001006 (From SF Health Dept)	226 Harrison Street San Francisco, CA 94105-9991	Yes	Yes	no	Yes - DUSTO Training. **More training will be provided when tanks are fully installed and operational.	05/05/06 San Francisco City Fire Department (Secondary Containment Testing)	Never inspected					056786-G03	Tanks are currently being installed. The tanks are for emergency generator use only. More training and testing of tanks will be completed as soon as the tanks are completely installed and operational.
EMBARCADERO POSTAL CTR	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	005563001007 (From SF Health Dept)	226 Harrison Street San Francisco, CA 94105-9991	Yes	Yes	no	Yes - DUSTO Training. **More training will be provided when tanks are fully installed and operational.	05/05/06 San Francisco City Fire Department (Secondary Containment Testing)	Never inspected					056786-G03	Tanks are currently being installed. The tanks are for emergency generator use only. More training and testing of tanks will be completed as soon as the tanks are completely installed and operational.
LONG BEACH VMF	USPS	Name: Robert Wyant Email address: robert.wyant@usps.gov Mail ing address: 2300 Redondo Ave. Long Beach, CA 90809-9351 Phone number: 562) 494-2365	F0000000000000 000140 (From FMS found in old OMMF)	2300 Redondo Ave. Long Beach, CA 90809-9351	Yes	Yes	no	Yes - Release Detection / Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Waste Handling Procedures, Inspection Procedures, DUSTO Training	02/02/05 South Coast Air Quality Management District	UST is compliant					054482-G05	
LOS ANGELES	USPS	Name: Ignacio Quezada Email address: ignacio.g.quezada@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9310 Phone number: (323) 586-1900	020888	7001 S. Central Ave., Los Angeles, CA 90052	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	08/13/02 Secondary Containment Testing (performed by Montijo Tank Tech)	UST is compliant					054531-G36	CUPA facility ID number FA0022892.
LOS ANGELES	USPS	Name: Ignacio Quezada Email address: ignacio.g.quezada@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9310 Phone number: (323) 586-1900	020889	7001 S. Central Ave., Los Angeles, CA 90052	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	08/13/02 Secondary Containment Testing (performed by Montijo Tank Tech)	UST is compliant					054531-G36	CUPA facility ID number FA0022892.
LOS ANGELES	USPS	Name: Ignacio Quezada Email address: ignacio.g.quezada@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9310 Phone number: (323) 586-1900	020890	7001 S. Central Ave., Los Angeles, CA 90052	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	08/13/02 Secondary Containment Testing (performed by Montijo Tank Tech)	UST is compliant					054531-G36	CUPA facility ID number FA0022892.
LOS ANGELES	USPS	Name: Ignacio Quezada Email address: ignacio.g.quezada@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9310 Phone number: (323) 586-1900	020891	7001 S. Central Ave., Los Angeles, CA 90052	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	08/13/02 Secondary Containment Testing (performed by Montijo Tank Tech)	UST is compliant					054531-G36	CUPA facility ID number FA0022892.
LOS ANGELES	USPS	Name: Rod Sweetwine roderick.j.sweetwine@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348		7001 S. Central Ave., Los Angeles, CA 90052	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	12/07/05 Secondary Containment Testing (performed by Tait Environmental Systems)	UST is compliant					054531-G36	CUPA facility ID number FA0022892.
MIDWAY DU	USPS	Name: Tony Esqueda Email address: tony.esqueda@usps.gov Mail ing address: 2535 Midway Drive San Diego, CA 92186-9721 Phone number: (619) 758-7194	18202 (From SD County UST Operating Permit)	2535 Midway Drive San Diego, CA 92186-9721	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	06/23/04 Monitoring Equipment Test (County of San Diego HMD) Secondary Containment Testing (performed by GTB Co./Montijo Tank Tech)	UST is compliant					056771-G03	
MIDWAY DU	USPS	Name: Tony Esqueda Email address: tony.esqueda@usps.gov Mail ing address: 2535 Midway Drive San Diego, CA 92186-9721 Phone number: (619) 758-7194	18203 (From SD County UST Operating Permit)	2535 Midway Drive San Diego, CA 92186-9721	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	06/23/04 Monitoring Equipment Test (County of San Diego HMD) Secondary Containment Testing (performed by GTB Co./Montijo Tank Tech)	UST is compliant					056771-G03	
OAKLAND	USPS	Name: Charley Simmons Email address: charley.c.simmons@usps.gov Mail ing address: 1675 7th Street Oakland, CA 94615-9604 Phone number: (510) 874-8462	032063-043701 (From City of Oakland Fire Services UST Operating Permit)	1675 7th Street Oakland, CA 94615-9604	no	Yes	no	Yes - Spill Prevention Control and Countermeasure, Emergency Evacuation Training, Hazard Communications	03/24/06 Oakland Fire Department and Alameda Countywide Clean Water Program	UST is compliant					Lessor Info: SS Silberblatt Inc & Oakland Associates c/o Levin MGMT Corp / H Harris PO Box 326 Plainfield, NJ 07061-0326 055509-029	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
OAKLAND	USPS	Name: Charley Simmons Email address: charley.c.simmons@usps.gov Mail ing address: 1675 7th Street Oakland, CA 94615-9604 Phone number: (510) 874-8462	032063-043702 (From City of Oakland Fire Services UST Operating Permit)	1675 7th Street Oakland, CA 94615-9604	no	Yes	no	Yes - Spill Prevention Control and Countermeasure, Emergency Evacuation Training, Hazard Communications	03/24/06 Oakland Fire Department and Alameda Countywide Clean Water Program	UST is compliant					Lessor Info: SS Silberblatt Inc & Oakland Associates c/o Levin MGMT Corp / H Harris PO Box 326 Plainfield, NJ 07061-0326 055509-029	
OAKLAND	USPS	Name: Charley Simmons Email address: charley.c.simmons@usps.gov Mail ing address: 1675 7th Street Oakland, CA 94615-9604 Phone number: (510) 874-8462	032063-043703 (From City of Oakland Fire Services UST Operating Permit)	1676 7th Street Oakland, CA 94615-9604	no	Yes	no	Yes - Spill Prevention Control and Countermeasure, Emergency Evacuation Training, Hazard Communications	03/24/06 Oakland Fire Department and Alameda Countywide Clean Water Program	UST is compliant					Lessor Info: SS Silberblatt Inc & Oakland Associates c/o Levin MGMT Corp / H Harris PO Box 326 Plainfield, NJ 07061-0326 055509-029	3rd Tank converted from Gasoline to Diesel in September 2005
SAN DIEGO - MLS	USPS	Name: Gary Korf Email address: gary.korf@usps.gov Mail ing address: 11251 Rancho Carmel Drive San Diego, CA 92199-9721 Phone number: (858) 674-0313	28671 (from SD County UST Operating Permit)	11251 Rancho Carmel Drive San Diego, CA 92199-9722	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	05/26/05 County of San Diego (Compliance Inspection)	UST is compliant					056761-G01	
SAN DIEGO - MLS	USPS	Name: Gary Korf Email address: gary.korf@usps.gov Mail ing address: 11251 Rancho Carmel Drive San Diego, CA 92199-9721 Phone number: (858) 674-0313	28672 (from SD County UST Operating Permit)	11252 Rancho Carmel Drive San Diego, CA 92199-9722	Yes	Yes	no	Yes - Release Detection/Release Reporting, Spill Prevention and Counter Measures, Emergency Equipment, Monitoring Requirements	05/26/05 County of San Diego (Compliance Inspection)	UST is compliant					056761-G01	
SAN FRANCISCO	USPS	Name: Leon L. Robinson Email address: leon.l.robinson@usps.gov Mail ing address: 1300 Evans Ave., San Francisco, CA 94188-1448 Phone number: (415) 550-5219	000992001008 (from SF City/County CUPA)	1300 Evans Avenue San Francisco, CA 94188-1448	Yes	Yes	no	Yes - Release Prevention, Release Response and Corrective Action	01/30/06 City and County of San Francisco, Department of Public Health (HMJPA UST Compliance Inspection)	UST is compliant					056786-G28	UST was in violation on 1/30/06 due to record keeping. As of 2/10/06 violations were corrected
SAN FRANCISCO BMC	USPS	Name: Jose A. Bonner Email address: jose.a.bonner@usps.gov Mail ing address: 2501 Rydin Road, Richmond, CA 94804-9751 Phone number: (510) 528-9751	07-000-742132-000007 (from Contra Costa County UST Operator Permit)	2501 Rydin Road Richmond, CA 94804-9751	Yes	Yes	no	Yes - Release Prevention, Release Response and Corrective Action	Never Inspected	UST is compliant					056785-G01	
SAN MATEO IT/ASC	USPS	Name: Robert Sibal Mail ing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	PR0031299 (from San Mateo CUPA Permit)	2700 Campus Drive San Mateo, CA 94403-2504	Yes	Yes	no	Yes - Certified California UST Operator, DUSTO Training	01/25/05 San Mateo County, Environmental Health (UST Compliance Inspection 05/12/05 Hygienetics Environmental Services, Inc. (Secondary Containment)	UST is compliant					056890-G02	UST is for emergency generator only.
BARRIGADA	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	USPS-1 (from Guam EPA)	Guam Main Facility Barrigada, GU 96921-9998	Yes	Yes	no	Yes - Release Detection / Release Reporting	6/23/99 USEPA	UST is compliant					130500-G07	
BARRIGADA	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	USPS-2 (from Guam EPA)	Guam Main Facility Barrigada, GU 96921-9998	Yes	Yes	no	Yes - Release Detection / Release Reporting	6/23/99 USEPA	UST is compliant					130500-G07	
BARRIGADA	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	USPS-3 (from Guam EPA)	Guam Main Facility Barrigada, GU 96921-9998	Yes	Yes	no	Yes - Release Detection / Release Reporting	6/23/99 USEPA	UST is compliant					130500-G07	
HONOLULU	USPS	Name: Herb Yokoyama, Maintenance Manager, Mail ing address: 3600 Aolele Street Honolulu, HI 96820 Phone number: 808-423-3887	9-101765-4A (from Hawaii DOH)	3600 Aolele Street Honolulu, HI 96820	Yes	Yes	no	Yes - Release Detection / Release Reporting	01/24/05 HI DOH	UST is compliant					142401-G10	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
FARMINGTON MPO	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	31394	Farmington Main Post Office, 2301 East 20th Street, Farmington, NM 87401-9998	Yes	Yes	No	Yes Automatic Tank Monitoring System Check, Leak Detection System Check, UST System Visual Walk-Thru Inspection, Emergency Response Plan Review, Emergency Response Equipment	5/15/2003 State Regulator	UST is compliant.						The facility appears to have two FDB numbers. Besides the one listed in the first column, the WebEMIS ECR module also lists FDB number 1363178 for Farmington MPO. Both numbers also appear on an April 2005 Excel file provided by EMP. The UST Identification Number provided on this report is the same as the Facility Number listed on NMED's Storage Tank Registration Certificate. Since there is only one UST, the ID number hasn't been modified with "A", "B", etc.
ALBUQUERQUE VMF	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	UL 713056	Albuquerque VMF, 1135 Broadway Boulevard NE, Albuquerque, NM 87101-9721	Yes	Yes	no	Yes Automatic Tank Monitoring System Check, Leak Detection System Check, UST System Visual Walk-Thru Inspection, Emergency Response Plan Review, Emergency Response Equipment	10/15/1999 State Regulator	UST is compliant.						
ALBUQUERQUE VMF	USPS	Name: Thomas C. Smith (Mgr., Vehicle Maintenance) E-mail address: thomas.c.smith@usps.gov Mailing address: 1135 Broadway Boulevard NE, Albuquerque, NM 87101-9721 Phone number: 505-346-8330	UL 713057	Albuquerque VMF, 1135 Broadway Boulevard NE, Albuquerque, NM 87101-9721	Yes	Yes	No	Yes Automatic Tank Monitoring System Check, Leak Detection System Check, UST System Visual Walk-Thru Inspection, Emergency Response Plan Review, Emergency Response Equipment	10/15/1999 State Regulator	UST is compliant.						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
MONTGOMERY VILLAGE	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	MDE Facility ID No. 0005083	10079 Stedwick Rd., Gaithersburg, MD 20879	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
SILVER SPRING CARRIER ANNEX	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	MDE Facility ID No. 0002172	12010 Plum Orchard Dr., Silver Spring, MD 20904	YES	YES	no	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
SOUTHERN MD VMF	USPS	Name: Dave Cook E-mail address: david.e.cook@usps.gov Mailing address: 9111 Edgeworth Drive, Capital Heights, MD 20743 Phone number: 301-499-7350	MDE Facility ID No. 0009535	9111 Edgeworth Drive, Capital Heights, MD 20743	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
SOUTHERN MD VMF	USPS	Name: Dave Cook E-mail address: david.e.cook@usps.gov Mailing address: 9111 Edgeworth Drive, Capital Heights, MD 20743 Phone number: 301-499-7350	MDE Facility ID No. 0009535	9111 Edgeworth Drive, Capital Heights, MD 20743	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
SOUTHERN MD VMF	USPS	Name: Dave Cook E-mail address: david.e.cook@usps.gov Mailing address: 9111 Edgeworth Drive, Capital Heights, MD 20743 Phone number: 301-499-7350	MDE Facility ID No. 0009535	9111 Edgeworth Drive, Capital Heights, MD 20743	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
SOUTHERN MD VMF	USPS	Name: Dave Cook E-mail address: david.e.cook@usps.gov Mailing address: 9111 Edgeworth Drive, Capital Heights, MD 20743 Phone number: 301-499-7350	MDE Facility ID No. 0009535	9111 Edgeworth Drive, Capital Heights, MD 20743	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
RIVERDALE	USPS	Name: Dave Cook E-mail address: david.e.cook@usps.gov Mailing address: 9111 Edgeworth Drive, Capital Heights, MD 20743 Phone number: 301-499-7350	MDE Facility ID No. 0007392	9111 Edgeworth Drive, Capital Heights, MD 20743	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
RIVERDALE	USPS	Name: Rod Sweetwine roderick.j.sweetwine@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348	MDE Facility ID No. 0007392	6511 Baltimore Ave. Riverdale, MD 20737	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
RIVERDALE	USPS	Name: Dave Cook E-mail address: david.e.cook@usps.gov Mailing address: 9111 Edgeworth Drive, Capital Heights, MD 20743 Phone number: 301-499-7350	MDE Facility ID No. 0007392	6511 Baltimore Ave. Riverdale, MD 20737	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
RIVERDALE	USPS	Name: Dave Cook E-mail address: david.e.cook@usps.gov Mailing address: 9111 Edgeworth Drive, Capital Heights, MD 20743 Phone number: 301-499-7350	MDE Facility ID No. 0007392	6511 Baltimore Ave. Riverdale, MD 20737	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
SUBURBAN MARYLAND VMF	USPS	Name: DIANE HATFIELD, VMF Mgr. E-mail address: diane.hatfield@usps.gov Mailing address: 16501 Shady Grove Rd., Gaithersburg, MD 20898 Phone number: 301-670-6064	MDE Facility ID No. 0002219 ALTERNATE# (5-00027)	16501 Shady Grove Rd., Gaithersburg, MD 20877	YES	YES	No	YES. UST operation and monitoring, release detection	MDE compliance inspection on 5/24/06	UST is compliant.						
SUBURBAN MARYLAND VMF	USPS	Name: DIANE HATFIELD, VMF Mgr. E-mail address: diane.hatfield@usps.gov Mailing address: 16501 Shady Grove Rd., Gaithersburg, MD 20898 Phone number: 301-670-6064	MDE Facility ID No. 0002219 ALTERNATE# (5-00027)	16501 Shady Grove Rd., Gaithersburg, MD 20877	YES	YES	No	YES. UST operation and monitoring, release detection	MDE compliance inspection on 5/24/06	UST is compliant.						
SUBURBAN MARYLAND VMF	USPS	Name: DIANE HATFIELD, VMF Mgr. E-mail address: diane.hatfield@usps.gov Mailing address: 16501 Shady Grove Rd., Gaithersburg, MD 20898 Phone number: 301-670-6064	MDE Facility ID No. 0002219 ALTERNATE# (5-00027)	16501 Shady Grove Rd., Gaithersburg, MD 20877	YES	YES	No	YES. UST operation and monitoring, release detection	MDE compliance inspection on 5/24/06	UST is compliant.						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
SUBURBAN MARYLAND VMF	USPS	Name: DIANE HATFIELD, VMF Mgr. E-mail address: diane.hatfield@usps.gov Mailing address: 16501 Shady Grove Rd., Gaithersburg, MD 20898 Phone number: 301-670-6064	MDE Facility ID No. 0002219 ALTERNATE# (5-00027)	16501 Shady Grove Rd., Gaithersburg, MD 20877	YES	YES	No	YES. UST operation and monitoring, release detection	MDE compliance inspection on 5/24/06	UST is compliant.						
SUBURBAN MARYLAND VMF	USPS	Name: DIANE HATFIELD, VMF Mgr. E-mail address: diane.hatfield@usps.gov Mailing address: 16501 Shady Grove Rd., Gaithersburg, MD 20898 Phone number: 301-670-6064	MDE Facility ID No. 0002219 ALTERNATE# (5-00027)	16501 Shady Grove Rd., Gaithersburg, MD 20877	YES	YES	No	YES. UST operation and monitoring, release detection	MDE compliance inspection on 5/24/06	UST is compliant.						
BALTIMORE	USPS	Name: Wayne Griffith, Facility Mgr. E-mail address: wayne.griffith@usps.gov Mailing address: 900 East Fayette Street, Baltimore, MD 21233 Phone number: 410-347-4555	MDE Facility ID No. 0008993	900 East Fayette Street, Baltimore, MD 21233	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
BALTIMORE	USPS	Name: Wayne Griffith, Facility Mgr. E-mail address: wayne.griffith@usps.gov Mailing address: 900 East Fayette Street, Baltimore, MD 21233 Phone number: 410-347-4555	MDE Facility ID No. 0008993	900 East Fayette Street, Baltimore, MD 21233	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
BALTIMORE	USPS	Name: Robert Sibal Mail ing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	MDE Facility ID No. 0008993	900 East Fayette Street, Baltimore, MD 21233	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
GERMANTOWN	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	MDE Facility ID No. 0005186	12774 Wisteria Dr., Germantown, MD 20874	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
GERMANTOWN	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	MDE Facility ID No. 0005186	12774 Wisteria Dr., Germantown, MD 20874	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
ANNAPOLIS DDU	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	MDE Facility ID No. 0002259	210 Admiral Cochrane Dr. Annapolis, MD 21401	YES	YES	No	YES. UST operation and monitoring, release detection	Last inspected by MDE in 2004	UST is compliant.						
BRENTWOOD	USPS	Name: Herb Yokoyama, Maintenance Manager. Mail ing address: 3600 Aolele Street Honolulu, HI 96820 Phone number: 808-423-3887	DC ERA Reg. No. Unknown	900 Brentwood Road NE, Washington, DC 20066	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
BRENTWOOD	USPS	Name: Joseph King E-mail address: joseph.d.king@email.usps.gov Mailing address: 400 T Street NE, Washington, DC 20002-1510 Phone number: 202-832-0212	DC ERA Reg. No. Unknown	900 Brentwood Road NE, Washington, DC 20066	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
BRENTWOOD	USPS	Name: Joseph King E-mail address: joseph.d.king@email.usps.gov Mailing address: 400 T Street NE, Washington, DC 20002-1510 Phone number: 202-832-0212	DC ERA Reg. No. Unknown	900 Brentwood Road NE, Washington, DC 20066	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
BRENTWOOD	USPS	Name: Joseph King E-mail address: joseph.d.king@email.usps.gov Mailing address: 400 T Street NE, Washington, DC 20002-1510 Phone number: 202-832-0212	DC ERA Reg. No. Unknown	900 Brentwood Road NE, Washington, DC 20066	YES	YES	No	YES. UST operation and monitoring, release detection	Never Inspected	UST is compliant.						
RICHMOND	USPS	Name: Penny Hembrick, VMF Mgr. E-mail address: Penny.P.Hembrick@usps.gov Mailing address: 1001 School Street, Richmond, V 23232 Phone number: 804-775-6153	VDEQ Facility ID No. 4002148	1801 Brook Road Richmond, VA 23232	YES	YES	No	YES. UST Operation and Maintenance, Penny Hembrick	Never Inspected	UST is compliant.						USTs were installed in 1998 and have had no operational problems, releases, or detected leaks. Annual tightness testing is performed by Precision, Inc.

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
RICHMOND	USPS	Name: Penny Hembrick, VMF Mgr. E-mail address: Penny.P.Hembrick@usps.gov Mailing address: 1001 School Street, Richmond, V 23232 Phone number: 804-775-6153	VDEQ Facility ID No. 4002148	1801 Brook Road Richmond, VA 23232	YES	YES	No	YES. UST Operation and Maintenance, Penny Hembrick	Never Inspected	UST is compliant.						USTs were installed in 1998 and have had no operational problems, releases, or detected leaks. Annual tightness testing is performed by Precision, Inc.
SEAPINES	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5014243	313 32 nd Street, Virginia Beach, VA 23451	YES	YES	No	YES. UST Operation and Maintenance, Paul Cora and Galip Yurtsever	Never Inspected	UST is compliant.						
SOUTH NORFOLK	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5022092	1210 Poindexter Street, Chesapeake, VA 23324	YES	YES	No	YES. UST Operation and Maintenance, Vicente Ferdinand	Never Inspected	UST is compliant.						
CHARLOTTESVILLE VMF	USPS	Name: Ronald Snead, VMF Mgr. E-mail address: David.r.snead@usps.gov Mailing address: 1155 Sminole Trail, Charlottesville, VA 22906 Phone number: 434-978-7644	VDEQ Facility ID No. 6002436	1155 Seminole Trail Charlottesville, VA 22906	YES	YES	No	YES. UST Operation and Maintenance, Ron Snead	VDEQ compliance inspection on May 23, 2006	UST is compliant.						
CHARLOTTESVILLE VMF	USPS	Name: Ronald Snead, VMF Mgr. E-mail address: David.r.snead@usps.gov Mailing address: 1155 Sminole Trail, Charlottesville, VA 22906 Phone number: 434-978-7644	VDEQ Facility ID No. 6002436	1155 Seminole Trail Charlottesville, VA 22906	YES	YES	No	YES. UST Operation and Maintenance, Ron Snead	VDEQ compliance inspection on May 23, 2006	UST is compliant.						
CHARLOTTESVILLE VMF	USPS	Name: Ronald Snead, VMF Mgr. E-mail address: David.r.snead@usps.gov Mailing address: 1155 Sminole Trail, Charlottesville, VA 22906 Phone number: 434-978-7644	VDEQ Facility ID No. 6002436	1155 Seminole Trail Charlottesville, VA 22906	YES	YES	No	YES. UST Operation and Maintenance, Ron Snead	VDEQ compliance inspection on May 23, 2006	UST is compliant.						
NORFOLK VMF	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5014521	600 Church Street Norfolk, VA 23501	YES	YES	No	YES. UST Operation and Maintenance, Robert Robinson	Never Inspected	UST is compliant.						
NORFOLK VMF	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5014521	600 Church Street Norfolk, VA 23501	YES	YES	No	YES. UST Operation and Maintenance, Robert Robinson	Never Inspected	UST is compliant.						
NORFOLK VMF	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5014521	600 Church Street Norfolk, VA 23501	YES	YES	No	YES. UST Operation and Maintenance, Robert Robinson	Never Inspected	UST is compliant.						
NORFOLK VMF	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5014521	600 Church Street Norfolk, VA 23501	YES	YES	No	YES. UST Operation and Maintenance, Robert Robinson	Never Inspected	UST is compliant.						
NORFOLK VMF	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5014521	600 Church Street Norfolk, VA 23501	YES	YES	No	YES. UST Operation and Maintenance, Robert Robinson	Never Inspected	UST is compliant.						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
NORTHERN VIRGINIA VMF	USPS	Name: Jim Marcelli E-mail address: James.Marcelli@usps.gov Mailing address: 8409 Lee Highway, Merrifield VA 22081 Phone number: 703-698-6545	VDEQ Facility ID No. 3002145 EPA ID # VA180000104	8409 Lee Highway, Merrifield, VA 22081	YES	YES	No	YES. UST Operation and Maintenance, leak detection	Never Inspected	UST is compliant.						
NORTHERN VIRGINIA VMF	USPS	Name: Jim Marcelli E-mail address: James.Marcelli@usps.gov Mailing address: 8409 Lee Highway, Merrifield VA 22081 Phone number: 703-698-6545	VDEQ Facility ID No. 3002145 EPA ID # VA180000104	8409 Lee Highway, Merrifield, VA 22081	YES	YES	No	YES. UST Operation and Maintenance, leak detection	Never Inspected	UST is compliant.						
NORTHERN VIRGINIA VMF	USPS	Name: Jim Marcelli E-mail address: James.Marcelli@usps.gov Mailing address: 8409 Lee Highway, Merrifield VA 22081 Phone number: 703-698-6545	VDEQ Facility ID No. 3002145 EPA ID # VA180000104	8409 Lee Highway, Merrifield, VA 22081	YES	YES	No	YES. UST Operation and Maintenance, leak detection	Never Inspected	UST is compliant.						
LAFAYETTE	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5022080	2655 Tidewater Dr., Norfolk, VA 23509	YES	YES	No	YES. UST Operation and Maintenance, Sandra Jones and Gloria McIntyre	Never Inspected	UST is compliant.						
HAMPTON	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 500697	809 Aberdeen Road Hampton, VA 23670	YES	YES	No	YES. UST Operation and Maintenance, Adrian Ames	Never Inspected	UST is compliant.						
HAMPTON	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 500697	809 Aberdeen Road Hampton, VA 23670	YES	YES	No	YES. UST Operation and Maintenance, Adrian Ames	Never Inspected	UST is compliant.						
HAMPTON	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 500697	809 Aberdeen Road Hampton, VA 23670	YES	YES	No	YES. UST Operation and Maintenance, Adrian Ames	Never Inspected	UST is compliant.						
HAMPTON	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 500697	809 Aberdeen Road Hampton, VA 23670	YES	YES	No	YES. UST Operation and Maintenance, Adrian Ames	Never Inspected	UST is compliant.						
CHESAPEAKE	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5013242	1425 Battlefield Blvd. N, Chesapeake, VA 23320	YES	YES	No	YES. UST Operation and Maintenance, Rodwick Robinson	Never Inspected	UST is compliant.						
NEWPORT NEWS (DENBIGH)	USPS	Name: Robert Robinson, District Mgr. E-mail address: robert.c.robinson@usps.gov Mailing address: 600 Church Street, Norfolk, VA 23501-9721 Phone number: 757-629-2250	VDEQ Facility ID No. 5022037	101 25 th Street, Newport News, VA 23607	YES	YES	No	YES. UST Operation and Maintenance, Lisa Hamby	Never Inspected	UST is compliant.						
DULLES	USPS	Name: Lou Frantz, Mgr. E-mail address: lfrantz@usps.gov Mailing address: 22363 Randolph Dr., Dulles, VA 20166-9103 Phone number: 703-406-6401	VDEQ Facility ID No. 3003938	22363 Randolph Dr. Dulles, VA 20166-9103	YES	YES	No	YES. UST Operation and Maintenance, leak detection	VDEQ Inspection on 1/18/01	UST is compliant.						
DULLES	USPS	Name: Lou Frantz, Mgr. E-mail address: lfrantz@usps.gov Mailing address: 22363 Randolph Dr., Dulles, VA 20166-9103 Phone number: 703-406-6401	VDEQ Facility ID No. 3003938	22363 Randolph Dr. Dulles, VA 20166-9103	YES	YES	No	YES. UST Operation and Maintenance, leak detection	VDEQ Inspection on 1/18/01	UST is compliant.						
DULLES	USPS	Name: Lou Frantz, Mgr. E-mail address: lfrantz@usps.gov Mailing address: 22363 Randolph Dr., Dulles, VA 20166-9103 Phone number: 703-406-6401	VDEQ Facility ID No. 3003938	22363 Randolph Dr. Dulles, VA 20166-9103	YES	YES	No	YES. UST Operation and Maintenance, leak detection	VDEQ Inspection on 1/18/01	UST is compliant.						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
MANASSAS	USPS	Name: Karl (Korky) Cooper E-mail address: n/a Mailing address: 8801 Sudley Road, Manassas, VA 20110 Phone number: (703)368-2146	VDEQ Facility ID No. 3002142	8801 Sudley Road Manassas, VA 20110	YES	YES	No	YES. UST Operation and Maintenance, leak detection	Never Inspected	UST is compliant.						
PRINCE WILLIAM	USPS	Name: Jodi Cundiff E-mail address: Jodi.Cundiff@usps.gov Mailing address: 3360 Post Office Rd., Woodbridge, VA 22193 Phone number: 703-878-2715	VDEQ Facility ID No. 3037707	3360 Post Office Road, Woodbridge, VA 22193	YES	YES	No	YES. UST Operation and Maintenance, leak detection; Harry Atkins	VDEQ Inspection on 4/27/06	UST is compliant.						
RALEIGH VMF	USPS	Name: Jim Hobbins, VMF manager Email address: james.j.hobbins@usps.gov Mailing address: 3 Floretta Place, Raleigh, NC 27676-9721 Phone number: 919-420-5303	0-033663 (UST Permit Number)	3 Floretta Place, Raleigh, NC 27676-9721	YES	YES	YES	YES Other: Veeder-Root Custodial Awareness Training	4/22/2004 North Carolina Department of Environmental and Natural Resources, UST Compliance Branch	UST is compliant.					No USTs	
RALEIGH VMF	USPS	Name: Jim Hobbins, VMF manager Email address: james.j.hobbins@usps.gov Mailing address: 3 Floretta Place, Raleigh, NC 27676-9721 Phone number: 919-420-5303	0-033663 (UST Permit Number)	3 Floretta Place, Raleigh, NC 27676-9721	YES	YES	YES	YES Other: Veeder-Root Custodial Awareness Training	4/22/2004 North Carolina Department of Environmental and Natural Resources, UST Compliance Branch	UST is compliant.					No USTs	
CAYCE-WEST COLUMBIA AO (WEST COLUMBIA PO)	USPS	Name: Harry Byrd, VMF Mgr. Email address: harry.a.byrd@usps.gov Mailing address: 1531 Platt Springs Rd. West Columbia, SC 29169 Phone number: 803-926-4301	06154-1	1531 Platt Springs Rd. West Columbia, SC 29169	YES	YES	No	YES Other: Veeder-Root Custodial Awareness Training	10/7/2005 State SC Licensed Site Professional (SC DHEC)	UST is compliant.					Added AO (WEST COLUMBIA PO) to Facility Name.	
COLUMBIA PO	USPS	Name: Harry Byrd, VMF Mgr. Email address: harry.a.byrd@usps.gov Mailing address: PO Box 929341 Columbia, SC 29292-9341 Phone number: 803-926-4301	12823-1	1601 Assembly St. Columbia, SC 29201	YES	YES	No	No	11/29/2005 State SC Licensed Site Professional (SC DHEC)	UST is compliant.					Added PO to Facility Name. Changed tank type from Fiberglass 2-Wall to Steel 2-Wall (installed in 1992/1993).	
SPARTANBURG VMF	USPS	Name: Sam Newgent, VMF Mgr. USPS UST POC: Kurtis Pike, Lead Mechanic Email address: mnewgent@usps.gov Mailing address: 250 S. Church St. Spartanburg, SC 29306-9998 Phone number: 864-676-4265; 864-542-2361	12977-1	250 S. Church St. Spartanburg, SC 29306-9998	YES	YES	No	YES Release Prevention, Release Detection, Release Response & Corrective Action	5/1/2005 State SC Licensed Site Professional	UST is compliant.						Property is Leased. Owner Information: Unknown.
COLUMBIA VMF	USPS	Name: Harry Byrd, VMF Mgr. Email address: harry.a.byrd@usps.gov Mailing address: PO Box 929341 Columbia, SC 29292-9341 Phone number: 803-926-4301	15281-1	2001 Dixiana Rd. West Columbia, SC 29172-3007	YES	YES	No	YES Release Prevention, Release Detection, Release Response & Corrective Action	3/10/2006 State SC Licensed Site Professional (SC DHEC)	UST is compliant.					Tank Type changed from Fiberglass 2-Wall to Steel 2-Wall; Tank Size changed from 10000 to 15000 gallons.	
COLUMBIA VMF	USPS	Name: Harry Byrd, VMF Mgr. Email address: harry.a.byrd@usps.gov Mailing address: PO Box 929341 Columbia, SC 29292-9341 Phone number: 803-926-4301	15281-2	2001 Dixiana Rd. West Columbia, SC 29172-3007	YES	YES	No	YES Release Prevention, Release Detection, Release Response & Corrective Action	3/10/2006 State SC Licensed Site Professional (SC DHEC)	UST is compliant.					Tank Type changed from Fiberglass 2-Wall to Steel 2-Wall; Tank Size changed from 10000 to 15000 gallons.	
FLORENCE VMF	USPS	Name: Harry Byrd, VMF Mgr. USPS UST POC: Therion Tisdale, Lead Mechanic Email address: harry.a.byrd@usps.gov, therion.tisdale@usps.gov Mailing address: 1901 West Evanes Street Florence, SC 29501 Phone number: 803-926-4301; 843-679-2459	11072-1	1901 West Evanes Street Florence, SC 29501	YES	YES	No	YES SPCC Release Prevention, Release Detection, Release Response & Corrective Action	10/1/2005 State SC Licensed Site Professional (SC DHEC)	UST is compliant.					Tank Size changed from 10000 to 12000.	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
AURORA	USPS	Name: Alfred Cardenas Mailing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	NA	16890 E Alameda Pkwy, Aurora, CO 80017	yes	yes	no	Yes - Release Prevention, Detection, and Response	6/28/2005 - Colorado Oil & Public Safety	UST is compliant						
LAKEWOOD	USPS	Name: Alfred Cardenas Mailing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	3746-1 & 3746-2	10799 W Alameda Avenue, Lakewood, CO 80226	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						
BELLEVUE	USPS	Name: Eugene Broom Mailing address: 1171 Bellevue Way NE, WA 98004 Phone number: 425-454-3086	SEA-1	1171 Bellevue Way NE, WA 98004	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected (however schedule June 2006) Dept of Ecology Technical Assistance	Never Inspected						
BEN LOMOND	USPS	Name: Valorie Story Mailing address: 221 N Washington Blvd, Ogden, UT 84404 Phone number: 801-612-1807	SLC-1	221 N Washington Blvd, Ogden, UT 84404	yes	yes	no	Yes - Release Prevention, Detection, and Response	5/10/2005 UT DEQ	UST is compliant						
GATEWAY	USPS	Name: Ken Walczyk Mailing address: 2500 S Abilene Street, Aurora, CO 80014 Phone number: 303-227-5427	5625-2	2500 S Abilene Street, Aurora, CO 80014	yes	yes	no	Yes - Release Prevention, Detection, and Response	6/28/1905 CO OSP	UST is non-compliant	State	Yes ⁱ	Yes ⁱⁱ			
LYNNWOOD	USPS	Name: Larry Rosmith Mailing address: 6817 208th Street NW, Lynnwood, WA 98036 Phone number: 425-774-0121	SEA-2	6817 208th Street NW, Lynnwood, WA 98036	yes	yes	no	Yes - Release Prevention, Detection, and Response	5/1/2006 Dept of Ecology Technical Assistance	UST is compliant						
OMAHA	USPS	Name: Larry Guertin Mailing address: 1124 Pacific Street, Omaha, NE 68108 Phone number: 402-348-2803	Omaha-1	1124 Pacific Street, Omaha, NE 68108	yes	yes	no	Yes - Release Prevention, Detection, and Response	February 2006 Nebrasak DEQ	UST is compliant						
OMAHA	USPS	Name: Rod Sweetwine roderick.j.sweetwine@usps.gov Mailing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348	Omaha-2	1124 Pacific Street, Omaha, NE 68108	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						
SANDY	USPS	Name: Dan Corral Mailing address: 8850 South 700 Street, Sandy, UT 84070	SLC-2	8850 South 700 Street, Sandy, UT 84070	yes	yes	no	Yes - Release Prevention, Detection, and Response	3/22/2005 UT DEQ	UST is compliant						
SEATTLE AIR MAIL CENTER	USPS	Name: Mike Welch Mailing address: 16601 Air Cargo Rd, Seattle, WA 98158 Phone number: 253-437-4200	SEA-3	16601 Air Cargo Rd, Seattle, WA 98158	yes	yes	no	Yes - Release Prevention, Detection, and Response	5/1/2006 Dept of Ecology Technical Assistance	UST is compliant						
SUGARHOUSE	USPS	Name: Kaya Skola Mailing address: 1953 S 1100 E, SLC, UT 84106 Phone number: 801-453-0378	SLC-3	1953 S 1100 E, SLC, UT 84106	yes	yes	no	Yes - Release Prevention, Detection, and Response	4/18/2005 UT DEQ	UST is compliant						
TACOMA CTRL CAR FACLTY 1	USPS	Name: Brad Wise Mailing address: 3825 South Warner Street, Tacoma, WA 98409 Phone number: 253-471-0785	SEA-4	3825 South Warner Street, Tacoma, WA 98409	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected (however schedule June 2006) Dept of Ecology Technical Assistance	UST is compliant						
TACOMA CTRL CAR FACLTY 1	USPS	Name: Brad Wise Mailing address: 3825 South Warner Street, Tacoma, WA 98409 Phone number: 253-471-0786	SEA-5	3825 South Warner Street, Tacoma, WA 98409	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected (however schedule June 2006) Dept of Ecology Technical Assistance	UST is compliant						
WESTWOOD	USPS	Name: Louis Stafford Mailing address: 2721 SW Trenton, Seattle, WA 98106 Phone number: 206-935-6051	SEA-6	2721 SW Trenton, Seattle, WA 98106	yes	yes	no	Yes - Release Prevention, Detection, and Response	5/1/2006 Dept of Ecology Technical Assistance	UST is compliant						
MINNEAPOLIS VMF	USPS	Name: Ron Halling Mailing address: 1141 Filmore Street, Minneapolis, MN 55413 Phone number: 612-349-4987	4	1141 Filmore Street, Minneapolis, MN 55413	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						
MINNEAPOLIS VMF	USPS	Name: Ron Halling Mailing address: 1141 Filmore Street, Minneapolis, MN 55413 Phone number: 612-349-4988	5	1141 Filmore Street, Minneapolis, MN 55413	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
MINNEAPOLIS VMF	USPS	Name: Ron Halling Mailing address: 1141 Filmore Street, Minneapolis, MN 55413 Phone number: 612-349-4988	6	1141 Filmore Street, Minneapolis, MN 55413	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						
BLOOMINGTON VMF	USPS	Name: Robert Sibal Mail ing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	1	9641 Garfield, Bloomington, MN 55124	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						
COTTONWOOD	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	SLC-4	6890S 2300 East, SLC, UT 84121	yes	yes	no	Yes - Release Prevention, Detection, and Response	8/11/2005 UT DEQ	UST is compliant						
WEST VALLEY	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	SLC-5	3490 S 4400 West, West Valley City, UT 84120	yes	yes	no	Yes - Release Prevention, Detection, and Response	8/11/2005 UT DEQ	UST is compliant						
SEATTLE	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	SEA-7	2460 4th Avenue, Seattle, WA 98205	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected (however schedule June 2006) Dept of Ecology Technical Assistance	UST is compliant						
SEATTLE	USPS	Name: Herb Yokoyama, Maintenance Mgr Mail ing address: 3600 Aolele Street Honolulu, HI 96820 Phone number: 808-423-3887	SEA-8	2460 4th Avenue, Seattle, WA 98205	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected (however schedule June 2006) Dept of Ecology Technical Assistance	UST is compliant						
YAKIMA	USPS	Name: David Hill Mailing address: 205 W Washington Avenue, WA 98103 Phone number: 509-225-1331	SEA-9	205 W Washington Avenue, WA 98103	yes	yes	no	Yes - Release Prevention, Detection, and Response	2/1/2006 Dept of Ecology Technical Assistance	UST is compliant						
GRAND JUNCTION VMF	USPS	Name: Larry Hartman Mailing address: 308 Grand Avenue, Grand Junction, CO 81501 Phone number: 303-853-6731	3161-2	308 Grand Avenue, Grand Junction, CO 81501	yes	yes	no	Yes - Release Prevention, Detection, and Response	6/28/1905 CO OSP	UST is compliant						
SALT LAKE CITY DISTRICT	USPS	Name: Ric Wilkens Mailing address: 10108 S Redwood Road South Jordan, UT 84095-9351 Phone number: 801-446-5064	SLC-6	1760 West 2100 South, SLC, UT 84199	yes	yes	no	Yes - Release Prevention, Detection, and Response	38460 UT DEQ	UST is compliant						
LINCOLN	USPS	Name: Harry Storz Mailing address: 700 R Street, Lincoln, NE 68501 Phone number: 402-473-1630	Lincoln-1	700 R Street, Lincoln, NE 68501	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						
PORTLAND	USPS	Name: Kenneth Crick Mailing address: 918 NW Park Ave, Portland, OR 97208 Phone number: 503-294-2445	Port-1	918 NW Park Ave, Portland, OR 97208	yes	yes	no	Yes - Release Prevention, Detection, and Response	Never Inspected	Never Inspected						
SEATTLE BMC	USPS	Name: Gary Wanzong Mailing address: 34301 9th Ave S, Federal Way, WA 98003 Phone number: (253) 874-7255	SEA-10	34301 9th Ave S, Federal Way, WA 98003	yes	yes	no	Yes - Release Prevention, Detection, and Response	5/6/2006 Dept of Ecology Technical Assistance	UST is compliant						
SEATTLE BMC	USPS	Name: Gary Wanzong Mailing address: 34301 9th Ave S, Federal Way, WA 98003 Phone number: (253) 874-7255	SEA-11	34301 9th Ave S, Federal Way, WA 98003	yes	yes	no	Yes - Release Prevention, Detection, and Response	5/6/2006 Dept of Ecology Technical Assistance	UST is compliant						
PASCO	USPS	Name: Bob Peterson Mailing address: 11211 E. Montgomery Street Spokane Valley, WA 99206-4779 Phone number: 509-891-9733	SPO 1	3500 W Court Street, Pasco, WA 99301	yes	yes	no	Yes - Release Prevention, Detection, and Response	11/2/2002 Dept of Ecology UST Unit	UST is compliant						
PASCO	USPS	Name: Bob Peterson Mailing address: 11211 E. Montgomery Street Spokane Valley, WA 99206-4779 Phone number: 509-891-9733	SPO 2	3500 W Court Street, Pasco, WA 99301	yes	yes	no	Yes - Release Prevention, Detection, and Response	11/2/2002 Dept of Ecology UST Unit	UST is compliant						
DENVER VMF	USPS	Name: Pete Carrillo Mailing address: 5001 Syracuse, Denver, CO 80226 Phone number: 303-853-6166	7160-1	5001 Syracuse, Denver, CO 80226	yes	yes	no	Yes - Release Prevention, Detection, and Response	6/26/2005 CO OSP	UST is compliant						
DENVER VMF	USPS	Name: Pete Carrillo Mailing address: 5001 Syracuse, Denver, CO 80226 Phone number: 303-853-6167	7160-2 & 7160-3	5001 Syracuse, Denver, CO 80226	yes	yes	no	Yes - Release Prevention, Detection, and Response	6/26/2005 CO OSP	UST is compliant						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
CACTUS STATION	USPS	Name: Sandra Lentz Mailing address: 2901 East Greenway, Phoenix, AZ 85032 Phone number: 602-404-3225	AZ-1	2901 East Greenway, Phoenix, AZ 85032	yes	yes	no	Unknown	6/7/2005 Arizona Inspected DEQ	UST is non-compliant	Federal	Yes*	Yes*			
DESERT FOOTHILLS STATION	USPS	Name: Alicia Gonzalez Mailing address: 1700 East River Road, Pima County, AZ 85718 Phone number: 480-844-1734	AZ-2	1700 East River Road, Pima County, AZ 85718	yes	yes	no	Unknown	Never Inspected Arizona Inspected DEQ	Never Inspected						
PHOENIX VMF	USPS	Name: George Hernandez Mailing address: 4949 East Van Buren, Phoenix, AZ 85026 Phone number: 602-225-3341	AZ-3	4949 East Van Buren, Phoenix, AZ 85026	yes	yes	no	Unknown	6/1/2005 Arizona Inspected DEQ	UST is compliant						
PHOENIX VMF	USPS	Name: George Hernandez Mailing address: 4949 East Van Buren, Phoenix, AZ 85026 Phone number: 602-225-3341	AZ-4	4949 East Van Buren, Phoenix, AZ 85026	yes	yes	no	Unknown	Never Inspected Arizona Inspected DEQ	Never Inspected						
SHAW BUTTE STATION	USPS	Name: Troy Weber Mailing address: 12208 North 19th Avenue, Phoenix, AZ 85029 Phone number: 602-331-1656	AZ-5	12208 North 19th Avenue, Phoenix, AZ 85029	yes	yes	no	Unknown	Never Inspected Arizona Inspected DEQ	Never Inspected						
TUCSON VMF	USPS	Name: Judy Whetherhult Mailing address: 1501 S. Cherrybell Stravenue Tucson, AZ 85726 Phone number: 520-388-5033	AZ-6	1501 S. Cherrybell Tucson, AZ 85726	yes	yes	no	Unknown	Never Inspected Arizona Inspected DEQ	Never Inspected						
TUCSON VMF	USPS	Name: Judy Whetherhult Mailing address: 1501 S. Cherrybell Stravenue Tucson, AZ 85726 Phone number: 520-388-5033	AZ-7	1501 S. Cherrybell Tucson, AZ 85726	yes	yes	no	Unknown	Never Inspected Arizona Inspected DEQ	Never Inspected						
MOUNTAINVIEW STATION	USPS	Name: Alicia Gonzalez Mailing address: 2747 East University Drive, Mesa, AZ 85203 Phone number: 480-844-1734	AZ-8	2747 East University Drive, Mesa, AZ 85203	yes	yes	no	Unknown	5/10/2006 Arizona Inspected DEQ	Never Inspected						
LAS VEGAS VMF	USPS	Name: Larry Arnold Mailing address: 1001 East Sunset Road, Las Vegas, NV 89199 Phone number: 702-361-9363	NV-1	1001 East Sunset Road, Las Vegas, NV 89199	yes	yes	no	Unknown	2/1/2006 Nevada EPA	UST is compliant						
LAS VEGAS VMF	USPS	Name: Larry Arnold Mailing address: 1001 East Sunset Road, Las Vegas, NV 89199 Phone number: 702-361-9363	NV-2	1001 East Sunset Road, Las Vegas, NV 89199	yes	yes	no	Unknown	2/1/2006 Nevada EPA	UST is compliant						
LAS VEGAS VMF	USPS	Name: Larry Arnold Mailing address: 1001 East Sunset Road, Las Vegas, NV 89199 Phone number: 702-361-9363	NV-3	1001 East Sunset Road, Las Vegas, NV 89199	yes	yes	no	Unknown	2/1/2006 Nevada EPA	UST is compliant						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
ALLENTOWN PA AO	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	667748	1000 Postal Road Allentown, PA 18109-8900	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected					Changed tank size from 5000 to 8000.	
BENSALEM AO	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	612311	1800 Bayberry Road Bensalem, PA 19020-9998	Yes	Yes	no	Yes Release Prevention, Release Detection, Release Response & Corrective Action	8/27/2003 State PA Licensed Site Professional (DEP)	UST is non-compliant.	State PA Licensed Site Professional (DEP)	Yes ^{vi}	Yes ^{vi}		Added AO to Facility Name.	
BETHLEHEM AO	USPS	Name: Stephen Dzienis, Building Maintenance USPS UST POC: Bill Sarko Email address: stephen.j.dzienis@usps.gov, william.sarko@usps.gov Mailing address: 535 Wood St. Bethlehem, PA 18016-9998 Phone number: 610-866-0911 610-390-4879	695396	535 Wood St. Bethlehem, PA 18016-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/20/2004 State PA Licensed Site Professional (DEP)	UST is non-compliant.	State PA Licensed Site Professional (DEP)	Yes ^{vii}	Yes ^{ix}		Added AO to Facility Name. Tank didn't pass line tightness test; it has been fixed, but the facility is still waiting for official paperwork.	
CHERRY HILL AO	USPS	Name: John Barnes, Postmaster USPS UST POC: Russell Carmody, Supervisor, Customer Service Email address: john.r.barnes@usps.gov, russell.j.carmody@usps.gov Mailing address: 1175 Marl Kress Rd. Cherry Hill, NJ 08034-9998 Phone number: 856-424-0093; 856-424-4533	007578-1	1175 Marl Kress Rd. Cherry Hill, NJ 08034-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	3/1/2006 Camden County Department of Health	UST is non-compliant.	Camden County Department of Health	Yes ⁱ	Yes ⁱⁱ		Added AO to Facility Name.	
CINCINNATI BMC VMF	USPS	Name: Dave Combs, VMF Mgr. USPS UST POC: Chris Burk, Lead Mechanic Email address: david.o.combs@usps.gov Mailing address: 3055 Crescentville Rd. Cincinnati, OH 45235 Phone number: 513-684-5627 513-733-7128	31002232-1	3055 Crescentville Rd. Cincinnati, OH 45235	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	4/30/1999 EPA Inspector	UST is non-compliant.	EPA inspector	Yes ⁱⁱⁱ	Yes ⁱⁱⁱ		Tank size changed from 10000 to 8000 gallons; added VMF to Facility Name.	
CLARKSBURG PO	USPS	Name: Terry Dean, Postmaster Email address: terry.l.dean@usps.gov Mailing address: 500 W. Pike Street Clarksburg, WV 26301-9998 Phone number: 304-623-4796	1703313-1	500 W. Pike Street Clarksburg, WV 26301-9998	Yes	Yes	No	No	Never Inspected	Never Inspected					Added PO to Facility Name.	
FAIRMONT AO	USPS	Name: Ken Owens, Postmaster USPS UST POC: Bill Knowlton, Maintenance Mechanic Email address: wknowlton@email.usps.gov Mailing address: 321 Madison St. Fairmont, WV 26554 Phone number: 304-366-1610	2-506461-1	321 Madison St. Fairmont, WV 26554	Yes	Yes	No	No	10/18/2005 State WV Licensed Site Professional (WV DEP)	UST is non-compliant.	State WV Licensed Site Professional (WV DEP)	Yes ^{iv}	Yes ^{iv}		Added AO to Facility Name.	
FRANKFORD AO	USPS	Name: Rod Sweetwine roderick.j.sweetwine@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348	70531	4410 Paul Street Philadelphia, PA 19124-9998	Yes	Yes	No	No	7/14/2005 State PA Licensed Site Professional (DEP)	UST is non-compliant.	State PA Licensed Site Professional (DEP)	Yes ^v	Yes ^{vii}		Added AO to Facility Name.	
GLENSIDE AO	USPS	Name: Dominic Canpellone, Postmaster USPS UST POC: Ed Casey, Supervisor Email address: dominic.a.canpellone@usps.gov, edward.t.casey@usps.gov Mailing address: 262 S. Easton Rd. Glenside, PA 19038-9998 Phone number: 215-884-8461	46-45574-1	262 S. Easton Rd. Glenside, PA 19038-9998	Yes	Yes	No	No	4/24/2006 State PA Licensed Site Professional (DEP)	UST is compliant.					Added AO to Facility Name.	
GREENTREE VMF	USPS	Name: Kevin Coyle, VMF Mgr. USPS UST POC: Dave Singer, Lead Mechanic Email address: kevin.coyle@usps.gov Mailing address: 770 Trumbull Drive Pittsburgh, PA 15242 Phone number: 412-359-7681; 412-923-1323	02-82708-2	770 Trumbull Drive Pittsburgh, PA 15242	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	2/6/2002 State PA Licensed Site Professional	UST is compliant.						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
GREENTREE VMF	USPS	Name: Kevin Coyle, VMF Mgr. USPS UST POC: Dave Singer, Lead Mechanic Email address: kevin.coyle@usps.gov Mailing address: 770 Trumbull Drive Pittsburgh, PA 15242 Phone number: 412-359-7681; 412-923-1323	02-82708-3	770 Trumbull Drive Pittsburgh, PA 15242	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	2/6/2002 State PA Licensed Site Professional	UST is compliant.						
IROQUOIS AO	USPS	Name: Jerry Board, Supervisor USPS UST POC: James Brown, COR Email address: N/A Mailing address: 4772 Almond Ave. Louisville, KY 40209-9998 Phone number: 502-368-8911; 502-361-0078	3139056-1	4772 Almond Ave. Louisville, KY 40209-9998	Yes	Yes	No	Yes SPCC, Hazardous Materials Spill Prevention Control Plan, Air Pollution Control Permit Stage 1	Never Inspected	Never Inspected					Added AO to Facility Name.	
LANGHORNE AO	USPS	Name: Eugene Urban, Postmaster USPS UST POC: Mr. Fran Dummond, VOMA Email address: eugene.a.urban@usps.gov Mailing address: 980 Wheeler Way Langhorne, PA 19047-9998 Phone number: 215-752-2560	611511	980 Wheeler Way Langhorne, PA 19047-9998	Yes	Yes	No	Yes Other: UST and Stormwater Training	1/10/2006 State PA Licensed Site Professional (DEP)	UST is compliant.					Added AO to Facility Name.	
MANSFIELD VMF	USPS	Name: Bill Myers, Lead Mechanic USPS UST POC: Kathy Dummm, General Clerk Email address: william.a.myers@usps.gov, kathy.dummm@usps.gov Mailing address: 200 N. Diamond St. Mansfield, OH 44901-9998 Phone number: 419-755-4622; 419-755-4612	70000498-6	200 N. Diamond St. Mansfield, OH 44901-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected					Added VMF to Facility Name.	
MANSFIELD VMF	USPS	Name: Bill Myers, Lead Mechanic; USPS UST POC: Kathy Dummm, General Clerk Email address: william.a.myers@usps.gov, kathy.dummm@usps.gov Mailing address: 200 N. Diamond St. Mansfield, OH 44901-9998 Phone number: 419-755-4622; 419-755-4612	70000498-7	200 N. Diamond St. Mansfield, OH 44901-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected					Added VMF to Facility Name: tank size changed from 600 to 550 gallons.	
MANSFIELD VMF	USPS	Name: Bill Myers, Lead Mechanic; USPS UST POC: Kathy Dummm, General Clerk Email address: william.a.myers@usps.gov, kathy.dummm@usps.gov Mailing address: 200 N. Diamond St. Mansfield, OH 44901-9998 Phone number: 419-755-4622; 419-755-4612	70000498-8	200 N. Diamond St. Mansfield, OH 44901-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected					Added VMF to Facility Name.	
MAPLE SHADE AO	USPS	Name: Salim Waleed, Postmaster Email address: salim.waleed@usps.gov Mailing address: 1 E. Main Street Maple Shade, NJ 08052-9998 Phone number: 856-779-7176	007571-1	1 E. Main Street Maple Shade, NJ 08052-9998	Yes	Yes	No	Yes Annual Stormwater Training Release Prevention, Release Detection, Release Response & Corrective Action	5/1/2005 State NJ Licensed Site Professional (DEP)	UST is compliant.					Added AO to Facility Name.	
MARION AO	USPS	Name: Robert Sibal Mailing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	51000776-1	230 Barks Road Marion, OH 43302- 9998	Yes	Yes	No	Yes Other: UST OMM Training	Never Inspected	Never Inspected					Added AO to Facility Name.	
MILLVILLE AO	USPS	Name: Tony San Nicholas Mailing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	007573-1	302 N. High St. Millville, NJ 08332- 9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/1/2004 State NJ Licensed Site Professional (DEP)	UST is compliant.					Added AO to Facility Name.	
MORRISVILLE AO	USPS	Name: Tony San Nicholas Mailing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	09-42743-1	950 W. Trenton Ave. Morrisville, PA 19067-9998	Yes	Yes	No	No	4/5/2002 State PA Licensed Site Professional (DEP)	UST is compliant.					Added AO to Facility Name.	
OAKLAND PARK STATION	USPS	Name: Tony San Nicholas Mailing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	25007046-1	2200 Innis Road Columbus, OH 43224-998	Yes	Yes	No	Yes Other: UST OMM Training	Never Inspected	Never Inspected						
SAINT ALBANS AO	USPS	Name: Herb Yokoyama, Maintenance Manager, Mailing address: 3600 Aolele Street Honolulu, HI 96820 Phone number: 808-423-3887	2009454-1	431 B Street Saint Albans, WV 25177-9998	Yes	Yes	No	No	10/1/2005 State WV Licensed Site Professional (WV DEP)	UST is compliant.					Added AO to Facility Name.	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
WEST WORTHINGTON AO	USPS	Name: Brenda Seanor, Station Manager; USPS UST POC: Dale Patterson, Supervisor Vehicle Supplies Email address: brenda.s.seanor@usps.gov, dale.w.patterson@usps.gov Mailing address: 6316 Nicholas Drive Columbus, OH 43235-9998 Phone number: 614-783-2120; 614-469-4286	25004973-1	6316 Nicholas Drive Columbus, OH 43235-9998	Yes	Yes	No	Yes Other: UST OMM Training	Never Inspected	Never Inspected					Added AO to Facility Name.	
WILLINGBORO AO	USPS	Name: Willard Gillespie, Postmaster Email address: willard.g.gillespie@usps.gov Mailing address: 16 Salem Rd. Willingboro, NJ 08046-9998 Phone number: 609-877-2117	0075747-1	16 Salem Rd. Willingboro, NJ 08046-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/1/2005 State NJ Licensed Site Professional (DEP)	UST is compliant.					Added AO to Facility Name.	
DEPTFORD AO	USPS	Name: Dave Pignatello, Postmaster Email address: dave.pignatello@usps.gov Mailing address: 1265 Hurlville Road Deptford, NJ 08096-5699 Phone number: 835-232-3812	033469-1	1265 Hurlville Road Deptford, NJ 08096-5699	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	2/9/2006 State NJ Licensed Site Professional (DEP)	UST is non-compliant.		Yes ^{non}			Added AO to Facility Name.	
SOUTH JERSEY VMF	USPS	Name: Joe Bradley, VMF Mgr. USPS UST POC: Tony Cristoforo, Supervisor Supplies Email address: joe.bradley@usps.gov, anthony.cristoforo@usps.gov Mailing address: 421 Benigno Blvd. Bellmawr, NJ 08031-9721 Phone number: 856-933-4065; 856-933-4071	006574-1	421 Benigno Blvd. Bellmawr, NJ 08031-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	8/15/2006 State NJ Licensed Site Professional (DEP)	UST is compliant.						
SOUTH JERSEY VMF	USPS	Name: Joe Bradley, VMF Mgr. USPS UST POC: Tony Cristoforo, Supervisor Supplies Email address: joe.bradley@usps.gov, anthony.cristoforo@usps.gov Mailing address: 421 Benigno Blvd. Bellmawr, NJ 08031-9721 Phone number: 856-933-4065; 856-933-4071	006574-2	421 Benigno Blvd. Bellmawr, NJ 08031-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	8/15/2005 State NJ Licensed Site Professional (DEP)	UST is compliant.						
KINGSTON AO	USPS	Name: Walter Shumlas, Station Mgr. Email address: walter.shumlas@usps.gov Mailing address: 435 Wyoming Ave. Kingston, PA 18704-3698 Phone number: 570-287-9673	674039	435 Wyoming Ave. Kingston, PA 18704-3698	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected					Added AO to Facility Name. UST is to be removed according to Area UST Inspection project .	
PALMER AO	USPS	Name: Darell Lambert, VOMA Email address: darell.lambert@usps.gov Mailing address: 650 Greenwood Ave. Easton, PA 18045-9998 Phone number: 610-252-9964	695398	650 Greenwood Ave. Easton, PA 18045-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	1/14/2003 State PA Licensed Site Professional (DEP)	UST is compliant.					Added AO to Facility Name.	
WILLIAMSPORT VMF	USPS	Name: Todd Sulouff, Supervisor Vehicle Maintenance; USPS UST POC: Karen Crawford, Admin Clerk Email address: t.sulouff@email.usps.gov Mailing address: 2901 Reach Road Williamsport, PA 17701-9998 Phone number: 717-257-2178; 570-320-4136	675866	2901 Reach Road Williamsport, PA 17701-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	1/1/2005 State PA Licensed Site Professional (DEP)	UST is compliant.					Added VMF to Facility Name	
LOUISVILLE VMF	USPS	Name: Scott Sullivan, VMF Mgr.; USPS UST POC: John W. Jones, VMF Supervisor Email address: scott.j.sullivan@usps.gov, john.w.jones@usps.gov Mailing address: 1420 Gardiner Ln. Louisville, KY 40231-9999 Phone number: 502-454-1750; 502-454-1891	2238-1	1420 Gardiner Ln. Louisville, KY 40231-9999	Yes	Yes	Yes	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
LOUISVILLE VMF	USPS	Name: Scott Sullivan, VMF Mgr.; USPS UST POC: John W. Jones, VMF Supervisor Email address: scott.j.sullivan@usps.gov, john.w.jones@usps.gov Mailing address: 1420 Gardiner Ln. Louisville, KY 40231-9999 Phone number: 502-454-1750; 502-454-1891	2238-2	1420 Gardiner Ln. Louisville, KY 40231-9999	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
LOUISVILLE VMF	USPS	Name: Scott Sullivan, VMF Mgr.; USPS UST POC: John W. Jones, VMF Supervisor Email address: scott.j.sullivan@usps.gov, john.w.jones@usps.gov Mailing address: 1420 Gardiner Ln. Louisville, KY 40231-9999 Phone number: 502-454-1750; 502-454-1891	2238-3	1420 Gardiner Ln. Louisville, KY 40231-9999	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
LOUISVILLE VMF	USPS	Name: Scott Sullivan, VMF Mgr.; USPS UST POC: John W. Jones, VMF Supervisor Email address: scott.j.sullivan@usps.gov, john.w.jones@usps.gov Mailing address: 1420 Gardiner Ln. Louisville, KY 40231-9999 Phone number: 502-454-1750; 502-454-1891	2238-4	1420 Gardiner Ln. Louisville, KY 40231-9999	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
EVANSVILLE VMF	USPS	Name: Mike Winchell, VMF Mgr. Email address: mwinchel@usps.gov Mailing address: 800 Sycamore Street Evansville, IN 47708-9721 Phone number: 812-429-3448	9497-1	800 Sycamore Street Evansville, IN 47708-9721	Yes	Yes	No	Yes OSHA Safety Talk on Spill Prevention, Release Response and Corrective Action	6/21/1905 State IN Licensed Site Professional (DEM)	UST is compliant.						
EVANSVILLE VMF	USPS	Name: Mike Winchell, VMF Mgr. Email address: mwinchel@usps.gov Mailing address: 800 Sycamore Street Evansville, IN 47708-9721 Phone number: 812-429-3448	9497-2	800 Sycamore Street Evansville, IN 47708-9721	Yes	Yes	No	Yes OSHA Safety Talk on Spill Prevention, Release Response and Corrective Action	6/21/1905 State IN Licensed Site Professional (DEM)	UST is compliant.						
EVANSVILLE VMF	USPS	Name: Mike Winchell, VMF Mgr. Email address: mwinchel@usps.gov Mailing address: 800 Sycamore Street Evansville, IN 47708-9721 Phone number: 812-429-3448	9497-3	800 Sycamore Street Evansville, IN 47708-9721	Yes	Yes	No	Yes OSHA Safety Talk on Spill Prevention, Release Response and Corrective Action	6/21/1905 State IN Licensed Site Professional (DEM)	UST is compliant.						
SOUTHEASTER N VMF	USPS	Name: Joe Jones, VMF Mgr. Donald Whalen, Supervisor Vehicle Maintenance Email address: dwhalen@usps.gov Mailing address: 1000 W Valley Road Southeastern, PA 19399-9331 Phone number: 610-964-6490	622812	1000 W Valley Road Southeastern, PA 19399-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
SOUTHEASTER N VMF	USPS	Name: Joe Jones, VMF Mgr. Donald Whalen, Supervisor Vehicle Maintenance Email address: dwhalen@usps.gov Mailing address: 1000 W Valley Road Southeastern, PA 19399-9331 Phone number: 610-964-6490	622813	1000 W Valley Road Southeastern, PA 19399-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
SOUTHEASTER N VMF	USPS	Name: Joe Jones, VMF Mgr. Donald Whalen, Supervisor Vehicle Maintenance Email address: dwhalen@usps.gov Mailing address: 1000 W Valley Road Southeastern, PA 19399-9331 Phone number: 610-964-6490	622814	1000 W Valley Road Southeastern, PA 19399-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
SOUTHEASTER N VMF	USPS	Name: Joe Jones, VMF Mgr. Donald Whalen, Supervisor Vehicle Maintenance Email address: dwhalen@usps.gov Mailing address: 1000 W Valley Road Southeastern, PA 19399-9331 Phone number: 610-964-6490	622815	1000 W Valley Road Southeastern, PA 19399-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
WEST PHILADELPHIA VMF	USPS	Name: George Buechele, VMF Mgr. Email address: george.buechele@usps.gov Mailing address: 3000 Chestnut Street Philadelphia, PA 19104-9721 Phone number: 215-895-9290	701575	3000 Chestnut Street Philadelphia, PA 19104-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/8/2003 EPA Inspector	UST is compliant.						
WEST PHILADELPHIA VMF	USPS	Name: George Buechele, VMF Mgr. Email address: george.buechele@usps.gov Mailing address: 3000 Chestnut Street Philadelphia, PA 19104-9721 Phone number: 215-895-9290	701576	3000 Chestnut Street Philadelphia, PA 19104-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/8/2003 EPA Inspector	UST is compliant.						
WEST PHILADELPHIA VMF	USPS	Name: George Buechele, VMF Mgr. Email address: george.buechele@usps.gov Mailing address: 3000 Chestnut Street Philadelphia, PA 19104-9721 Phone number: 215-895-9290	701577	3000 Chestnut Street Philadelphia, PA 19104-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/8/2003 EPA Inspector	UST is compliant.						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
WEST PHILADELPHIA VMF	USPS	Name: George Buechele, VMF Mgr. Email address: george.buechele@usps.gov Mailing address: 3000 Chestnut Street Philadelphia, PA 19104-9721 Phone number: 215-895-9290	701578	3000 Chestnut Street Philadelphia, PA 19104-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/8/2003 EPA Inspector	UST is compliant.						
PHILADELPHIA BMC VMF	USPS	Name: Robert Elliott, VMF Supervisor; USPS UST POC: John Corneale, Lead Mechanic Email address: robert.a.elliott@usps.gov, john.c.corneale@usps.gov Mailing address: 1900 Byberry Rd. Ste. 3 Philadelphia, PA 19116-9722 Phone number: 215-671-7752	70528	1900 Byberry Rd. Ste. 3 Philadelphia, PA 19116-9722	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	7/5/2006 State PA Licensed Site Professional (DEP)	UST is compliant.					Changed Tank Contents from Gasoline to Diesel.	
PHILADELPHIA BMC VMF	USPS	Name: Robert Elliott, VMF Supervisor; USPS UST POC: John Corneale, Lead Mechanic Email address: robert.a.elliott@usps.gov, john.c.corneale@usps.gov Mailing address: 1900 Byberry Rd. Ste. 3 Philadelphia, PA 19116-9722 Phone number: 215-671-7752	70529	1900 Byberry Rd. Ste. 3 Philadelphia, PA 19116-9722	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	7/5/2006 State PA Licensed Site Professional (DEP)	UST is compliant.						
LANCASTER VMF	USPS	Name: Bruce Morgan, VMF Mgr. USPS UST POC: Jim Dissenger, VMF Supervisor Email address: bruce.r.morgan@usps.gov, james.p.dissenger@usps.gov Mailing address: 1400 Harrisburg Pike Lancaster, PA 17604-9331 Phone number: 717-396-6923	657006	1400 Harrisburg Pike Lancaster, PA 17604-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	8/24/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
LANCASTER VMF	USPS	Name: Bruce Morgan, VMF Mgr. USPS UST POC: Jim Dissenger, VMF Supervisor Email address: bruce.r.morgan@usps.gov, james.p.dissenger@usps.gov Mailing address: 1400 Harrisburg Pike Lancaster, PA 17604-9331 Phone number: 717-396-6923	657007	1400 Harrisburg Pike Lancaster, PA 17604-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	8/24/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
READING VMF	USPS	Name: Bruce Morgan, VMF Mgr. USPS UST POC: Jim Dissenger, VMF Supervisor Email address: bruce.r.morgan@usps.gov, james.p.dissenger@usps.gov Mailing address: 1400 Harrisburg Pike Lancaster, PA 17604-9331 Phone number: 717-396-6923	597781	2100 N. 13th St. Reading, PA 19612-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	3/6/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
READING VMF	USPS	Name: Bruce Morgan, VMF Mgr. USPS UST POC: Jim Dissenger, VMF Supervisor Email address: bruce.r.morgan@usps.gov, james.p.dissenger@usps.gov Mailing address: 1400 Harrisburg Pike Lancaster, PA 17604-9331 Phone number: 717-396-6923	597782	2100 N. 13th St. Reading, PA 19612-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	3/6/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
READING VMF	USPS	Name: Bruce Morgan, VMF Mgr. USPS UST POC: Jim Dissenger, VMF Supervisor Email address: bruce.r.morgan@usps.gov, james.p.dissenger@usps.gov Mailing address: 1400 Harrisburg Pike Lancaster, PA 17604-9331 Phone number: 717-396-6923	597779	2100 N. 13th St. Reading, PA 19612-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	3/6/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
READING VMF	USPS	Name: Bruce Morgan, VMF Mgr. USPS UST POC: Jim Dissenger, VMF Supervisor Email address: bruce.r.morgan@usps.gov, james.p.dissenger@usps.gov Mailing address: 1400 Harrisburg Pike Lancaster, PA 17604-9331 Phone number: 717-396-6923	597780	2100 N. 13th St. Reading, PA 19612-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	3/6/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
LEHIGH VALLEY VMF	USPS	Name: John McAtee, VMF Mgr. USPS UST POC: Raymond Barth, VMF Supervisor Email address: john.t.mcatee@usps.gov, raymond.barth@usps.gov Mailing address: 17 S. Commerce Way Lehigh Valley, PA 18002-9371 Phone number: 610-882-3248; 610-882-3250	695208	2100 N. 13th St. Reading, PA 19612-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
LEHIGH VALLEY VMF	USPS	Name: John McAtee, VMF Mgr. USPS UST POC: Raymond Barth, VMF Supervisor Email address: john.t.mcatee@usps.gov, raymond.barth@usps.gov Mailing address: 17 S. Commerce Way Lehigh Valley, PA 18002-9371 Phone number: 610-882-3248; 610-882-3250	695209	2100 N. 13th St. Reading, PA 19612-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
LEHIGH VALLEY VMF	USPS	Name: John McAtee, VMF Mgr. USPS UST POC: Raymond Barth, VMF Supervisor Email address: john.t.mcatee@usps.gov, raymond.barth@usps.gov Mailing address: 17 S. Commerce Way Lehigh Valley, PA 18002-9371 Phone number: 610-882-3248; 610-882-3250	695211	2100 N. 13th St. Reading, PA 19612-9331	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
SCRANTON VMF	USPS	Name: Jamie Johnson, VMF Supervisor USPS UST POC: Jack Dolan, Administrative Clerk Email address: james.t.johnson@usps.gov, jack.dolan.@usps.gov Mailing address: 2800 Stafford Ave. Scranton, PA 18505-9371 Phone number: 570-969-5172; 570-969-5171	65048	2800 Stafford Ave. Scranton, PA 18505-9371	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/1/2005 State PA Licensed Site Professional (DEP)	UST is compliant.						
SCRANTON VMF	USPS	Name: Jamie Johnson, VMF Supervisor USPS UST POC: Jack Dolan, Administrative Clerk Email address: james.t.johnson@usps.gov, jack.dolan.@usps.gov Mailing address: 2800 Stafford Ave. Scranton, PA 18505-9371 Phone number: 570-969-5172; 570-969-5171	65049	2800 Stafford Ave. Scranton, PA 18505-9371	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/1/2005 State PA Licensed Site Professional (DEP)	UST is compliant.						
PITTSBURGH VMF	USPS	Name: Kevin Coyle, VMF Manager Email address: kevin.coyle@usps.gov Mailing address: 1136 Western Ave. Pittsburgh, PA 15233 Phone number: 412-359-7681	580058	1001 California Ave. Pittsburgh, PA 15290	Yes	Yes	No	Yes Release Prevention	8/22/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
PITTSBURGH VMF	USPS	Name: Kevin Coyle, VMF Manager Email address: kevin.coyle@usps.gov Mailing address: 1136 Western Ave. Pittsburgh, PA 15233 Phone number: 412-359-7681	580059	1001 California Ave. Pittsburgh, PA 15290	Yes	Yes	No	Yes Release Prevention	8/22/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
PITTSBURGH VMF	USPS	Name: Kevin Coyle, VMF Manager Email address: kevin.coyle@usps.gov Mailing address: 1136 Western Ave. Pittsburgh, PA 15233 Phone number: 412-359-7681	580060	1001 California Ave. Pittsburgh, PA 15290	Yes	Yes	No	Yes Release Prevention	8/22/2003 State PA Licensed Site Professional (DEP)	UST is compliant.						
CAVE SPRING AO	USPS	Name: Richard Kassebaum, Customer Service Mgr. Email address: richard.a.kassebaum Mailing address: 4069 Postal Drive Roanoke, VA 24018-9908 Phone number: 540-772-3245	2014518-1	4069 Postal Drive Roanoke, VA 24018-9908	Yes	Yes	No	No	4/1/2002 State VA Licensed Site Professional	UST is compliant.					Added AO to Facility Name.	
CLEVELAND VMF	USPS	Name: Ulysses Bradley, VMF Manager USPS UST POC: Kevin Hood Email address: ubradley@email.usps.gov, khood@email.usps.gov Mailing address: 1801 Broadway Ave. Cleveland, OH 44101-9350 Phone number: 216-443-4043	18002476-8	1801 Broadway Ave. Cleveland, OH 44101-9350	Yes	Yes	No	No	Never Inspected	Never Inspected						
CLEVELAND VMF	USPS	Name: Ulysses Bradley, VMF Manager USPS UST POC: Kevin Hood Email address: ubradley@email.usps.gov, khood@email.usps.gov Mailing address: 1801 Broadway Ave. Cleveland, OH 44101-9350 Phone number: 216-443-4043	18002476-10	1801 Broadway Ave. Cleveland, OH 44101-9350	Yes	Yes	No	No	Never Inspected	Never Inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
CLEVELAND VMF	USPS	Name: Ulysses Bradley, VMF Manager USPS UST POC: Kevin Hood Email address: ubradley@email.usps.gov, khood@email.usps.gov Mailing address: 1801 Broadway Ave. Cleveland, OH 44101-9350 Phone number: 216-443-4043	18002476-9	1801 Broadway Ave. Cleveland, OH 44101-9350	Yes	Yes	No	No	Never Inspected	Never Inspected						
COLUMBUS VMF	USPS	Name: Lloyd Dalton, VMF Manager USPS UST POC: Dale Patterson, Supervisor Vehicle Supplies Email address: dale.w.patterson@usps.gov Mailing address: 850 Twin Rivers Dr. Columbus, OH 43216-9361 Phone number: 614-469-4252; 614-469-4286	25004675-1	850 Twin Rivers Dr. Columbus, OH 43216-9361	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/24/1905 Fire Marshall	UST is compliant.						
COLUMBUS VMF	USPS	Name: Lloyd Dalton, VMF Manager USPS UST POC: Dale Patterson, Supervisor Vehicle Supplies Email address: dale.w.patterson@usps.gov Mailing address: 850 Twin Rivers Dr. Columbus, OH 43216-9361 Phone number: 614-469-4252; 614-469-4286	25004675-2	850 Twin Rivers Dr. Columbus, OH 43216-9361	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/24/1905 Fire Marshall	UST is compliant.						
COLUMBUS VMF	USPS	Name: Lloyd Dalton, VMF Manager USPS UST POC: Dale Patterson, Supervisor Vehicle Supplies Email address: dale.w.patterson@usps.gov Mailing address: 850 Twin Rivers Dr. Columbus, OH 43216-9361 Phone number: 614-469-4252; 614-469-4286	25004675-3	850 Twin Rivers Dr. Columbus, OH 43216-9361	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/24/1905 Fire Marshall	UST is compliant.						
COLUMBUS VMF	USPS	Name: Lloyd Dalton, VMF Manager USPS UST POC: Dale Patterson, Supervisor Vehicle Supplies Email address: dale.w.patterson@usps.gov Mailing address: 850 Twin Rivers Dr. Columbus, OH 43216-9361 Phone number: 614-469-4252; 614-469-4286	25004675-4	850 Twin Rivers Dr. Columbus, OH 43216-9361	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/24/1905 Fire Marshall	UST is compliant.						
TOLEDO VMF	USPS	Name: Paul Fillion, VMF Manager Email address: pfillion@email.usps.gov Mailing address: 435 S. Saint Clair St. Toledo, OH 43601 Phone number: 419-245-6948	W011198-1	435 S. Saint Clair St. Toledo, OH 43601	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/17/1905 Local Fire Marshall	UST is compliant.						
TOLEDO VMF	USPS	Name: Paul Fillion, VMF Manager Email address: pfillion@email.usps.gov Mailing address: 435 S. Saint Clair St. Toledo, OH 43601 Phone number: 419-245-6948	W011198-2	435 S. Saint Clair St. Toledo, OH 43601	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/17/1905 Local Fire Marshall	UST is compliant.						
TOLEDO VMF	USPS	Name: Paul Fillion, VMF Manager Email address: pfillion@email.usps.gov Mailing address: 435 S. Saint Clair St. Toledo, OH 43601 Phone number: 419-245-6948	W011198-3	435 S. Saint Clair St. Toledo, OH 43601	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/17/1905 Local Fire Marshall	UST is compliant.						
TOLEDO VMF	USPS	Name: Paul Fillion, VMF Manager Email address: pfillion@email.usps.gov Mailing address: 435 S. Saint Clair St. Toledo, OH 43601 Phone number: 419-245-6948	W011198-4	435 S. Saint Clair St. Toledo, OH 43601	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	6/17/1905 Local Fire Marshall	UST is compliant.						
CINCINNATI VMF	USPS	Name: Dave Combs, VMF Mgr. USPS UST POC: Steve Mitchell, Supervisor, Vehicle Supplies Email address: david.o.combs@usps.gov, steve.j.mitchell@usps.gov Mailing address: 1591 Dalton Ave. Cincinnati, OH 45234-9721 Phone number: 513-684-5627; 513-684-5631	31002231-1	1591 Dalton Ave. Cincinnati, OH 45234-9721	Yes	Yes	No	Yes Release Prevention, Release Response & Corrective Action (Annual OMM Plan Training), Release Detection Annual (Veeder Root System Training)	Never Inspected	Never Inspected					Never Inspected, but Annual Stage II Vapor Recovery conducted by State.	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
CINCINNATI VMF	USPS	Name: Dave Combs, VMF Mgr. USPS UST POC: Steve Mitchell, Supervisor, Vehicle Supplies Email address: david.o.combs@usps.gov, steve.j.mitchell@usps.gov Mailing address: 1591 Dalton Ave. Cincinnati, OH 45234-9721 Phone number: 513-684-5627; 513-684-5631	31002231-2	1591 Dalton Ave. Cincinnati, OH 45234-9721	Yes	Yes	No	Yes Release Prevention, Release Response & Corrective Action (Annual OMM Plan Training), Release Detection Annual (Veeder Root System Training)	Never Inspected	Never Inspected					Never Inspected, but Annual Stage II Vapor Recovery conducted by State.	
CINCINNATI VMF	USPS	Name: Dave Combs, VMF Mgr. USPS UST POC: Steve Mitchell, Supervisor, Vehicle Supplies Email address: david.o.combs@usps.gov, steve.j.mitchell@usps.gov Mailing address: 1591 Dalton Ave. Cincinnati, OH 45234-9721 Phone number: 513-684-5627; 513-684-5631	31002231-3	1591 Dalton Ave. Cincinnati, OH 45234-9721	Yes	Yes	No	Yes Release Prevention, Release Response & Corrective Action (Annual OMM Plan Training), Release Detection Annual (Veeder Root System Training)	Never Inspected	Never Inspected					Never Inspected, but Annual Stage II Vapor Recovery conducted by State.	
YOUNGSTOWN VMF	USPS	Name: Maureen Gutierrez, VMF Mgr. USPS UST POC: Tom Schobel, Administrative Clerk Email address: maureen.gutierrez@usps.gov Mailing address: 99 S. Walnut St. Youngstown, OH 44501 Phone number: 330-740-8920	50002217-7	99 S. Walnut St. Youngstown, OH 44501	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
YOUNGSTOWN VMF	USPS	Name: Maureen Gutierrez, VMF Mgr. USPS UST POC: Tom Schobel, Administrative Clerk Email address: maureen.gutierrez@usps.gov Mailing address: 99 S. Walnut St. Youngstown, OH 44501 Phone number: 330-740-8920	50002217-8	99 S. Walnut St. Youngstown, OH 44501	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
YOUNGSTOWN VMF	USPS	Name: Maureen Gutierrez, VMF Mgr. USPS UST POC: Tom Schobel, Administrative Clerk Email address: maureen.gutierrez@usps.gov Mailing address: 99 S. Walnut St. Youngstown, OH 44501 Phone number: 330-740-8920	50002217-9	99 S. Walnut St. Youngstown, OH 44501	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
YOUNGSTOWN VMF	USPS	Name: Maureen Gutierrez, VMF Mgr. USPS UST POC: Tom Schobel, Administrative Clerk Email address: maureen.gutierrez@usps.gov Mailing address: 99 S. Walnut St. Youngstown, OH 44501 Phone number: 330-740-8920	50002217-10	99 S. Walnut St. Youngstown, OH 44501	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
WARREN VMF	USPS	Name: Maureen Gutierrez, VMF Mgr. USPS UST POC: Tom Schobel, Administrative Clerk Email address: maureen.gutierrez@usps.gov Mailing address: 99 S. Walnut St. Youngstown, OH 44501 Phone number: 330-740-8920	78002361-1	2801 Niles Rd. SE Warren, OH 44484	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
WARREN VMF	USPS	Name: Maureen Gutierrez, VMF Mgr. USPS UST POC: Tom Schobel, Administrative Clerk Email address: maureen.gutierrez@usps.gov Mailing address: 99 S. Walnut St. Youngstown, OH 44501 Phone number: 330-740-8920	78002361-2	2801 Niles Rd. SE Warren, OH 44484	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
AKRON VMF	USPS	Name: Myrick Russel, VMF Mgr. USPS UST POC: Roger Leisure Email address: myrick.r.russel@usps.gov Mailing address: 625 Wolf Ledges Pkwy Akron, OH 44309-9710 Phone number: 330-996-9570; 330-996-9572	77001419-1	625 Wolf Ledges Pkwy Akron, OH 44309-9710	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
AKRON VMF	USPS	Name: Myrick Russel, VMF Mgr. USPS UST POC: Roger Leisure Email address: myrick.r.russel@usps.gov Mailing address: 625 Wolf Ledges Pkwy Akron, OH 44309-9710 Phone number: 330-996-9570; 330-996-9572	77001419-2	625 Wolf Ledges Pkwy Akron, OH 44309-9710	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
AKRON VMF	USPS	Name: Myrick Russel, VMF Mgr. USPS UST POC: Roger Leisure Email address: myrick.r.russel@usps.gov Mailing address: 625 Wolf Ledges Pkwy Akron, OH 44309-9710 Phone number: 330-996-9570; 330-996-9572	77001419-3	625 Wolf Ledges Pkwy Akron, OH 44309-9710	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
AKRON VMF	USPS	Name: Myrick Russel, VMF Mgr. USPS UST POC: Roger Leisure Email address: myrick.r.russel@usps.gov Mailing address: 625 Wolf Ledges Pkwy Akron, OH 44309-9710 Phone number: 330-996-9570; 330-996-9572	77001419-4	625 Wolf Ledges Pkwy Akron, OH 44309-9710	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected					Changed used oil tank size from 1,000 gallons to 600 gallons.	
CANTON VMF	USPS	Name: Ed Dagg, VMF Mgr. mail address: edward.m.dagg@usps.gov Mailing address: 2650 Cleveland Ave Canton, OH 44711-9703 Phone number: 330-438-6404	76002419-5	2650 Cleveland Ave Canton, OH 44711-9703	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
CANTON VMF	USPS	Name: Ed Dagg, VMF Mgr. mail address: edward.m.dagg@usps.gov Mailing address: 2650 Cleveland Ave Canton, OH 44711-9703 Phone number: 330-438-6404	76002419-6	2650 Cleveland Ave Canton, OH 44711-9703	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
CANTON VMF	USPS	Name: Ed Dagg, VMF Mgr. mail address: edward.m.dagg@usps.gov Mailing address: 2650 Cleveland Ave Canton, OH 44711-9703 Phone number: 330-438-6404	76002419-7	2650 Cleveland Ave Canton, OH 44711-9703	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
CANTON VMF	USPS	Name: Ed Dagg, VMF Mgr. mail address: edward.m.dagg@usps.gov Mailing address: 2650 Cleveland Ave Canton, OH 44711-9703 Phone number: 330-438-6404	76002419-8	2650 Cleveland Ave Canton, OH 44711-9703	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						
CHARLESTON VMF	USPS	Name: Ellen Keefer, VMF Mgr. Email address: ellen.m.keefer@usps.gov Mailing address: 602 Donnelly Street Charleston, WV 25301-9721 Phone number: 304-344-0487	2002589-1	602 Donnelly Street Charleston, WV 25301-9721	Yes	Yes	No	No	3/1/2004 State SC Licensed Site Professional	UST is non-compliant.	State SC Licensed Site Professional	Yes ^{ix}	Yes ^{ix}			
CHARLESTON VMF	USPS	Name: Ellen Keefer, VMF Mgr. Email address: ellen.m.keefer@usps.gov Mailing address: 602 Donnelly Street Charleston, WV 25301-9721 Phone number: 304-344-0487	2002589-2	602 Donnelly Street Charleston, WV 25301-9721	Yes	Yes	No	No	3/1/2004 State SC Licensed Site Professional	UST is compliant.						
CLARKSBURG VMF	USPS	Name: Steve Kovalic, VMF Mgr. Email address: steven.m.kovalic@usps.gov Mailing address: 200 Cava Drive Clarksburg, WV Phone number: 304-623-7771	1709145-1	200 Cava Drive Clarksburg, WV	Yes	Yes	No	No	Never Inspected	Never Inspected						
CLARKSBURG VMF	USPS	Name: Steve Kovalic, VMF Mgr. Email address: steven.m.kovalic@usps.gov Mailing address: 200 Cava Drive Clarksburg, WV Phone number: 304-623-7771	1709145-2	200 Cava Drive Clarksburg, WV	Yes	Yes	No	No	Never Inspected	Never Inspected						
HUNTINGTON VMF	USPS	Name: Jack Golden, Lead Mechanic Email address: jack.golden@usps.gov Mailing address: 1000 Virginia Ave. W Huntington, WV 25704-9990 Phone number: 304-526-9626	0600705-1	1000 Virginia Ave. W Huntington, WV 25704-9990	Yes	Yes	No	No	3/1/2006 EPA Inspector	UST is compliant.						
LEXINGTON VMF	USPS	Name: Maria Gaines, VMF Mgr. USPS UST POC: Dean Neace, Administrative Clerk Email address: maria.d.gaines@usps.gov, wallace.d.neace@usps.gov Mailing address: 1088 Nandino Blvd. Lexington, KY 40511-9998 Phone number: 859-231-6735; 859-231-6737	1105-1	1088 Nandino Blvd. Lexington, KY 40511-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/12/2005 EPA Inspector	UST is compliant.					Added VMF to Facility Name.	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
LEXINGTON VMF	USPS	Name: Maria Gaines, VMF Mgr. USPS UST POC: Dean Neace, Administrative Clerk Email address: maria.d.gaines@usps.gov, wallace.d.neace@usps.gov Mailing address: 1088 Nandino Blvd. Lexington, KY 40511-9998 Phone number: 859-231-6735; 859-231-6737	1105-2	1088 Nandino Blvd. Lexington, KY 40511-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/12/2005 EPA Inspector	UST is compliant.						
LEXINGTON VMF	USPS	Name: Maria Gaines, VMF Mgr. USPS UST POC: Dean Neace, Administrative Clerk Email address: maria.d.gaines@usps.gov, wallace.d.neace@usps.gov Mailing address: 1088 Nandino Blvd. Lexington, KY 40511-9998 Phone number: 859-231-6735; 859-231-6737	1105-3	1088 Nandino Blvd. Lexington, KY 40511-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	12/12/2005 EPA Inspector	UST is compliant.						
HARRISBURG VMF	USPS	Name: Rick Wilhelm, VMF Mgr. USPS UST POC: Todd Sulouff, Supervisor Email address: rich.wilhelm@usps.gov, t.sulouff@email.usps.gov Mailing address: 1425 Crooked Hill Rd Harrisburg, PA 17106-9711 Phone number: 717-257-2175; 717-257-2178	637259	1425 Crooked Hill Rd Harrisburg, PA 17106-9711	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	11/1/2005 State PA Licensed Site Professional (DEP)	UST is compliant.					Added VMF to Facility Name.	
HARRISBURG VMF	USPS	Name: Rick Wilhelm, VMF Mgr. USPS UST POC: Todd Sulouff, Supervisor Email address: rich.wilhelm@usps.gov, t.sulouff@email.usps.gov Mailing address: 1425 Crooked Hill Rd Harrisburg, PA 17106-9711 Phone number: 717-257-2175; 717-257-2178	637260	1425 Crooked Hill Rd Harrisburg, PA 17106-9711	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	11/1/2005 State PA Licensed Site Professional (DEP)	UST is compliant.					Added VMF to Facility Name.	
HARRISBURG VMF	USPS	Name: Rick Wilhelm, VMF Mgr. USPS UST POC: Todd Sulouff, Supervisor Email address: rich.wilhelm@usps.gov, t.sulouff@email.usps.gov Mailing address: 1425 Crooked Hill Rd Harrisburg, PA 17106-9711 Phone number: 717-257-2175; 717-257-2178	637261	1425 Crooked Hill Rd Harrisburg, PA 17106-9711	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	11/1/2005 State PA Licensed Site Professional (DEP)	UST is compliant.					Added VMF to Facility Name.	
DAYTON VMF	USPS	Name: James Earnest, VMF Mgr. USPS UST POC: Dwayne Humdley, Store Keeper Email address: james.k.earnest@usps.gov, dwayne.l.humdley@usps.gov Mailing address: 1111 E. 5th St. Dayton, OH 45401-9998 Phone number: 937-227-1114; 937-227-1116	57001471-1	1111 E. 5th St. Dayton, OH 45401-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected					Added VMF to Facility Name.	
BOWLING GREEN VMF	USPS	Name: Charles Longston, Louisville VMF Supervisor USPS UST POC: Steve Hilton, Lead Mechanic Email address: charles.longston@usps.gov Mailing address: 1227 Center St. Bowling Green, KY 42101 Phone number: 270-782-4208; 270-782-9342	19101114-1	1227 Center St. Bowling Green, KY 42101	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never Inspected						Property is Leased. Owner Information: Leased Contact: Clifton Smith. Phone: 270-842-2173. Address: 1141 Glenview Way, Bowling Green, KY 42104.

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
ATLANTA VMF	USPS	Name: Alfrad Cardenas Mailing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	9060338-13	3900 Crown Rd. SW Atlanta, GA 30304-9323	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Data from the SEA Bulk Storage Container Survey conducted in 2004	
ATLANTA VMF	USPS	Name: Alfrad Cardenas Mailing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	9060338-14	3900 Crown Rd. SW Atlanta, GA 30304-9323	Yes	Yes	no	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Data from the SEA Bulk Storage Container Survey conducted in 2004	
ATLANTA VMF	USPS	Name: Mike Ivie, Dist. VMF Mgr., USPS UST POC: Mike Wallace, VMF Mgr. Email: a.m.ivie@usps.gov, michael.l.wallace@usps.gov Mailing Address: 3900 Crown Rd. SW Atlanta, GA 30304-9323 Phone Number: 770-717-3794, 404-765-7742	9060338-15	3900 Crown Rd. SW Atlanta, GA 30304-9323	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Data from the SEA Bulk Storage Container Survey conducted in 2004	
MEMPHIS VMF (@BMC)	USPS	Name: George Tong, VMF Mgr., USPS UST POC: Horace Owens, Lead Mechanic Email: george.p.tong@usps.gov Mailing Address: 1921 Elvis Presley Blvd. Memphis, TN 38136-9997 Phone Number: 901-521-2207, 901-947-7579	0790801-1	1921 Elvis Presley Blvd. Memphis, TN 38136-9997	Yes	Yes	No	Yes Stormwater Management Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Added VMF (@BMC) to Facility Name.	
MEMPHIS VMF (@BMC)	USPS	Name: George Tong, VMF Mgr., USPS UST POC: Horace Owens, Lead Mechanic Email: george.p.tong@usps.gov Mailing Address: 1921 Elvis Presley Blvd. Memphis, TN 38136-9997 Phone Number: 901-521-2207, 901-947-7579	0790801-2	1921 Elvis Presley Blvd. Memphis, TN 38136-9997	Yes	Yes	No	Yes Stormwater Management Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Added VMF (@BMC) to Facility Name.	
MEMPHIS VMF	USPS	Name: George Tong, VMF Mgr. Email: george.p.tong@usps.gov Mailing Address: 685 S. 3rd St. Memphis, TN 38101-9721 Phone Number: 901-521-2207	0790802-6A	685 S. 3rd St. Memphis, TN 38101-9721	Yes	Yes	No	Yes Stormwater Management Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Data from the SEA Bulk Storage Container Survey conducted in 2004	
MEMPHIS VMF	USPS	Name: George Tong, VMF Mgr. Email: george.p.tong@usps.gov Mailing Address: 685 S. 3rd St. Memphis, TN 38101-9721 Phone Number: 901-521-2207	0790802-5A	685 S. 3rd St. Memphis, TN 38101-9721	Yes	Yes	No	Yes Stormwater Management Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Data from the SEA Bulk Storage Container Survey conducted in 2004	
NORTH METRO VMF	USPS	Name: Rod Sweetwine roderick.j.sweetwine@usps.gov Mailing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348	9067077-1	1605 Boggs Rd. Atlanta, GA 30026-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Added VMF to Facility Name.	
NORTH METRO VMF	USPS	Name: Mike Ivie, Dist. VMF Mgr. Email: a.m.ivie@usps.gov Mailing Address: 1605 Boggs Rd. Atlanta, GA 30026-9998 Phone Number: 770-717-3794	9067077-2	1605 Boggs Rd. Atlanta, GA 30026-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Added VMF to Facility Name.	
NORTH METRO VMF	USPS	Name: Mike Ivie, Dist. VMF Mgr. Email: a.m.ivie@usps.gov Mailing Address: 1605 Boggs Rd. Atlanta, GA 30026-9998 Phone Number: 770-717-3794	9067077-3	1605 Boggs Rd. Atlanta, GA 30026-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	Never Inspected	Never inspected					Added VMF to Facility Name.	
OAK RIDGE MPO	USPS	Name: Frank Chmielewicz, Postmaster Email: frank.p.chmielewicz@usps.gov Mailing Address: 301 S. Tulane Ave. Oak Ridge, TN 37830-9998 Phone Number: 865-482-2750	4311-2A	301 S. Tulane Ave. Oak Ridge, TN 37830-9998	Yes	Yes	No	No	6/8/2000 State TN Licensed Site Professional	UST is compliant.					Added MPO to Facility Name.	
JOHNSON CITY VMF	USPS	Name: Charles Campbell, VMF Supervisor Email: charles.b.campbell@usps.gov Mailing Address: 1414 E. Main St. Johnson City, TN 37601-4969 Phone Number: 423-434-2180	0900337-1A	1414 E. Main St. Johnson City, TN 37601-4969	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	State TN Licensed Site Professional	UST is non-compliant.	State TN Licensed Site Professional	Yes ^(x)	Yes ^(x)			

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
KNOXVILLE P&DC	USPS	Name: Dale Reese, Plant Mgr., USPS UST POC: Albert Craig, Maintenance Mgr. Email: rdale.reese@usps.gov, albert.m.craig@usps.gov Mailing Address: 1237 E. Weisgarber Rd. Knoxville, TN 37950-9998 Phone Number: 865-558-4536, 865-558-4553	470878-1A	1237 E. Weisgarber Rd. Knoxville, TN 37950-9998	Yes	Yes	No	Yes Spill Leak & Response Release Prevention, Release Detection, Release Response & Corrective Action	State TN Licensed Site Professional	UST is compliant.					Data from the SEA Bulk Storage Container Survey conducted in 2004	
KNOXVILLE P&DC	USPS	Name: Dale Reese, Plant Mgr., USPS UST POC: Albert Craig, Maintenance Mgr. Email: rdale.reese@usps.gov, albert.m.craig@usps.gov Mailing Address: 1237 E. Weisgarber Rd. Knoxville, TN 37950-9998 Phone Number: 865-558-4536, 865-558-4553	470878-2A	1237 E. Weisgarber Rd. Knoxville, TN 37950-9998	Yes	Yes	No	Yes Spill Leak & Response Release Prevention, Release Detection, Release Response & Corrective Action	State TN Licensed Site Professional	UST is compliant.					Data from the SEA Bulk Storage Container Survey conducted in 2004	
CHATTANOOGA GARAGE/VMF	USPS	Name: Janis Orr, Supervisor Email: janis.l.orr@usps.gov Mailing Address: 1112 Riverfront Parkway Chattanooga, TN 37402-9721 Phone Number: 423-266-5811	0330774-2A	1112 Riverfront Parkway Chattanooga, TN 37402-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	9/12/2005 State TN Licensed Site Professional	UST is compliant.					Added Garage to Facility Name.	
CHATTANOOGA GARAGE/VMF	USPS	Name: Janis Orr, Supervisor Email: janis.l.orr@usps.gov Mailing Address: 1112 Riverfront Parkway Chattanooga, TN 37402-9721 Phone Number: 423-266-5811	0330774-1A	1112 Riverfront Parkway Chattanooga, TN 37402-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	9/12/2005 State TN Licensed Site Professional	UST is compliant.					Added Garage to Facility Name.	
CHATTANOOGA GARAGE/VMF	USPS	Name: Janis Orr, Supervisor Email: janis.l.orr@usps.gov Mailing Address: 1112 Riverfront Parkway Chattanooga, TN 37402-9721 Phone Number: 423-266-5811	0330774-3A	1112 Riverfront Parkway Chattanooga, TN 37402-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	9/12/2006 State TN Licensed Site Professional	UST is compliant.					Added Garage to Facility Name.	
MIAMI VMF	USPS	Name: Robert Sibal Mailing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	8520606-1	2250 NW 72 Ave. Miami, FL 33152-9891	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	5/11/2006 State FL Licensed Site Professional	UST is compliant.						
MIAMI VMF	USPS	Name: Tony San Nicholas Mailing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	8520606-2	2250 NW 72 Ave. Miami, FL 33152-9891	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	5/11/2008 State FL Licensed Site Professional	UST is compliant.						
MIAMI VMF	USPS	Name: Tony San Nicholas Mailing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	8520606-3	2250 NW 72 Ave. Miami, FL 33152-9891	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	5/11/2009 State FL Licensed Site Professional	UST is compliant.						
MIAMI VMF	USPS	Name: Tony San Nicholas Mailing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	8520606-4	2250 NW 72 Ave. Miami, FL 33152-9891	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	5/11/2010 State FL Licensed Site Professional	UST is compliant.						
MIAMI VMF	USPS	Name: Herb Yokoyama, Maintenance Manager, Mailing address: 3600 Aolele Street Honolulu, HI 96820 Phone number: 808-423-3887	8520606-5	2250 NW 72 Ave. Miami, FL 33152-9891	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	5/11/2011 State FL Licensed Site Professional	UST is compliant.						
MIAMI VMF	USPS	Name: Les Machek, Dist. VMF Mgr., USPS UST POC: Luis Lopez, Supervisor, Vehicle Maint. Email: luis.a.lopez@usps.gov Mailing Address: 2250 NW 72 Ave. Miami, FL 33152-9891 Phone Number: 305-470-0258	8520606-6	2250 NW 72 Ave. Miami, FL 33152-9891	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	5/11/2012 State FL Licensed Site Professional	UST is compliant.						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
MIAMI VMF	USPS	Name: Les Machek, Dist. VMF Mgr., USPS UST POC: Luis Lopez, Supervisor, Vehicle Maint. Email: luis.a.lopez@usps.gov Mailing Address: 2250 NW 72 Ave. Miami, FL 33152-9891 Phone Number: 305-470-0258	8520606-7	2250 NW 72 Ave. Miami, FL 33152-9891	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response & Corrective Action	5/11/2013 State FL Licensed Site Professional	UST is compliant.					Data from the SEA Bulk Storage Container Survey conducted in 2004	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
BACON STATION	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	6949-1	2727 E. 55th Street Indianapolis, IN 46220-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected					Tank size changed from 10000 to 12000	
MISHAWAKA	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	15704-1	111 E. 3rd Street Mishawaka, IN 46544-9998	Yes	Yes	no	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected						Property is Leased. Owner Information. Willie P. Sylvester Jr., 760-568-0322, 138 Running Springs Drive, Palm Desert, CA 92211-3214
SAINT LOUIS BMC	USPS	Name: Kevin Nielsen, Plant Manager USPS UST POC: Craig Seavert Email address: craig.m.seavert@usps.gov Mailing address: 5800 Phantom Drive Hazelwood, MO 63042-2487 Phone number: 314-895-9201	0001459-5	5800 Phantom Drive Hazelwood, MO 63042-2487	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	7/31/2004 State MO Licensed Site Professional	UST is compliant.						
SOUTH BEND VMF	USPS	Name: Randy Stines, VMF Mgr. E mail address: randy.stines@usps.gov Mailing address: 424 S. Michigan Street South Bend, IN 46624-9351 Phone number: 574-282-8471	6914-1	424 S. Michigan Street South Bend, IN 46624-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/20/2002 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1382104 to 1444549	
SOUTH BEND VMF	USPS	Name: Randy Stines, VMF Mgr. E mail address: randy.stines@usps.gov Mailing address: 424 S. Michigan Street South Bend, IN 46624-9351 Phone number: 574-282-8471	6914-2	424 S. Michigan Street South Bend, IN 46624-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/20/2002 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1382104 to 1444549	
SOUTH BEND VMF	USPS	Name: Randy Stines, VMF Mgr. E mail address: randy.stines@usps.gov Mailing address: 424 S. Michigan Street South Bend, IN 46624-9351 Phone number: 574-282-8471	6914-3	424 S. Michigan Street South Bend, IN 46624-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/20/2002 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1382104 to 1444549	
SOUTH BEND VMF	USPS	Name: Randy Stines, VMF Mgr. E mail address: randy.stines@usps.gov Mailing address: 424 S. Michigan Street South Bend, IN 46624-9351 Phone number: 574-282-8471	6914-4	424 S. Michigan Street South Bend, IN 46624-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/20/2002 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1382104 to 1444549; Contents changed from Motor Oil to ATF.	
SOUTH BEND VMF	USPS	Name: Rod Sweetwine roderick.j.sweetwine@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348	6914-5	424 S. Michigan Street South Bend, IN 46624-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/20/2002 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1382104 to 1444549	
CHICAGO VMF	USPS	Name: Laura Jones, General Clerk Email address: laura.a.jones@usps.gov Mailing address: 740 S. Canal Street Chicago, IL 60607-9361 Phone number: 312-983-8727	2-001281-1	740 S. Canal Street Chicago, IL 60607-9361	Yes	Yes	No	Yes UST Leak Detection & Monthly Inspection Training	5/12/2006 Fire Marshall	UST is compliant.					Tank Type changed from Fiberglass 2-Wall to Steel 2-Wall	
CHICAGO VMF	USPS	Name: Laura Jones, General Clerk Email address: laura.a.jones@usps.gov Mailing address: 740 S. Canal Street Chicago, IL 60607-9361 Phone number: 312-983-8727	2-001281-2	740 S. Canal Street Chicago, IL 60607-9361	Yes	Yes	No	Yes UST Leak Detection & Monthly Inspection Training	5/12/2006 Fire Marshall	UST is compliant.					Tank Type changed from Fiberglass 2-Wall to Steel 2-Wall	
CHICAGO VMF	USPS	Name: Laura Jones, General Clerk Email address: laura.a.jones@usps.gov Mailing address: 740 S. Canal Street Chicago, IL 60607-9361 Phone number: 312-983-8727	2-001281-3	740 S. Canal Street Chicago, IL 60607-9361	Yes	Yes	No	Yes UST Leak Detection & Monthly Inspection Training	5/12/2008 Fire Marshall	UST is compliant.					Tank Type changed from Fiberglass 2-Wall to Steel 2-Wall	
CHICAGO BMC VMF	USPS	Name: Alonzo Taylor, VMF Supervisor Email address: alonzo.taylor@usps.gov Mailing address: 7500 W. Roosevelt Road Forest Park, IL 60130-9998 Phone number: 708-583-4532	2-008452-2	7500 W. Roosevelt Road Forest Park, IL 60130-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	12/31/2004 Fire Marshall	UST is compliant.					Added BMC VMF to Facility Name	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
CHICAGO BMC VMF	USPS	Name: Alonzo Taylor, VMF Supervisor Email address: alonzo.taylor@usps.gov Mailing address: 7500 W. Roosevelt Road Forest Park, IL 60130-9998 Phone number: 708-583-4532	2-008452-1	7500 W. Roosevelt Road Forest Park, IL 60130-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	12/31/2004 Fire Marshall	UST is compliant.					Added BMC VMF to Facility Name	
SAINT LOUIS VMF	USPS	Name: Neal Worland, VMF Mgr. Email address: neal.t.worland@usps.gov Mailing address: 1720 Market Street St. Louis, MO 63155-9099 Phone number: 314-436-4314	0012717-1	1720 Market Street St. Louis, MO 63155-9099	Yes	Yes	No	Yes Spill and Leak Training, SPCC Annual Training Release Prevention, Release Detection, Release Response and Corrective Action	2002 Federal Regulator	UST is compliant.						
SAINT LOUIS VMF	USPS	Name: Neal Worland, VMF Mgr. Email address: neal.t.worland@usps.gov Mailing address: 1720 Market Street St. Louis, MO 63155-9099 Phone number: 314-436-4314	0012717-2	1720 Market Street St. Louis, MO 63155-9099	Yes	Yes	No	Yes Spill and Leak Training, SPCC Annual Training Release Prevention, Release Detection, Release Response and Corrective Action	2002 Federal Regulator	UST is compliant.						
ROCKFORD VMF	USPS	Name: Donald Brown, Manager Vehicle Maintenance Email address: d.brown@usps.gov Mailing address: 5225 Harrison Avenue Rockford, IL 61125-9721 Phone number: 815-229-4827	1-024290-1	5225 Harrison Avenue Rockford, IL 61125-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	6/26/2000 Fire Marshall	UST is compliant.						
ROCKFORD VMF	USPS	Name: Donald Brown, Manager Vehicle Maintenance Email address: d.brown@usps.gov Mailing address: 5225 Harrison Avenue Rockford, IL 61125-9721 Phone number: 815-229-4827	1-024290-2	5225 Harrison Avenue Rockford, IL 61125-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	6/26/2000 Fire Marshall	UST is compliant.						
BEDFORD PARK VMF	USPS	Name: Robert Sibal Mail ing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	2-026442-00	7423 South Sayre Bedford Park, IL 60499-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/4/2005 Fire Marshall	UST is compliant.						
BEDFORD PARK VMF	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	2-026442-04	7423 South Sayre Bedford Park, IL 60499-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/4/2005 Fire Marshall	UST is compliant.						
BEDFORD PARK VMF	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	2-026442-01	7423 South Sayre Bedford Park, IL 60499-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/4/2005 Fire Marshall	UST is compliant.						
BEDFORD PARK VMF	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	2-026442-02	7423 South Sayre Bedford Park, IL 60499-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	5/4/2005 Fire Marshall	UST is compliant.						
CASTLETON	USPS	Name: Herb Yokoyama, Maintenance Manager, Mail ing address: 3600 Aoolee Street Honolulu, HI 96820 Phone number: 808-423-3887	15833-1	8710 Bash Street Indianapolis, IN 46256-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected						
EAGLE CREEK	USPS	Name: Bill Jamerson, A/Branch Mgr. Email address: william.c.jamerson@usps.gov Mailing address: 6401 Gateway Indianapolis, IN 46254-9998 Phone number: 317-464-6814	15863-1	6401 Gateway Indianapolis, IN 46254-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	1/15/2002 State IN Licensed Site Professional	UST is compliant.						
NEW AUGUSTA	USPS	Name: Clint Helmod, Branch Mgr. Email address: clint.helmod@usps.gov Mailing address: 8401 Mollier Road Indianapolis, IN 46268-9998 Phone number: 317-464-6868	15864-1	8401 Mollier Road Indianapolis, IN 46268-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
PARK FLETCHER	USPS	Name: Rick Sconce, Branch Mgr. USPS UST POC: Linda Lemon Email address: rick.sconce@usps.gov Mailing address: 2760 Fortune Circle E Indianapolis, IN 46241-9998 Phone number: 317-464-6841	6951-1	2760 Fortune Circle E Indianapolis, IN 46241-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	8/27/1998 State IN Licensed Site Professional	UST is compliant.						
SOUTHPORT	USPS	Name: Patricia Klimek, Branch Mgr. Email address: patricia.j.klimek@usps.gov Mailing address: 1701 E. Edgewood Avenue Indianapolis, IN 46227-9998 Phone number: 317-464-6817	6952-1	1701 E. Edgewood Avenue Indianapolis, IN 46227-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected						
WOODBIDGE	USPS	Name: Greg Tielking, A/Station Mgr. USPS UST POC: Mike Nickless Mailing address: 3210 E. 10th Street Bloomington, IN 47408-9990 Phone number: 812-331-4553 812-331-4554	15701-1	3210 E. 10th Street Bloomington, IN 47408-9990	Yes	Yes	No	No Have SWPPP but personnel lost trained list of facility	6/9/1998 State IN Licensed Site Professional	UST is compliant.						
FT WAYNE VMF	USPS	Name: Tracye Trent-Cashdollar, VMF Mgr. Email address: tracye.d.trent-cashdollar@usps.gov Mailing address: 1501 S. Clinton Street For Wayne, IN 46802-9351 Phone number: 260-427-7342	6926-1	1501 S. Clinton Street For Wayne, IN 46802-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected						
FT WAYNE VMF	USPS	Name: Tracye Trent-Cashdollar, VMF Mgr. Email address: tracye.d.trent-cashdollar@usps.gov Mailing address: 1501 S. Clinton Street For Wayne, IN 46802-9351 Phone number: 260-427-7342	6926-2	1501 S. Clinton Street For Wayne, IN 46802-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected						
FT WAYNE VMF	USPS	Name: Tracye Trent-Cashdollar, VMF Mgr. Email address: tracye.d.trent-cashdollar@usps.gov Mailing address: 1501 S. Clinton Street For Wayne, IN 46802-9351 Phone number: 260-427-7342	6926-3	1501 S. Clinton Street For Wayne, IN 46802-9351	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected						
NORA VMF	USPS	Name: Mervin Simpson, Supervisor Email address: mervin.t.simpson@usps.gov Mailing address: 1300 E. 86th Street Indianapolis, IN 46240-1910 Phone number: 317-464-6247	6897-1	1300 E. 86th Street Indianapolis, IN 46240-1910	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	8/2004 State IN Licensed Site Professional	UST is compliant.						Property is Leased. Owner Information. P. K. Partners LLC. 317-817-8888, 3815 River Crossing Parkway, Indianapolis, IN 46240.
WAUWATOSA	USPS	Name: Ed Graczyk, Station Mgr. Email address: edward.w.graczyk@usps.gov Mailing address: 1655 N. Mayfair Road Wauwatosa, WI 53226 Phone number: 414-258-9217	297378	1655 N. Mayfair Road Wauwatosa, WI 53226	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	7/21/2005 State WI Licensed Site Professional	UST is compliant.						
MADISON VMF	USPS	Name: Michael Zamjahn, VMF Mgr. Email address: michael.g.zamjahn@usps.gov Mailing address: 3902 Milwaukee Street Madison, WI 53714-9998 Phone number: 608-246-1300	273922	3902 Milwaukee Street Madison, WI 53714-9998	Yes	Yes	No	No	Never Inspected	Never inspected						
MADISON VMF	USPS	Name: Michael Zamjahn, VMF Mgr. Email address: michael.g.zamjahn@usps.gov Mailing address: 3902 Milwaukee Street Madison, WI 53714-9998 Phone number: 608-246-1300	273921	3902 Milwaukee Street Madison, WI 53714-9998	Yes	Yes	No	No	Never Inspected	Never inspected					New tank	
MILWAUKEE VMF	USPS	Name: Michael McFarland, VMF Mgr. Email address: michael.d.mcfarland@usps.gov Mailing address: 341 W. Saint Paul Avenue Milwaukee, WI 53203-9721 Phone number: 414-270-2148	305634	341 W. Saint Paul Avenue Milwaukee, WI 53203-9721	Yes	Yes	No	Yes UST OMM Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	12/2005 State WI Licensed Site Professional	UST is compliant.						Property is Leased. Owner Information. Milwaukee Investments, C/O Glenora Co., 735 N. Water St. Suite 712, Milwaukee, WI 53202-4104.
MILWAUKEE VMF	USPS	Name: Michael McFarland, VMF Mgr. Email address: michael.d.mcfarland@usps.gov Mailing address: 341 W. Saint Paul Avenue Milwaukee, WI 53203-9721 Phone number: 414-270-2148	305635	341 W. Saint Paul Avenue Milwaukee, WI 53203-9721	Yes	Yes	No	Yes UST OMM Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	12/2005 State WI Licensed Site Professional	UST is compliant.						Property is Leased. Owner Information. Milwaukee Investments, C/O Glenora Co., 735 N. Water St. Suite 712, Milwaukee, WI 53202-4104.

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
MILWAUKEE VMF	USPS	Name: Michael McFarland, VMF Mgr. Email address: michael.d.mcfarland@usps.gov Mailing address: 341 W. Saint Paul Avenue Milwaukee, WI 53203-9721 Phone number: 414-270-2148	139796-3	341 W. Saint Paul Avenue Milwaukee, WI 53203-9721	Yes	Yes	No	Yes UST OMM Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	12/2005 State WI Licensed Site Professional	UST is compliant.						Property is Leased. Owner Information. Milwaukee Investments, C/O Glenora Co., 735 N. Water St. Suite 712, Milwaukee, WI 53202-4104.
IRVING PARK RD P&DC	USPS	Name: Robert Davis, Environmental Coordinator Email address: davisroberto2@usps.gov Mailing address: 11560 W. Irving Park Road Chicago, IL 60701-9997 Phone number: 773-894-1162	F-001893-13	11560 W. Irving Park Road Chicago, IL 60701- 9997	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	01/29/2004 Fire Marshall	UST is compliant.					Added P&DC to Facility Name	
IRVING PARK RD P&DC	USPS	Name: Robert Davis, Environmental Coordinator Email address: davisroberto2@usps.gov Mailing address: 11560 W. Irving Park Road Chicago, IL 60701-9997 Phone number: 773-894-1162	F-001893-14	11560 W. Irving Park Road Chicago, IL 60701- 9997	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	01/29/2004 Fire Marshall	UST is compliant.					Added P&DC to Facility Name	
CAROL STREAM VMF	USPS	Name: Keith Howard, VMF Mgr. Email address: keith.howard@usps.gov Mailing address: 500 E. Fullerton Avenue Carol Stream, IL 60199-9721 Phone number: 630-260-5403	2-031280-04	500 E. Fullerton Avenue Carol Stream, IL 60199-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	12/2005 Fire Marshall	UST is compliant.					Added VMF to Facility Name	
CAROL STREAM VMF	USPS	Name: Keith Howard, VMF Mgr. Email address: keith.howard@usps.gov Mailing address: 500 E. Fullerton Avenue Carol Stream, IL 60199-9721 Phone number: 630-260-5403	2-031280-02	500 E. Fullerton Avenue Carol Stream, IL 60199-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	12/2005 Fire Marshall	UST is compliant.					Added VMF to Facility Name	
CAROL STREAM VMF	USPS	Name: Keith Howard, VMF Mgr. Email address: keith.howard@usps.gov Mailing address: 500 E. Fullerton Avenue Carol Stream, IL 60199-9721 Phone number: 630-260-5403	2-031280-01	500 E. Fullerton Avenue Carol Stream, IL 60199-9721	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	12/2005 Fire Marshall	UST is compliant.					Added VMF to Facility Name	
CHAMPAIGN VMF	USPS	Name: Stephen Bozdech, VMF Mgr. Email address: stephen.w.bozdech@usps.gov Mailing address: 2001 N Mattis Avenue Champaign, IL 61821-9998 Phone number: 217-373-6059	4028803-1	2001 N Mattis Avenue Champaign, IL 61821-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	3/8/2005 State IL Fire Marshall 5-year Permit Renewal Inspection	UST is compliant.					ID number changed from 1441101 to 1435500	
CHAMPAIGN VMF	USPS	Name: Stephen Bozdech, VMF Mgr. Email address: stephen.w.bozdech@usps.gov Mailing address: 2001 N Mattis Avenue Champaign, IL 61821-9998 Phone number: 217-373-6059	4028803-2	2001 N Mattis Avenue Champaign, IL 61821-9998	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	3/8/2005 State IL Fire Marshall 5-year Permit Renewal Inspection	UST is compliant.					ID number changed from 1441101 to 1435500	
GARY VMF	USPS	Name: Kathy Mayfield, VMF Mgr. Email address: kathy.mayfield@usps.gov Mailing address: 1490 Martin Luther King Dr. Gary, IN 46401-9998 Phone number: 219-886-8067	13269-02	1490 Martin Luther King Dr. Gary, IN 46401- 9998	Yes	Yes	No	Yes (OMM) Release Prevention, Release Detection, Release Response and Corrective Action	1/10/2006 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441216 to 1436824; added VMF to Facility Name	
GARY VMF	USPS	Name: Kathy Mayfield, VMF Mgr. Email address: kathy.mayfield@usps.gov Mailing address: 1490 Martin Luther King Dr. Gary, IN 46401-9998 Phone number: 219-886-8067	13269-04	1490 Martin Luther King Dr. Gary, IN 46401- 9998	Yes	Yes	No	Yes (OMM) Release Prevention, Release Detection, Release Response and Corrective Action	1/10/2006 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441216 to 1436824; added VMF to Facility Name	
GARY VMF	USPS	Name: Kathy Mayfield, VMF Mgr. Email address: kathy.mayfield@usps.gov Mailing address: 1490 Martin Luther King Dr. Gary, IN 46401-9998 Phone number: 219-886-8067	13269-00	1490 Martin Luther King Dr. Gary, IN 46401- 9998	Yes	Yes	No	Yes (OMM) Release Prevention, Release Detection, Release Response and Corrective Action	1/10/2006 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441216 to 1436824; added VMF to Facility Name	
GARY VMF	USPS	Name: Kathy Mayfield, VMF Mgr. Email address: kathy.mayfield@usps.gov Mailing address: 1490 Martin Luther King Dr. Gary, IN 46401-9998 Phone number: 219-886-8067	13269-03	1490 Martin Luther King Dr. Gary, IN 46401- 9998	Yes	Yes	No	Yes (OMM) Release Prevention, Release Detection, Release Response and Corrective Action	1/10/2006 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441216 to 1436824; added VMF to Facility Name	
GARY VMF	USPS	Name: Kathy Mayfield, VMF Mgr. Email address: kathy.mayfield@usps.gov Mailing address: 1490 Martin Luther King Dr. Gary, IN 46401-9998 Phone number: 219-886-8067	13269-01	1490 Martin Luther King Dr. Gary, IN 46401- 9998	Yes	Yes	No	Yes (OMM) Release Prevention, Release Detection, Release Response and Corrective Action	1/10/2006 State IN Licensed Site Professional	UST is compliant.					Used oil UST for oil from oil/wate separator.	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
INDIANAPOLIS VMF	USPS	Name: Tom Buckles, A/VMF Mgr. USPS UST Tank POC: Jane Vehling, Office Clerk Email address: tom.buckles@usps.gov Mailing address: 615 South Capital Avenue Indianapolis, IN 46225-1274 Phone number: 317-464-6079; 317-464-6077	6848-1	615 South Capital Avenue Indianapolis, IN 46225-1274	Yes	Yes	No	Yes UST Control (OMM) Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	9/1/2004 State IN Licensed Site Professional	UST is compliant.	State				ID number changed from 1441217 to 1436831; added VMF to Facility Name	
INDIANAPOLIS VMF	USPS	Name: Tom Buckles, A/VMF Mgr. USPS UST Tank POC: Jane Vehling, Office Clerk Email address: tom.buckles@usps.gov Mailing address: 615 South Capital Avenue Indianapolis, IN 46225-1274 Phone number: 317-464-6077; 317-464-6077	6848-2	615 South Capital Avenue Indianapolis, IN 46225-1274	Yes	Yes	No	Yes UST Control (OMM) Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	9/1/2004 State IN Licensed Site Professional	UST is compliant.	State	Yes ^{xvii}	Yes ^{xvii}		ID number changed from 1441217 to 1436831; added VMF to Facility Name	
INDIANAPOLIS VMF	USPS	Name: Tom Buckles, A/VMF Mgr. USPS UST Tank POC: Jane Vehling, Office Clerk Email address: tom.buckles@usps.gov Mailing address: 615 South Capital Avenue Indianapolis, IN 46225-1274 Phone number: 317-464-6079; 317-464-6077	6848-3	615 South Capital Avenue Indianapolis, IN 46225-1274	Yes	Yes	No	Yes UST Control (OMM) Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	9/1/2004 State IN Licensed Site Professional	UST is compliant.	State	Yes ^{xvii}	Yes ^{xvii}		ID number changed from 1441217 to 1436831; added VMF to Facility Name	
INDIANAPOLIS VMF	USPS	Name: Tom Buckles, A/VMF Mgr. USPS UST Tank POC: Jane Vehling, Office Clerk Email address: tom.buckles@usps.gov Mailing address: 615 South Capital Avenue Indianapolis, IN 46225-1274 Phone number: 317-464-6079; 317-464-6077	6848-4	615 South Capital Avenue Indianapolis, IN 46225-1274	Yes	Yes	No	Yes UST Control (OMM) Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	9/1/2004 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441217 to 1436831; added VMF to Facility Name	
INDIANAPOLIS VMF	USPS	Name: Tom Buckles, A/VMF Mgr. USPS UST Tank POC: Jane Vehling, Office Clerk Email address: tom.buckles@usps.gov Mailing address: 615 South Capital Avenue Indianapolis, IN 46225-1274 Phone number: 317-464-6079; 317-464-6077	6848-5	615 South Capital Avenue Indianapolis, IN 46225-1274	Yes	Yes	No	Yes UST Control (OMM) Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	9/1/2004 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441217 to 1436831; added VMF to Facility Name	
INDIANAPOLIS VMF	USPS	Name: Tom Buckles, A/VMF Mgr. USPS UST Tank POC: Jane Vehling, Office Clerk Email address: tom.buckles@usps.gov Mailing address: 615 South Capital Avenue Indianapolis, IN 46225-1274 Phone number: 317-464-6079; 317-464-6077	6848-6	615 South Capital Avenue Indianapolis, IN 46225-1274	Yes	Yes	No	Yes UST Control (OMM) Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	9/1/2004 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441217 to 1436831; added VMF to Facility Name	
INDIANAPOLIS VMF	USPS	Name: Tom Buckles, A/VMF Mgr. USPS UST Tank POC: Jane Vehling, Office Clerk Email address: tom.buckles@usps.gov Mailing address: 615 South Capital Avenue Indianapolis, IN 46225-1274 Phone number: 317-464-6079; 317-464-6077	6848-7	615 South Capital Avenue Indianapolis, IN 46225-1274	Yes	Yes	No	Yes UST Control (OMM) Plan Training Release Prevention, Release Detection, Release Response and Corrective Action	9/1/2004 State IN Licensed Site Professional	UST is compliant.					ID number changed from 1441217 to 1436831; added VMF to Facility Name	
LAFAYETTE VMF	USPS	Name: Ron Phillippo, Lead Mechanic USPS UST Tank POC: J.D. Jessee, Store Keeper Email address: james.d.jessee@usps.gov Mailing address: 3450 State Road 26 Lafayette, IN 47901-9997 Phone number: 765-448-9231	6807-1	3450 State Road 26 Lafayette, IN 47901-9997	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected					ID number changed from 1441218 to 1436830; added VMF to Facility Name	
LAFAYETTE VMF	USPS	Name: Ron Phillippo, Lead Mechanic USPS UST Tank POC: J.D. Jessee, Store Keeper Email address: james.d.jessee@usps.gov Mailing address: 3450 State Road 26 Lafayette, IN 47901-9997 Phone number: 765-448-9231	6807-2	3450 State Road 26 Lafayette, IN 47901-9997	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected					ID number changed from 1441218 to 1436830; added VMF to Facility Name	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
LAFAYETTE VMF	USPS	Name: Ron Philippo, Lead Mechanic USPS UST Tank POC: J.D. Jessee, Store Keeper Email address: james.d.jessee@usps.gov Mailing address: 3450 State Road 26 Lafayette, IN 47901-9997 Phone number: 765-448-0224	6807-3	3450 State Road 26 Lafayette, IN 47901-9997	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected					ID number changed from 1441218 to 1436830; added VMF to Facility Name	
LAFAYETTE VMF	USPS	Name: Ron Philippo, Lead Mechanic USPS UST Tank POC: J.D. Jessee, Store Keeper Email address: james.d.jessee@usps.gov Mailing address: 3450 State Road 26 Lafayette, IN 47901-9997 Phone number: 765-448-0224	6807-4	3450 State Road 26 Lafayette, IN 47901-9997	Yes	Yes	No	Yes Release Prevention, Release Detection, Release Response and Corrective Action	Never Inspected	Never inspected					ID number changed from 1441218 to 1436830; added VMF to Facility Name	

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
ENFIELD	USPS	Name: Alfred Cardenas Mailing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	1362612	31 Palomba, Enfield, CT 06082-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	Never inspected						
GROTON	USPS	Name: Alfred Cardenas Mailing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	1365768A	100 Plaza CT, Groton, CT 06340-9998	No	Yes	no	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
GROTON	USPS	Name: Mike Romano Email address: michael.j.romano@usps.gov Mailing address: 100 Plaza CT, Groton, CT 06340-9998 Phone number: 860-445-8154	1365768B	100 Plaza CT, Groton, CT 06340-9998	No	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
MANCHESTER	USPS	Name: Ronald Boyne Email address: ronald.boyne@usps.gov Mailing address: 111 Sheldon Rd, Manchester, CT 06040-9998 Phone number: 860-643-2735	1371619	111 Sheldon Rd, Manchester, CT 06040-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
MIDDLETOWN	USPS	Name: Jodi Heslin Email address: Jodi.heslin@usps.gov Mailing address: 11 Silver Street, Middletown, CT 06457-9998 Phone number: 860-638-6977	1372972	11 Silver Street, Middletown, CT 06457-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
MONROE	USPS	Name: Michael Kaylor Email address: michael.kaylor@usps.gov Mailing address: 270 Monroe Tpke, Monroe, CT 06468-9998 Phone number: 203-261-3880	1373538	270 Monroe Tpke, Monroe, CT 06468-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
NEW BRITAIN	USPS	Name: Christine Murphy Email address: christine.murphy@usps.gov Mailing address: 135 Chestnut St, New Britain, CT 06050-9998 Phone number: 860-223-3681	1374658	135 Chestnut St, New Britain, CT 06050-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
NEW LONDON	USPS	Name: Rod Sweetwine Email address: roderick.j.sweetwine@usps.gov Mailing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348	1374782A	27 Masonic St, New London, CT 06320-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
WATERBURY	USPS	Name: Carl Johnson Email address: carl.johnson@usps.gov Mailing address: 41 Wigwam Ave, Waterbury, CT 06704-9998 Phone number: 203-574-6521	1377781	41 Wigwam Ave, Waterbury, CT 06704-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
TORRINGTON	USPS	Name: Jay Pompei Email address: jay.pompei@usps.gov Mailing address: 185 E. Elm St, Torrington, CT 06790-9998 Phone number: 860-489-0438	1384854	185 E. Elm St, Torrington, CT 06790-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
VERNON ROCKVILLE	USPS	Name: Donald Pelletier Email address: donald.pelletier@usps.gov Mailing address: 141 Union St, Vernon, CT 06066-9998 Phone number: 860-872-7311	1385867	141 Union St, Vernon, CT 06066-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
WALLINGFORD	USPS	Name: Michael Schrader Email address: michael.schrader@usps.gov Mailing address: 4 S Main St, Wallingford, CT 06492-9998 Phone number: 203-269-8712	1386273	4 S Main St, Wallingford, CT 06492-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
NEW HAVEN (EAST HAVEN)	USPS	Name: Norman Lalonde Email address: norman.lalonde@usps.gov Mailing address: 151 Frontage Rd, East Haven, CT 06512-9998 Phone number: 203-782-7000	1434088	151 Frontage Rd, East Haven, CT 06512-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
HARTFORD	USPS	Name: Michael Pugliese Email address: michael.pugliese@usps.gov Mailing address: 85 Weston Street, Hartford, CT 06101-9331 Phone number: 860-524-6240	1434099A	85 Weston Street, Hartford, CT 06101-9331	No	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
HARTFORD	USPS	Name: Michael Pugliese Email address: michael.pugliese@usps.gov Mailing address: 85 Weston Street, Hartford, CT 06101-9331 Phone number: 860-524-6240	1434099B	85 Weston Street, Hartford, CT 06101-9331	No	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
NEW HAVEN	USPS	Name: Rey Melendez Email address: reymond.melendez@usps.gov Mailing address: 50 Brewery St, New Haven, CT 06511-9331 Phone number: 203-782-7334	1434108A	50 Brewery St, New Haven, CT 06511-9331	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	1995 state	UST is compliant						
NEW HAVEN	USPS	Name: Rey Melendez Email address: reymond.melendez@usps.gov Mailing address: 50 Brewery St, New Haven, CT 06511-9331 Phone number: 203-782-7334	1434108B	50 Brewery St, New Haven, CT 06511-9331	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	1995 state	UST is compliant						
NEW HAVEN	USPS	Name: Robert Sibal Mail ing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	1434108C	50 Brewery St, New Haven, CT 06511-9331	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	1996 state	UST is compliant						
WATERBURY	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	1434163A	135 Grand St, Waterbury, CT 06702-9602	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
WATERBURY	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	1434163B	135 Grand St, Waterbury, CT 06702-9602	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
STAMFORD	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	1444325A	427 Weston Ave, Stamford, CT 06910-9721	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
STAMFORD	USPS	Name: Herb Yokoyama, Maintenance Manager, Mail ing address: 3600 Aolele Street Honolulu, HI 96820 Phone number: 808-423-3887	1444325B	427 Weston Ave, Stamford, CT 06910-9721	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
STRATFORD	USPS	Name: Michael Boccio Email address: michael.boccio@usps.gov Mailing address: 3100 Main Street, Stratford, CT 06615-9998 Phone number: 203-380-1302	1434154*	3100 Main Street, Stratford, CT 06615-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
CHICOPEE	USPS	Name: Stanley A. Haley Email address: stanley.a.haley@usps.gov Mailing address: 28 Main Street, Chicopee, MA 01020-9998 Phone number: 413-592-9451	1357917	28 Main Street, Chicopee, MA 01020-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	Never inspected						
HOLYOKE	USPS	Name: Wayne P. Desroches Email address: wayne.p.desroches@usps.gov Mailing address: 650 Dwight Street, Holyoke, MA 01040-9998 Phone number: 413-534-4577	1367277	650 Dwight Street, Holyoke, MA 01040-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
LAWRENCE	USPS	Name: Richard Pace Email address: richard.d.pace@usps.gov Mailing address: 431 Common St., Lawrence, MA 01842 Phone number: 978-691-4588	1369989	431 Common St., Lawrence, MA 01842	No	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
PEABODY - DANVERS	USPS	Name: Joan Inglis Email address: joan.m.inglis@usps.gov Mailing address: 4 Essex Center Drive, Peabody, MA 01960 Phone number: 978-531-6666	1377028	4 Essex Center Drive, Peabody, MA 01960	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
RANDOLPH	USPS	Name: Michael Watson Email address: michael.p.watson@usps.gov Mailing address: 6 Thomas Drive, Randolph, MA 02368 Phone number: 781-963-0823	1378786	6 Thomas Drive, Randolph, MA 02368	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Yes - State sponsored inspection *	UST is compliant						
WESTFIELD	USPS	Name: Mark C. Edstrom Email address: mark.c.edstrom@usps.gov Mailing address: 8 West Silver Street, Westfield, MA 01085-9998 Phone number: 413-568-0096	1387284	8 West Silver Street, Westfield, MA 01085-9998	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
WOBURN	USPS	Name: William Harris Email address: william.p.harris@usps.gov Mailing address: 462 Washington St., Woburn, MA 01801 Phone number: 781-729-6024	1388103	462 Washington St., Woburn, MA 01801	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
WORCESTER	USPS	Name: James Beaudoin Email address: james.s.beaudoin@usps.gov Mailing address: 4 East Central St., Worcester, MA 01613 Phone number: 508-795-3707	1388293A	4 East Central St., Worcester, MA 01613	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
WORCESTER	USPS	Name: James Beaudoin Email address: james.s.beaudoin@usps.gov Mailing address: 4 East Central St., Worcester, MA 01613 Phone number: 508-795-3707	1388293B	4 East Central St., Worcester, MA 01613	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
WORCESTER	USPS	Name: James Beaudoin Email address: james.s.beaudoin@usps.gov Mailing address: 4 East Central St., Worcester, MA 01613 Phone number: 508-795-3707	1388293C	4 East Central St., Worcester, MA 01613	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
FRAMINGHAM	USPS	Name: Nelson Rodrigues Email address: nelson.s.rodrigues@usps.gov Mailing address: 330 Cochituate Rd., Framingham, MA 01701 Phone number: 508-872-7660	1434676A	330 Cochituate Road, Framingham, MA 01701	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
Chelsea VMF	USPS	Name: Joseph Caroll Email address: joseph.f.caroll@usps.gov Mailing address: 307 Beacham Street, Chelsea, MA 02150 Phone number: 617-348-2117	1432470	307 Beacham Street, Chelsea, MA 02150	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Never Inspected	UST is compliant						
FRAMINGHAM	USPS	Name: Nelson Rodrigues Email address: nelson.s.rodrigues@usps.gov Mailing address: 330 Cochituate Rd., Framingham, MA 01701 Phone number: 508-872-7660	1434676B	330 Cochituate Road, Framingham, MA 01701	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
LYNN	USPS	Name: Nelson Rodrigues Email address: nelson.s.rodrigues@usps.gov Mailing address: 330 Cochituate Rd., Framingham, MA 01701 Phone number: 508-872-7660	1434677	100 Buffam St., Lynn, MA 01902	No	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
BOSTON VMF	USPS	Name: Joseph Caroll Email address: joseph.f.caroll@usps.gov Mailing address: 135 A Street, Boston, MA 02210 Phone number: 617-348-2117	1434680A	135 A Street, Boston, MA 02210	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	6/1996 Federal; State sponsored inspection *	UST is compliant						
SPRINGFIELD VMF	USPS	Name: Allan T. Balicki Email address: allan.t.balicki@usps.gov Mailing address: 1800 Page Blvd., Springfield, MA 01152-9320 Phone number: 413-785-6383	1434688A	1800 Page Blvd., Springfield, MA 01152-9320	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	8/96 & 7/03 Federal; State sponsored inspection *	UST is compliant						
SPRINGFIELD VMF	USPS	Name: Allan T. Balicki Email address: allan.t.balicki@usps.gov Mailing address: 1800 Page Blvd., Springfield, MA 01152-9320 Phone number: 413-785-6383	1434688B	1800 Page Blvd., Springfield, MA 01152-9320	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	8/96 & 7/03 Federal; State sponsored inspection *	UST is compliant						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
SPRINGFIELD VMF	USPS	Name: Allan T. Balicki Email address: allan.t.balicki@usps.gov Mailing address: 1800 Page Blvd., Springfield, MA 01152-9320 Phone number: 413-785-6383	1434688C	1800 Page Blvd., Springfield, MA 01152-9320	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	8/96 & 7/04 Federal; State sponsored inspection *	UST is compliant						
SPRINGFIELD VMF	USPS	Name: Allan T. Balicki Email address: allan.t.balicki@usps.gov Mailing address: 1800 Page Blvd., Springfield, MA 01152-9320 Phone number: 413-785-6383	1434688D	1800 Page Blvd., Springfield, MA 01152-9320	Yes	Yes	No	Yes Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator training (i.e. VOMA)	Yes - State sponsored inspection *	UST is compliant						
PITTSFIELD	USPS	Name: Allan T. Balicki Email address: allan.t.balicki@usps.gov Mailing address: 1800 Page Blvd., Springfield, MA 01152-9320 Phone number: 413-785-6383	1434689A	Pittsfield VMF/MPO, 212 Fenn Street, Pittsfield, MA 01201-9998	Yes	Yes	No	Yes Training to Operator on Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator (i.e. lead mechanic)	Yes - State sponsored inspection *	UST is compliant						
PITTSFIELD	USPS	Name: Allan T. Balicki Email address: allan.t.balicki@usps.gov Mailing address: 1800 Page Blvd., Springfield, MA 01152-9320 Phone number: 413-785-6383	1434689B	Pittsfield VMF/MPO, 212 Fenn Street, Pittsfield, MA 01201-9998	Yes	Yes	No	Yes Training to Operator on Release Detection, Prevention, Response, Recordkeeping and State Required Stage II Vapor Recover System Operator (i.e. lead mechanic)	Yes - State sponsored inspection *	UST is compliant						
BROCKTON	USPS	Name: Michaela Saccoccio Email address: michaela.a.saccoccio@usps.gov Mailing address: 149 Crescent Street Brockton, MA 02301 Phone number: 401-752-5212	240952G02A	149 Crescent Street Brockton, MA 02301	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Yes - State sponsored inspection *	UST is compliant						
BROCKTON	USPS	Name: Michaela Saccoccio Email address: michaela.a.saccoccio@usps.gov Mailing address: 149 Crescent Street Brockton, MA 02301 Phone number: 401-752-5212	240952G02B	149 Crescent Street Brockton, MA 02301	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Yes - State sponsored inspection *	UST is compliant						
RANDOLPH	USPS	Name: Michael Watson Email address: michael.p.watson@usps.gov Mailing address: 16 Thomas Patton Drive Randolph, MA 02368 Phone number: 781-963-0823	246358G01	16 Thomas Patton Drive Randolph, MA 02368	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Yes - State sponsored inspection *	UST is compliant						
PORTLAND	USPS	Name: Pat Hanley Email address: PATRICIA.M.HANLEY@USPS.GOV Mailing address: VMF, 171 Kennebec St, Portland, ME 04101-9721 Phone number: 207-871-8466	1434690A	VMF, 171 Kennebec St, Portland, ME 04101-9721	No	Yes	No	Yes State Required UST training	Yes - State sponsored inspection *	UST is compliant						
PORTLAND	USPS	Name: Pat Hanley Email address: PATRICIA.M.HANLEY@USPS.GOV Mailing address: VMF, 171 Kennebec St, Portland, ME 04101-9721 Phone number: 207-871-8466	1434690B	VMF, 171 Kennebec St, Portland, ME 04101-9721	No	yes	No	Yes State Required UST training	Yes - State sponsored inspection *	UST is compliant						
MANCHESTER	USPS	Name: Joe Breslin Email address: JBRSLN@EMAIL.USPS.GOV Mailing address: VMF, 955 Goffs Falls Rd, Manchester, NH 03103-9721 Phone number: 603-644-4022	1434678A	VMF, 955 Goffs Falls Rd, Manchester, NH 03103-9721	Yes	Yes	No	Yes State Required UST training	Yes - State sponsored inspection *	UST is compliant						
MANCHESTER	USPS	Name: Joe Breslin Email address: JBRSLN@EMAIL.USPS.GOV Mailing address: VMF, 955 Goffs Falls Rd, Manchester, NH 03103-9721 Phone number: 603-644-4022	1434678B	VMF, 955 Goffs Falls Rd, Manchester, NH 03103-9721	Yes	yes	No	Yes State Required UST training	Yes - State sponsored inspection *	UST is compliant						

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
ITHACA	USPS	Name: William Hrynko Email address: william.hrynko@usps.gov Mailing address: 757 Warren Avenue, Ithaca, NY 14850-9998 Phone number: 716-846-2550	1368129	757 Warren Avenue, Ithaca, NY 14850-9998	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Never Inspected	Never inspected						Line leak and tank monitor testing done annually by local contractor to determine compliance with EPA and State regs. Last tested on 8/1/05 by Darren Ricker
WEBSTER	USPS	Name: Jim Ellingham Email address: james.ellingham@usps.gov Mailing address: 75 Barrett Drive, Webster, NY 14580-9998 Phone number: 585-671-1500	1386785	75 Barrett Drive, Webster, NY 14580-9998	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Never Inspected	Never inspected						
BUFFALO	USPS	Name: Jim Rusiniak Email address: james.rusiniak@usps.com Mailing address: 1200 William Street, Buffalo, NY 14240-9351 Phone number: 716-846-2550	1433721A	1200 William Street, Buffalo, NY 14240-9351	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Never Inspected	Never inspected						
BUFFALO	USPS	Name: Jim Rusiniak Email address: james.rusiniak@usps.com Mailing address: 1200 William Street, Buffalo, NY 14240-9351 Phone number: 716-846-2550	1433721B	1200 William Street, Buffalo, NY 14240-9351	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Never Inspected	Never inspected						
ROCHESTER	USPS	Name: Mark Gartz Email address: mark.gartz@usps.gov Mailing address: 1335 Jefferson Road, Rochester, NY 14692 Phone number: 585-272-5940	1434029aA	1335 Jefferson Road, Rochester, NY 14692	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	11/02 & 5/04 state, Fed.	Pending ^{xxx}	state					
ROCHESTER	USPS	Name: Mark Gartz Email address: mark.gartz@usps.gov Mailing address: 1335 Jefferson Road, Rochester, NY 14692 Phone number: 585-272-5940	1434029B	1335 Jefferson Road, Rochester, NY 14692	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	11/02 & 5/04 state, Fed.	Pending ^{xxx}	state					
ELMIRA	USPS	Name: Jim Rusiniak Email address: james.rusiniak@usps.com Mailing address: 1200 William Street, Buffalo, NY 14240-9351 Phone number: 716-846-2550	1434032	7 Industrial Park Blvd., Elmira, NY 14901-9353	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Never Inspected	Never inspected						
ALBANY	USPS	Name: Jules Titolo Email address: jules.titolo@usps.gov Mailing address: 30 Old Karner Road, Albany NY 12288-9991 Phone number: 518-452-2270	1441026A	30 Old Karner Road, Albany, NY 12288-9991	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	1/13/2006 state	UST is compliant						
ALBANY	USPS	Name: Jules Titolo Email address: jules.titolo@usps.gov Mailing address: 30 Old Karner Road, Albany NY 12288-9991 Phone number: 518-452-2270	1441026B	30 Old Karner Road, Albany, NY 12288-9991	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	1/13/2006 state	UST is compliant						
ALBANY	USPS	Name: Jules Titolo Email address: jules.titolo@usps.gov Mailing address: 30 Old Karner Road, Albany NY 12288-9991 Phone number: 518-452-2270	1441026C	30 Old Karner Road, Albany, NY 12288-9991	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	1/13/2006 state	UST is compliant						Line leak and tank monitor testing done annually by local contractor to determine compliance with EPA and State regulations.
ALBANY	USPS	Name: Jules Titolo Email address: jules.titolo@usps.gov Mailing address: 30 Old Karner Road, Albany NY 12288-9991 Phone number: 518-452-2270	1441026D	30 Old Karner Road, Albany, NY 12288-9991	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	1/13/2009 state	UST is compliant						
BINGHAMTON	USPS	Name: Jules Titolo Email address: jules.titolo@usps.gov Mailing address: 30 Old Karner Road, Albany NY 12288-9991 Phone number: 518-452-2270	1441027	115 Henri Street, Binghamton, NY 13902-9997	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Never Inspected	Never inspected						
SYRACUSE	USPS	Name: Deb Fink Email address: debra.k.fink@usps.gov Mailing address: 5640 East Taft Road, Syracuse, NY 13220 Phone number: 315-452-3426	1441040A	5640 East Taft Road, Syracuse, NY 13220-9991	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	2/18/2006 state	UST is compliant	state	Yes ^{xxx}	Yes ^{xxx}	URS will remove replace old tank in 7/06.		annual tank testing
SYRACUSE	USPS	Name: Deb Fink Email address: debra.k.fink@usps.gov Mailing address: 5640 East Taft Road, Syracuse, NY 13220 Phone number: 315-452-3426	1441040B	5640 East Taft Road, Syracuse, NY 13220-9991	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	Never Inspected	Never inspected						Line leak and tank monitor testing done annually by local contractor to determine compliance with EPA and State regulations. Last done Tested on 8/1/05 by Darren Ricker

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
PROVIDENCE	USPS	Name: Michaela Saccoccio Email address: michaela.a.saccoccio@usps.gov Mailing address: 149 Crescent Street Brockton, MA 02301 Phone number: 401-752-5212	437140G07A	55 Corliss Street, Providence, RI 02904	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	7/18/06-state	UST is compliant						
PROVIDENCE	USPS	Name: Michaela Saccoccio Email address: michaela.a.saccoccio@usps.gov Mailing address: 149 Crescent Street Brockton, MA 02301 Phone number: 401-752-5212	437140G07B	55 Corliss Street, Providence, RI 02904	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	7/18/06-state	UST is compliant						
PROVIDENCE	USPS	Name: Michaela Saccoccio Email address: michaela.a.saccoccio@usps.gov Mailing address: 149 Crescent Street Brockton, MA 02301 Phone number: 401-752-5212	437140G07C	55 Corliss Street, Providence, RI 02904	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	7/18/06-state	UST is compliant						
PROVIDENCE	USPS	Name: Michaela Saccoccio Email address: michaela.a.saccoccio@usps.gov Mailing address: 149 Crescent Street Brockton, MA 02301 Phone number: 401-752-5212	437140G07D	55 Corliss Street, Providence, RI 02904	Yes	Yes	No	Yes RP, RD, RR&CA, SR training	7/18/06-state	UST is compliant						

* State Sponsor. Inspect. In MA, RI, ME, & NH, all USTs are periodical, inspected by state approved inspectors with the reports sent to the state, making these tanks compliant.

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
PONCE	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	02-86-0427-1	2340 AVE EDUARDO RUBERTE PONCE, PR 00717-9998	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
PONCE	USPS	Name: Alfred Cardenas Mail ing address: 390 Main Street San Francisco, CA 94105-9991 Phone number: (415) 536-6430	02-86-0427-2	2340 AVE EDUARDO RUBERTE PONCE, PR 00717-9998	Owned	Yes	no	no	Yes	Never Inspected	Never Inspected					
San Juan	USPS	Name: Yazdel Molina Email address: yazdel.molina@usps.gov Mailing Address: Mario Julia Ind Park 728 C Street Phone number:(787) 782-3675		585 Ave FD Roosevelt STE 370 San Juan, PR 00936-9312	Leased	No	Yes	no	No	Never Inspected	Never Inspected					Owner of property
San Juan	USPS	Name: Yazdel Molina Email address: yazdel.molina@usps.gov Mailing Address: Mario Julia Ind Park 728 C Street Phone number:(787) 782-3675		585 Ave FD Roosevelt STE 370 San Juan, PR 00936-9312	Leased	No	Yes	no	No	Never Inspected	Never Inspected					Owner of property
HICKSVILLE VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		109 LUDY ST HICKSVILLE, NY 11801-5155	Leased	No	Yes	no	No	Never Inspected	Never Inspected					Owner of property
HICKSVILLE VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		109 LUDY ST HICKSVILLE, NY 11801-5155	Leased	No	Yes	no	No	Never Inspected	Never Inspected					Owner of property
HICKSVILLE VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		109 LUDY ST HICKSVILLE, NY 11801-5155	Leased	No	Yes	no	No	Never Inspected	Never Inspected					Owner of property
MID ISLAND	USPS	Name: Rod Sweetwine roderick.j.sweetwine@usps.gov Mail ing address: 7001 S. Central Ave., Los Angeles, CA 90052-9998 Phone number: (323) 586-4348		160 DURYE RD MELVILLE, NY 11747-3832	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
MID ISLAND	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		160 DURYE RD MELVILLE, NY 11747-3832	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
WESTERN NASSAU VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		830 STEWART AVE GARDEN CITY, NY 11599-9726	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
WESTERN NASSAU VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		830 STEWART AVE GARDEN CITY, NY 11599-9726	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
WESTERN NASSAU VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		830 STEWART AVE GARDEN CITY, NY 11599-9726	Owned	Yes	Yes	no	No	Never Inspected	Never Inspected					
WESTERN NASSAU VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		830 STEWART AVE GARDEN CITY, NY 11599-9726	Owned	Yes	Yes	no	No	Never Inspected	Never Inspected					

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
FDR VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-455059-1	909 3RD AVE OFC NEW YORK, NY 10022-9998	Leased	No	Yes	no	Yes	36694	UST is compliant.					Owner of Property
FDR VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-455059-2	909 3RD AVE OFC NEW YORK, NY 10022-9998	Leased	No	Yes	no	Yes	36694	UST is compliant.					Owner of Property
FDR VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-455059-3	909 3RD AVE OFC NEW YORK, NY 10022-9998	Leased	No	Yes	no	Yes	36694	UST is compliant.					Owner of Property
FDR VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-455059-4	909 3RD AVE OFC NEW YORK, NY 10022-9998	Leased	No	Yes	no	Yes	36694	UST is compliant.					Owner of Property
MANHATTAN VMF	USPS	Name: Robert Sibal Mail ing address: 2700 Campus Drive, San Mateo, CA 94403-2504 Phone number: (650) 377-1337	2-452645-1	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	2-452645-2	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	2-452645-3	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Tony San Nicholas Mail ing address: Postmaster Guam Main Facility Barrigada, GU 96921-9998 Phone number: 671-734-3921	2-452645-4	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Herb Yokoyama, Maintenance Manager, Mail ing address: 3600 Aoolele Street Honolulu, HI 96820 Phone number: 808-423-3887	2-452645-13	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-452645-18	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-452645-19	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-452645-20	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-452645-21	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-452645-22	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
MANHATTAN VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3134	2-452645-23	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
MANHATTAN VMF	USPS	Name: Jim Nagy Email address: james.e.nagy@usps.gov Mailing Address: 421 8th Ave, NY NY 10199 Phone number:212 330-3167	2-452645-24	201 11TH AVE NEW YORK, NY 10199-9761	Owned	Yes	Yes	no	Yes	36573	UST is compliant.					
NEW JERSEY BMC	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		80 COUNTY RD JERSEY CITY, NJ 07097-9998	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
NEW JERSEY BMC	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		80 COUNTY RD JERSEY CITY, NJ 07097-9998	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
Newark VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		308 Thomas St. Newark, NJ 07114-9997	Owned	Yes	Yes	no	No	Never Inspected	Never Inspected					
PATERSON VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		194 WARD ST PATERSON, NJ 07510-9691	Owned	Yes	Yes	no	No	Never Inspected	Never Inspected					
PATERSON VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		194 WARD ST PATERSON, NJ 07510-9691	Owned	Yes	Yes	no	No	Never Inspected	Never Inspected					
BROOKLYN VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692	2-333174-1	1050 FORBELL ST BROOKLYN, NY 11256-9721	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
JFK ISC	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692	2-331805-1	BLDG250 N BOUNDARY RD STE 1 JAMAICA, NY 11430-9508	Leased	No	Yes	no	no	Never Inspected	Never Inspected					Port Authority of NY
JFK ISC	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692	2-331805-2	BLDG250 N BOUNDARY RD STE 1 JAMAICA, NY 11430-9508	Leased	No	Yes	no	No	Never Inspected	Never Inspected					Port Authority of NY
QUEENS	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		142-02 20th Ave, Queens NY 11351	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
QUEENS	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		142-02 20th Ave, Queens NY 11351	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
QUEENS	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		142-02 20th Ave, Queens NY 11351	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
QUEENS	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		142-02 20th Ave, Queens NY 11351	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
QUEENS	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		142-02 20th Ave, Queens NY 11351	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					

Underground Storage Tank Inventory and Compliance Strategy Report

1. Facility Name	2. Agency	3. Point of Contact	4. Tank #	5. UST Location Information	6. Federal Ownership	7. Federal Operator	8. UST on Federally Managed Lands	9. UST Operator Training	10. Inspection Date / Inspection Org.	11. Status of UST	12. Determinations of Non-Compliant UST	13. UST Violation Information	14. Status of UST Violation(s)	15. Status of UST Compliance Strategy	16. Comments	17. Narrative
SMALLWOOD	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		220 PINE GROVE RD SMALLWOOD, NY 12778-9800	Other	Yes	Yes	no	No	Never Inspected	Never Inspected					Owner of property
WHITE PLAINS	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		100 FISHER AVE WHITE PLAINS, NY 10606-1953	Owned	Yes	Yes	no	No	Never Inspected	Never Inspected					
WHITE PLAINS	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		100 FISHER AVE WHITE PLAINS, NY 10606-1953	Owned	Yes	Yes	no	No	Never Inspected	Never Inspected					
Westchester P&DC/VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		1000 Westchester Avenue White Plains, NY 10601-1000	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					
Westchester P&DC/VMF	USPS	Name: Jim Gaffney Email address: james.f.gaffney@usps.gov Mailing Address: 850 Newark Turnpike Kearny NJ 07099-9998 Phone number:201 955-9692		1000 Westchester Avenue White Plains, NY 10601-1000	Owned	Yes	Yes	no	Yes	Never Inspected	Never Inspected					

ENDNOTES

- i. UST system requirements: Design, Construction, Installation and Notification
- ii. Corrective Action In Progress
- iii. Corrective action options are currently being evaluated. All required actions will be completed to address existing issues
- iv. Release detection. Additional investigation and corrective actions are in progress
- v. Corrective Action In Progress
- vi. UST system requirements: Design, Construction, Installation and Notification
- vii. Corrective Action Completed
- viii. UST system requirements: Design, Construction, Installation and Notification
- ix. Corrective Action Completed - Waiting on Regulatory Concurrence
- x. UST system requirements: Design, Construction, Installation and Notification
- xi. Corrective Action Completed
- xii. Release detection. Additional investigation and corrective actions are in progress
- xiii. Corrective Action Completed
- xiv. UST system requirements: Design, Construction, Installation and Notification
- xv. Corrective Action Completed
- xvi. UST system requirements: Design, Construction, Installation and Notification
- xvii. Corrective Action Completed
- xviii. Corrective Action Completed
- xix. General Operations Requirements
- xx. Corrective Action Completed
- xxi. UST system requirements: Design, Construction, Installation and Notification
- xxii. Corrective Action Completed
- xxiii. UST system requirements: Design, Construction, Installation and Notification
- xxiv. Corrective Action Completed
- xxv. UST system requirements: Design, Construction, Installation and Notification
- xxvi. Corrective Action Completed
- xxvii. All requested information provided. No anticipated corrective actions needed. Formal response from EPA still pending
- xxviii. All requested information provided. No anticipated corrective actions needed. Formal response from EPA still pending
- xxvi. UST system requirements: Design, Construction, Installation and Notification; General Operating Requirements; Release detection. Additional investigation and corrective actions are in progress
- xxx. UST pumped out in 2/06 by an independent contractor and the tank is being replaced