

NO_x REDUCTION OF A 165 MW WALL FIRED BOILER UTILIZING AIR AND FUEL FLOW MEASUREMENT AND CONTROL

Author: Marion Cherry – Santee Cooper


Co-Authors: Dave Earley – Air Monitor Corporation

David Silzle – Air Monitor Corporation





**AIR MONITOR
CORPORATION**


Airflow Measurement: Pitot-Fechheimer Probe



CCV DAZ Low NO_x Burner




CCV[®] Dual Air Zone Burner




BABCOCK BORSIG POWER, INC.



Sectional View of Burner




SECTIONAL SIDE VIEW




SECTIONAL END VIEW



Coal Density Measurement



Coal Velocity Measurement



Absolute Measurement

- ◆ Independent
- ◆ Repeatable
- ◆ Individual
- ◆ Accurate

Absolute Coal Flow Measurement



- ◆ Output from each pipe not dependent on other pipes, primary air, or other variables.
- ◆ Output not dependent on coal feeder information.
- ◆ No coal sampling required to yield relative flow distribution.
- ◆ Output is directly proportionate to coal flow in each pipe.

Scaled Mass Flow


- ◆ Only need to apply a scaling factor to absolute output.
- ◆ Scaling factor may be obtained from gravimetric feed rate input, or manual sampling of a single coal pipe.



Pf-FLO Sensor Installation



Burner Arrangement



Baseline Air and Coal Data

Date: 7/24/01
 Time: 10:30 PM
 Load: 165 MW

O ₂ Grid:	2.40%	3.65%	4.66%	4.59%
	A1	A2	A3	A4
Air Flow:	84078 lb/hr	89280 lb/hr	83115 lb/hr	80965 lb/hr
Fuel Flow:	6690 a.u.	5170 a.u.	6560 a.u.	7015 a.u.
Air / Fuel	12.57	17.27	12.67	11.54
	D1	D2	D3	D4
Air Flow:	83719 lb/hr	78715 lb/hr	73614 lb/hr	90834 lb/hr
Fuel Flow:	5005 a.u.	4550 a.u.	4800 a.u.	4625 a.u.
Air / Fuel	16.73	17.30	15.34	19.64
	C1	C2	C3	C4
Air Flow:	94041 lb/hr	103786 lb/hr	94041 lb/hr	91023 lb/hr
Fuel Flow:	5585 a.u.	5445 a.u.	5705 a.u.	4265 a.u.
Air / Fuel	16.84	19.06	16.48	21.34
	B1	B2	B3	B4
Air Flow:	66650 lb/hr	75626 lb/hr	66729 lb/hr	73563 lb/hr
Fuel Flow:	5715 a.u.	7020 a.u.	8260 a.u.	5790 a.u.
Air / Fuel	11.66	10.77	8.08	12.71



Data After Balancing Fuel/Air

Date: 7/25/01
 Time: 1:30 AM
 Load: 165 MW

O ₂ Grid:	3.92%	4.15%	4.26%	4.05%
	A1	A2	A3	A4
Air Flow:	95836 lb/hr	87396 lb/hr	87162 lb/hr	89076 lb/hr
Fuel Flow:	6300 a.u.	5000 a.u.	6030 a.u.	6750 a.u.
Air / Fuel	15.21	17.48	14.45	13.20
	D1	D2	D3	D4
Air Flow:	87485 lb/hr	77522 lb/hr	77827 lb/hr	89280 lb/hr
Fuel Flow:	6070 a.u.	4980 a.u.	5390 a.u.	5310 a.u.
Air / Fuel	14.41	15.57	14.44	16.81
	C1	C2	C3	C4
Air Flow:	97578 lb/hr	106969 lb/hr	97294 lb/hr	72906 lb/hr
Fuel Flow:	5600 a.u.	6510 a.u.	7260 a.u.	5040 a.u.
Air / Fuel	17.42	16.43	13.40	14.47
	B1	B2	B3	B4
Air Flow:	73388 lb/hr	75175 lb/hr	61599 lb/hr	77610 lb/hr
Fuel Flow:	5680 a.u.	6750 a.u.	7720 a.u.	7070 a.u.
Air / Fuel	12.92	11.14	7.98	10.98



NO_x Reduction Baseline Data

Date: 9/12/01
 Time: 10:00 AM
 Load 162 MW

O₂ Grid:

3.80

 %

4.52

 %

5.20

 %

4.42

 %

4.48

 %

	A1	A2	A3	A4	A – TOTAL
Air Flow:	105643 lb/hr	94368 lb/hr	93648 lb/hr	90460 lb/hr	384119 lb/hr
Fuel Flow:	8290 a.u.	6080 a.u.	8050 a.u.	5660 a.u.	28080 a.u.
Air / Fuel	12.74	15.52	11.63	15.98	13.67
PA Signal	4060				
Feeder Signal	46960				

	D1	D2	D3	D4	D – TOTAL
Air Flow:	87485 lb/hr	76349 lb/hr	85601 lb/hr	89139 lb/hr	338574 lb/hr
Fuel Flow:	6080 a.u.	4500 a.u.	5540 a.u.	5070 a.u.	21190 a.u.
Air / Fuel	14.39	16.97	15.45	17.58	15.97
PA Signal	4209				
Feeder Signal	45740				

	C1	C2	C3	C4	C – TOTAL
Air Flow:	89076 lb/hr	104106 lb/hr	84707 lb/hr	92792 lb/hr	370681 lb/hr
Fuel Flow:	5750 a.u.	5320 a.u.	5280 a.u.	2580 a.u.	18930 a.u.
Air / Fuel	15.49	19.57	16.04	35.97	19.58
PA Signal	4811				
Feeder Signal	45820				

	B1	B2	B3	B4	B – TOTAL
Air Flow:	64880 lb/hr	73191 lb/hr	66797 lb/hr	77788 lb/hr	282656 lb/hr
Fuel Flow:	5830 a.u.	6190 a.u.	6580 a.u.	5060 a.u.	23660 a.u.
Air / Fuel	11.13	11.82	10.15	15.37	11.94
PA Signal	5038				
Feeder Signal	43470				

Column Average Air Flow	347085 lb/hr	348015 lb/hr	330753 lb/hr	350179 lb/hr	1376032 lb/hr
Column Average Fuel Flow	25950 a.u.	22090 a.u.	25450 a.u.	18370 a.u.	91860 a.u.
Column Average Air / Fuel	13.38	15.75	13.00	19.06	14.97



After Staging - Reduced NOx Data

Date: 9/12/01
 Time: 10:00 AM
 Load 160 MW

O ₂ Grid:	4.06 %	4.79 %	4.52 %	3.04 %	4.10 %	
	A1	A2	A3	A4	A - TOTAL	
Air Flow:	102534 lb/hr	75764 lb/hr	91733 lb/hr	94466 lb/hr	364497 lb/hr	
Fuel Flow:	7850 a.u.	4800 a.u.	6380 a.u.	4840 a.u.	23870 a.u.	
Air / Fuel	13.06	15.78	14.38	19.52	15.27	
PA Signal	4182					
Feeder Signal	3723					
	D1	D2	D3	D4	D - TOTAL	
Air Flow:	87485 lb/hr	71185 lb/hr	83749 lb/hr	69511 lb/hr	311930 lb/hr	
Fuel Flow:	5780 a.u.	4530 a.u.	5530 a.u.	5470 a.u.	21310 a.u.	
Air / Fuel	15.14	15.71	15.14	12.71	14.63	
PA Signal	4190					
Feeder Signal	4676					
	C1	C2	C3	C4	C - TOTAL	
Air Flow:	83115 lb/hr	71187 lb/hr	87162 lb/hr	58327 lb/hr	299791 lb/hr	
Fuel Flow:	6350 a.u.	6070 a.u.	6280 a.u.	3320 a.u.	22020 a.u.	
Air / Fuel	13.09	11.73	13.88	17.57	13.61	
PA Signal	4932					
Feeder Signal	5576					
	B1	B2	B3	B4	B - TOTAL	
Air Flow:	81442 lb/hr	68979 lb/hr	59098 lb/hr	65858 lb/hr	275376 lb/hr	
Fuel Flow:	5930 a.u.	6730 a.u.	7240 a.u.	5430 a.u.	25330 a.u.	
Air / Fuel	13.73	10.25	8.16	12.13	10.87	
PA Signal	5007					
Feeder Signal	4637					
Column Average	Air Flow	354576 lb/hr	287115 lb/hr	321742 lb/hr	288162 lb/hr	1251595 lb/hr
Column Average	Fuel Flow	25910 a.u.	22130 a.u.	25430 a.u.	19060 a.u.	92530 a.u.
Column Average	Air / Fuel	13.68	12.97	12.65	15.12	13.52



Recorded NO_x During Testing

J3 PF-FLO TESTING
SEPTEMBER 12, 2001



Final reduced
NO_x from staged
combustion. Unit
back to "normal"
@ 16:49.



AIR MONITOR
CORPORATION

LOI as Sampled During Test Period


Loss on Ignition, %
Hopper Designation / Sample

	1	2	3	4	5	AVG
Full Load As-Found	8.5	8.7	9.2	11.0	9.3	9.3
Full Load After	8.1	8.0	10.4	9.4	6.7	8.5
LOI Change	- 0.4	- 0.7	+1.2	- 1.6	- 2.6	- 0.8



Conclusions

- ◆ The use of individual burner air and fuel flow measurement can be used to:
 - ◆ Reduce overall NO_x levels: 18.7% decrease (from .48 to .39 lb/MMBtu).
 - ◆ Improve/flatten NO_x and O₂ profiles.
 - ◆ Reduce overall O₂ levels.
 - ◆ Improve heat rate.
 - ◆ Reduce LOI: .8% reduction while simultaneously reducing NO_x by 18.7%.
 - ◆ Adjust feeder rate curves for better mill balance.



Effects of Pipe Balance on LOI



While the above NO_x reduction program was performed on JSG Unit 3, this unit did not have adjustable coal valves.

Santee Cooper wanted to try to reduce its LOI on both units at JSG.


JSG Unit 4 is “identical” to unit 3 but it has adjustable coal valves on all 16 pipes.







Double ended Atrita Mills




Adjustable Coal Valves






Problem
with C
Mill. →




AIR MONITOR
CORPORATION

Diagnosing a Mill Problem



Effects of Pipe Balance on LOI

When the mill problem was corrected, the LOI in the flyash was reduced by 24% (from 10.6% to 8.1%).



Effects of Pipe Balance on LOI






Why the large
change here?







Jefferies Fly Ash – Unit Daily Average	
Date	Unit 4
2/3/2003	11.4
2/4/2003	10.7
2/5/2003	11.9
2/6/2003	11.1
2/6/2003	10.7
2/7/2003	11.0
2/10/2003	–
2/11/2003	–
2/12/2003	7.1
2/13/2003	7.4
2/14/2003	8.1
2/17/2003	7.4
2/18/2003	7.5
2/19/2003	7.3
2/20/2003	7.5
2/21/2003	7.6
2/24/2003	7.2
2/25/2003	7.2
2/26/2003	7.2
2/27/2003	7.4
2/28/2003	6.9




An imbalance
in Mill D pipes
was causing
high LOI



AIR MONITOR
CORPORATION



Problem
with C
Mill. →



AIR MONITOR
CORPORATION

Conclusions

- ◆ In addition to being able to reduce NO_x, Pf-FLO can be used to help reduce overall LOI levels.
- ◆ Pf-FLO offers assistance with mill diagnostics.
- ◆ Coal pipe balancing can lead to LOI reductions of over 35%.
- ◆ Balancing coal pipes may require more than the use of adjustable coal valves.

