

Sorbent Injection for Small ESP Mercury Control

DE-FC26-03NT41987

**DOE/NETL Mercury Control Technology
Conference
December 11, 2006**

**Katherine Dombrowski
URS Corporation**

Project Team



Pierina Noceti
(COR)



Ramsay Chang



Mark Berry
Nick Irvin
Ken McBee



Greg Newman
Larry Rapski



Carl Richardson
Katherine Dombrowski



Sharon Sjostrom



Tim Ebner

Project Objectives

Evaluate sorbent injection for Hg control in bituminous flue gas across small-sized electrostatic precipitators (ESPs)

- Mercury removal performance & variability
 - Optimal process conditions
- Balance of plant effects
 - ESP performance
 - FGD operation
 - Effects on byproduct ash, gypsum

Project Background

- Financial Assistance Program DE-FC26-03NT41987
- Most previous ACI testing with ESPs performed on relatively large units
 - High levels of Hg removal possible
 - No apparent detrimental effects on ESP performance
- 70% of utility ESPs have SCA $<300 \text{ ft}^2/1000 \text{ acfm}$
 - Sorbent injection performance in this size range not currently known
 - Effects on ESP performance

Project Background

- Full-scale activated carbon injection tests at Southern Company's Georgia Power Plant Yates
 - Units 1 and 2
 - 100 MW; low-sulfur eastern bituminous coal
 - ESPs with SCA <200 ft²/1000 acfm
- Full-scale sorbent injection tests at Reliant Energy's Shawville Station Unit 3
 - 175 MW; medium-sulfur eastern bituminous coal
 - Two ESPs configured in series
 - SCA = 82, 230 ft²/1000 acfm, respectively

Project Status

All field testing completed

■ Plant Yates Testing

- Units 1 and 2 Parametric Tests (Spring-04)
- Unit 1 Long-term test (Fall-04)
- Site Reports Completed
- Economic Analysis Completed


■ Shawville-3 Testing

- Parametric tests (July-06)
- Data analysis on-going

Test Plan
Baseline Tests
Parametric Test
Long-term tests
Cost Analysis
Final Report



Plant Yates Unit 1 Configuration




Summary – Plant Yates Results

Carbon Name	Manufacturer	Carbon Description	Cost (\$/lb)
Darco FGD™	Norit Americas	Tx lignite-derived activated carbon; baseline carbon; 19 µm mean particle size	0.50
Super HOK	RWE Rhinebraun	German lignite-derived activated carbon; 23 µm mean particle size	0.35*
NH Carbon	Ningxia Huahui Activated Carbon Co.	Chinese chemically treated bituminous-derived activated carbon; 24 µm mean particle size	0.88


Summary – Plant Yates Results

Hg Removal Across Unit 1 ESP




Summary – Plant Yates Results

ESP Hg Removal Due to Activated Carbon




Summary – Plant Yates Results


ESP Hg Removal Due to Activated Carbon




Mercury Removal during Long-term Test




ESP Arcing During Long-term Injection



ESP Outlet Particulate Concentrations




Economic Analysis – Plant Yates Data



Summary of Results

- Large variations in ESP inlet Hg concentration
- Vapor Hg removals typically 65 to 85% across ESP at 4 lb/Macf
 - With ACI only, outlet emissions were 0.5-3.5 lb/TBtu
 - Combination of ACI/JBR, outlet emissions were less than 2 lb/TBtu
- ESP Effects
 - Increase in ESP arcing with ACI
 - Particulate breakthrough measured at ESP outlet
 - Carbon particles found in M17 filters and JBR scrubber

Shawville 3 Configuration



Sorbents Evaluated at Shawville

Sorbent	Supplier	Description
Super HOK	RWE (Germany)	Activated German lignite; $d_{50} = 24 \mu\text{m}$
HOK – Coarse	RWE (Germany)	Activated German lignite; $d_{50} = 63 \mu\text{m}$
Darco Hg	Norit Americas (Marshall, TX)	Activated Texas lignite
Darco Hg-LH	Norit Americas (Marshall, TX)	Activated Texas lignite treated with bromine
Darco Hg/High Calcium Hydrated Lime	Norit Americas (Marshall, TX) /Chemical Lime (Dallas, TX)	30/70 mixture of Darco Hg with high surface area hydrated lime (for SO_3 control)



Shawville 3 Summary


■ Baseline Testing

- Hg values range: 26 – 43 $\mu\text{g}/\text{Nm}^3$ @ 3% O_2
- Oxidation high: >80% at ESP-2 outlet
- Hg removal to fly ash occurs upstream of ESPs
- Little to no Hg removal across ESPs


■ Sorbent Injection Testing

- Effect of injection rate and location
- Co-injection of high surface area lime
 - Pre-mixed; separate injection configurations
- Impact of SNCR operation


Shawville 3 Summary – Super HOK Injection




Shawville 3 Summary – Super HOK Injection




Shawville 3 Summary



Shawville 3 Summary - HOK vs Darco



Shawville 3 Summary – Comparison of SO₃ Levels and Sorbent Mercury Removal



Shawville Summary

- High levels of mercury removal achieved across small ESPs
- Better performance with Darco-Hg than Super HOK
- Apparent effect of SO₃ at very low levels (<2 ppm)
- ESP performance
 - Electrical properties (TBD)
 - PM removal (single-point M17)
 - Baseline outlet emissions
 - 0.013 to 0.020 gr/dscf
 - ACI outlet emissions
 - 0.009 to 0.030 gr/dscf

Future Project Plans

- Completion of Shawville data/results characterization (Q1FY07)
- Complete Shawville Site Report (Q1FY07)
- Project Close-out