

**April / May Shutdown 4/22/05 ~ 5/24/05**

WORK Items	WRQ #	Tech's	Eng's	Start Date	Status
<b>LEUTL</b>					
ACIS Validation	<a href="#">17317</a>				Complete
<b>Linac</b>					
ACIS Validation	<a href="#">17196</a>				Complete
Replace Beam permit fiber between Gun door and Linac Door	<a href="#">17264</a>				Complete
<b>Booster</b>					
ACIS Validation	<a href="#">17197</a>				
<b>Zone F</b>					
Prep work for New MCR UPS's. This includes routing conduit and installing hardware on top of the Storage ring & just outside the crosswalk		Gibson			Ongoing
Shutdown Panel Board EDP-A1 and install two 125amp circuit breakers. Run two 1-1/2" conduit circuits from EDP-A1 to column 61 on the storage ring mezz.	<a href="#">17585</a>	Gibson		4/23/2005	Complete
<b>Storage Ring</b>					
Investigate Fiber link between 420 A005 & MCR	<a href="#">17240</a>				Complete
Replace the strobe light for BSS inside the Zone A maze door.	<a href="#">17514</a>				Complete
<b>Front Ends</b>					
24BM Front End install	<a href="#">17323</a>	Sawatski / Budz	McNamara		Cancelled
11BM Front End install	<a href="#">17324</a>	Sawatski / Budz	McNamara		Complete
Upgrade & Test PLC code, this upgrades the EPICS interface for 26ID, 30ID and 23BM	<a href="#">17325</a>		McNamara		Complete
Inventory All PLC Components in FEEPS Systems	<a href="#">17321</a>	Gibson	McNamara		Complete
Upgrade 21ID FEEPS System to latest version	<a href="#">17666</a>	Gibson	McNamara		Complete
Install covers on 110v connections in FEEPS Racks	<a href="#">17499</a>	Budz	McNamara		Complete
<b>Beamlines</b>					
Validate 1BM	<a href="#">17214</a>		Hawkins / Boron	4/25/2005	Complete
Validate 11D	<a href="#">17456</a>		Emerson / Servino	4/25/2005	Complete
Validate 2BM	<a href="#">17457</a>		Friedman / Nguyen	4/28/2005	Complete
Validate 3ID	<a href="#">17458</a>	Budz		4/28/2005	Complete
Validate 5ID	<a href="#">17460</a>	Roberts		5/2/2005	Complete
Validate 7ID	<a href="#">17461</a>	Francis		5/2/2005	Complete
Validate 9BM	<a href="#">17462</a>	Sawatski / Gibson	Boron	5/5/2005	Complete
Validate 12BM	<a href="#">17463</a>		Emerson / Servino	5/5/2005	Complete
Validate 13ID	<a href="#">17464</a>	Budz		5/12/2005	Complete
Validate 15ID	<a href="#">17465</a>	Sawatski	Hawkins / Boron	5/16/2005	Complete
Validate 16BM	<a href="#">17466</a>		Friedman / Nguyen	5/16/2005	Complete
Validate 17ID	<a href="#">17467</a>	Francis		5/19/2005	Complete
Validate 18ID	<a href="#">17468</a>	Roberts		5/19/2005	Complete
Validate 20ID	<a href="#">17469</a>	Sawatski / Gibson	McNamara / Nguyen	5/23/2005	Complete
Validate 22BM	<a href="#">17470</a>		Hawkins, Forestal / Boron	5/23/2005	Complete
Validate 33BM	<a href="#">17471</a>		Friedman, Hogref / Nguyen	5/26/2005	
Validate 33ID	<a href="#">17472</a>		Emerson, Belcher / Servino	5/26/2005	
Inventory PLC's for above beamlines		Roberts / Francis	Dawson	4/22/2005	Complete
Complete install of 11BM PSS System		Sawatski / Budz	Hawkins		Complete
Tie in intigral shutter @ 11BM		Budz	Hawkins		Complete
Pre Validation Checkout of 11BM		Roberts/Gibson	Boron	5/9/2005	Complete
Validate 11BM					
Support Vac Group with work @ 14BM	<a href="#">17765</a>	Roberts	McNamara		Complete
Support work @ 14ID (Remove shutter & other various tasks)	<a href="#">17806</a>	Roberts	McNamara		Complete
Install and calibrate switches @ 14ID	<a href="#">17790</a>	Sawatski	McNamara		Complete
Support ME Group with 19BM PS1 Water Leak					Complete
Investigate SS1 No Switch @ 10ID	<a href="#">17610</a>				Cancelled
12ID Activate P4-B non-mono mode. Cylinders & switches have to be calibrated.b) Instrument DIW monitoring of the manual beam shutters MBS-C and MBS-D, and pink beam stop PBSt-D.	<a href="#">17604</a>	Roberts	Friedman		Cancelled
15ID correct wiring for Station C Door 2 Click and Buzz sounds	<a href="#">17606</a>		Friedman		Complete
Ground 15U chassis @ 18ID, 19BM, 19ID, 20BM, 20ID	<a href="#">17612</a>	Roberts	Dawson		Complete
Ground 15U chassis @ 22BM, 22ID, 23ID, 24ID, 31ID, 32ID, 33BM, 33ID, 34ID, 35BM & 35ID	<a href="#">17840</a>	Roberts	Dawson		Complete
Remove obsolete diw cables @ 2ID, 3ID, 5ID, 6ID, 7ID, 8ID, 16ID, 20ID, 31ID, 32ID, 33ID, 34ID & 35ID	<a href="#">17748</a>	Francis	Dawson		Ongoing
Check and remove Blowers from PSS / FEEPS racks		Francis			Complete

301D BLEPS install





