

HADCRT Results for Benchmark Exercise #2

May 3, 2002

Presented to the:

**International Collaborative Project to Evaluate Fire Models
for Nuclear Power Plant Applications**

Presented by:

Boro Malinovic and Martin G. Plys

Fauske and Associates, Inc.

16W070 West 83rd Street

Burr Ridge, IL 60521

Background

- **Nuclear fuel cycle facility source term analysis code, HADCRT (Hanford Double Contained Receiver Tanks).**
- **Logical to extend HADCRT explosion & accident capability by adding fire models to the validated baseline code.**

Background

- **Generic features:**

- Arbitrary topology
- Arbitrary specification of chemical species & properties
- Fog formation (vapor/aerosol equilibrium)
- Density-driven counter-current gas flows between compartments
- Aerosol agglomeration, settling, transport, & source models
- Radiation networks
- Multi-dimensional heat conduction

May 3, 2001

Fauske and Associates, Inc. 5th
Meeting at NIST

3

Background


- **Fire features include:**

- Stratified layer composition and thickness per compartment
- Pilot fire definitions (burn rates, yields, etc.)
- Plume model

May 3, 2001

Fauske and Associates, Inc. 5th
Meeting at NIST

4



- ### HADCRT Model for Benchmark Exercise #2
- **Two regions: hall and the environment**
 - Hall: 5891 m³, 378 m² floor area, 1800 m² wall HX area, parallelepiped, 22 C, 101350 Pa
 - Environment: 20 C, 101350 Pa

 - **Seven Heat Sinks**
 - Floor 1 ft. thick concrete; adiabatic on the outside
 - Sheet metal is neglected
 - Walls and ceiling are 5 cm mineral wool
 - One HS for floor, six for walls
 - Wall HS model the wall as six panels
 - Material properties from Table 1 of the problem specification
- May 3, 2001 Fauske and Associates, Inc. 5th Meeting at NIST 6


HADCRT Model for Benchmark Exercise #2



- **Junctions: depends on the case**
 - Case 1: Four junctions, as shown in Table 2 of the problem specification, but only “z” coordinate matters
 - Case 2: Same as Case 1
 - Case 3: Two doors, one top junction has 11 m³/s forced flow
- **Code inputs for fires: region, area, burn flux, fuel properties, start time, fuel mass, yields for CO, CO₂, CH, soot, H₂O; limit of five fires**
- **Use handbook values for heptane; e.g., 44.6 MJ/kg**
- **As a first cut, skip radiation; fire is 100% convective**



May 3, 2001



Fauske and Associates, Inc. 5th
Meeting at NIST



7


















- Results Summary**
- **Non-smoky layer temperatures are low**
 - Radiation neglected
 - Problem specification for junctions creates a chimney effect that brings cold air into the non-smoky layer
 - **Junction specification creates no pressure differential between the hall and the environment**
 - **Parametric studies for leakage areas and infiltration are desirable**
 - **Smoky layer temperatures are in good agreement**
 - need to include the 80/20 split between convection and radiation and consider absorptivity
- May 3, 2001 Fauske and Associates, Inc. 5th Meeting at NIST 20

Future Work

- **Parametric studies of leakage and infiltration**
- **Radiative aspects of the problem; set up radiation networks to better model gas and heat sink temperatures in the non-smoky layer, and target temperatures**
- **Smoky layer absorptivity**
- **Report plume temperatures**
- **Volume vs. height relationships for regions**

May 3, 2001

Fauske and Associates, Inc. 5th
Meeting at NIST

21