

MERCURY TEST #1

DATE/TIME	GROSS LOAD	AUX USE	P1 AUX	NET GEN	STM		1ST STG PRESS	MAIN STM FLOW	FW TEMP	ATTEMP FLOW MS	CIRC H2O IN TEMP		CIRC H2O OUT TEMP		COND. PRESS	BARO METER
					AL1SM50A	PT1SM50A					TE1RC49C	TE1RC49B	PT1IT21A	PTOMI26		
01-Sep-99 10:35:00	40.02	1.52	JT0EN15A	37.15	899.21	825.26	629.12	341.98	382.80	344.74	69.63	80.61	80.61	80.61	1.42	29.46
01-Sep-99 11:05:00	39.93	1.52	JT0EN15A	37.24	901.06	826.63	625.74	340.09	382.56	342.27	69.77	80.86	80.86	80.86	1.45	29.46
01-Sep-99 11:35:00	39.89	1.52	JT0EN15A	37.15	900.08	825.26	624.94	340.31	382.73	343.62	70.13	81.10	81.10	81.10	1.47	29.46
01-Sep-99 12:05:00	40.02	1.51	JT0EN15A	37.23	901.62	828.03	629.79	342.24	382.81	345.11	70.49	81.35	81.35	81.35	1.49	29.44
01-Sep-99 12:35:00	40.44	1.51	JT0EN15A	37.74	899.26	822.72	638.22	345.25	383.91	353.46	70.84	81.56	81.56	81.56	1.51	29.43

MERCURY TEST #1

AH 1 GAS IN TEMP	AH1 GAS OUT TEMP	AH1 AIR IN TEMP	AH1 AIR OUT TEMP	TEMP FD FAN SUCTION	AMBIENT TEMP	STACK FLOW	STACK TEMP	OPACITY	CARBON DIOXIDE	FEEDER			TOTAL COAL USAGE LBS.	CO2 PERCENT
										A FEEDER RPM	B FEEDER RPM	C FEEDER RPM		
597.46	388.53	102.00	496.57	102.00	64.52	8.00	350.20	2.74	56.86	7.01	6.96	6.97		12.23
598.79	389.86	103.83	498.09	103.83	67.14	8.00	350.20	3.03	56.80	7.12	7.01	7.05		12.28
600.13	390.77	105.30	499.53	105.30	69.05	8.00	350.20	2.60	57.09	6.93	6.92	6.91		12.10
601.89	392.23	106.57	500.60	106.57	70.81	8.00	350.20	2.29	58.09	6.98	6.93	6.92		12.28
604.43	388.93	107.06	498.47	107.06	71.82	9.00	350.20	15.02	61.67	6.63	6.58	6.59	75429.8	11.75

MERCURY TEST #2

DATE/TIME	GROSS LOAD	AUX USE	P1 AUX	NET GEN	STM		STM PRESS	1ST STG PRESS	MAIN STM FLOW		FW TEMP	ATTEMP FLOW MS		CIRC H2O IN TEMP	CIRC H2O OUT TEMP	COND. PRESS	BARO METER
					AL1SM50A	PT1SM50A			AM1SM50D	AM1G02S		TE1CF51A	AM1CF50M				
01-Sep-99 14:50:00	40.27	1.51	JT0EN15A	37.55	899.07	825.82	825.82	634.39	344.62	383.96	347.53	72.63	83.59	1.61	29.39		
01-Sep-99 15:20:00	40.22	1.51		37.52	901.62	827.11	827.11	634.55	343.88	383.72	346.86	73.01	84.04	1.63	29.37		
01-Sep-99 15:50:00	40.07	1.51		37.39	900.04	826.26	826.26	634.65	344.54	383.74	347.31	73.39	84.49	1.65	29.35		
01-Sep-99 16:20:00	40.14	1.51		37.19	904.07	825.78	825.78	635.20	343.60	383.68	346.65	73.77	84.95	1.67	29.34		
01-Sep-99 16:50:00	40.25	1.51		37.21	900.84	828.00	828.00	637.76	345.10	384.59	348.90	74.14	85.10	1.69	29.33		

MERCURY TEST #2

AH 1 GAS IN TEMP	AH1 GAS OUT TEMP	AH1 AIR IN TEMP	AH1 AIR OUT TEMP	TEMP FD FAN SUCTION	TEMP FD FAN TEMP	AMBIENT TEMP	STACK FLOW	STACK TEMP	OPACITY	CARBON DIOXIDE	A FEEDER		B FEEDER		C FEEDER		TOTAL COAL USEAGE LBS.	CO2 PERCENT
											RPM	FT1FH01A	RPM	FT1FH01B	RPM	FT1FH01C		
600.75	391.50	111.04	500.84	111.04	350.20	75.85	8.00	350.20	2.03	57.34	7.03	6.91	6.92					12.14
601.07	391.91	111.61	501.09	111.61	350.20	76.60	8.00	350.20	2.14	57.31	7.08	7.02	6.99					12.20
601.50	392.34	113.06	501.72	113.06	350.20	77.51	8.00	350.20	2.28	57.27	7.11	7.06	7.17					12.13
602.88	394.25	112.76	502.37	112.76	350.20	78.68	8.00	350.20	2.41	57.23	7.13	7.13	7.11					12.05
604.17	394.75	112.74	503.47	112.74	350.20	79.30	8.00	350.20	2.45	57.20	7.02	6.99	7.07				75670.8	12.18

MERCURY TEST #3

DATE/TIME	GROSS LOAD	AUX USE	P1 AUX	NET GEN	STM		1ST STG		MAIN STM		FW		ATTEMP		CIRC H2O IN TEMP	CIRC H2O OUT TEMP	COND. PRESS	BARO METER
					AL1SM50A	PT1SM50A	PT1SM50D	AM1G02S	TE1CF51A	AM1CF50M	TE1RC49C	TE1RC49B	PT1IT21A	PT0M126				
02-Sep-99 08:15:00	40.03	1.33	1.49	37.21	900.26	822.97	629.64	341.87	382.87	346.44	71.02	82.24	1.41	29.38				
02-Sep-99 08:45:00	39.98	1.37	1.50	37.11	899.52	826.99	628.23	341.42	382.72	344.66	70.76	82.07	1.43	29.38				
02-Sep-99 09:15:00	40.03	1.42	1.50	37.11	900.73	827.39	625.54	341.31	382.67	344.17	70.58	81.91	1.45	29.38				
02-Sep-99 09:45:00	40.03	1.46	1.29	37.27	900.17	827.79	627.03	341.10	382.50	344.96	70.42	81.74	1.46	29.38				
02-Sep-99 10:15:00	39.91	1.51	1.22	37.18	899.88	827.06	624.78	339.65	382.24	343.70	70.27	81.57	1.48	29.38				

MERCURY TEST #3

AL1GAS IN TEMP	AL1GAS OUT TEMP	AH1AIR IN TEMP	AH1AIR OUT TEMP	TEMP FD FAN SUCTION	TEMP FD FAN AMBIENT	STACK FLOW	STACK TEMP	OPACITY	CARBON DIOXIDE	A FEEDER RPM	B FEEDER RPM	C FEEDER RPM	TOTAL COAL USAGE LBS.	CO2 PERCENT
AL1FH81D	AL1FH81C	AL1FH81A	AL1FH81B	AL1FH81A	TEOM126	AL1AME03	AL1AME12	AL1AME23	AL1AME01	FT1FH01A	FT1FH01B	FT1FH01C		AL1AME27
589.42	378.08	99.50	487.24	99.50	55.18	8.00	350.20	2.48	56.19	7.26	7.01	7.18		12.30
591.49	380.68	100.42	489.63	100.42	57.80	8.00	350.20	2.56	55.99	6.99	6.89	6.93		12.23
593.17	382.16	101.35	491.96	101.35	60.70	8.00	350.20	2.47	55.79	6.96	6.84	6.87		12.30
595.07	383.91	102.63	494.46	102.63	63.84	8.00	350.20	2.41	55.59	7.03	6.87	6.93		12.23
596.92	385.80	104.84	495.82	104.84	67.38	8.00	350.20	2.20	55.40	7.09	6.87	6.98	75306.2	12.27

Test 3

9/2/99

Form 400221 (R8-96) • Previously Form 18898

CLIFFSIDE STEAM STATION PRECIPITATOR DAILY READINGS

DATE

MORNING READINGS

Unit	Unit Status On/Off	Time of Reading	Control Cabinet	Opacity %	O ₂ %	AC Amps	VAC Volts	PPTR MA	Spark Rate	Gross MW	ID Amps		PHTR Gas Inlet Temp.
											A	B	
1	On	8:45	A	2.6	2.3	47	297	332	17	40	147	X	591
1			B			75	296	691	1				
1			C			95	311	786	0				
1			D			100	303	822	0				
2			A										
2			B										
2			C										
2			D										
3			A										
3			B										
3			C										
3			A										
3			B										
3			C										
4			A										
4			B										
4			C										

Shift Supv.

Additional Comments:

1051-3

CLIFFSIDE STEAM STATION PRECIPITATOR DAILY READINGS

Form 400221 (R8-96) • Previously Form 18898

9/2/99

DATE

Unit	Unit Status On/Off	Time of Reading	Control Cabinet	Opacity %	O ₂ %	AC Amps	VAC Volts	PPTR MA	Spark Rate	Gross MW	ID Amps		PHTR Gas Inlet Temp.
											A	B	
1	DOWN	9:45	A	2.4	2.5	26	168	450	14	40	150	X	595
1			B			85	302	681	0				
1			C			95	311	782	0				
1			D			100	302	822	0				
2			A										
2			B										
2			C										
2			D										
3			A										
3			B										
3			C										
4			A										
4			B										
4			C										

Shift Supv.

Additional Comments:

MORNING READINGS

1051-3

CLIFFSIDE STEAM STATION PRECIPITATOR DAILY READINGS

Form 40021 (R8-96) • Previously Form 18898

9/2/99

DATE

Unit	Unit Status On/Off	Time of Reading	Control Cabinet	Opacity %	O ₂ %	AC Amps	VAC Volts	PPTR MA	Spark Rate	Gross MW	ID Amps		PHTR Gas Inlet Temp.
											A	B	
1	ON	10:15	A	2.2	2.5	38	267	395	16	40	149	X	597
1			B			85	302	687	0				
1			C			95	309	784	0				
1			D			100	303	830	0				
2			A										
2			B										
2			C										
2			D										
3			A										
3			B										
3			C										
4			A										
4			B										
4			C										

MORNING READINGS

Shift Supv.

Additional Comments:

SUMMARY OF RESULTS CALCULATIONS

$$V_m (\text{std}) = 17.647 \times V_m \times \left[\frac{P_{\text{bar}} + \frac{DH}{13.6}}{(460 + T_m)} \right] \times Y$$

$$V_w (\text{std}) = 0.0471 \times V_{lc}$$

V_{lc} = water + silica net

$$B_{ws} = \left[\frac{V_w (\text{std})}{V_w (\text{std}) + V_m (\text{std})} \right]$$

$$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + [0.28 \times (100 - \%CO_2 - \%O_2)]$$

$$M_S = M_d \times (1 - B_{ws}) + (18 \times B_{ws})$$

$$V_s = \sqrt{\frac{(T_s + 460)}{M_s \times P_s}} \times \sqrt{DP} \times C_p \times 85.49$$

C_p = pitot tube correction factor

P_s = absolute flue gas pressure

M_s = molecular weight of gas (lb/lb mole)

M_d = dry molecular weight of gas (lb/lb mole)

B_{ws} = water vapor in gas stream proportion by volume

$$A_{cfm} = V_s \times \text{Area (of stack or duct)} \times 60$$

$$D_{scfm} = A_{cfm} \times 17.647 \times \left[\frac{P_s}{(460 + T_s)} \right] \times (1 - B_{ws})$$

$$S_{cfm} = A_{cfm} \times 17.647 \times \left[\frac{P_s}{(460 + T_s)} \right]$$

$$S_{cfh} = S_{cfm} \times 60 \frac{\text{min}}{\text{hr}}$$

CALCULATION FORMULAS

$$1. V_{m(\text{std})} = V_m Y \left(\frac{T_{\text{std}}}{T_m} \right) \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{P_{\text{std}}} \right) = K_1 V_m Y \frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m}$$

$$2. V_{w(\text{std})} = V_{lc} \left(\frac{\rho_w}{M_w} \right) \left(\frac{RT_{\text{std}}}{P_{\text{std}}} \right) = K_2 V_{lc}$$

$$3. B_{ws} = \frac{V_{w(\text{std})}}{V_{m(\text{std})} + V_{w(\text{std})}}$$

$$4a. C_a = \frac{m_a}{V_a \rho_a}$$

$$4b. W_a = C_a V_{aw} \rho_a$$

$$5. C_s = (15.43 \text{ grains/gram}) (m_n / V_{m(\text{std})})$$

$$6. C_{\text{acf}} = 15.43 K_i \left(\frac{m_n P_s}{V_{w(\text{std})} + V_{m(\text{std})} T_s} \right)$$

$$7. \%EA = \left(\frac{\%O_2 - (0.5 \%CO)}{0.264 \%N_2 - (\%O_2 - 0.5 \%CO)} \right) \times 100$$

$$8. M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2 + \%CO)$$

$$9. M_s = M_d(1 - B_{ws}) + 18.0 B_{ws}$$

$$10. v_s = K_p C_p \sqrt{\frac{\Delta P T_s}{P_s M_s}}$$

$$11. Q_{\text{acfm}} = v_s A (60 \text{ sec/min})$$

$$12. Q_{\text{sd}} = (3600 \text{ sec/hr}) (1 - B_{ws}) v_s \left(\frac{T_{\text{std}} P_s}{T_s P_{\text{std}}} \right) A$$

$$13. E \text{ (emission rate, lbs/hr)} = Q_{\text{std}} (C_s / 7000 \text{ grains/lb})$$

$$14. IKV = \frac{T_s V_{m(\text{std})} P_{\text{std}}}{T_{\text{std}} v_s \theta A_n P_s 60 (1 - B_{ws})} = K_4 \frac{T_s V_{m(\text{std})}}{P_s v_s A_n \theta (1 - B_{ws})}$$

NOMENCLATURE

- A = Cross-sectional area of stack or duct, ft^2
 A_n = Cross-sectional area of nozzle, ft^2
 B_{ws} = Water vapor in gas stream, proportion by volume
 C_a = Acetone blank residue concentration, g/g
 C_{acf} = Concentration of particulate matter in gas stream at actual conditions, gr/acf
 C_p = Pitot tube coefficient, dimensionless
 C_s = Concentration of particulate matter in gas stream, dry basis, corrected to standard conditions, gr/dscf
 IKV = Isokinetic sampling variance, must be $.90 \leq \text{IKV} \leq 1.10$
 M_d = Dry molecular weight of gas, $\text{lb}/\text{lb-mole}$
 m_n = Total amount of particulate matter collected, grams
 M_s = Molecular weight of gas, wet basis, $\text{lb}/\text{lb-mole}$
 M_w = Molecular weight of water, $18.0 \text{ lb}/\text{lb-mole}$
 m_a = Mass of residue of acetone after evaporation, grams
 P_{bar} = Barometric pressure at testing site, in. Hg
 P_g = Static pressure of gas, in. Hg (in. $\text{H}_2\text{O}/13.6$)
 P_s = Absolute pressure of gas, in. Hg = $P_{\text{bar}} + P_g$
 P_{std} = Standard absolute pressure, 29.92 in. Hg
 Q_{acfm} = Actual volumetric gas flow rate, acfm
 Q_{sd} = Dry volumetric gas flow rate corrected to standard conditions, dscf/hr
 R = Ideal gas constant, $21.85 \text{ in. Hg}\cdot\text{ft}^3/\text{°R}\cdot\text{lb-mole}$
 T_m = Absolute dry gas meter temperature, °R
 T_s = Absolute gas temperature, °R
 T_{std} = Standard absolute temperature, 528°R
 V_a = Volume of acetone blank, ml
 V_{aw} = Volume of acetone used in wash, ml
 V_{lc} = Total volume of liquid collected in impingers and silica gel, ml
 V_m = Volume of gas sample as measured by dry gas meter, dcf
 $V_{m(\text{std})}$ = Volume of gas sample measured by dry gas meter, corrected to standard conditions, dscf
 v_s = Gas velocity, ft/sec
 $V_{w(\text{std})}$ = Volume of water vapor in gas sample, corrected to standard conditions, scf
 W_a = Weight of residue in acetone wash, grams
 Y = Dry gas meter calibration factor
 ΔH = Average pressure differential across the orifice meter, in. H_2O
 Δp = Velocity head of gas, in. H_2O
 ρ_a = Density of acetone, $0.7855 \text{ g}/\text{ml}$ (average)
 ρ_w = Density of water, $0.002201 \text{ lb}/\text{ml}$
 θ = Total sampling time, minutes
 K_1 = $17.64 \text{ °R}/\text{in. Hg}$
 K_2 = $0.04707 \text{ ft}^3/\text{ml}$
 K_4 = $0.09450/100 = 0.000945$
 K_p = Pitot tube constant, $85.49 \frac{\text{ft}}{\text{sec}} \left[\frac{(\text{lb}/\text{lb - mole})(\text{in. Hg})}{(\text{°R})(\text{in. H}_2\text{O})} \right]^{1/2}$
 $\%EA$ = Percent excess air
 $\%\text{CO}_2$ = Percent carbon dioxide by volume, dry basis
 $\%\text{O}_2$ = Percent oxygen by volume, dry basis
 $\%\text{CO}$ = Percent carbon monoxide by volume, dry basis
 $\%\text{N}_2$ = Percent nitrogen by volume, dry basis
 0.264 = Ratio of O_2 to N_2 in air, v/v
 0.28 = Molecular weight of N_2 or CO , divided by 100
 0.32 = Molecular weight of O_2 , divided by 100
 0.44 = Molecular weight of CO_2 , divided by 100
 13.6 = Specific gravity of mercury (Hg)

MERCURY CALCULATIONS

Determination of Speciated Mercury

Concentration

$$\frac{\text{ug of Mercury detected} \times \frac{10^{-6} \text{ g}}{\text{ug}}}{453.6 \text{ g/lb}} = \text{lbs Mercury / sample}$$

$$\frac{\text{lbs Mercury / sample}}{V_m(\text{std})} = \text{lbs Mercury / dscf}$$

Emission Rates

$$\text{lbs Mercury / hr} = \text{lbs / dscf} \times \text{dscf / min} \times 60 \text{ min / hr}$$

$$\text{lbs Mercury / } 10^{12} \text{ Btu} = \text{lbs / dscf} \times F_d \text{ Factor} (\text{dscf / } 10^6 \text{ Btu}) \times \frac{20.9\%}{20.9\% - O_2\%} \times 10^6$$

Mercury Fractions

Elemental Mercury Catch – mercury collected in the acidified hydrogen peroxide (HNO₃-H₂O₂) and potassium permanganate (H₂SO₄-KMnO₄) impinger solutions.

Oxidized Mercury Catch – mercury collected in the aqueous potassium chloride (KCl) impinger solution.

Particle-bound Mercury Catch – mercury associated with the particulate matter collected in the front half of the sampling train.

Determination of Mercury Available from Coal

$$\text{lbs Mercury / hr} = \frac{\text{ug Mercury}}{\text{g Coal}} (\text{dry}) \times \frac{10^{-6} \text{ g}}{\text{ug}} \times \frac{\text{lbs Coal (wet)}}{\text{hr}} \times (1 - B_{ws}) \text{ moisture corr.}$$

$$\text{lbs Mercury / } 10^{12} \text{ Btu} = \frac{\text{lbs Mercury}}{\text{hr}} \div \frac{10^{12} \text{ Btu}}{\text{hr}}$$

EMISSION RATE CALCULATIONS

A pollutant emission rate (E), expressed as pounds of pollutant per million Btu heat input from the fuel combusted can be calculated by several methods as follows:

1. $C = C_s/7000$ where, C = pollutant concentration, lb/dscf
 c_s = pollutant concentration, grains/dscf
2. If fuel flow is monitored and the fuel combusted during the test is sampled and analyzed for gross calorific value, then:

$$E = \frac{Q_{sd} C}{\text{fuel flow rate (lb / hr) GCV}} \times 10^6$$

where, E = lbs per million Btu

GCV = gross calorific value, Btu / lb

Q_{sd} = dry volumetric gas flow at standard conditions, dscf / hr

3. If an integrated gas sample is taken during the test and analyzed for %CO₂ or %O₂, dry basis by volume, with an Orsat gas analyzer, then

$$E = C F_c \frac{100}{(\%CO_2)} \text{ or, } E = C F \frac{20.9}{(20.9 - \%O_2)} \text{ where,}$$

%CO₂ and %O₂ are expressed as percent; and, for example, for subbituminous and bituminous coals:

F_c = a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted, 1800 scf CO₂/million Btu.

F = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted, 9780 dscf/million Btu.

4. If fuel sample increments are taken and composited during the test and an ultimate analysis is performed and the GCV is determined, then

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV} \text{ where, \%C = carbon content by weight expressed as percent}$$

$$F = \frac{[3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O_2)]}{GVC} \times 10^6$$

where, H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent) respectively.

5. If fuels other than subbituminous and bituminous coals are fired, other F-factors than those above will apply; and, if combinations of different fuels are fired, the F-factors must be prorated according to the fraction of the total heat input derived from each type of fuel.

MOSTARDI-PLATT ASSOCIATES, INC.
TEST SUPPORT DATA

TEST RUN NO. #1 O.H. Hg

COMPANY: Duke Energy THIMBLE NO: 028 TARE WT: 3.1786
 PLANT: Cliffside Station SA In FILTER NO: None TARE WT: None
 TEST LOCATION: #1 Unit - Precip. Inlet BAROMETRIC PRESSURE in. Hg: 29.5
 CLIENT: Duke Energy FLUE PRESSURE in. H₂O: -0.4" Hg
 OPERATOR: Jeff Daniels FLUE PRESSURE in. Hg ABS: 29.1
 DATE: 9-1-99 PROBE LENGTH: 3.75 ft.
 CONTROL BOX: E35 POT. NO.: E35 PROBE LINER MATERIAL: glass
 METER NO.: E35 NOZZLE IDENTIFICATION NO: glass set 2
 METER CALIBRATION FACTOR: 1.001 CALIBRATED NOZZLE DIAMETER: 0.236
 PITOT ID NO.: 514A LEAK CHECK: * PRE: 0.002 POST: 0.002 @ 16/11 in. Hg
 PITOT TUBE COEFFICIENT: 18 DUCT SHAPE: Rectangle DIAMETER: _____
 PORT LENGTH: 4 sq. ft. L 6' W 14'
 PORT SIZE: 4 DISTURBANCE UPSTREAM: 28' DOWNSTREAM: 4'
 PORT TYPE: Nipple w/cap TEST LENGTH: 120 MINUTES PER POINT: 10 (1 reading/5 min)
 IMPINGER H₂O SILICA GEL: TOTAL NUMBER OF TRAVERSE POINTS: 12 (2 readings/point)
 FINAL: 4818.7 ml/gm FINAL WT: 801.4 gm
 INITIAL: 4736.4 ml/gm INITIAL WT: 789.5 gm
 GAIN: 82.3 ml/gm WT. GAIN: 11.9 gm
 TOTAL H₂O COLLECTED: 94.2 CO₂: 14 14 14.0 13.8
 DESCRIPTION OF IMPINGER H₂O: See Lab Notes O₂: 4.4 4.2 4.2 4.4
 SILICA GEL EXHAUSTED?: ✓ Total 18.4 18.2 18.2 18.2
 IMPINGERS RECOVERED BY: JW PITOT LEAK CHECK: PRE 5.2 POST 3.8
 SILICA GEL WEIGHED BY: JW ΔH@ 1.878 SAMPLES REMOVED FROM SITE BY: JRP/JW

COMMENTS & NOTES LIMITED CLEARANCE PART TO GRATING For computer data entry: Supervisor, please complete.

Glass Thimble holder = 14" long Do you want to enter a fuel analysis? Y N
 Port = 18" long What value do you want to use? F = 9,780 F_c = 1,800 Other = _____
 Point 1 = 34" Point 2 = 39.5 Point 3 = 45" Circle to indicate "Yes" or add other value if not given.

* from probe extension 0.002 @ 11" Hg

FIELD TEST DATA SHEET
FOR ISOKINETIC SAMPLING

MOSTARDI-PLATT ASSOCIATES, INC.

PROJECT Duke Energy Corp

TEST RUN NO: # 1 = CLIFFSIDE STATION

TEST LOCATION CLIFFSIDE INLET - UNIT #1

(709)

DATE / SEPT 99 PAGE / 2

Port-Point No.	Velocity Head (P) in. H ₂ O	√F	Clock Time 24 hr.	Meter Volume (V/m) ft ³	Orifice (H) in. H ₂ O	Stack Temp (t) °F	Meter Temp. (t _m)		0.634 Meter Rate cfm	Pump Vacuum in. Hg	Notes	Probe Temp. °F	HEATED LINE Filter Hotter Temp. °F	Fully Heated Impinger Outlet Temp. °F
							Inlet °F	Outlet °F						
1-1	0.19	0.436	1035	179.82	0.25	632	69	72	0.276	3	1.382	246	225	64
2-1	0.19	0.436	1040	181.50	0.25	649	70	72	0.276	3	1.382	259	235	63
2-1	0.19	0.436	1045	182.69	0.25	651	74	71	0.276	3	1.382	263	237	62
2-1	0.19	0.436	1050	184.285	0.25	649	74	72	0.276	3	1.382	262	226	61
3-1	0.19	0.436	1055	185.645	0.25	647	72	73	0.276	3	1.382	263	234	62
2-1	0.21	0.459	1100	187.61	0.28	651	73	74	0.291	3	1.453	262	235	60
		(2.6377)	1105	188.585	(1.53)	(5079)	(866)							
				(8.765)										
1-1	0.38	0.616	1107:30	188.64	0.50	648	74	74	0.381	4	1.954	261	240	59
2-1	0.37	0.608	112:30	190.68	0.49	655	75	74	0.386	4	1.928	264	240	60
2-1	0.39	0.625	11:17:30	192.40	0.52	654	76	74	0.396	4	1.980	262	229	59
2-1	0.40	0.632	11:27:30	194.32	0.53	657	77	75	0.401	4	2.005	262	235	59
3-1	0.42	0.648	11:27:30	196.39	0.56	653	77	75	0.411	4	2.054	265	240	59
2-1	0.42	0.648	11:32:30	198.38	0.56	650	78	76	0.411	4	2.054	262	238	59
		(3.7778)	11:37:30	200.75	(3.16)	(3917)	(905)							
				(12.11)										
1-1	0.43	0.656	11:41	200.87	0.57	648	76	76	0.416	7	2.079	264	238	59
2-1	0.42	0.648	11:46	202.97	0.56	656	77	76	0.411	4	2.054	265	238	58
2-1	0.45	0.671	11:51	204.92	0.60	656	78	76	0.425	4	2.127	266	239	59
2-1	0.45	0.671	11:56	207.25	0.60	653	78	76	0.425	5	2.127	264	238	58
3-1	0.48	0.693	12:01	209.20	0.64	655	78	76	0.439	5	2.196	266	240	59
2-1	0.49	0.70	12:06	211.32	0.65	656	79	76	0.444	5	2.219	266	240	59
		(4.0383)	12:11	213.46	(5.62)	(3724)	(922)							
				(12.59)										
				33.465	8.31	11720	2693							
		10.4538												

1-1 1-1 2-1 3-1 1-1 2-1 2-1 2-1 3-1 2-1

FIELD TEST DATA SHEET
FOR ISOKINETIC SAMPLING

MOSTARDI-PLATT ASSOCIATES, INC.

PROJECT Duke Energy Corporation
TEST RUN NO. 1
TEST LOCATION _____

DATE 9/1/99 PAGE 2 OF 2

Port-Point No.	Velocity Head (P) in. H ₂ O	√P	Clock Time 24 hr.	Meter Volume (V _m) ft ³	Orifice (H) in. H ₂ O	Stack Temp (t _s) °F	Meter Temp. (t _m)		Pump Vacuum in. Hg	Notes	Probe Temp. °F	Heated Filter Hotter Temp. °F	Fully Impinger Outlet Temp. °F
							Inlet °F	Outlet °F					
1-1	0.60	0.693	12:13:30	813.53	0.80	652	80	76	5	2.196	263	240	61
2	0.61	0.781	12:16:30	815.66	0.81	653	80	77	7	2.476	265	241	61
2-1	0.63	0.794	12:23:20	818.14	0.84	651	80	76	8	2.516	263	240	61
2	0.64	0.80	12:28:30	820.65	0.85	655	81	77	8	2.536	265	240	60
3-1	0.55	0.742	12:33:30	822.95	0.73	647	81	78	7	2.351	267	239	63
2	0.52	0.721	12:38:30	824.98	0.69	647	81	76	7	2.286	266	239	65
		<u>9.61208</u>	<u>12:43:30</u>	<u>827.80</u>	<u>4.72</u>	<u>3905</u>	<u>943</u>			<u>827.816</u>			
				<u>14.27</u>									
		10.4538		33.465	8.31	11720	2693						
		15.066			13.03	15625	3636						
		0.6277		47.735	0.543	651.04	75.75						

est
4

MOSTARDI-PLATT ASSOCIATES, INC.
TEST SUPPORT DATA

TEST RUN NO. #2

COMPANY: Duke Energy Corporation THIMBLE NO: 026 TARE WT: 3.2667
 PLANT: Cliffside Steam Station FILTER NO: NONE TARE WT: NONE
 TEST LOCATION: Unit #1 - Precip. Inlet BAROMETRIC PRESSURE in. Hg: 29.50
 CLIENT: Duke Energy Corporation FLUE PRESSURE in. H₂O: -0.4" Hg
 OPERATOR: Jeff Daniels FLUE PRESSURE in. Hg ABS: 29.10
 DATE: 9-1-99 PROBE LENGTH: 3.75 ft.
 CONTROL BOX: E35 POT. NO.: E35 PROBE LINER MATERIAL: GLASS
 METER NO.: E35 NOZZLE IDENTIFICATION NO: GLASS SET 3
 METER CALIBRATION FACTOR: 1.001 CALIBRATED NOZZLE DIAMETER: 0.235
 PITOT ID NO.: 514A LEAK CHECK: PRE: 0.008 POST: 0.002 @ 14/8 in. Hg
 PITOT TUBE COEFFICIENT: .828 DUCT SHAPE: Rectangular DIAMETER:
 PORT LENGTH: 18 in. DUCT AREA: 84.0 sq. ft. L 6' W 14'
 PORT SIZE: 3 PORT TYPE: Nipple w/cap DISTURBANCE UPSTREAM: 28' DOWNSTREAM: 4'
 IMPINGER H₂O SILICA GEL: TEST LENGTH: 120 MINUTES PER POINT: 10 (5 min readings)
 FINAL: 466.1 ml/gm FINAL WT: 716.7 gm TOTAL NUMBER OF TRAVERSE POINTS: 12
 INITIAL: 4586.9 ml/gm INITIAL WT: 702.6 gm GAS ANALYSIS (ORSAT/FYRITE):
 GAIN: ml/gm WT. GAIN: 90.3 gm CO₂: 13.6 13.8 13.6
 O₂: 4.2 4.2 4.4
 TOTAL H₂O COLLECTED: 18.0 18.0 18.0
 DESCRIPTION OF IMPINGER H₂O: See lab notes
 SILICA GEL EXHAUSTED?: Jw PITOT LEAK CHECK: PRE 4.2" H₂O POST 6" H₂O
 IMPINGERS RECOVERED BY: Jw AH@ 1.878
 SILICA GEL WEIGHED BY: Jw SAMPLES REMOVED FROM SITE BY: JRP, JW

COMMENTS & NOTES

For computer data entry: Supervisor, please complete.
 Do you want to enter a fuel analysis? Y N
 What value do you want to use? F = 9,780 F_c = 1,800 Other = _____
 Circle to indicate "Yes" or add other value if not given.

PROJECT Duke Energy Corp.
 TEST RUN NO. #2 - Cliffside Steam Station
 TEST LOCATION Precip. Inlet - Unit #1

DATE 1 SEPT 99 PAGE 1 OF 2

Port-Point No.	Velocity Head (P) in. H ₂ O	√P	Clock Time 24 hr.	Meter Volume (V/m) ft ³	1.338 Orifice (H) in. H ₂ O	Stack Temp (t) °F	Meter Temp. (t _m)		0.645 Meter Rate cfm	Pump Vacuum in. Hg	Notes	Probe Temp. °F	HEATED Filter Holder Temp. °F	Fully Sealed Impinger Outlet Temp. °F
							Inlet °F	Outlet °F						
1-1	0.19	0.436	1450	828.81	0.25	642	83	82	0.281	3	1.406	242	67	
2	0.18	0.424	55	830.12	0.24	645	85	84	0.274	3	1.368	239	66	
2-1	0.21	0.458	1500	831.48	0.28	642	84	84	0.296	3	1.478	242	62	
2	0.19	0.436	05	833.17	0.25	644	84	84	0.281	3	1.406	239	63	
3-1	0.18	0.424	10	834.50	0.24	644	84	84	0.274	3	1.368	240	66	
2	0.20	0.447	15	835.98	0.27	647	85	84	0.288	3	1.447	241	67	
		2.626	20	837.48	1.53	3864	1007				837.276			
				8.67							LEAK CHECKS			
1-1	0.37	0.608	15:30:30	837.66	0.50	644	86	85	0.392	3	1.962	242	68	
2	0.40	0.632	15:35:30	839.58	0.54	652	86	84	0.408	3	2.039	242	68	
2-1	0.40	0.632	15:40:30	841.75	0.54	654	86	86	0.408	3	2.040	243	66	
2	0.39	0.624	15:45:30	843.77	0.52	652	87	87	0.403	3	2.014	242	64	
3-1	0.38	0.616	15:50:30	845.58	0.51	652	84	86	0.398	3	1.988	242	65	
2	0.40	0.632	15:55:30	847.81	0.54	653	88	84	0.408	4	2.040	244	66	
		3.746	16:00:30	849.80	3.15	3907	1033				849.742			
				12.23							LEAK CHECK			
1-1	0.43	0.656	1607	850.03	0.58	651	88	86	0.423	4	2.115	241	67	
2	0.42	0.648	1612	850.26	0.56	651	89	87	0.418	4	2.090	241	66	
2-1	0.45	0.671	1617	854.33	0.60	654	89	88	0.433	4	2.163	242	67	
2	0.45	0.671	1622	856.34	0.60	655	89	88	0.433	5	2.163	241	68	
3-1	0.44	0.663	1627	858.37	0.59	653	89	88	0.428	5	2.139	244	66	
2	0.45	0.671	1632	860.57	0.60	653	90	88	0.433		2.163	242		
		3.996	1637	862.78	3.53	3916	1059				862.863			
				12.75							LEAK CHECK			
											0.002 @ 7" Hg			
		10.352		33.64	8.21	11687	3099							

PROJECT Duke Energy Corporation

TEST RUN NO. 2 CLIFFSIDE Stream Station

TEST LOCATION INLET 0. H. Hg

DATE 9-1-99

PAGE

2

OF

2

Port-Point No.	Velocity Head (P) in. H ₂ O	√P	Clock Time 24 hr.	Meter Volume (Vm) ft ³	1.338 Orifice (H) in. H ₂ O	Stack Temp (t) °F	Meter Temp. (t _m)		0.645 Meter Rate cfm	Pump Vacuum in. Hg	Notes	Probe Temp. °F	TRANSFER LINE Filter-Holder Temp. °F	Fully Impinger Outlet Temp. °F
							Inlet °F	Outlet °F						
1-1	0.52	0.721	1643	862.91	0.70	646	92	88	0.465	5	2.326	264	242	64
2	0.53	0.728	1648	865.11	0.70	649	91	88	0.470	5	2.348	264	244	65
2-1	0.51	0.714	1653	867.47	0.68	647	91	88	0.460	5	2.303	264	245	66
2	0.51	0.714	1658	869.88	0.68	648	91	88	0.46	5	2.303	262	241	67
3-1	0.55	0.742	1702	871.82	0.74	646	91	88	0.478	6	2.392	262	242	68
2	0.53	0.728	1708	874.61	0.71	646	92	88	0.470	6	2.348	267	243	
		(4.347)	1713	876.60	(4.21)	(3882)	(1076)				876.894			
				(13.69)										
		10.3522		33.64	8.21	11687	3099							
		14.692			12.42	15569	4175							
		0.6125		47.33	0.5175	698.71	86.98							
						1108.71	546.98							

4-57

MOSTARDI-PLATT ASSOCIATES, INC.
TEST SUPPORT DATA

TEST RUN NO. 3 O.H. Hg

COMPANY: Duke Energy Corporation
 PLANT: Cliffside Generating Station
 TEST LOCATION: Inlet
 CLIENT: Duke Energy Corp.
 OPERATOR: Jeff Daniels
 DATE: 9-1-99
 CONTROL BOX: E35 POT. NO.: E35
 METER NO.: E35
 METER CALIBRATION FACTOR: 1.001
 PITOT ID NO.: 514A
 PITOT TUBE COEFFICIENT: 4 in.
 PORT LENGTH: 18 in.
 PORT SIZE: 5/8 Nipple with Cap
 PORT TYPE: _____
 IMPINGER H₂O: _____ SILICA GEL: _____
 FINAL: 4233.4 ml/gm FINAL WT: 804.5 gm
 INITIAL: 4833.4 ml/gm INITIAL WT: 792.9 gm
 GAIN: _____ ml/gm WT. GAIN: 95.3 gm
 TOTAL H₂O COLLECTED: _____
 DESCRIPTION OF IMPINGER H₂O: See lab notes
 SILICA GEL EXHAUSTED?: W
 IMPINGERS RECOVERED BY: JW
 SILICA GEL WEIGHED BY: JW
 THIMBLE NO: 023 TARE WT: 3.8785
 FILTER NO: None TARE WT: None
 BAROMETRIC PRESSURE in. Hg: _____
 FLUE PRESSURE in. H₂O: -4.0
 FLUE PRESSURE in. Hg ABS: 28.96
 PROBE LENGTH: 3.75 ft.
 PROBE LINER MATERIAL: Glass
 NOZZLE IDENTIFICATION NO: Glass set #2
 CALIBRATED NOZZLE DIAMETER: 0.236
 LEAK CHECK: PRE: 0.004 POST: 0.002 @ 15/8 in. Hg
 DUCT SHAPE: Rectangle DIAMETER: 10.34177
 DUCT AREA: 84 sq. ft. L 0 W 14'
 DISTURBANCE UPSTREAM: 28' DOWNSTREAM: 4'
 TEST LENGTH: 120 MINUTES PER POINT: 10 (5 minute readings)
 TOTAL NUMBER OF TRAVERSE POINTS: 12
 GAS ANALYSIS (ORSAT/FYRITE): _____
 CO₂: 13.5
 O₂: 4.4
 PITOT LEAK CHECK: PRE 3.9" H₂O POST _____
 AH@ 1.878
 SAMPLES REMOVED FROM SITE BY: JRP, JW

COMMENTS & NOTES

For computer data entry: Supervisor, please complete.
 Do you want to enter a fuel analysis? Y N
 What value do you want to use? F = 9,780 F_c = 1,800 Other = _____
 Circle to indicate "Yes" or add other value if not given.

PROJECT DUKE ENERGY CORP
TEST RUN NO. 3 CLIFFSIDE
TEST LOCATION PRECIP INLET

DATE 7-2-99 PAGE 2 OF 2

Port-Point No.	Velocity Head (P) in. H ₂ O	√P	Clock Time 24 hr.	Meter Volume (V _m) ft ³	Orifice (H) in. H ₂ O	Stack Temp (G) °F	Meter Temp. (t _m)		0.637 Meter Rate cfm	Pump Vacuum in. Hg	Notes	Probe Temp. °F	Filter Holder Temp. °F	Impinger Outlet Temp. °F
							Inlet °F	Outlet °F						
1-1	0.53	0.728	1001	910.30	0.71	643	76	73	0.464	6	2.319	257	240	52
2	0.53	0.728	1006	912.55	0.71	642	77	75	0.464	6	2.319	259	239	53
2-1	0.54	0.735	1011	914.75	0.73	642	78	75	0.468	6	2.340	258	240	53
2	0.55	0.742	1016	917.31	0.73	646	78	75	0.472	7	2.362	259	241	54
3-1	0.56	0.745	1024	919.91	0.74	648	79	76	0.474	7	2.372	259	242	54
2	0.54	0.735	1026	921.64	0.72	647	80	76	0.468	7	2.340	257	241	56
		<u>(7.457)</u>	1031	923.99	4.34	<u>(3868)</u>	<u>(918)</u>				924.352			
				13.69										
		10.431		32.83	8.32	11624	2483							
		14.847			12.66	15492	3401							
		8.619		46.52	0.528	645.5	7085							

1-EST
ND
4-

MOSTARDI-PLATT ASSOCIATES, INC.
TEST SUPPORT DATA

TEST RUN NO. 1

COMPANY: Duke Energy THIMBLE NO: 032 TARE WT: 339.2
 PLANT: Cliffside 1 FILTER NO: _____ TARE WT: _____
 TEST LOCATION: Stack BAROMETRIC PRESSURE in. Hg: 29.45
 CLIENT: VERA FLUE PRESSURE in. H₂O: -0.50
 OPERATOR: JAP FLUE PRESSURE in. Hg ABS: 29.41
 DATE: 9/1/99 PROBE LENGTH: 10.5 ft.
 CONTROL BOX: F-18 POT. NO.: E-18
 METER NO.: E-18 NOZZLE IDENTIFICATION NO: #10 (SET A)
 METER CALIBRATION FACTOR: 0.992 CALIBRATED NOZZLE DIAMETER: 0.308
 PITOT ID NO: 427A LEAK CHECK: PRE: 0.00 POST: 0.00 @ 14"/12" in. Hg
 PITOT TUBE COEFFICIENT: 0.830 DUCT SHAPE: ROUND DIAMETER: 10.6"
 PORT LENGTH: 6 sq. ft. L _____ W _____
 PORT SIZE: 4 DISTURBANCE UPSTREAM: 235' DOWNSTREAM: 38'
 PORT TYPE: Flange TEST LENGTH: 120 min
 IMPINGER H₂O MINUTES PER POINT: 5
 FINAL: 149 ml/gm SILICA GEL: FINAL WT: 771.0 gm
 INITIAL: 0 ml/gm INITIAL WT: 750.8 gm
 GAIN: 149.0 ml/gm WT. GAIN: 20.2 gm
 TOTAL H₂O COLLECTED: 169.2
 DESCRIPTION OF IMPINGER H₂O: _____
 SILICA GEL EXHAUSTED?: _____
 IMPINGERS RECOVERED BY: _____
 SILICA GEL WEIGHED BY: JAP

PITOT LEAK CHECK: PRE POST

AH@ _____ SAMPLES REMOVED FROM SITE BY: JAP

For computer data entry: Supervisor, please complete.

Do you want to enter a fuel analysis? Y N

What value do you want to use? F = 9,780 F_C = 1,800 Other = _____

Circle to indicate "Yes" or add other value if not given.

COMMENTS & NOTES

PROJECT Duke Energy
 TEST RUN NO. 1
 TEST LOCATION Stack

DATE 9/1/99 PAGE 1 OF 1

Port-Point No.	Velocity Head (F) in. H ₂ O	√P	Clock Time 24 hr.	Meter Volume (V _m) ft ³	Orifice (H) in. H ₂ O	Stack Temp (t _s) °F	Meter Temp. (t _m)		1.27 Meter Rate cfm	Pump Vacuum in. Hg	Notes	Probe Temp. °F	Filter Holder Temp. °F	Impinger Outlet Temp. °F
							Inlet °F	Outlet °F						
1-1	0.33	0.575	1035	29.88	1.74	381	76	76	0.73	8.0		220	247	58
2	0.35	0.572	1040	33.40	1.85	383	77	77	0.75		33.5	230	249	58
3	0.35	0.572	1045	37.10	1.85	383	77	77	0.75		37.26	233	245	59
4	0.28	0.524	1050	40.70	1.48	384	79	78	0.67		41.01	232	246	59
5	0.27	0.469	1055	44.30	1.16	383	79	78	0.60		44.36	232	245	59
6	0.27	0.520	1100	47.47	1.42	384	80	78	0.66	8.0	47.36	229	243	60
7	0.35	0.572	1105	50.70	1.54	385	81	79	0.75		50.66	229	245	60
8	0.38	0.616	1110	54.40	2.00	385	83	80	0.78	8.5	54.41	229	247	60
9	0.53	0.728	1115	58.20	2.79	384	85	81	0.92	10.0	58.31	228	243	61
10	0.65	0.806	1120	62.90	3.43	384	89	85	1.07	15.5	62.91	222	245	66
11	0.75	0.964	1125	68.20	3.75	385	89	86	1.10	16	68.91	228	246	64
12	0.62	0.787	1130	73.90	3.29	344	90	87	1.00	17	74.41	228	246	69
		0.672	1135	78.8	2.638	4565	(1947)				79.41			
2-1	0.35	0.572	1144	79.5	1.85	384	91	87	0.75	7.5		225	246	65
2	0.33	0.575	1149	82.91	1.74	384	91	87	0.73		83.16	227	246	61
3	0.30	0.548	1154	86.30	1.58	384	93	88	0.70		86.81	231	245	60
4	0.30	0.548	1159	90.10	1.58	384	93	88	0.70		90.31	233	246	60
5	0.35	0.572	1204	93.40	1.85	385	96	90	0.75		93.81	234	246	61
6	0.35	0.572	1209	97.37	1.85	386	96	90	0.75		97.56	234	247	63
7	0.35	0.572	1214	101.10	1.85	387	98	91	0.75	8.5	101.31	229	243	63
8	0.45	0.671	1219	105.10	2.37	390	98	91	0.85		105.06	230	243	66
9	0.60	0.770	1224	109.30	3.16	395	99	95	0.98		109.31	228	248	65
10	0.55	0.742	1229	114.10	2.90	385	99	95	0.94	12.0	114.21	228	249	67
11	0.37	0.608	1234	118.76	1.95	384	99	95	0.77		118.91	228	248	67
12	0.32	0.506	1239	126.90	1.68	382	99	95	0.72		122.76	228	245	67
		7.402	1244	126.67	2.436	4630	2744				126.36			
		15.024		-0.70	5.14	4955	4191							
		0.6781		96.09	2.13	383.1	873							

843.1 1549.3

TEST SUPPORT DATA

TEST RUN NO. 2

COMPANY: Duka Energy THIMBLE NO: 017 TARE WT: 3.2408
 PLANT: CHIFFSIDE 1 FILTER NO: _____ TARE WT: _____
 TEST LOCATION: FRNS STACK BAROMETRIC PRESSURE in. Hg: 28.45
 CLIENT: FRNS FLUE PRESSURE in. H₂O: -0.50
 OPERATOR: JRL FLUE PRESSURE in. Hg ABS: 29.41
 DATE: 9/1/99 PROBE LENGTH: 10.5 ft.
 CONTROL BOX: E-18 POT. NO.: E-18
 METER NO.: E-18 PROBE LINER MATERIAL: GLASS
 METER CALIBRATION FACTOR: 0.992 NOZZLE IDENTIFICATION NO: #8 (Set A)
 PITOT ID NO.: 427A PRE: 0.00 POST: 0.00 @ 15/15 in. Hg
 PITOT TUBE COEFFICIENT: 0.810 DIAMETER: 10.6"
 PORT LENGTH: 6 in. DUCT SHAPE: ROUND DUCT AREA: 86.59 sq. ft. L _____ W _____
 PORT SIZE: 1/2 in. DISTURBANCE UPSTREAM: 23.5' DOWNSTREAM: 32'
 PORT TYPE: FLANGES TEST LENGTH: 120 MINUTES PER POINT: 5
 IMPINGER H₂O SILICA GEL: TOTAL NUMBER OF TRAVERSE POINTS: 24
 FINAL: 102 ml/gm FINAL WT: 733.5 gm
 INITIAL: 0 ml/gm INITIAL WT: 718.2 gm
 GAIN: 102 ml/gm WT. GAIN: 15.3 gm
 TOTAL H₂O COLLECTED: 117.3
 DESCRIPTION OF IMPINGER H₂O: _____
 SILICA GEL EXHAUSTED?: _____
 IMPINGERS RECOVERED BY: _____
 SILICA GEL WEIGHED BY: _____
 PITOT LEAK CHECK: PRE _____ POST _____
 ΔH@ _____
 SAMPLES REMOVED FROM SITE BY: _____

COMMENTS & NOTES

For computer data entry: Supervisor, please complete.
 Do you want to enter a fuel analysis? Y N
 What value do you want to use? F = 9,780 F_c = 1,800 Other = _____
 Circle to indicate "Yes" or add other value if not given.

FIELD TEST DATA SHEET
FOR ISOKINETIC SAMPLING

MOSTARDI-PLATT ASSOCIATES, INC.

PROJECT Duke Energy
TEST RUN NO. 2
TEST LOCATION Stack

DATE 9/1/99 PAGE 1 OF 1

Port-Point No.	Velocity Head (P) in. H ₂ O	√P	Clock Time 24 hr.	Meter Volume (V _m) ft ³	2.21 Orifice (H) in. H ₂ O	Stack Temp (t _s) °F	Meter Temp. (t _m)		8.49 Meter Rate cfm	Pump Vacuum in. Hg	Notes	Probe Temp. °F	Filter Holder Temp. °F	Impinger Outlet Temp. °F
							Inlet °F	Outlet °F						
1-1	0.35	0.592	1450	27.39	0.77	385	97	97	0.50	6		225	247	71
2	0.35	0.592	1455	29.80	0.77	386	97	97	0.50		29.89	235	247	70
3	0.35	0.592	1500	32.35	0.77	386	97	97	0.50		32.39	245	245	66
4	0.35	0.592	1505	34.80	0.77	385	97	97	0.50		34.89	245	247	67
5	0.35	0.592	1510	37.30	0.77	385	97	97	0.50		37.39	245	245	67
6	0.30	0.548	1515	39.80	0.66	386	97	97	0.47	5.5	39.89	244	245	67
7	0.36	0.600	1520	42.15	0.80	386	98	98	0.51		42.24	245	245	67
8	0.50	0.707	1525	44.55	1.11	385	98	98	0.60		44.79	242	247	67
9	0.55	0.742	1530	47.50	1.22	386	99	98	0.63		47.79	242	244	62
10	0.75	0.866	1535	50.70	1.66	386	99	98	0.74		50.94	242	246	63
11	0.80	0.894	1540	54.50	1.77	387	100	98	0.76	11.0	54.64	242	246	64
12	0.80	0.894	1545	58.15	1.77	384	100	98	0.76		58.44	240	246	67
		(8.21)	1550	62.15	(2.54)	(462.7)	(234.6)	(98)			62.24			
2-1	0.35	0.592	1555	62.34	0.77	384	100	98	0.50	6.5		239	245	70
2	0.35	0.592	1600	64.90	0.77	383	100	98	0.50		64.84	243	248	67
3	0.36	0.600	1615	67.50	0.80	383	100	98	0.51		67.34	240	247	66
4	0.36	0.600	1610	70.00	0.80	384	100	98	0.51		64.89	248	247	66
5	0.36	0.600	1615	72.50	0.80	384	100	98	0.51	6.0	72.44	241	248	66
6	0.38	0.616	1620	75.10	0.84	388	100	98	0.52		74.99	250	247	66
7	0.32	0.566	1625	77.50	0.71	387	100	98	0.48		77.59	246	247	66
8	0.32	0.565	1630	80.00	0.71	389	100	98	0.48		79.89	245	239	68
9	0.32	0.565	1635	82.40	0.71	390	100	98	0.48		82.39	245	247	68
10	0.40	0.633	1640	84.80	0.88	391	100	98	0.54		84.79	244	247	69
11	0.30	0.548	1645	87.40	0.66	388	101	98	0.47		87.99	243	247	71
12	0.30	0.548	1650	89.80	0.66	384	101	98	0.47		89.89	241	245	71
		7.027	1655	92.20	9.11	4635	8328				92.19			
		15.238		-0.17	2.95	9262	4724							
		0.6349			0.915	3859	984							
						8459	5584							

MOSTARDI-PLATT ASSOCIATES, INC.
TEST SUPPORT DATA

TEST RUN NO. 3

COMPANY: Duke Energy THIMBLE NO: 027 TARE WT: 3,1779
 PLANT: CLIFFSIDE 1 FILTER NO: _____ TARE WT: _____
 TEST LOCATION: STACK BAROMETRIC PRESSURE in. Hg: 29.25
 CLIENT: EG&G FLUE PRESSURE in. H₂O: -0.50
 OPERATOR: JN FLUE PRESSURE in. Hg ARS: 29.21
 DATE: 9/2/99 PROBE LENGTH: 10.5 ft.
 CONTROL BOX: E-18 POT. NO.: E-18 PROBE LINER MATERIAL: GLASS
 METER NO.: E-18 NOZZLE IDENTIFICATION NO: #8 (S-05 A)
 METER CALIBRATION FACTOR: 0.992 CALIBRATED NOZZLE DIAMETER: 0.245
 PITOT ID NO.: 427A LEAK CHECK: PRE: 0.00 POST: 0.00 @ 16/18 in. Hg
 PITOT TUBE COEFFICIENT: 0.830 DUCT SHAPE: ROUND DIAMETER: 10.6"
 PORT LENGTH: 6 in. DUCT AREA: 86.57 sq. ft. L _____ W _____
 PORT SIZE: 4 in. DISTURBANCE UPSTREAM: 23.5 DOWNSTREAM: 38
 PORT TYPE: FLANG TEST LENGTH: 120 min
 IMPINGER H₂O _____ MINUTES PER POINT: 5
 FINAL: 93.1 ml/gm SILICA GEL: _____ TOTAL NUMBER OF TRAVERSE POINTS: 24
 INITIAL: 0 ml/gm FINAL WT: 756.4 gm INITIAL WT: 745.7 gm
 GAIN: 93.1 ml/gm WT. GAIN: 10.7 gm
 TOTAL H₂O COLLECTED: _____ GAS ANALYSIS (ORSAT/FYRITE):
 CO₂: 12.2 12.2 12.2
 O₂: 6.1 6.1 6.1
 DESCRIPTION OF IMPINGER H₂O: _____
 SILICA GEL EXHAUSTED?: _____ PITOT LEAK CHECK: PRE POST
 IMPINGERS RECOVERED BY: _____ ΔH@ _____
 SILICA GEL WEIGHED BY: JN SAMPLES REMOVED FROM SITE BY: _____

COMMENTS & NOTES

For computer data entry: Supervisor, please complete.
 Do you want to enter a fuel analysis? Y N
 What value do you want to use? F = 9,780 F_c = 1,800 Other = _____
 Circle to indicate "Yes" or add other value if not given.

FIELD TEST DATA SHEET
FOR ISOKINETIC SAMPLING

MOSTARDI-PLATT ASSOCIATES, INC.

PROJECT WKA Energy
TEST RUN NO. 3
TEST LOCATION 5720R

DATE 9/2/99 PAGE 1 OF 1

Port-Point No.	Velocity Head (F) in. H ₂ O	√P	Clock Time 24 hr.	Meter Volume (Vm) ft ³	Orifice (H) in. H ₂ O	Stack Temp (t) °F	Meter Temp. (t _m)		Meter Rate cfm	Pump Vacuum in. Hg	Notes	Probe Temp. °F	Filter Holder Temp. °F	Impinger Outlet Temp. °F
							Inlet °F	Outlet °F						
1-1	0.34	0.583	0815	98.52	0.71	374	69	69	0.47	3.0		225	246	62
2	0.30	0.518	0820	94.86	0.62	374	65	65	0.44		94.87	241	242	55
3	0.34	0.584	0825	97.00	0.71	375	66	66	0.49		97.07	248	248	57
4	0.32	0.550	0830	98.30	0.67	375	67	67	0.45		97.42	245	245	57
5	0.32	0.566	0835	101.55	0.67	375	68	68	0.44		101.67	245	245	53
6	0.30	0.548	0840	103.90	0.63	376	70	70	0.42		103.42	242	242	53
7	0.37	0.600	0845	106.05	0.77	376	71	67	0.49		106.12	242	247	53
8	0.50	0.707	0850	108.50	1.04	375	71	68	0.57		108.57	241	248	48
9	0.60	0.787	0855	111.30	1.29	372	72	68	0.63	3.0	111.42	241	248	48
10	0.71	0.843	0900	114.42	1.48	375	74	69	0.68	6.0	113.57	240	247	50
11	0.75	0.866	0905	117.80	1.57	376	75	70	0.69	6.0	117.97	240	243	51
12	0.82	0.906	0910	121.30	1.71	376	76	71	0.73		121.42	239	240	51
		8.11	0915	125.02	1.83	4503	(6.47)				125.07			
2-1	0.35	0.512	0919	125.20	0.73	376	77	71	0.47	3.0		238	247	57
2	0.35	0.542	0924	127.65	0.73	376	78	72	0.47		127.55	239	244	55
3	0.35	0.552	0929	129.95	0.73	376	78	72	0.47		129.90	242	244	55
4	0.38	0.615	0934	132.10	0.79	376	79	73	0.49		132.25	243	250	56
5	0.35	0.572	0939	134.75	0.73	378	80	74	0.47		134.70	245	250	58
6	0.35	0.592	0944	137.10	0.73	379	80	74	0.47		137.05	245	249	58
7	0.21	0.408	0949	139.43	0.44	380	81	74	0.47		139.40	244	249	60
8	0.21	0.438	0954	141.30	0.44	381	82	74	0.47		141.25	243	249	60
9	0.25	0.510	0959	143.20	0.52	381	82	74	0.40		143.10	242	249	60
10	0.30	0.548	1004	145.20	0.63	381	83	74	0.44		145.11	242	248	59
11	0.25	0.502	1009	147.40	0.52	381	84	75	0.40		147.31	241	248	59
12	0.24	0.520	1014	149.40	0.52	381	84	75	0.40		149.31	241	247	58
		6.510	1019	151.45	0.51	4546	1850				151.31			
		17.651				9049	3497							
		0.6105		-0.15	0.508	377.0	72.9							

58.750 847.0 5329

METHOD 3 - FIELD DATA SHEET
INTEGRATED SAMPLES - GAS ANALYSIS

Project: Duke Energy - Cliffside
 Sampling Location: Inlet
 Source Condition: Full Load
 Fuel Type: Coal
 Module No: 1 Rate Meter Units: lpm

Date: 9-2-99
 Monitor Model No: _____
 Serial No: _____
 Orsat No. 3008-008 Bag Type: _____

Test (Run) No. <u>3</u>			Test (Run) No. _____																	
SAMPLING			ANALYSIS				SAMPLING			ANALYSIS										
Port-Point No.	Clock Time 24hr	Flow Rate	% By Volume (dry basis)				Port-Point No.	Clock Time 24hr	Flow Rate	% By Volume (dry basis)										
			Total	CO ₂	O ₂	CO				Total	CO ₂	O ₂	CO							
1-2	825	1 lpm	18	13.4	4.6															
3	840	↓	18	13.6	4.4															
2-1	853	↓	18.2	13.8	4.2															
2	908	1 lpm																		
3-1	931	↓	Avg.	13.6	4.4															
2	946	↓	Pre-Run Leak Check:				Pre-Run Leak Check:													
4-1	1005	1 lpm	Train: <u>ok @ 10" Hg</u>				Train: _____													
2	1015	"	Bag: <u>ok @ 10" Hg</u>				Bag: _____													
			Pipettes: <u>✓ @ 4 min</u>				Pipettes: _____													
			Burette: <u>✓ @ 4 min</u>				Burette: _____													
			Post-Run Leak Check:				Post-Run Leak Check:													
			Train: <u>✓ @ 10" Hg</u>				Train: _____													
			Bag: <u>✓ @ 10" Hg</u>				Bag: _____													
			Pipettes: <u>✓ @ 4 min</u>				Pipettes: _____													
			Burette: <u>✓ @ 4 min</u>				Burette: _____													
VALIDATION			VALIDATION				VALIDATION			VALIDATION										
Fuel Factor (F ₀)		Percent Difference		Fuel Factor (F ₀)		Percent Difference		Fuel Factor (F ₀)		Percent Difference		Fuel Factor (F ₀)		Percent Difference						
Orsat	Fuel			Orsat	Fuel			Orsat	Fuel			Orsat	Fuel							

Comments:

Operator: Jeff Daniels

$$F_{12,0}(\text{Orsat}) = \frac{20.9 - (\%O_2 - 0.5 \%CO)}{\%CO_2 + \%CO}$$

$$F_0(\text{Fuel}) = \frac{0.209 F_{12,0}}{F_1} = \frac{0.651 (1.53 \%C - 3.64 \%H + 0.57 \%S + 0.14 \%N - 0.46 \%O)}{\%C}$$

$$\% \text{ Difference} = \frac{F_0(\text{Orsat}) - F_0(\text{Fuel})}{F_0(\text{Fuel})} \cdot 100$$

METHOD 3 - FIELD DATA SHEET
INTEGRATED SAMPLES - GAS ANALYSIS

Project: Duke Energy Cliffside 1
 Sampling Location: Stack
 Source Condition: _____
 Fuel Type: COAL
 Module No: _____ Rate Meter Units: _____ Orsat No. _____

Date: 9/1/99
 Monitor Model No: _____
 Serial No: _____
 Bag Type: _____

Test (Run) No. _____			Test (Run) No. _____				
SAMPLING			SAMPLING				
Port-Point No.	Clock Time 24hr	SCFH Flow Rate	ANALYSIS				
			% By Volume (dry basis)				
			Total	CO ₂	O ₂	CO	
1-1	1038	3	18.6	12.2	6.4	-	
2	1043	2	18.6	12.2	6.4	-	
3	1048	2	18.6	12.2	6.4	-	
4	1053	1.5					
5	1058	1.5					
6	1103	1.5	Avg.	12.2	6.4	-	
7	1105	1.5	Pre-Run Leak Check:				
8	1108	1.5	Train: <input checked="" type="checkbox"/>				
9	1113	1.5	Bag: <input checked="" type="checkbox"/>				
10	1118	1.5	Pipettes: <input checked="" type="checkbox"/>				
11	-	-	Burette: <input checked="" type="checkbox"/>				
12	-	-	Post-Run Leak Check:				
			Train: <input checked="" type="checkbox"/>				
			Bag: <input checked="" type="checkbox"/>				
			Pipettes: <input checked="" type="checkbox"/>				
			Burette: <input checked="" type="checkbox"/>				
VALIDATION			VALIDATION				
Fuel Factor (F _o)		Percent Difference		Fuel Factor (F _o)		Percent Difference	
Orsat	Fuel			Orsat	Fuel		

Comments: _____

Operator: JH

$$F_{12_o}(\text{Orsat}) = \frac{20.9 - (\%O_2 - 0.5 \%CO)}{\%CO_2 + \%CO}$$

$$F_o(\text{Fuel}) = \frac{0.209 F_{12_o}}{F_1} = \frac{0.651 (1.53 \%C - 3.64 \%H - 0.57 \%S - 0.14 \%N - 0.46 \%O)}{\%C}$$

$$\% \text{ Difference} = \frac{F_o(\text{Orsat}) - F_o(\text{Fuel})}{F_o(\text{Fuel})} \cdot 100$$

METHOD 3 - FIELD DATA SHEET
 INTEGRATED SAMPLES - GAS ANALYSIS

Project: Pine Energy Cleanup
 Sampling Location: Stack
 Source Condition: _____
 Fuel Type: Coal
 Module No: _____ Rate Meter Units: _____ Orsat No. _____

Date: 9/1/99
 Monitor Model No: _____
 Serial No: _____
 Bag Type: _____

Test (Run) No. <u>2</u>			Test (Run) No. <u>2</u>			
SAMPLING			SAMPLING			
Port-Point No.	Clock Time 24hr	Flow Rate	ANALYSIS			
			% By Volume (dry basis)			
			Total	CO ₂	O ₂	CO
1-1	- Punge		18.3	12.0	6.3	
2	1457	1.5	18.3	12.0	6.3	
3	1503	1.5	18.3	12.0	6.3	
4	1508	1.5				
5	1512	1.5				
6	1516	1.5				
7	1522	1.5				
8	1526	1.5				
9	1531	1.5				
10	1537	1.5				
11	-	-				
12	-	-				
			Avg.	12.0	6.3	
			Pre-Run Leak Check:			
			Train: <input checked="" type="checkbox"/>			
			Bag: <input checked="" type="checkbox"/>			
			Pipettes: <input checked="" type="checkbox"/>			
			Burette: <input checked="" type="checkbox"/>			
			Post-Run Leak Check:			
			Train: <input checked="" type="checkbox"/>			
			Bag: <input checked="" type="checkbox"/>			
			Pipettes: <input checked="" type="checkbox"/>			
			Burette: <input checked="" type="checkbox"/>			
VALIDATION			VALIDATION			
Fuel Factor (F _o)		Percent Difference				
Orsat	Fuel					

Comments:

Operator: JM


$$F_{12, (Orsat)} = \frac{20.9 - (\%O_2 - 0.5 \%CO)}{\%CO_2 + \%CO}$$

$$F_o (Fuel) = \frac{0.209 F_{12}}{F_c} = \frac{0.651 (1.53 \%C - 3.64 \%H - 0.57 \%S - 0.14 \%N - 0.46 \%O)}{\%C}$$

$$\% \text{ Difference} = \frac{F_o (Orsat) - F_o (Fuel)}{F_o (Fuel)} \cdot 100$$

57

PITOT TRAVERSE DATA




Project: Duke Energy Corporation - Cliffside

Location: Inlet

Date: Sept 1, 1999 Test No: Null Point Preliminary Time: 738-759
CYCLONIC FLOW
From O CHECK

EAST

Point No.	ΔP	√ΔP	t _s	α	Point No.	ΔP	√ΔP	t _s	α
1-1	0.23		635	-2.5					
2	0.23		639	0					
3	0.25		636	0					
2-1	0.43		654	-5°					
2	0.46		649	0					
3	0.46		636	0					
3-1	0.45		649	-7°					
2	0.44		648	-2.5°					
3	0.45		637	0					
4-1	0.53		637	0					
2	0.50		627	0					
3	0.48		620	-2°					
		7.60428	7667						
		0.63369	638.92	1098.92					



P_{bar} 29.50 "Hg Static -5.44"H₂O P_g -0.4 "Hg P_s 29.1 "Hg Pitot ID → C_p .84 Temp. ID
 0.44 × 14.0 %CO₂ = 6.16 √ΔP, 6337 t_s 639 °F T 1099 °R Flue Area 84.0 ft²
 0.32 × 4.2 %O₂ = +1.344 Duct Dimensions 6' x 14'
 0.28 × 81.8 %N₂ = +22.904 B_{ws} .10 1 - B_{ws} .90 Disturbance: Upstream 3.3 dia 28
 (20.408 Md × .7 1 - B_{ws}) + (18 × .1 B_{ws}) = 29.1692 (Ms) Downstream 0.48 dia

V_{ks} = 81.712 v_s = 85.49 × C_p × √ $\frac{(\frac{P_s}{T_s}) \frac{R}{M} \times \frac{P_s}{T_s}}{29.17 \text{ Ms} \times 29.1 \text{ Ps}}$ × √ΔP = ft/sec (V_s)
 Q_{acfm} = 57.8 V_s × Flue Area × 60 = 260970 acfm Port Length 18 Inches

Q_{dscfm} = 17.647 × ACFM × $\frac{P_s}{T_s \text{ °R}}$ = SCFM
 Q_{dscfm} = 17.647 × ACFM × $\frac{P_s}{T_s \text{ °R}}$ × (1 - B_{ws}) = DSCFM

Pre-test leak check 5.8 "H₂O Data Taken By: JCD / NS
 Post-test leak check "H₂O Field Engineer / Test Technician

PITOT TRAVERSE DATA

Project: Duke Energy Cliffside 1
 Location: Outlet (Stack)
 Date: 9/1/99 Test No: Pr. 11.1.4 Time: 7:05-7

Point No.	ΔP	√ΔP	t _s	NULL	Point No.	ΔP	√ΔP	t _s	NULL
2-1	0.35	0.592	363	3.0	1-1	0.30	0.548	365	0
2	0.35	0.592	365	4.5	2	0.34	0.583	368	0
3	0.34	0.583	364	5.0	3	0.32	0.566	371	0
4	0.37	0.608	364	5.2	4	0.32	0.566	372	6.5
5	0.30	0.548	364	4.0	5	0.28	0.529	373	10.3
6	0.36	0.600	365	7.0	6	0.38	0.566	372	11.2
7	0.35	0.592	367	7.0	7	0.36	0.600	371	13.0
8	0.32	0.566	368	11.0	8	0.45	0.671	371	13.3
9	0.41	0.643	369	10.0	9	0.62	0.787	372	17.0
10	0.37	0.608	369	8.0	10	0.75	0.866	371	13.0
11	0.41	0.640	369	9.0	11	0.80	0.894	370	16.0
12	0.43	0.656	366	10.7	12	0.90	0.894	369	13.0
									198.3
									8.3 Avg
									38.38
									368.3
									328.3

P_{bar} 29.45 Hg Static 0.5 "H₂O P_g _____ "Hg P_s 29.41 "Hg Pitot ID 427A C_p 0.83 Temp. ID _____
 0.44 × 12.1 %CO₂ = _____ √ΔP _____ t_s _____ °F T _____ °R Flue Area _____ ft²
 0.32 × 5.0 %O₂ = + _____ Duct Dimensions 10 x _____
 0.28 × 5.1 %N₂ = + _____ B_{ws} 0.10 1 - B_{ws} 0.90 Disturbance: Upstream _____
 (30.96 Md × 0.90 1 - B_{ws}) + (18 × 0.10 B_{ws}) = _____ (Ms) Downstream _____

$$v_s = 85.49 \times C_p \times \sqrt{\frac{(P_s - P_t) \times 144}{M_s \times P_s}} \times \sqrt{\Delta P} = \text{ft/sec (Vs)}$$

Q_{acfm} = Vs × Flue Area × 60 = _____ acfm Port Length 6 Inches

Q_{dscfm} = 17.647 × ACFM × $\frac{P_s}{T_s \times R}$ = _____ SCFM

Q_{dscfm} = 17.647 × ACFM × $\frac{P_s}{T_s \times R} \times (1 - B_{ws})$ = _____ DSCFM

Pre-test leak check _____ "H₂O
 Post-test leak check _____ "H₂O

Data Taken By: JNY
 Field Engineer / Test Technician

CALIBRATION PROCEDURES

PITOT TUBES

The pitot tubes used during this test program are fabricated according to the specification described and illustrated in the *Code of Federal Regulations*, Title 40, Part 60, Appendix A, Methods 1 through 5 as published in the *Federal Register*, Volume 42, No. 160; hereafter referred to by the appropriate method number. The pitot tubes comply with the alignment specifications in Method 2, Section 4; and the pitot tube assemblies are in compliance with specifications in the same section.

Pitot tube assemblies are calibrated in accordance with Method 2, Section 4, against a standard hemispherical pitot utilizing a wind tunnel meeting the specification in Method 2, Section 4.1.2.

NOZZLES

The nozzles are measured according to Method 5, Section 5.1.

TEMPERATURE SENSING DEVICES

The potentiometer and thermocouples are calibrated against a mercury thermometer in a calibration well. Alternatively, readings are checked utilizing a NBS traceable millivolt source.

DRY GAS METERS

The test meters are calibrated according to Method 5, Section 5.3 and "Procedures for Calibrating and Using Dry Gas Volume Meters as Calibration Standards" by P.R. Westlin and R.T. Shigehara, March 10, 1978.

ANALYTICAL BALANCE

The accuracy of the analytical balance is checked with Class S, Stainless Steel Type 303 weights manufactured by F. Hopken and Son, Jersey City, New Jersey.

Pitot Tube Calibration Data

Calibration Pitot Tube: Type: HEMI STD Size (OD): 1/4" Pitot ID #: 16018

Type "S" Pitot Tube ID Number: 514 (1/4") Cp(std) = 0.99

Calibration Date: 12/4/1997 Performed By: M. McIntyre

P _{std} , (in.) H ₂ O		A-Side Calibration		
Set Value	Read Value	P _s , (in.) H ₂ O	C _{p(S)} ^a	DEV. ^b
0.25	0.27	0.39	0.829	0.001
0.55	0.55	0.79	0.822	0.005
0.85	0.85	1.20	0.831	0.003
1.00	1.05	1.50	0.828	0.001
2.00	2.00	2.85	0.829	0.002
3.00	3.00	4.30	0.827	0.001
Average			0.828	0.002

P _{std} , (in.) H ₂ O		B-Side Calibration		
Set Value	Read Value	P _s , (in.) H ₂ O	C _{p(S)} ^a	DEV. ^b
0.25	0.26	0.37	0.830	0.000
0.55	0.55	0.78	0.830	0.000
0.85	0.85	1.20	0.831	0.001
1.00	1.05	1.50	0.828	0.002
2.00	2.00	2.85	0.829	0.001
3.00	3.00	4.25	0.832	0.002
Average			0.830	0.001

$$\bar{C}_p(A) - \bar{C}_p(B) = 0.002 \quad (\text{must be } \leq 0.01)$$

$$^a C_{p(S)} = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$

$$^b \text{DEV} = C_{p(S)} - \bar{C}_p, \quad (\text{must be } \leq 0.01)$$

Pitot Tube Calibration Data

Calibration Pitot Tube: Type: HEMI STD Size (OD): 1/4" Pitot ID #: 16018

Type "S" Pitot Tube ID Number: 427 (1/4") Cp(std) = 0.99

Calibration Date: 12/4/1997 Performed By: M. McIntyre

P _{std} , (in.) H ₂ O		A-Side Calibration		
Set Value	Read Value	P _s , (in.) H ₂ O	C _{p(S)} ^a	DEV. ^b
0.25	0.27	0.39	0.829	0.001
0.55	0.55	0.78	0.830	0.000
0.85	0.85	1.20	0.831	0.001
1.00	1.05	1.50	0.828	0.002
2.00	2.00	2.85	0.829	0.001
3.00	3.00	4.25	0.832	0.002
Average			0.830	0.001

P _{std} , (in.) H ₂ O		B-Side Calibration		
Set Value	Read Value	P _s , (in.) H ₂ O	C _{p(S)} ^a	DEV. ^b
0.25	0.26	0.37	0.830	0.001
0.55	0.55	0.78	0.830	0.001
0.85	0.85	1.20	0.831	0.001
1.00	1.05	1.50	0.828	0.003
2.00	2.00	2.80	0.837	0.005
3.00	3.00	4.25	0.832	0.000
Average			0.831	0.002

$$\overline{C_p}(A) - \overline{C_p}(B) = 0.001 \quad (\text{must be } \leq 0.01)$$

$${}^a C_{p(S)} = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$


$${}^b \text{DEV} = C_{p(S)} - \overline{C_p}, \quad (\text{must be } \leq 0.01)$$

Nozzle Calibration

Date: 9/1/99

Nozzle ID No.: Set 2

Analyst: JCD



Pre Test **Post Test**

0.235 1 ✓

0.236 2 ✓

0.236 3 ✓

0.235 4 ✓


Average
<u>0.236</u>

Nozzle Calibration

Date: 9/1/99

Nozzle ID No.: Set 3

Analyst: JCD



Pre Test Post Test

0.235 1 ✓

0.235 2 ✓

0.234 3 ✓

0.235 4 ✓



Average
<u>0.235</u>

Nozzle Calibration

Date: 9/1/99

Nozzle ID No.: #10 Set A

Analyst: JCD



Pre Test Post Test

0.308 1 ✓

0.308 2 ✓

0.308 3 ✓

0.308 4 ✓


Average
<u>0.308</u>

Nozzle Calibration

Date: 9/1/99

Nozzle ID No.: #8 Set A

Analyst: JCD



Pre Test

Post Test

0.244

1

✓

0.245

2

✓

0.245

3

✓

0.245

4

✓

Average

0.245

**STACK TEMPERATURE SENSOR CALIBRATION DATA FORM
(FOR K-TYPE THERMOCOUPLES)**

EPA Control Module Number: E35

Name: Sarah Kaufman

Ambient Temperature: 88 °F

Date: 07-27-99

Model 1061; S/N: A20821

Reference Source (T/C Calibrator): Transmation, Inc.

Date of Calibration Verification: 10/18/94

Primary Standards Directly Traceable to
National Institute of Standards and Technology (NIST)

Reference* Source Temperature, (°F)	Test Thermometer Temperature, (°F)	Temperature Difference, %
50	51	0.196
100	100	0.000
150	150	0.000
200	200	0.000
250	250	0.000
300	300	0.000
350	350	0.000
400	400	0.000
450	451	0.110
500	500	0.000
550	551	0.099
600	601	0.094
650	650	0.000
700	700	0.000
800	800	0.000
900	901	0.074
1000	1000	0.000
1100	1101	0.064
1200	1201	0.060

*Every (50°F) for each reference point.

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

**STACK TEMPERATURE SENSOR CALIBRATION DATA FORM
(FOR K-TYPE THERMOCOUPLES)**

EPA Control Module Number: 677191

Name: Sarah Kaufman

Ambient Temperature: 72 °F

Date: 08-09-99

Model 1061; S/N: A20821

Reference Source (T/C Calibrator): Transmation, Inc.

Date of Calibration Verification: 10/18/94

Primary Standards Directly Traceable to
National Institute of Standards and Technology (NIST)


Reference ^a Source Temperature, (°F)	Test Thermometer Temperature, (°F)	Temperature Difference, ^b %
50	51	0.196
100	101	0.179
150	151	0.164
200	200	0.000
250	250	0.000
300	300	0.000
350	350	0.000
400	400	0.000
450	450	0.000
500	500	0.000
550	549	0.099
600	599	0.094
650	649	0.090
700	699	0.086
800	799	0.079
900	898	0.147
1000	998	0.137
1100	1098	0.128
1200	1198	0.120

^aEvery (50°F) for each reference point.

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Gas Meter Calibration Train



10

METER BOX CALIBRATION

Dry Gas Meter No. E35
 Standard Meter No. 3623853
 Standard Meter (Yr) 0.9943

Date: 07-27-99
 Calibrated By: Sarah Kaufman
 Barometric Pressure: 29.29

Formula Protection Password: MPA

Run Number	Orifice Setting in H2O Chg (Hf)	Standard Meter Gas Volume Vr	Dry Meter Gas Volume Vd	Standard Meter Temp. F tr	Dry Gas Meter Inlet Temp. F tdi	Dry Gas Meter Outlet Temp. F tdo	Dry Gas Meter Avg. Temp. F td	Time Min.	Time Sec.	Y	Chg (H@)
Final		34.299	69.181	88	91	92					
Initial		28.936	63.809	88	91	90					
Difference	1	5.363	5.372	88	91	91	91	20	14	1.003	1.678
Final		39.699	74.629	89	92	92					
Initial		34.440	69.339	89	91	92					
Difference	2	5.259	5.290	89	91.5	92	91.75	13	1	0.998	1.810
Final		22.614	57.504	88	91	91					
Initial		16.544	51.396	88	90	89					
Difference	3	6.070	6.108	88	90.5	90	90.25	12	56	0.996	1.876
Final		45.019	79.949	89	93	92					
Initial		39.954	74.882	89	92	92					
Difference	4	5.065	5.067	89	92.5	92	92.25	9	34	1.003	1.895
Final		50.304	85.236	89	93	91					
Initial		45.206	80.155	89	92	92					
Difference	5	5.098	5.081	89	92.5	91.5	92	8	31	1.006	1.978
Final		28.595	63.471	88	92	91					
Initial		22.922	57.793	88	90	91					
Difference	6	5.673	5.678	88	91	91	91	7	27	1.000	2.033

Average 1.001 1.878

VOLUME METERING SYSTEM FIELD AUDIT

Date: 07-27-99

Name: Sarah Kaufman

EPA Control Module No.: E35

Ambient Temperature: 90 °F

Calibration (Y): 1.001

Barometric Pressure: 29.29 "Hg

Delta H: 1.878

#VALUE!

Run No.	Time	Gas Meter Reading/Gas Meter Temperature			Yc (Calculated)
	(Minutes)	(Cubic Feet)	Inlet (°F)	Outlet (°F)	
1	0	8.861	94	93	1.020
	10	16.474	95	92	
	Vm=	7.613	Avg. = 93.50	553.50	
2	0	16.474	94	92	1.018
	10	24.099	95	93	
	Vm=	7.625	Avg. = 93.50	553.50	
3	0	24.099	94	92	1.018
	10	31.724	95	92	
	Vm=	7.625	Avg. = 93.25	553.25	

$$Y_c = \frac{10}{V_m} \sqrt{\frac{P_{bar}}{0.0319 T_m}}$$

Limit: $0.97Y < Y_c < 1.03Y$

Limit: $0.971 < Y_c < 1.031$

Calc. Delta H @ = $\frac{0.0319 (\Delta H)(T_m)(100)}{P_{bar}(Y^2)(V_m^2)}$ (From Calibration Data) = 1.945

METER BOX CALIBRATION

Dry Gas Meter No. E18
 Standard Meter No. 677191
 Standard Meter (Yr) 0.9991

Date: 08-09-99
 Calibrated By: Sarah Kaufman
 Barometric Pressure: 29.33

Formula Protection Password: MPA

Run Number	Orifice Setting in H2O Chg (H)	Standard Meter Gas Volume Vr	Dry Meter Gas Volume Vd	Standard Meter Temp. F tr	Dry Gas Meter Inlet Temp. F tdi	Dry Gas Meter Outlet Temp. F tdo	Dry Gas Meter Avg. Temp. F td	Time Min.	Time Sec.	Chg (H@)
Final		66.251	72.771	72	77	77				
Initial		61.204	67.646	71	76	76				
Difference	1	5.047	5.125	71.5	76.5	76.5	76.5	20	10	0.994
Final		71.415	78.032	73	78	78				1.816
Initial		66.393	72.916	72	77	77				
Difference	2	5.022	5.116	72.5	77.5	77.5	77.5	12	47	0.990
Final		54.506	60.846	71	75	75				1.846
Initial		49.489	55.782	70	74	74				
Difference	3	5.017	5.064	70.5	74.5	74.5	74.5	10	57	0.996
Final		76.832	83.549	73	79	79				1.896
Initial		71.580	78.196	73	78	78				
Difference	4	5.252	5.353	73	78.5	78.5	78.5	10	4	0.989
Final		82.079	88.892	73	79	79				1.884
Initial		76.977	83.691	73	79	79				
Difference	5	5.102	5.201	73	79	79	79	8	37	0.989
Final		61.046	67.469	71	76	76				1.949
Initial		54.714	61.061	71	75	75				
Difference	6	6.332	6.408	71	75.5	75.5	75.5	8	21	0.992

Run Number	Orifice Setting in H2O Chg (H)	Standard Meter Gas Volume Vr	Dry Meter Gas Volume Vd	Standard Meter Temp. F tr	Dry Gas Meter Inlet Temp. F tdi	Dry Gas Meter Outlet Temp. F tdo	Dry Gas Meter Avg. Temp. F td	Time Min.	Time Sec.	Chg (H@)
Final		66.251	72.771	72	77	77				
Initial		61.204	67.646	71	76	76				
Difference	1	5.047	5.125	71.5	76.5	76.5	76.5	20	10	0.994
Final		71.415	78.032	73	78	78				1.816
Initial		66.393	72.916	72	77	77				
Difference	2	5.022	5.116	72.5	77.5	77.5	77.5	12	47	0.990
Final		54.506	60.846	71	75	75				1.846
Initial		49.489	55.782	70	74	74				
Difference	3	5.017	5.064	70.5	74.5	74.5	74.5	10	57	0.996
Final		76.832	83.549	73	79	79				1.896
Initial		71.580	78.196	73	78	78				
Difference	4	5.252	5.353	73	78.5	78.5	78.5	10	4	0.989
Final		82.079	88.892	73	79	79				1.884
Initial		76.977	83.691	73	79	79				
Difference	5	5.102	5.201	73	79	79	79	8	37	0.989
Final		61.046	67.469	71	76	76				1.949
Initial		54.714	61.061	71	75	75				
Difference	6	6.332	6.408	71	75.5	75.5	75.5	8	21	0.992

Average 0.992 1.895

VOLUME METERING SYSTEM FIELD AUDIT

Date: 08-09-99

Name: Sarah Kaufman

EPA Control Module No.: E18

Ambient Temperature: 79 °F

Calibration (Y): 0.992

Barometric Pressure: 29.33 "Hg

Delta H: 1.895

Run No.	Time	Gas Meter Reading/Gas Meter Temperature			Yc (Calculated)
	(Minutes)	(Cubic Feet)	Inlet (°F)	Outlet (°F)	
1	0	89.056	80	80	1.004
	10	96.689	80	80	
	Vm=	7.633	Avg. = 80.00	540.00	
2	0	96.689	80	80	1.012
	10	104.262	81	81	
	Vm=	7.573	Avg. = 80.50	540.50	
3	0	11.052	76	76	0.996
	10	18.725	77	77	
	Vm=	7.673	Avg. = 76.50	536.50	

$$Y_c = \frac{10}{V_m} \sqrt{\frac{P_{bar}}{0.0319 T_m}}$$

Limit: $0.97Y < Y_c < 1.03Y$

Limit: $0.962 < Y_c < 1.022$

Calc. Delta H @ = $\frac{0.0319 (\Delta H)(T_m)(100)}{P_{bar}(Y^2)(V_m^2)}$ (From Calibration Data) = 1.941

Appendix D

ONTARIO HYDRO METHOD TEST SUPPORT DATA

PROJECT NO.:	93504	TEST RUN NO.:	1	TEST DATE:	9/2/99
CUSTOMER:	Duke Energy Corporation	BAROMETRIC PRESSURE (Pb)	29.5	in. Hg.	
PLANT:	Cliffside Steam Station	STATIC PRESSURE	-0.4	in. H2O	
TEST LOC.:	Unit 1 Precipitator Inlet	FLUE PRESSURE (Ps)	29.47	in. Hg. abs.	
CLIENT:	Electric Power Research Institute	PROBE LENGTH:	3.75	ft.	
OPERATOR:	J. Daniels	PROBE LINER MATERIAL:	Glass		
CONTROL BOX:	E-35	NOZZLE IDENTIFICATION NO.:	Glass Set 2		
METER NO.:	E-35	CALIBRATED NOZZLE DIAMETER:	0.236	in.	
METER CALIBRATION FACTOR:	1.001	LEAK CHECK	PRE:	0.002	POST: 0.002 @ 11 in. Hg.
PITOT ID NO.:	514A	DUCT SHAPE:	Circular	DIA.	Feet
PITOT TUBE COEFFICIENT:	0.828	DUCT AREA:	Rectangular		6 Feet 84 sq. ft.
PORT LENGTH:	18	TEST LENGTH:	120	min.	
PORT SIZE:	4	MINUTES PER POINT:	10		
PORT TYPE:	Nipple W/Cap	TOTAL NUMBER OF TRAVERSE POINTS:	12		

ONTARIO HYDRO METHOD TRAVERSE DATA

Company: Duke Energy Corporation

Date: 9/2/99

Test Ru 1

Location: Unit 1 Precipitator Inlet

Point	Δp	Sq. Root Δp	Time	Volume cubic feet	ΔH	Stack Temp °F	Meter Inlet °F	Meter Outlet °F	Vacuum in. Hg	
1-1	0.19	0.436	10:35	779.82	0.25	632	69	72	3	1.680
1-1	0.19	0.436	10:40	781.50	0.25	649	70	72	3	1.190
1-2	0.19	0.436	10:45	782.69	0.25	651	74	71	3	1.595
1-2	0.19	0.436	10:50	784.29	0.25	649	74	72	3	1.360
1-3	0.19	0.436	10:55	785.65	0.25	647	72	73	3	1.365
1-3	0.21	0.458	11:00	787.01	0.28	651	73	74	3	1.575
			11:05	788.59						0.000
2-1	0.38	0.616	11:07	788.64	0.50	648	74	74	4	2.040
2-1	0.37	0.608	11:12	790.68	0.49	655	75	74	4	1.720
2-2	0.39	0.624	11:17	792.40	0.52	654	76	74	4	1.920
2-2	0.40	0.632	11:22	794.32	0.53	657	77	75	4	2.070
2-3	0.42	0.648	11:27	796.39	0.56	653	77	75	4	1.990
2-3	0.42	0.648	11:32	798.38	0.56	650	78	76	4	2.370
			11:37	800.75						0.000
3-1	0.43	0.656	11:41	800.87	0.57	648	76	76	4	2.100
3-1	0.42	0.648	11:46	802.97	0.56	656	77	76	4	1.950
3-2	0.45	0.671	11:51	804.92	0.60	656	78	76	4	2.330
3-2	0.45	0.671	11:56	807.25	0.60	653	78	76	5	1.950
3-3	0.48	0.693	12:01	809.20	0.64	655	78	76	5	2.120
3-3	0.49	0.700	12:06	811.32	0.65	656	79	76	5	2.140
			12:11	813.46						0.000
4-1	0.60	0.775	12:13	813.53	0.80	652	80	76	5	2.130
4-1	0.61	0.781	12:18	815.66	0.81	653	80	77	7	2.480
4-2	0.63	0.794	12:23	818.14	0.84	651	80	76	8	2.510
4-2	0.64	0.800	12:28	820.65	0.85	655	81	77	8	2.300
4-3	0.55	0.742	12:33	822.95	0.73	647	81	78	7	2.030
4-3	0.52	0.721	12:38	824.98	0.69	647	81	76	7	2.820
			12:43	827.80						0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
		0.628		47.735	0.54	651	77	75		#####
							75.75			

MOISTURE, DILUENT AND MERCURY DATA

Company Duke Energy Corporation

Date: 9/2/99

Test Run: 1

Location: Unit 1 Precipitator Inlet

SILICA GEL FINAL WT.: 801.40 grams
 SILICA GEL INITIAL WT.: 789.50 grams
 DIFFERENCE: 11.90

FINAL IMPINGER WATER: 4818.70 mls.
 INITIAL IMPINGER WATER: 4736.40 mls.
 DIFFERENCE: 82.30

TOTAL WATER GAIN: 94.20

ITEM	MERCURY (UG)	=	NET WT. (G)
FILTER:	0.207		0.00000207
PROBE WASH:	0.000		0.00000000
	Particle-bound Total:		0.00000207
KCl:	4.538		0.00004538
	Oxidized Total:		0.00004538
HNO ₃ /H ₂ O ₂ :	0.338		0.00000338
KMNO ₄ :	3.703		0.00003703
	Elemental Total:		0.00004041

Orsat Analysis	1	2	3	Average
Carbon Dioxide:	14.00	14.00	14.00	14.00
Oxygen:	4.40	4.20	4.20	4.27

ONTARIO HYDRO METHOD DATA ENTRY FORM

Field Data/Calculated Data

Company: Duke Energy Corporation

Date: 9/2/99

Test Run: 1

Stack or Duct No.: Unit 1 Precipitator Inlet

Start Time: 10:35

Stop Time: 12:43

Pb:	29.50	Inches Hg
Static	-0.40	Inches H2O
Ps:	29.47	Inches Hg Abs.
Vlc:	94	ml + grams
Mn:	0.0000	gm
Test Time:	120	minutes
% O2:	4.27	%
% CO2:	14.00	%
% N2:	81.73	%
Delta H:	0.54	Inches H2O
Cp:	0.828	Dimensionless - pitot
Tm:	75.75	°F
Sqrt P:	0.628	Inches H2O
Ts:	651.04	°F
Vm:	47.735	Cubic Feet
Dn:	0.236	Inches - nozzle
As:	84.00	Sq. Feet
Yd:	1.001	Mcf
CF:	N/A	Process tons/hr
Heat Input:	N/A	MM BTU/hr
Fd:	N/A	dscf/10 ⁶ Btu
Fc:	N/A	scf/10 ⁶ Btu

Vmstd:	46.493	cubic feet (dry)
Vwstd:	4.437	cubic feet (wet)
Bwo:	0.087	
Md:	30.411	lb/lb-mole (dry)
Ms:	29.329	lb/lb-mole (wet)
Excess Air (%)	24.647	
Vs:	50.379	fps
ACFM:	253909.	
DSCFM:	108498.	
WSCFM:	118852	
%I:	98.8	isokinetic variance
GR/ACF:	---	
GR/DSCF:	---	
lbs/hr	---	
lbs/ton prod.:	N/A	
lbs/MM BTU:	N/A	Heat Input
lbs/MM BTU:	N/A	O2 Basis
lbs/MM BTU:	N/A	CO2 Basis

ONTARIO HYDRO METHOD TEST SUPPORT DATA

PROJECT NO.: 93504	TEST RUN NO.: 2	TEST DATE: 9/1/99	
CUSTOMER: Duke Energy Corporation	BAROMETRIC PRESSURE (Pb) 29.5 in. Hg.		
PLANT: Cliffside Steam Station	STATIC PRESSURE -0.4 in. H ₂ O		
TEST LOC.: Unit 1 Precipitator Inlet	FLUE PRESSURE (Ps) 29.47 in. Hg. abs.		
CLIENT: Electric Power Research Institute	PROBE LENGTH: 3.75 ft.		
OPERATOR: J. Daniels	PROBE LINER MATERIAL: Glass		
CONTROL BOX: E-35	NOZZLE IDENTIFICATION NO.: Glass Set 3		
METER NO.: E-35	CALIBRATED NOZZLE DIAMETER: 0.235 in.		
METER CALIBRATION FACTOR: 1.001	LEAK CHECK PRE: 0.008 POST: 0.002 @ 8 in. Hg.		
PITOT ID NO.: 514A	DUCT SHAPE: Circular DIA. 6 Feet		14 Feet
PITOT TUBE COEFFICIENT: 0.828	DUCT AREA: Rectangular 84 sq. ft.		
PORT LENGTH: 18 in.	TEST LENGTH: 120 min.		
PORT SIZE: 4 in.	MINUTES PER POINT: 10		
PORT TYPE: Nipple W/Cap	TOTAL NUMBER OF TRAVERSE POINTS: 12		

ONTARIO HYDRO METHOD TRAVERSE DATA

Company: Duke Energy Corporation

Date: 9/1/99

Test Ru 2

Location: Unit 1 Precipitator Inlet

Point	Δp	Sq. Root Δp	Time	Volume cubic feet	ΔH	Stack Temp °F	Meter Inlet °F	Meter Outlet °F	Vacuum in. Hg	
1-1	0.19	0.436	14:50	828.81	0.25	642	83	82	3	1.310
1-1	0.18	0.424	14:55	830.12	0.24	645	85	84	3	1.360
1-2	0.21	0.458	15:00	831.48	0.28	642	84	84	3	1.690
1-2	0.19	0.436	15:05	833.17	0.25	644	84	84	3	1.330
1-3	0.18	0.424	15:10	834.50	0.24	644	84	84	3	1.480
1-3	0.20	0.447	15:15	835.98	0.27	647	85	84	3	1.500
			15:20	837.48						0.000
2-1	0.37	0.608	15:30	837.66	0.50	644	86	85	3	1.920
2-1	0.40	0.632	15:35	839.58	0.54	652	86	84	3	2.170
2-2	0.40	0.632	15:40	841.75	0.54	654	86	86	3	2.020
2-2	0.39	0.624	15:45	843.77	0.52	652	87	87	3	1.810
2-3	0.38	0.616	15:50	845.58	0.51	652	88	86	3	2.230
2-3	0.40	0.632	15:55	847.81	0.54	653	88	84	4	2.070
			16:00	849.88						0.000
3-1	0.43	0.656	16:07	850.03	0.58	651	88	86	4	2.230
3-1	0.42	0.648	16:12	852.26	0.56	651	89	87	4	2.070
3-2	0.45	0.671	16:17	854.33	0.60	654	89	88	4	2.010
3-2	0.45	0.671	16:22	856.34	0.60	655	89	88	5	2.030
3-3	0.44	0.663	16:27	858.37	0.59	653	89	88	5	2.220
3-3	0.45	0.671	16:32	860.59	0.60	652	90	88	5	2.190
			16:37	862.78						0.000
4-1	0.52	0.721	16:43	862.91	0.70	646	92	88	5	2.200
4-1	0.53	0.728	16:48	865.11	0.70	649	91	88	5	2.360
4-2	0.51	0.714	16:53	867.47	0.68	647	91	88	5	2.410
4-2	0.51	0.714	16:58	869.88	0.68	648	91	88	5	1.940
4-3	0.55	0.742	17:03	871.82	0.74	646	91	88	6	2.790
4-3	0.53	0.728	17:08	874.61	0.71	646	92	88	6	1.990
			17:13	876.60						0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
		0.612		47.330	0.52	649	88	86		#####
							86.98			

MOISTURE, DILUENT AND MERCURY DATA

Company Duke Energy Corporation

Date: 9/1/99

Test Run: 2

Location: Unit 1 Precipitator Inlet

SILICA GEL FINAL WT.: 716.70 grams
 SILICA GEL INITIAL WT.: 702.60 grams
 DIFFERENCE: 14.10

FINAL IMPINGER WATER: 4663.10 mls.
 INITIAL IMPINGER WATER: 4586.90 mls.
 DIFFERENCE: 76.20

TOTAL WATER GAIN: 90.30

ITEM	MERCURY (UG)	=	NET WT. (G)
FILTER:	0.105		0.000000105
PROBE WASH:	0.000		0.000000000
		Particle-bound Total:	0.000000105
KCl:	4.198		0.000004198
		Oxidized Total:	0.000004198
HNO ₃ /H ₂ O ₂ :	0.246		0.000000246
KMNO ₄ :	3.703		0.000003703
		Elemental Total:	0.000003949

Orsat Analysis	1	2	3	Average
Carbon Dioxide:	13.80	13.80	13.60	13.73
Oxygen:	4.20	4.20	4.40	4.27

ONTARIO HYDRO METHOD DATA ENTRY FORM

Field Data/Calculated Data

Company: Duke Energy Corporation

Date: 9/1/99

Test Run: 2

Stack or Duct No.: Unit 1 Precipitator Inlet

Start Time: 14:50

Stop Time: 17:13

Pb:	29.50	Inches Hg
Static	-0.40	Inches H2O
Ps:	29.47	Inches Hg Abs.
Vlc:	90	ml + grams
Mn:	0.0000	gm
Test Time:	120	minutes
% O2:	4.27	%
% CO2:	13.73	%
% N2:	82.00	%
Delta H:	0.52	Inches H2O
Cp:	0.828	Dimensionless - pitot
Tm:	86.98	°F
Sqrt P:	0.612	Inches H2O
Ts:	648.71	°F
Vm:	47.330	Cubic Feet
Dn:	0.235	Inches - nozzle
As:	84.00	Sq. Feet
Yd:	1.001	Mcf
CF:	N/A	Process tons/hr
Heat Input:	N/A	MM BTU/hr
Fd:	N/A	dscf/10 ⁶ Btu
Fc:	N/A	scf/10 ⁶ Btu

Vmstd:	45.149	cubic feet (dry)
Vwstd:	4.253	cubic feet (wet)
Bwo:	0.086	
Md:	30.368	lb/lb-mole (dry)
Ms:	29.303	lb/lb-mole (wet)
Excess Air (%)	24.547	
Vs:	49.122	fps
ACFM:	247577.	
DSCFM:	106134.	
WSCFM:	116132	
%I:	98.9	isokinetic variance
GR/ACF:	---	
GR/DSCF:	---	
lbs/hr	---	
lbs/ton prod.:	N/A	
lbs/MM BTU:	N/A	Heat Input
lbs/MM BTU:	N/A	O2 Basis
lbs/MM BTU:	N/A	CO2 Basis

ONTARIO HYDRO METHOD TEST SUPPORT DATA

PROJECT NO.:	93504	TEST RUN NO.:	3	TEST DATE:	9/1/99
CUSTOMER:	Duke Energy Corporation	BAROMETRIC PRESSURE (Pb)	29.25	in. Hg.	
PLANT:	Cliffside Steam Station	STATIC PRESSURE	-4	in. H2O	
TEST LOC.:	Unit 1 Precipitator Inlet	FLUE PRESSURE (Ps)	28.96	in. Hg. abs.	
CLIENT:	Electric Power Research Institute	PROBE LENGTH:	3.75	ft.	
OPERATOR:	J. Daniels	PROBE LINER MATERIAL:	Glass		
CONTROL BOX:	E-35	NOZZLE IDENTIFICATION NO.:	Glass Set #2		
METER NO.:	E-35	CALIBRATED NOZZLE DIAMETER:	0.236	in.	
METER CALIBRATION FACTOR:	1.001	LEAK CHECK	PRE:	0.004	POST: 0.002 @ 8 in. Hg.
PITOT ID NO.:	514A	DUCT SHAPE:	Circular	DIA.	6 Feet
PITOT TUBE COEFFICIENT:	0.828	DUCT AREA:	Rectangular		14 Feet
PORT LENGTH:	18	TEST LENGTH:	120	min.	
PORT SIZE:	4	MINUTES PER POINT:	10		
PORT TYPE:	Nipple W/Cap	TOTAL NUMBER OF TRAVERSE POINTS:	12		

ONTARIO HYDRO METHOD TRAVERSE DATA

Company: Duke Energy Corporation

Date: 9/1/99

Test Ru 3

Location: Unit 1 Precipitator Inlet

Point	Δp	Sq. Root Δp	Time	Volume cubic feet	ΔH	Stack Temp °F	Meter Inlet °F	Meter Outlet °F	Vacuum in. Hg	
1-1	0.17	0.412	8:15	876.92	0.23	641	63	63	3	1.320
1-1	0.18	0.424	8:20	878.24	0.24	641	64	63	3	1.320
1-2	0.19	0.436	8:25	879.56	0.25	640	65	64	3	1.430
1-2	0.19	0.436	8:30	880.99	0.25	641	65	64	3	1.050
1-3	0.19	0.436	8:35	882.04	0.25	645	67	67	4	1.170
1-3	0.19	0.436	8:40	883.21	0.27	647	67	67	4	1.670
			8:45	884.88						0.000
2-1	0.39	0.624	8:51	885.06	0.52	650	70	67	5	1.770
2-1	0.40	0.632	8:56	886.83	0.53	650	70	67	5	2.060
2-2	0.41	0.640	9:01	888.89	0.55	650	70	67	5	2.090
2-2	0.43	0.656	9:06	890.98	0.57	648	71	68	5	2.170
2-3	0.43	0.656	9:11	893.15	0.57	649	72	68	5	2.070
2-3	0.43	0.656	9:16	895.22	0.57	650	73	69	5	1.990
			9:21	897.21						0.000
3-1	0.42	0.648	9:26	897.42	0.56	641	73	70	5	2.140
3-1	0.43	0.656	9:31	899.56	0.57	645	73	70	5	2.110
3-2	0.43	0.656	9:36	901.67	0.57	646	74	71	5	2.080
3-2	0.43	0.656	9:41	903.75	0.57	643	74	72	5	1.968
3-3	0.46	0.678	9:46	905.72	0.61	647	74	72	5	2.162
3-3	0.48	0.693	9:51	907.88	0.64	650	76	73	5	2.260
			9:56	910.14						0.000
4-1	0.53	0.728	10:01	910.30	0.71	643	76	73	6	2.250
4-1	0.53	0.728	10:06	912.55	0.71	642	77	75	6	2.200
4-2	0.54	0.735	10:11	914.75	0.73	642	78	75	6	2.560
4-2	0.55	0.742	10:16	917.31	0.73	646	78	75	7	2.600
4-3	0.56	0.748	10:21	919.91	0.74	648	79	76	7	1.730
4-3	0.54	0.735	10:26	921.64	0.72	647	80	76	7	2.350
			10:31	923.99						0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
										0.000
		0.619		46.520	0.53	646	72	70		#####
							70.85			

MOISTURE, DILUENT AND MERCURY DATA

Company Duke Energy Corporation

Date: 9/1/99

Test Run: 3

Location: Unit 1 Precipitator Inlet

SILICA GEL FINAL WT.: 804.50 grams
 SILICA GEL INITIAL WT.: 792.90 grams
 DIFFERENCE: 11.60

FINAL IMPINGER WATER: 4917.10 mls.
 INITIAL IMPINGER WATER: 4833.40 mls.
 DIFFERENCE: 83.70

TOTAL WATER GAIN: 95.30

ITEM	MERCURY (UG)	=	NET WT. (G)
FILTER: 14	0.085		0.000000085
PROBE WASH:	0.000		0.000000000
		Particle-bound Total:	0.000000085
KCl:	4.918		0.000004918
		Oxidized Total:	0.000004918
HNO ₃ /H ₂ O ₂ :	0.305		0.000000305
KMNO ₄ :	8.303		0.000008303
		Elemental Total:	0.000008608

Orsat Analysis	1	2	3	Average
Carbon Dioxide:	13.60			13.60
Oxygen:	4.40			4.40

ONTARIO HYDRO METHOD DATA ENTRY FORM

Field Data/Calculated Data

Company: Duke Energy Corporation

Date: 9/1/99

Test Run: 3

Stack or Duct No.: Unit 1 Precipitator Inlet

Start Time: 8:15

Stop Time: 10:31

Pb:	29.25	Inches Hg
Static	-4.00	Inches H2O
Ps:	28.96	Inches Hg Abs.
Vlc:	95	ml + grams
Mn:	0.0000	gm
Test Time:	120	minutes
% O2:	4.40	%
% CO2:	13.60	%
% N2:	82.00	%
Delta H:	0.53	Inches H2O
Cp:	0.828	Dimensionless - pitot
Tm:	70.85	°F
Sqrt P:	0.619	Inches H2O
Ts:	645.50	°F
Vm:	46.520	Cubic Feet
Dn:	0.236	Inches - nozzle
As:	84.00	Sq. Feet
Yd:	1.001	Mcf
CF:	N/A	Process tons/hr
Heat Input:	N/A	MM BTU/hr
Fd:	N/A	dscf/10 ⁶ Btu
Fc:	N/A	scf/10 ⁶ Btu

Vmstd:	45.339	cubic feet (dry)
Vwstd:	4.489	cubic feet (wet)
Bwo:	0.090	
Md:	30.352	lb/lb-mole (dry)
Ms:	29.239	lb/lb-mole (wet)
Excess Air (%)	25.510	
Vs:	50.037	fps
ACFM:	252186.	
DSCFM:	106065.	
WSCFM:	116566	
%I:	98.6	isokinetic variance
GR/ACF:	---	
GR/DSCF:	---	
lbs/hr	---	
lbs/ton prod.:	N/A	
lbs/MM BTU:	N/A	Heat Input
lbs/MM BTU:	N/A	O2 Basis
lbs/MM BTU:	N/A	CO2 Basis

ONTARIO HYDRO METHOD TEST SUPPORT DATA

PROJECT NO.:	93504	TEST RUN NO.:	1	TEST DATE:	9/1/99
CUSTOMER:	Duke Energy Corporation				
PLANT:	Cliffside Steam Station				
TEST LOC.:	Stack	STATIC PRESSURE	-0.5	in. H2O	
CLIENT:	Electric Power Research Institute	FLUE PRESSURE (Ps)	29.41	in. Hg. abs.	
OPERATOR:	J. Platt	PROBE LENGTH:	10.5	ft.	
CONTROL BOX:	E-18	PROBE LINER MATERIAL:	Glass		
METER NO.:	E-18	NOZZLE IDENTIFICATION NO.:	#10 (Set A)		
METER CALIBRATION FACTOR:	0.992	CALIBRATED NOZZLE DIAMETER:	0.308	in.	
PITOT ID NO.:	427A	LEAK CHECK	PRE: 0.000	POST: 0.000 @ 17 in. Hg.	
PITOT TUBE COEFFICIENT:	0.830	DUCT SHAPE:	Circular	10.5	Feet
PORT LENGTH:	6	DUCT AREA:	Rectangular	86.590074	sq. ft.
PORT SIZE:	4	TEST LENGTH:	120	min.	
PORT TYPE:	Flange	MINUTES PER POINT:	5		
		TOTAL NUMBER OF TRAVERSE POINTS:	24		

MOISTURE, DILUENT AND MERCURY DATA

Company Duke Energy Corporation

Date: 9/1/99

Test Run: 1

Location: Stack

SILICA GEL FINAL WT.: 771.00 grams
 SILICA GEL INITIAL WT.: 750.80 grams
 DIFFERENCE: 20.20

FINAL IMPINGER WATER: 149.00 mls.
 INITIAL IMPINGER WATER: 0.00 mls.
 DIFFERENCE: 149.00

TOTAL WATER GAIN: 169.20

ITEM	MERCURY (UG)	=	NET WT. (G)
FILTER:	0.849		0.000000849
PROBE WASH:	0.000		0.000000000
		Particle-bound Total:	0.000000849
KCl:	5.828		0.000005828
		Oxidized Total:	0.000005828
HNO ₃ /H ₂ O ₂ :	0.682		0.000000682
KMNO ₄ :	7.563		0.000007563
		Elemental Total:	0.000008245

Orsat Analysis	1	2	3	Average
Carbon Dioxide:	12.20	12.20	12.20	12.20
Oxygen:	6.40	6.40	6.40	6.40

ONTARIO HYDRO METHOD DATA ENTRY FORM

Field Data/Calculated Data

Company: Duke Energy Corporation

Date: 9/1/99

Test Run: 1

Stack or Duct No.: Stack

Start Time: 10:35

Stop Time: 12:44

Pb:	29.45	Inches Hg
Static	-0.50	Inches H2O
Ps:	29.41	Inches Hg Abs.
Vlc:	169	ml + grams
Mn:	0.0000	gm
Test Time:	120	minutes
% O2:	6.40	%
% CO2:	12.20	%
% N2:	81.40	%
Delta H:	2.13	Inches H2O
Cp:	0.830	Dimensionless - pitot
Tm:	87.31	°F
Sqrt P:	0.628	Inches H2O
Ts:	383.13	°F
Vm:	96.090	Cubic Feet
Dn:	0.308	Inches - nozzle
As:	86.59	Sq. Feet
Yd:	0.992	Mcf
CF:	N/A	Process tons/hr
Heat Input:	N/A	MM BTU/hr
Fd:	N/A	dscf/10 ⁶ Btu
Fc:	N/A	scf/10 ⁶ Btu

Vmstd:	90.994	cubic feet (dry)
Vwstd:	7.969	cubic feet (wet)
Bwo:	0.081	
Md:	30.208	lb/lb-mole (dry)
Ms:	29.225	lb/lb-mole (wet)
Excess Air (%)	42.413	
Vs:	44.122	fps
ACFM:	229229.	
DSCFM:	129757.	
WSCFM:	141121	
%I:	97.9	isokinetic variance
GR/ACF:	---	
GR/DSCF:	---	
lbs/hr	---	
lbs/ton prod.:	N/A	
lbs/MM BTU:	N/A	Heat Input
lbs/MM BTU:	N/A	O2 Basis
lbs/MM BTU:	N/A	CO2 Basis

ONTARIO HYDRO METHOD TEST SUPPORT DATA

PROJECT NO.:	93504	TEST RUN NO.:	2	TEST DATE:	9/1/99
CUSTOMER:	Duke Energy Corporation	BAROMETRIC PRESSURE (Pb)	29.45	in. Hg.	
PLANT:	Cliffside Steam Station	STATIC PRESSURE	-0.5	in. H2O	
TEST LOC.:	Stack	FLUE PRESSURE (Ps)	29.41	in. Hg. abs.	
CLIENT:	Electric Power Research Institute	PROBE LENGTH:	10.5	ft.	
OPERATOR:	J. Platt	PROBE LINER MATERIAL:	Glass		
CONTROL BOX:	E-18	NOZZLE IDENTIFICATION NO.:	#8 (Set A)		
METER NO.:	E-18	CALIBRATED NOZZLE DIAMETER:	0.245	in.	
METER CALIBRATION FACTOR:	0.992	LEAK CHECK	PRE: 0.000	POST: 0.000	@ 15 in. Hg.
PITOT ID NO.:	427A	DUCT SHAPE:	Circular	DIA. 10.5	Feet
PITOT TUBE COEFFICIENT:	0.830	DUCT AREA:	Rectangular	86.590074	sq. ft.
PORT LENGTH:	6	TEST LENGTH:	120	min.	
PORT SIZE:	4	MINUTES PER POINT:	5		
PORT TYPE:	Flange	TOTAL NUMBER OF TRAVERSE POINTS:	24		

MOISTURE, DILUENT AND MERCURY DATA

Company Duke Energy Corporation

Date: 9/1/99

Test Run: 2

Location: Stack

SILICA GEL FINAL WT.: 733.50 grams
 SILICA GEL INITIAL WT.: 718.20 grams
 DIFFERENCE: 15.30

FINAL IMPINGER WATER: 102.00 mls.
 INITIAL IMPINGER WATER: 0.00 mls.
 DIFFERENCE: 102.00

TOTAL WATER GAIN: 117.30

ITEM	MERCURY (UG)	=	NET WT. (G)
FILTER:	0.139		0.000000139
PROBE WASH:	0.000		0.000000000
		Particle-bound Total:	0.000000139
KCl:	3.128		0.000003128
		Oxidized Total:	0.000003128
HNO ₃ /H ₂ O ₂ :	0.612		0.000000612
KMNO ₄ :	2.083		0.000002083
		Elemental Total:	0.000002695

Orsat Analysis	1	2	3	Average
Carbon Dioxide:	12.00	12.00	12.00	12.00
Oxygen:	6.30	6.30	6.30	6.30

ONTARIO HYDRO METHOD DATA ENTRY FORM

Field Data/Calculated Data

Company: Duke Energy Corporation

Date: 9/1/99

Test Run: 2

Stack or Duct No.: Stack

Start Time: 14:50

Stop Time: 16:55

Pb:	29.45	Inches Hg
Static	-0.50	Inches H2O
Ps:	29.41	Inches Hg Abs.
Vlc:	117	ml + grams
Mn:	0.0000	gm
Test Time:	120	minutes
% O2:	6.30	%
% CO2:	12.00	%
% N2:	81.70	%
Delta H:	0.91	Inches H2O
Cp:	0.830	Dimensionless - pitot
Tm:	98.42	°F
Sqrt P:	0.635	Inches H2O
Ts:	385.92	°F
Vm:	64.620	Cubic Feet
Dn:	0.245	Inches - nozzle
As:	86.59	Sq. Feet
Yd:	0.992	Mcf
CF:	N/A	Process tons/hr
Heat Input:	N/A	MM BTU/hr
Fd:	N/A	dscf/10 ⁶ Btu
Fc:	N/A	scf/10 ⁶ Btu

Vmstd:	59.795	cubic feet (dry)
Vwstd:	5.525	cubic feet (wet)
Bwo:	0.085	
Md:	30.172	lb/lb-mole (dry)
Ms:	29.142	lb/lb-mole (wet)
Excess Air (%)	41.261	
Vs:	44.743	fps
ACFM:	232458.	
DSCFM:	130572.	
WSCFM:	142636	
%I:	101.0	isokinetic variance
GR/ACF:	---	
GR/DSCF:	---	
lbs/hr	---	
lbs/ton prod.:	N/A	
lbs/MM BTU:	N/A	Heat Input
lbs/MM BTU:	N/A	O2 Basis
lbs/MM BTU:	N/A	CO2 Basis

ONTARIO HYDRO METHOD TEST SUPPORT DATA

PROJECT NO.:	93504	TEST RUN NO.:	3	TEST DATE:	9/2/99
CUSTOMER:	Duke Energy Corporation	BAROMETRIC PRESSURE (Pb)	29.25	in. Hg.	
PLANT:	Cliffside Steam Station	STATIC PRESSURE	-0.5	in. H2O	
TEST LOC.:	Stack	FLUE PRESSURE (Ps)	29.21	in. Hg. abs.	
CLIENT:	Electric Power Research Institute	PROBE LENGTH:	10.5	ft.	
OPERATOR:	J. Platt	PROBE LINER MATERIAL:	Glass		
CONTROL BOX:	E-18	NOZZLE IDENTIFICATION NO.:	#8 (Set A)		
METER NO.:	E-18	CALIBRATED NOZZLE DIAMETER:	0.245	in.	
METER CALIBRATION FACTOR:	0.992	LEAK CHECK	PRE:	0.000	POST: 0.000 @ 18 in. Hg.
PITOT ID NO.:	427A	DUCT SHAPE:	Circular	DIA.	10.5 Feet
PITOT TUBE COEFFICIENT:	0.830	DUCT AREA:	Rectangular		86.590074 sq. ft.
PORT LENGTH:	6	TEST LENGTH:	120	min.	
PORT SIZE:	4	MINUTES PER POINT:	5		
PORT TYPE:	Flange	TOTAL NUMBER OF TRAVERSE POINTS:	24		

MOISTURE, DILUENT AND MERCURY DATA

Company Duke Energy Corporation

Date: 9/2/99

Test Run: 3

Location: Stack

SILICA GEL FINAL WT.: 756.40 grams
 SILICA GEL INITIAL WT.: 745.70 grams
 DIFFERENCE: 10.70

FINAL IMPINGER WATER: 93.10 mls.
 INITIAL IMPINGER WATER: 0.00 mls.
 DIFFERENCE: 93.10

TOTAL WATER GAIN: 103.80

ITEM	MERCURY (UG)	=	NET WT. (G)
FILTER:	0.124		0.000000124
PROBE WASH:	0.000		0.000000000
		Particle-bound Total:	0.000000124
KCl:	5.278		0.000005278
		Oxidized Total:	0.000005278
HNO ₃ /H ₂ O ₂ :	0.508		0.000000508
KMNO ₄ :	2.863		0.000002863
		Elemental Total:	0.000003371

Orsat Analysis	1	2	3	<u>Average</u>
Carbon Dioxide:	12.20	12.20	12.20	12.20
Oxygen:	6.10	6.10	6.10	6.10

ONTARIO HYDRO METHOD DATA ENTRY FORM

Field Data/Calculated Data

Company: Duke Energy Corporation

Date: 9/2/99

Test Run: 3

Stack or Duct No.: Stack

Start Time: 8:15

Stop Time: 10:19

Pb:	29.25	Inches Hg
Static	-0.50	Inches H2O
Ps:	29.21	Inches Hg Abs.
Vlc:	104	ml + grams
Mn:	0.0000	gm
Test Time:	120	minutes
% O2:	6.10	%
% CO2:	12.20	%
% N2:	81.70	%
Delta H:	0.81	Inches H2O
Cp:	0.830	Dimensionless - pitot
Tm:	72.85	°F
Sqrt P:	0.610	Inches H2O
Ts:	377.04	°F
Vm:	58.750	Cubic Feet
Dn:	0.245	Inches - nozzle
As:	86.59	Sq. Feet
Yd:	0.992	Mcf
CF:	N/A	Process tons/hr
Heat Input:	N/A	MM BTU/hr
Fd:	N/A	dscf/10 ⁶ Btu
Fc:	N/A	scf/10 ⁶ Btu

Vmstd:	56.570	cubic feet (dry)
Vwstd:	4.889	cubic feet (wet)
Bwo:	0.080	
Md:	30.196	lb/lb-mole (dry)
Ms:	29.226	lb/lb-mole (wet)
Excess Air (%)	39.434	
Vs:	42.883	fps
ACFM:	222792.	
DSCFM:	126300.	
WSCFM:	137216	
%I:	98.8	isokinetic variance
GR/ACF:	---	
GR/DSCF:	---	
lbs/hr	---	
lbs/ton prod.:	N/A	
lbs/MM BTU:	N/A	Heat Input
lbs/MM BTU:	N/A	O2 Basis
lbs/MM BTU:	N/A	CO2 Basis

Project Summary-Samples Received Report

<i>Project</i>	<i>Client</i>	<i>Unit</i>
93504	DUKE ENERGY CORP.	CLIFFSIDE STEAMSTATION,NC

<i>Project</i>	<i>Sample</i>	<i>Sample Point</i>	<i>Date Received</i>	<i>Analyte Detail</i>
93504	001	INL HNO3 RNS T1	9/2/1999	Mercury
93504	002	INL HNO3 RNS T2	9/2/1999	Mercury
93504	003	INL HNO3 RNS T3	9/2/1999	Mercury
93504	004	INL KCL IMP T1	9/2/1999	Mercury
93504	005	INL KCL IMP T2	9/2/1999	Mercury
93504	006	INL KCL IMP T3	9/2/1999	Mercury
93504	007	IN HNO3/H2O2 T1	9/2/1999	Mercury
93504	008	IN HNO3/H2O2 T2	9/2/1999	Mercury
93504	009	IN HNO3/H2O2 T3	9/2/1999	Mercury
93504	010	INL KMNO4 IM T1	9/2/1999	Mercury
93504	011	INL KMNO4 IM T2	9/2/1999	Mercury
93504	012	INL KMNO4 IM T3	9/2/1999	Mercury
93504	013	OUT HNO3 RNS T1	9/2/1999	Mercury
93504	014	OUT HNO3 RNS T2	9/2/1999	Mercury
93504	015	OUT HNO3 RNS T3	9/2/1999	Mercury
93504	016	OUT KCL IMP T1	9/2/1999	Mercury
93504	017	OUT KCL IMP T2	9/2/1999	Mercury
93504	018	OUT KCL IMP T3	9/2/1999	Mercury
93504	019	OUT HNO3/H2O2-1	9/2/1999	Mercury
93504	020	OUT HNO3/H2O2-2	9/2/1999	Mercury
93504	021	OUT HNO3/H2O2-3	9/2/1999	Mercury
93504	022	OUT KMNO4 IM T1	9/2/1999	Mercury
93504	023	OUT KMNO4 IM T2	9/2/1999	Mercury
93504	024	OUT KMNO4 IM T3	9/2/1999	Mercury
93504	025	FLD BL INL KCL	9/2/1999	Mercury
93504	026	F/B INHNO3/H2O2	9/2/1999	Mercury

Friday, January 14, 2000

<i>Project</i>	<i>Sample</i>	<i>Sample Point</i>	<i>Date Received</i>	<i>Analyte Detail</i>
93504	027	FLD BL IN KMNO4	9/2/1999	Mercury
93504	028	FLD BL OUT KCL	9/2/1999	Mercury
93504	029	F/B HNO3/H2O2	9/2/1999	Mercury
93504	030	F/B OUTL KMNO4	9/2/1999	Mercury
93504	031	BLANK:QRTZ FLT	9/2/1999	Mercury
93504	032	BLANK:QRTZ FLT	9/2/1999	Mercury
93504	033	BLANK:QRTZ FLT	9/2/1999	Mercury
93504	034	REAG BLNK HNO3	9/2/1999	Mercury
93504	035	REAG BLNK KCL	9/2/1999	Mercury
93504	036	R/BL HNO3/H2O2	9/2/1999	Mercury
93504	037	REAG BL KMNO4	9/2/1999	Mercury
93504	038	REAG BL KMNO4	9/2/1999	Mercury
93504	039	R/BL HYDROXYLAM	9/2/1999	Mercury
93504	040	COAL SAMPLE T1	9/2/1999	Mercury
93504	040	COAL SAMPLE T1	9/2/1999	Ultimate/Proximate on Coal
93504	040	COAL SAMPLE T1	9/2/1999	Chloride
93504	041	COAL SAMPLE T2	9/2/1999	Chloride
93504	041	COAL SAMPLE T2	9/2/1999	Mercury
93504	041	COAL SAMPLE T2	9/2/1999	Ultimate/Proximate on Coal
93504	042	COAL SAMPLE T3	9/2/1999	Chloride
93504	042	COAL SAMPLE T3	9/2/1999	Mercury
93504	042	COAL SAMPLE T3	9/2/1999	Ultimate/Proximate on Coal
93504	043	FLY ASH SMPL T1	9/2/1999	Hold
93504	044	FLY ASH SMPL T2	9/2/1999	Hold
93504	045	FLY ASH SMPL T3	9/2/1999	Hold

LABORATORY REPORT



TEI Analytical, Inc.
7177 N. Austin
Niles, IL 60714-4617
847-647-1345

PREPARED FOR:

PAGE 1 of 4

Frank Jarke
Mostardi-Platt Associates, Inc.
945 Oaklawn Avenue
Elmhurst, IL 60126

Report #: 36089
Report Date: 1/27/00
Sample Received:
9/20/99 16:35

TEI	93504	Type	Total ug	mg/kg	Date	%RSD	Lin.Reg	Blank	CPI	MS	MSD
36089	001	HNO3	<0.004		1/4/00	9.04	1	NA	97	128	127
36090	002	HNO3	<0.004		1/4/00	2.37	1	NA	97	128	127
36091	003	HNO3	<0.004		1/4/00	0.689	1	NA	97	128	127
36092	004	KCl	4.69		12/23/99	0.416	1	0.219	96.8	101	103
36093	005	KCl	4.35		12/23/99	0.054	1	0.219	96.8	101	103
36094	006	KCl	5.07		12/23/99	0.342	1	0.219	96.8	101	103
36095	007	H2O2	0.338		1/3/00	1.05	0.99995	0.103	98.6	93.8	88.6
36096	008	H2O2	0.246		1/3/00	1.15	0.99995	0.103	98.6	93.8	88.6
36097	009	H2O2	0.305		1/3/00	1.28	0.99995	0.103	98.6	93.8	88.6
36098	010	KMnO4	3.83		12/12/99	0.341	0.99999	0.07	92.3	108	108
36099	011	KMnO4	5.39		12/12/99	0.348	0.99999	0.07	92.3	108	108
36100	012	KMnO4	8.43		12/13/99	1.27	1	<0.03	93.5	118	110
36101	013	HNO3	<0.004		1/4/00	5.12	1	<0.03	97	112	112
36102	014	HNO3	<0.004		1/4/00	1.64	1	<0.03	97	112	112
36103	015	HNO3	<0.004		1/4/00	0.373	1	<0.03	97	112	112
36104	016	KCl	5.98		12/28/99	0.822	1	0.282	97	98.5	98.5
36105	017	KCl	3.28		12/28/99	0.375	1	0.282	97	98.5	98.5
36106	018	KCl	5.43		12/28/99	0.476	1	0.282	97	98.5	98.5
36107	019	H2O2	0.682		1/3/00	0.022	0.99999	0.103	98.1	93.8	88.6
36108	020	H2O2	0.612		1/4/00	0.912	0.99999	0.103	98.1	93.8	88.6
36109	021	H2O2	0.508		1/4/00	0.142	1	0.103	97	112	112
36110	022	KMnO4	7.69		12/13/99	1.19	1	<0.03	93.5	118	110
36111	023	KMnO4	2.21		12/13/99	0.739	1	<0.03	93.5	118	110
36112	024	KMnO4	2.99		12/13/99	2.99	1	<0.03	93.5	118	110


Gayle E. O'Neill, Ph.D.

101

LABORATORY REPORT



TEI Analytical, Inc.
7177 N. Austin
Niles, IL 60714-4617
847-647-1345

PREPARED FOR:

PAGE 2 of 4

Frank Jarke
Mostardi-Platt Associates, Inc.
945 Oaklawn Avenue
Elmhurst, IL 60126

Report #: 36089
Report Date: 1/27/00
Sample Received:
9/20/99 16:35

TEI	93504	Type	Total ug	mg/kg	Date	%RSD	Lin.Reg	Blank	CPI	MS	MSD
36113	025	KCl	0.185		1/4/00	0.992	1	<0.03	97	112	112
36114	026	H2O2	<0.004		10/25/99	13.9	0.99883	<0.03	102	106	106
36115	027	KMnO4	3.42		12/12/99	0.754	0.99999	0.07	92.3	108	108
36116	028	KCl	0.185		1/4/00	1.71	1	<0.03	97	112	112
36117	029	H2O2	<0.004		10/25/99	10.6	0.99883	<0.03	102	106	106
36118	030	KMnO4	1.65		12/12/99	0.584	0.99999	0.07	92.3	108	108
36119	031	Filt		0.021	10/1/99	1.72	0.99928	0.129	107	91	89
36120	032	Filt		0.015	10/1/99	1.59	0.99925	0.129	107	91	89
36121	033	Filt	No sample								
36122	034	HNO3	<0.003		1/10/00	1.84	0.99998	0.135	97.2	103	113
36123	035	KCl	0.152		1/4/00	2.21	1	<0.03	97	112	112
36124	036	H2O2	<0.01		1/10/00	0.448	0.99998	0.135	97.2	103	103
36125	037	KMnO4	0.137		12/12/99	0.134	0.99999	0.07	92.3	108	108
36126	038	KMnO4	0.116		12/12/99	0.187	0.99999	0.07	92.3	108	108
36127	039	NH2OH	<0.003		12/15/99	5.99	0.99999	NA	102	111	111
36152	001	Filt		0.065	9/29/99	9.84	0.99884	0.545	98.2	109	84.1
36153	002	Filt		0.032	1/9/00	0.34	0.99998	0.138	101	122	108
36154	003	Filt		0.022	1/9/00	0.19	0.99998	0.138	101	122	108
36155	013	Filt		0.25	9/29/99	3.33	0.99884	0.545	98.2	109	84.1
36156	014	Filt		0.043	9/29/99	4.76	0.99884	0.545	98.2	109	84.1
36157	015	Filt		0.039	9/29/99	2.61	0.99884	0.545	98.2	109	84.1


Gayle E. O'Neill, Ph.D.

LABORATORY REPORT



TEI Analytical, Inc.
7177 N. Austin
Niles, IL 60714-4617
847-647-1345

PREPARED FOR:

PAGE 3 of 4

Frank Jarke
Mostardi-Platt Associates, Inc.
945 Oaklawn Avenue
Elmhurst, IL 60126

Report #: 36089
Report Date: 1/27/00
Sample Received:
9/20/99 16:35

Mercury (Ontario Hydro Method)

The QAPP called for the analysis of all samples in duplicate with every tenth sample run in triplicate. To simplify the instrument setup, we chose to run all samples, blanks, standards, matrix spikes and matrix spike duplicates in triplicate. The reported %RSD is for the triplicate measurements.

All sample results are reported as total micrograms in the sample received by the laboratory, with the exception of the filter samples. The filter sample results are expressed as mg/kg.

The instrument was calibrated at least daily with a blank and four standards. The Lin.Reg. column in this report represents the linear regression coefficient obtained during the calibration.

The laboratory method blank is reported in ug/l in the Blank column of this report. For samples requiring only addition of Hydroxylamine Hydrochloride, NA is entered in this column. No laboratory method blanks were applicable for these samples.

The CPI column presents the % Recovery of an independent standard (obtained from CPI). The calibration curve was prepared in our laboratory from Mercuric Chloride in accordance with EPA Method 7470.

The MS and MSD columns present the % Recovery of the Matrix Spikes and Matrix Spike Duplicates.



Gayle E. O'Neill, Ph.D.

LABORATORY REPORT



TEI Analytical, Inc.
7177 N. Austin
Niles, IL 60714-4617
847-647-1345

PREPARED FOR:

PAGE 4 of 4

Frank Jarke
Mostardi-Platt Associates, Inc.
945 Oaklawn Avenue
Elmhurst, IL 60126

Report #: 36089
Report Date: 1/27/00
Sample Received:
9/20/99 16:35

In reviewing the initial data for these samples, inconsistently high results were obtained, particularly for the KCl solutions. After considerable investigation, it was determined that the disposable plastic tubes used for the sample digestion were the source of the contamination.

It was also determined that adjustments in the instrument parameters and calibration levels were required to reach the lower limits required for this program. Where possible, samples were reanalysed following these adjustments. However, some samples had insufficient quantity for reanalysis. This was particularly true in the case of the filters.



Gayle E. O'Neill, Ph.D.



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908°



Member of the SGS Group (Société Générale de Surveillance)

ADDRESS: ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD.
SOUTH HOLLAND, IL 60473
TEL: (708) 331-2900
FAX: (708) 333-3060

September 28, 1999

MOSTARDI-PLATT ASSOCIATES, INC
945 Oaklawn Avenue
Elmhurst, IL 60126
Attn: Frank Jarke

Sample identification by
Mostardi-Platt Assoc., Inc.

Kind of sample reported to us Coal

MPA Sample No: 93504-040

Sample taken at -----

Test 1

Sample taken by Mostardi-Platt Assoc., Inc.

Date sampled September 1, 1999

Date received September 9, 1999

P.O. No. 22173

Analysis Report No. 71-102154

Page 1 of 2

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	7.34	xxxxxx
% Ash	8.49	9.16
% Volatile	33.03	35.65
% Fixed Carbon	<u>51.14</u>	<u>55.19</u>
	100.00	100.00
Btu/lb	12790	13803
% Sulfur	0.79	0.85
MAF Btu		15195

ULTIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	7.34	xxxxxx
% Carbon	71.20	76.84
% Hydrogen	4.56	4.92
% Nitrogen	1.54	1.66
% Sulfur	0.79	0.85
% Ash	8.49	9.16
% Oxygen(diff)	<u>6.08</u>	<u>6.57</u>
	100.00	100.00
% CHLORIDE	0.13	0.14

METHODS

Moisture: ASTM D 3302; Ash: ASTM D 3174; Volatile: ASTM D 3175; Fixed Carbon: Calculated Value; ASTM D 3172
Btu/lb: ASTM 3286; Sulfur: ASTM D 4239 (Method C); Carbon, Hydrogen & Nitrogen: ASTM D 5373; Chloride: ASTM D 4208

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

105

Joseph B. Fousek
South Holland Laboratory



OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

F-5
Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD.
SOUTH HOLLAND, IL 60473
TEL: (708) 331-2900
FAX: (708) 333-3060

September 28, 1999

MOSTARDI-PLATT ASSOCIATES, INC
945 Oaklawn Avenue
Elmhurst, IL 60126
Attn: Frank Jarke

Sample identification by
Mostardi-Platt Assoc., Inc.

Kind of sample reported to us Coal

MPA Sample No: 93504-040

Sample taken at -----

Sample taken by Mostardi-Platt Assoc., Inc.

Date sampled September 1, 1999

Date received September 9, 1999

P.O. No. 22173

Analysis Report No. 71-102154

Page 2 of 2

Dry Basis, ug/g

Mercury, Hg 0.07

	<u>Expected</u>	<u>Observed</u>
SARM 1157	0.05	0.05
NIST 1630A	0.11	0.11

METHOD

Mercury: ASTM D 3684

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

106

Joseph B. Fouser
South Holland Laboratory



OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

F-5
Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD.
SOUTH HOLLAND, IL 60473
TEL: (708) 331-2900
FAX: (708) 333-3060

September 28, 1999

MOSTARDI-PLATT ASSOCIATES, INC
945 Oaklawn Avenue
Elmhurst, IL 60126
Attn: Frank Jarke

Sample identification by
Mostardi-Platt Assoc., Inc.

Kind of sample reported to us Coal

MPA Sample No: 93504-041

Sample taken at -----

Test 2

Sample taken by Mostardi-Platt Assoc., Inc.

Date sampled September 1, 1999

Date received September 9, 1999

P.O. No. 22173

Analysis Report No. 71-102155

Page 1 of 2

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	7.83	xxxxxx
% Ash	7.66	8.31
% Volatile	33.27	36.10
% Fixed Carbon	<u>51.24</u>	<u>55.59</u>
	100.00	100.00
Btu/lb	12149	13181
% Sulfur	0.71	0.77
MAF Btu		14376

ULTIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	7.83	xxxxxx
% Carbon	69.51	75.41
% Hydrogen	4.37	4.74
% Nitrogen	1.58	1.71
% Sulfur	0.71	0.77
% Ash	7.66	8.31
% Oxygen(diff)	<u>8.34</u>	<u>9.06</u>
	100.00	100.00
% CHLORIDE	0.13	0.14

METHODS

Moisture: ASTM D 3302; Ash: ASTM D 3174; Volatile: ASTM D 3175; Fixed Carbon: Calculated Value; ASTM D 3172
Btu/lb: ASTM 3286; Sulfur: ASTM D 4239 (Method C); Carbon, Hydrogen & Nitrogen: ASTM D 5373; Chloride: ASTM D 4208

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

107 *Joseph B. Abusek*
South Holland Laboratory



OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

F-5
Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE

LIST OF PARTICIPANTS

<u>Name</u>	<u>Organization</u>	<u>Project Role</u>
Paul Chu	EPRI	Program Manager
Heidi Knach.....	Duke Energy Corporation	Plant Coordinator
James R. Platt	Mostardi Platt.....	Vice President
Jeffery C. Daniels.....	Mostardi Platt.....	Project Supervisor
John Wendell.....	Mostardi Platt.....	Laboratory Chemist
Norm Smith.....	Mostardi Platt.....	Test Technician
Corey Shelby	Mostardi Platt.....	Test Technician
Gayle E. O'Neill, Ph.D.....	TEI Analytical, Inc.....	Speciated Hg Sample Analysis
Joseph Houser	CTE	Coal Sample Analysis