

§ 761.2

40 CFR Ch. I (7-1-07 Edition)

B of this part, provided that such persons comply with subpart J of this part, as applicable.

(4) Except as provided in § 761.20 (d) and (e), persons who process, distribute in commerce, or use products containing excluded PCB products as defined in § 761.3, are exempt from the requirements of subpart B of this part.

(Sec. 6, Pub. L. 94-469, 90 Stat. 2020 (15 U.S.C. 2605)

[44 FR 31542, May 31, 1979, as amended at 49 FR 28189, July 10, 1984; 53 FR 24220, June 27, 1988; 63 FR 35436, June 29, 1998; 64 FR 33759, June 24, 1999]

§ 761.2 PCB concentration assumptions for use.

(a)(1) Any person may assume that transformers with < 3 pounds (1.36 kilograms (kgs)) of fluid, circuit breakers, reclosers, oil-filled cable, and rectifiers whose PCB concentration is not established contain PCBs at < 50 ppm.

(2) Any person must assume that mineral oil-filled electrical equipment that was manufactured before July 2, 1979, and whose PCB concentration is not established is PCB-Contaminated Electrical Equipment (i.e., contains ≥ 50 ppm PCB, but < 500 ppm PCB). All pole-top and pad-mounted distribution transformers manufactured before July 2, 1979, must be assumed to be mineral-oil filled. Any person may assume that electrical equipment manufactured after July 2, 1979, is non-PCB (i.e., < 50 ppm PCBs). If the date of manufacture of mineral oil-filled electrical equipment is unknown, any person must assume it to be PCB-Contaminated.

(3) Any person must assume that a transformer manufactured prior to July 2, 1979, that contains 1.36 kg (3 pounds) or more of fluid other than mineral oil and whose PCB concentration is not established, is a PCB Transformer (i.e., ≥ 500 ppm). If the date of manufacture and the type of dielectric fluid are unknown, any person must assume the transformer to be a PCB Transformer.

(4) Any person must assume that a capacitor manufactured prior to July 2, 1979, whose PCB concentration is not established contains ≥ 500 ppm PCBs. Any person may assume that a capacitor manufactured after July 2, 1979, is non-PCB (i.e., < 50 ppm PCBs). If the

date of manufacture is unknown, any person must assume the capacitor contains ≥ 500 ppm PCBs. Any person may assume that a capacitor marked at the time of manufacture with the statement "No PCBs" in accordance with § 761.40(g) is non-PCB.

(b) PCB concentration may be established by:

(1) Testing the equipment; or

(2)(i) A permanent label, mark, or other documentation from the manufacturer of the equipment indicating its PCB concentration at the time of manufacture; and

(ii) Service records or other documentation indicating the PCB concentration of all fluids used in servicing the equipment since it was first manufactured.

[63 FR 35436, June 29, 1998, as amended at 64 FR 33759, June 24, 1999]

§ 761.3 Definitions.

For the purpose of this part:

Administrator means the Administrator of the Environmental Protection Agency, or any employee of the Agency to whom the Administrator may either herein or by order delegate his authority to carry out his functions, or any person who shall by operation of law be authorized to carry out such functions.

Agency means the United States Environmental Protection Agency.

Air compressor system means air compressors, piping, receiver tanks, volume tanks and bottles, dryers, airlines, and related appurtenances.

Annual document log means the detailed information maintained at the facility on the PCB waste handling at the facility.

Annual report means the written document submitted each year by each disposer and commercial storer of PCB waste to the appropriate EPA Regional Administrator. The annual report is a brief summary of the information included in the annual document log.

ASTM means American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

Byproduct means a chemical substance produced without separate commercial intent during the manufacturing or processing of another chemical substance(s) or mixture(s).