



NIST Training Seminar

Augusta Maine

August 14-18, 2000

Loading Rack Meters

Loading Rack Meters

Ω EPO No. 25

- Safety
- Pretest Determinations
- Inspection
- Test Notes
- Test Procedure



Safety

Safety

∞ Clothing

- non-Synthetic

∞ Electrical Hazards

- Exposed wiring
- Sources of Ignition (heat or spark)

∞ Emergency Procedures

- Phone Numbers for Emergency Services
- Basic First Aid Training

∞ Eye Protection

- Goggles or Safety Glasses
- Eye Wash

Safety Cont.

∞ Fire Extinguisher

- Portable (20 lb or larger)
- Dry Chemical

∞ First Aid Kit

- Basic Supplies

∞ Grounding

- Grounding Cable and lugs
- Skully System

Safety Cont.

Ω Ignition Sources

- Open wiring
- Exposed Lights
- Improper Extension Cords
- Portable Heaters

Ω Lifting

- Proper Lifting Techniques
- Weight Limitations

Ω Location

- Condition (wet/slick)
- Obstructions, Overhead Hazards
- Petroleum Products, Hazardous Materials or Chemicals (MSDS's)

Safety Cont.

- ∞ Material Data Sheets
- ∞ Nature of Product
- ∞ Personal Protection Equipment
 - Safety Shoes
 - Protective Clothing, Gloves, Eye Wear, Respirator, Barrier Cream
 - Hard Hat
- ∞ Safety Cones/Warning Signs
- ∞ Static Discharge
 - Grounding
 - Clothing

Safety Cont.

- ∞ Support for Prover
 - Proper Leveling Jacks
 - Wheel Chocks

- ∞ Switch Loading
 - Diesel Fuel First

- ∞ Traffic

- ∞ Transportation of Equipment



Pretest Determinations

Pretest Determinations

Ω Prover

- Must have a current calibration certificate
- Seals must be in place
- Design compatible with system (top/bottom loading)
- Capacity sufficient to hold one minute flow at max rate and not less than 200 L (50 gal) N.3.5.
- Condition - no dents, rust, water, or foreign material , sight glass clean and not leaking
- For top loading prover inlet lower than meter outlet

Ω Thermometers

- Range 0 °F to 120 °F , 0.5 °F increments, 0.2 °F accuracy

Pretest Determinations Cont.

- ∞ Test Fluid N.1.1.
 - Same characteristics as that measured commercially
- ∞ Applicable Requirements G-T, T.1.
 - Basic Tolerances T.2.3.3.
 - Normal tests
 - Acceptance tolerance 0.2 %
 - Maintenance tolerance 0.3 %
 - Special tests
 - Acceptance tolerance and Maintenance tolerance 0.5 %



Inspection

Inspection

∞ Indicating and recording elements

- Design
 - Must have indicating element, may have recording element S.1.1.
 - Units in liters or gallons or binary-submultiples or decimal subdivisions S1.2., S.1.2.3.
- Readability
 - Indicating and recording elements clear, definite, and easily read G-S.5., S.1.4., S.1.5.
 - Required markings distinct, easily readable and permanent G-S.6., G-S.7.

Inspection

∞ Indicating and recording elements cont.

- Value of intervals
 - Uniform throughout series G-S.5.3.
 - If designed to indicate more than one unit - value must be appropriately identified G-S.5.3.1.
- Advancement and return to zero
 - Elements may only be advanced if S.1.3.
 - Cannot be stopped until zero is reached or
 - Indications are automatically obscured until zero is reached

Inspection

∞ Indicating and recording elements cont.

- Provision for sealing

- Provision must be made for sealing electronic adjustable components G-S.8.

- A security seal must be affixed to any adjustment mechanism designed to be sealed G-UR.4.5.

Inspection

∞ Measuring elements

- Effective vapor elimination system S.2.1.
 - Vent lines suitably rigid
- Means provided for determination of product temperature S.2.6.
- Provision for applying security seals to meter and automatic temperature compensating system
 - All security seals intact G-UR.4.5., S.2.2., S2.7.3.

Inspection

Ω Installation

- Readily accessible for testing G-UR.2.3., G-UR.4.4.
 - Assistance provided if required
- Liquid cannot be diverted from measuring chamber or discharge line and directional flow valve are automatic S.2.3., S.3.1.
- No leaks on meter outlet side G-UR.4.1., S.3.1.
 - Leaks on inlet side noted and called to users attention

Inspection

Ω Installation cont.

- System and associated equipment installation, and construction do not facilitate fraud G-S.2.
- Installation is proper and does not adversely affect system performance G-UR2.1., UR.2.1.
- Actual maximum discharge rate does not exceed manufacturer's specification UR.2.2.

Inspection

∞ Selection and use

- Device suitable for application G-UR.1.1., G-UR.1.2.
 - Design
 - Flow rate
 - Computing capability
 - Indicating and recording elements
 - Value of smallest unit and unit price
 - Environment

Inspection

∞ Selection and use cont.

- Device and associated equipment operated in manner intended by manufacturer G-UR.3.1., G-UR.4.1.
- If equipped with mechanical ATCS UR.3.6.1.1.
 - Connected and operable
 - In use at all times

Inspection

∞ Marking

- Make, model, and serial number G-S.1.
- Switches, lights, displays, pushbuttons, controls, and features clearly identified G-S.6.
- Limitations of use clearly and permanently marked S.4.1.
- Minimum and maximum discharge rate clearly marked S.4.3.1.
 - Minimum cannot exceed 20 % of maximum

Inspection

Ω Devices equipped with ATCS

- Provision to deactivate S.2.7.2.
- Thermometer well provided for determination of product temperature S.2.7.4.
- Primary indicating and recording elements marked to show delivered volume has been adjusted to 60 °F S.4.3.2.



Test Notes

Test Notes

∞ Level Prover

- Level indicators working properly

∞ Connect safety interlock, ground cable and vapor recovery hose if applicable

∞ Verify all valves closed and pumping mechanism functioning

∞ Record totalizer reading

- Before and after each draft

Test Notes

- ∞ Minimize temperature differences between meter and prover N.2.
- ∞ Minimize splashing in top loading provers and maintain fill spout in consistent position
- ∞ Examine printed tickets and invoices
 - Print after every draft G.S.5.6.
 - Computing type
 - Check computations S.1.7.2.
 - Total volume and unit price must accompany total price either printed or handscript UR.3.4.

Test Notes

Ω Examine printed tickets and invoices cont.

- Check indicated and recorded values for comparability G-S.5.2.2.
- With ATCS check invoices for UR.3.6.1.2. a & b
 - Notice that volume has been adjusted to 60 °F
 - For electronic systems, listing of API gravity, specific gravity, or coefficient of expansion, product temperature, and gross meter reading
- Without ATCS UR.3.6.2.1., UR.3.6.2.2.
 - If adjusted, notice that volume has been adjusted to 60 °F
 - Temperature of product used to make adjustment

Test Notes

∞ Reading meniscus

- Bottom for transparent liquids
- Top for opaque liquids

∞ Draining prover

- Lower sight glass
 - Close drain valve before liquid reaches zero, wait 30 seconds, open small zero drain valve till zero
 - do not readjust
- No lower sight glass
 - When drips start wait 30 seconds, close drain


Test Notes

Ω Temperature readings

- Read to nearest 0.5 °F
 - Use matching thermometers
- Read prover temperature immediately after each accuracy test run
 - Average readings if prover has multiple wells
- Read meter temperature
 - Thermometer well in measuring chamber or immediately adjacent
 - Read at 1/3 and 2/3 of prover capacity

Test Notes

- ⌚ Automatic stop mechanism (preset) must stop within one-half the minimum indicated interval
G-UR.4.1.



Test Procedure

Test Procedure

- ∞ Wet prover
- ∞ Empty prover using 30 second drain
- ∞ Insert ticket & set preset to prover volume
- ∞ Zero meter
- ∞ Start pump then open delivery valve
- ∞ At end of each run read prover & determine meter error
 - Repeat run if test result is near or out of tolerance

Test Procedure

∞ Notes for Repair Personnel

- At least two runs at same flow rate to determine repeatability
 - Individual runs within applicable tolerance
 - Difference not to exceed 40 % of applied tolerance
- Adjust meter if out of tolerance
 - Deactivate ATCS if necessary
 - Check performance of temperature sensor

Test Procedure

∞ Accuracy tests - *no ATCS* N.5.

- Normal test - full flow N.4.1., N.4.1.1., T.2.3.
 - Flow rate within meter rating G-UR.3.1., G-UR.2.2.
- Special test - slow flow N.4.2., N.4.2.4., T.2.3.
 - Fill prover at minimum flow rate marked on meter

∞ Read temperature at meter and prover make corrections for meter and prover readings

Test Procedure

∞ Accuracy tests - *no ATCS* N.5.

- Normal test - full flow N.4.1., N.4.1.1., T.2.3.

- Flow rate within meter rating G-UR.3.1., G-UR.2.2.
- Average product temperature at meter - read at 1/3 & 2/3 of prover capacity
- Product temperature in prover

∞ Correct prover, product in prover, & meter readings for temperature difference from 60 °F

Test Procedure

∞ Accuracy tests - *no ATCS* N.5.

- Special test - slow flow N.4.2., N.4.2.4., T.2.3.

- Fill prover at minimum flow rate marked on meter
- Average product temperature at meter - read at 1/3 & 2/3 of prover capacity
- Product temperature in prover

∞ Correct prover, product in prover, & meter readings for temperature difference from 60 °F

Test Procedure

- ∞ Accuracy tests of temperature compensated meter - indication in “net” gallons
 - Normal full flow test - *With ATCS activated*
 - Average product temperature at meter - read at 1/3 & 2/3 of prover capacity
 - Only to note large variation
 - Product temperature in prover
 - Correct prover reading & product in prover for temperature difference from 60 °F

Test Procedure

- Accuracy tests of temperature compensated meter - *ATCS deactivated*
 - Normal full flow test
 - Average product temperature at meter - read at 1/3 & 2/3 of prover capacity
 - Product temperature in prover
 - Correct prover, product in prover, & meter readings for temperature difference from 60 °F

Test Procedure

∞ Accuracy tests of temperature compensated meter

- Special test slow flow - *ATCS deactivated*
 - Average product temperature at meter - read at 1/3 & 2/3 of prover capacity
 - Product temperature in prover
- Correct prover, product in prover, & meter readings for temperature difference from 60 °F

Test Procedure

- ∞ Accuracy tests - For meters that display both “net” and “gross” deliveries
 - For “gross” delivery indication use correction procedure for meter without temperature compensation for normal & special tests
 - For “net” delivery indication use procedure for meter with ATCS for normal & special tests

Test Procedure

∞ For system with ATCS

- Difference in meter error with ATCS activated and ATCS deactivated shall not exceed
 - 0.2 % for mechanical ATCS and
 - 0.1% for electronic ATCS
- T.2.3.3.

Test Procedure

∞ Security seal

- Provision for security seals S.2.2.
- Seals in place & intact G-UR.4.5.

∞ Wet-hose system S.3.9.

- Check effectiveness of anti-drain valve

∞ Dry-hose system S.3.6.

- Check for complete drainage of hose

Test Procedure

Ω RFI/EMI

- Test with associated equipment only
 - Test only if a problem is suspected
 - G-N.2., G-UR.1.2., G-UR.3.2., G.UR.4.2.