

PCB INSPECTION CHECKLIST (REVISED FEBRUARY, 1999)

Name of Facility: _____

Address of Facility: _____

I. PCB USE/REUSE (Regulatory threshold = 50 ppm PCB)

TRANSFORMERS (containing >3 lb of fluid)

1. Does the facility use or have in storage for reuse any PCB transformers or PCB contaminated transformers? _____ Yes _____ No

If yes, complete table 1 and indicate below the total numbers.

- a. Total number of PCB transformers in service: _____
- b. Total number of PCB contaminated transformers in service: _____
- c. Total number of PCB transformers in storage for reuse: _____
- d. Total number of PCB contaminated transformers in storage for reuse: _____

2. Describe the basis of the facility's classification of its transformers (i.e., testing, name plate/label, service records, assumptions)

If assumptions were made, were they in accordance with §761.2(a) (i.e., pre 7/79 or unknown date, mineral oil - PCB contaminated; pre 7/79 or unknown date, non-mineral oil - PCB)? _____ Yes _____ No

761.30(a)(1)(i)

3. Are there any PCB transformers in use or in storage for reuse that pose an exposure risk to food or feed? _____ Yes _____ No

If yes, describe: _____

761.30(a)(1)(vi)(A)

4. Have all PCB transformers in use or in storage for reuse been registered with the EPA by December 28, 1998? Yes No
5. Have transformers which were identified as PCB transformers after December 28, 1998 been registered with EPA no later than 30 days after such identification was made? Yes No N/A

(If yes to either of the above, obtain a copy of the registration form and the return receipt signed by EPA. The facility must retain a copy of this material as required by §761.30(a)(1)(vi)(C))

6. Does the facility have any PCB transformers in or near commercial buildings? Yes No

(If no, skip to question 16)

7. Based on the facility's information, including electrical schematic diagrams, which of the following describes the type of transformers that are located in or near a commercial building?
- a. Network/Higher Secondary Voltage (480 volts) _____
 - b. Network/Lower Secondary Voltage (<480 volts) _____
 - c. Radial/Higher Secondary Voltage (480 volts) _____
 - d. Radial/Lower Secondary Voltage (<480 volts) _____

(Note that a is prohibited (761.30(a)(1)(ii)); b must be protected for high current faults; c must be protected for both high and low current faults; and d must be protected for high current faults(761.30(a)(1)(iv) & (v))

8. Describe below the type of enhanced electrical protection (i.e., current limiting fuses, circuit breakers, relays, etc.) that the facility has provided for its PCB transformers in or near commercial buildings.
-

761.30(a)(1)(vii)

9. Were PCB transformers located in or near a commercial building registered with the building(s) owner(s)? Yes No

(Note: PCB transformers located within a commercial building must be registered with the building owner of record while PCB transformers located near commercial buildings must be registered with all building owners located within 30 meters of the transformers)

10. Did registration occur by December 1, 1985? Yes No

If no, explain why: _____

761.30(a)(1)(xv)

11. For any transformer(s) located in or near commercial buildings assumed to contain less than 500 ppm of PCBs that were tested and found to contain 500 ppm or greater of PCBs, did the facility initiate the following:

a. register the transformer(s) with the building owner within thirty (30) days of discovery? Yes No N/A

If yes, is a copy of the registration letter available?

Yes No

(if yes, obtain a copy, if no, explain why)

b. install necessary protective equipment on radial or lower secondary voltage network transformers within 18 months of discovery or by Oct. 1, 1990, whichever is later? Yes No N/A

c. retrofit and reclassify or remove the above transformers within 18 months of discovery if enhanced electrical protection was not provided?
_____ Yes _____ No _____ N/A

12. List each building (name and address) and building owner with whom registration occurred:

13. Are copies of the registration letters available? ___ Yes ___ No

If yes, obtain copies

If no, explain why:

761.30(a)(1)(vii)

14. Did registration with the building owner(s) include provision of the following:

a. Specific location of PCB transformers? ___ Yes ___ No

b. Principal constituent of dielectric fluid? ___ Yes ___ No

c. Type of transformer installation? ___ Yes ___ No

761.30(a)(1)(iii)

15. Has the facility installed any PCB transformers which were placed in storage for reuse or which were moved from another location in or near commercial buildings since October 1, 1985? ___ Yes ___ No

If yes, list locations and dates of installations and volume of each PCB transformer installed:

761.30(a)(1)(viii)

16. Are any combustible materials stored within:

- a. PCB transformer enclosure? Yes No
- b. 5 (five) meters of a PCB transformer enclosure? Yes No
- c. 5 (five) meters of an unenclosed PCB transformer? Yes No

If any are answered yes, take photographs and list the locations, type of situation, type of combustibles and any relevant comments:

761.30(a)(1)(ix)

17. Are visual inspections of each in use or stored for reuse PCB transformer for leaks performed at least once every three months since August 1981? Yes No

If no, indicate missing inspections:

761.30(a)(1)(xii)

18. Are inspection logs available? Yes No
If yes, obtain copies.

If no, explain why: _____

761.30(a)(1)(x)

19. Have arrangements been made to repair or replace leaking (i.e. PCB oil running off or about to run off the external surface) PCB transformers?
 N/A Yes No

If yes, describe arrangements: _____

If no, explain why: _____

761.30(a)(1)(x)

20. Was clean-up of released PCBs resulting from a leaking PCB transformer initiated within 48 hours of its discovery? N/A Yes No

If no, explain why: _____

761.30(a)(1)(x)

21. Was an active leak of PCBs from a PCB transformer adequately contained after its discovery? N/A Yes No

761.30(a)(1)(x)

22. Are daily inspections performed of actively leaking PCB transformers to verify proper containment? N/A Yes No

761.30(a)(1)(xi)

23. Were any fire-related incidents involving a PCB transformer reported to the National Response Center? N/A Yes No

761.30(a)(1)(xii)

24. Are inspection logs maintained for these daily inspections?
 N/A Yes No

If yes, obtain copies.

761.30(a)(1)(xii)

25. Are inspection and maintenance records maintained at least 3 years after disposal of the PCB transformer? N/A Yes No

761.30(a)(1)(xii)

26. Do inspection/maintenance records include:

- a. Location of transformer? Yes No
- b. Date of Inspection? Yes No
- c. Date leak discovered? Yes No
- d. Inspector's Name? Yes No
- e. Location of Leaks? Yes No
- f. Amount of dielectric fluid released? Yes No
- g. Date(s) of cleanup, containment provision and leak repair? Yes No

761.30(a)(1)(xiii)

27. If annual inspections are performed of in use or stored for reuse PCB transformers:

- a. Does adequate (i.e. 100%) secondary containment exist for these transformers? Yes No

Obtain dimensions.

- b. Does evidence exist to demonstrate that testing of these transformers was performed and that they contained less than 60,000 ppm PCB after 3 months of in-service use? _____Yes _____No

If yes, obtain copies of test results.

761.30(a)(1)(xiv)

28. Were weekly inspections performed and records maintained at least 3 years where a PCB transformer in use or stored for reuse posed an exposure risk to food or feed prior to October 1, 1985?
_____N/A _____Yes _____No

761.30(a)(2)(i) and (ii)

29. Were any PCB transformers serviced as follows:

- a. Dielectric fluid containing more than 500 ppm PCB was used?
_____N/A _____Yes _____No
- b. Transformer coil was removed? _____N/A _____Yes _____No
- c. Mixture of dielectric fluids, some of which contained more than 500 ppm PCB, was used? _____N/A _____Yes _____No

If any are answered **yes**, obtain copies of appropriate records that are available.

761.30(a)(2)(v)

30. If there was testing of a transformer(s) for reclassification purposes, did such testing occur after a minimum of 3 months of in-service use subsequent to last servicing and did temperature of dielectric fluid reach 50° C or more?
_____N/A _____Yes _____No

761.40(a)

31. Are all PCB transformers in use or in storage for reuse properly marked with a M_L label? _____Yes _____No

If no, describe circumstances:

761.40(j)

32. Are all vault/room doors, fences, hallways or other accessways to PCB transformers properly marked with a M_L label? Yes No

If no, describe cases where M_L mark is missing and take photographs:

761.30(a)(1)(xv)

33. Does the facility have any mineral oil transformers assumed to contain less than 500 ppm of PCBs that were tested and found to contain 500 ppm or greater of PCBs? Yes No

If yes, has the facility initiated the following:

- a. Marked the transformer(s) with a PCB M_L label within seven (7) days after discovery? Yes No
- b. Marked the vault door, machinery room door, fence, hallway or other means of access to PCB transformers with a PCB M_L label within seven (7) days after discovery? Yes No

CAPACITORS (containing > 3 lb of fluid)

34. Does the facility use or have in storage for reuse any large PCB capacitors? Yes No

If yes, complete Table 2 and indicate below the total numbers:

a. Total number of PCB large high voltage capacitors in service: _____

- b. Total number of PCB large low voltage capacitors in service: _____
- c. Total number of PCB large high voltage capacitors in storage for reuse: _____
- d. Total number of PCB large low voltage capacitors in storage for reuse: _____

35. Describe the basis of the facility's classification of its large capacitors (i.e., name plate/label, service records, assumptions)

761.2(a)(4)

36. Has the facility assumed that any capacitor manufactured prior to July 2, 1979 or any capacitor whose date of manufacture is unknown and whose PCB concentration is not established contains 500 ppm PCB?
 _____ Yes _____ No _____ N/A

761.30(1)(1)(i)

37. After October 1, 1988, did the facility have any PCB Large High or Low Voltage Capacitors in use or in storage for reuse that pose an exposure risk to food or feed? _____ Yes _____ No

761.30(1)(1)(ii)

38. After October 1, 1988, did the facility have any PCB Large High or Low Voltage Capacitors in use in an area other than a restricted-access electrical substation or a contained and restricted-access indoor installation? _____ Yes _____ No

761.40(c)(2)(ii)

39. Are all PCB large high voltage capacitors individually marked with an M_L label unless they are installed in a protected location such as on a power pole, a structure, or behind a fence, in which case the pole, structure or fence must be properly labelled?
 _____ Yes _____ No

If no, describe circumstances:

761.40(k) (1)

40. Are all PCB large low voltage capacitors individually marked with an M_L mark unless they are installed in a protected location such as on a power pole, structure, or behind a fence, in which case the pole structure or fence is labelled by April 26, 1999?
_____ N/A _____ Yes _____ No

761.40(k) (2)

41. Is all equipment containing a PCB large high or low voltage capacitor labelled with an M_L mark by April 26, 1999?
_____ N/A _____ Yes _____ No

VOLTAGE REGULATORS (containing >3 lb of fluid - regulations effective Aug. 28, 1998)

42. Does the facility use or have in storage for reuse any PCB voltage regulators that contain three (3) lbs or more of dielectric fluid?
_____ Yes _____ No

If yes, answer the following questions:

761.40(1) (1)

43. Are all PCB voltage regulators individually marked with an M_L label?
_____ Yes _____ No

761.40(1) (2)

44. Are locations of PCB voltage regulators such as vault doors, machinery room doors, fences, hallways or other means of access marked with an M_L label? _____ Yes _____ No _____ N/A

761.30(h) (1) (ii) (B)

45. Are fire related incidents involving voltage regulators reported to the National Response Center? Yes No N/A

761.30(h)(1)(ii)(C)

46. Are inspections of PCB voltage regulators performed in a fashion similar to those required for PCB transformers (i.e., same frequency, scope, provisions when leaks occur, documentation, etc.)? Yes No

761.30(h)(1)(ii)(D)

47. Does facility owning PCB voltage regulators comply with the recordkeeping and reporting requirements applicable to PCB transformers (§761.180)? Yes No

HEAT TRANSFER OR HYDRAULIC SYSTEMS

48. Does the facility have any heat transfer or hydraulic systems? Yes No

If yes, answer the next question:

761.30(d) & (e)

49. Does heat transfer or hydraulic system(s) contain PCBs above 50 ppm? Yes No

If yes, how many systems and what was the basis of determination:

PCB CONTAMINATED POROUS SURFACES

50. Does the facility have a continued use of any PCB contaminated porous surface (porous surface includes concrete, wood, and coated metal surfaces; contaminated means >10 ug/100cm²)? Yes No

If yes, answer the following questions:

761.30(p)(1)(i)

51. Was the source of PCB contamination removed or contained to prevent further release to the porous surface(s) in use? Yes No

761.30(p)(1)(ii)

52. Was the surface(s) properly cleaned if accessible? Yes No N/A

761.30(p)(1)(iii)

53. Was the surface(s) properly coated and marked with an M_L label? Yes No

Note: there are other authorized uses of PCB but they are not covered by this checklist

54. Does the facility store for reuse, in an area not meeting the requirements of §761.65 (Storage for Disposal), any PCB Article? Yes No

If yes, answer the following questions:

761.35(a) & (b)

55. Has the facility stored for reuse any PCB Article for greater than 5 years after the date the Article was originally removed from service or 5 years after August 28, 1998, whichever is later, without written approval from EPA? Yes No

761.35(a) (1)

56. Has the facility complied with all use and marking requirements applicable to the PCB Articles in storage for reuse (see questions above pertaining to §761.30 and §761.40)? Yes No

761.35(a) (2)

57. Has the facility maintained records on its PCB Articles in storage for reuse which indicate when they were removed from use, the projected location and future use of the Articles and repair or servicing dates, if applicable? Yes No

Pertinent Comments:

Transformer Observations

Table 1

Transformer Make, No	Minor*	Mod*	Major*	In Stor.	Dielectric	PCB/PCB	M _L
Ser#,Instal.	Type	Location	In Use	for Reuse	Fluid Name	Contam.	Affixed?
Leak	Leak	Leak	Leak				

* Minor Leak - oil on outer surface but not about to run off
 Moderate Leak - oil about to run off of outer surface

* Take photographs of leak

II STORAGE FOR DISPOSAL (Regulatory threshold = 50 ppm)

(If PCB items are in storage for disposal, complete Table 3)

761.65(a)(1)

1. Were any PCB Articles, PCB Containers or other PCB items in storage for disposal for more than one (1) year from the date in which the item was removed from service for disposal? Yes No

761.65(a)(2)

If yes, did the facility obtain a one (1) year extension from EPA?
 Yes No

761.65(b)(1)(i)

2. Does the storage facility have an adequate roof and walls to prevent rain water from reaching the stored PCBs or PCB Items? Yes No

761.65(b)(1)(ii)

3. Does the storage facility have an adequate floor with continuous curbing at least six inches high? Yes No

4. What are the dimensions of the curbed storage area?

Length Width Depth

5. List below the internal volume of the largest PCB Article or Container in the storage area (1) and the figure representing 25 percent of the total internal volume of all the PCB Articles or Containers in the storage area (2):

(1) _____

(2) _____

761.65(b)(1)(ii)

6. Does the floor and curbing provide a containment volume equal to at least two times the internal volume of the largest PCB Article or Container stored therein or 25 percent of the total internal volume of all the PCB Articles or Containers stored therein, whichever is greater?

_____Yes _____No

761.65(b)(1)(iii)

7. Are there any drain valves, floor drains, sewer lines, or other openings that would allow liquids to flow from the curbed storage area?

_____Yes _____No

If yes, describe which type of potential outlet is present.

761.65(b)(1)(iv)

8. Are the storage area floor and curbing constructed of continuous smooth and impervious materials, such as Portland cement, concrete or steel, to prevent or minimize penetration of PCBs? _____Yes _____No

What material was used for construction of storage area?

761.65(b)(1)(v)

9. Is the storage area located at a site that is below the 100-year flood water elevation? _____Yes _____No _____Unknown

If no, provide documentation that the storage area is above the 100-year flood water elevation. If unknown, obtain as much information as possible so that determination can be made in the Region.

761.65(c)(5)

10. Are PCB Articles and PCB Containers in storage for disposal checked for leaks at least once every 30 days? Yes No

761.65(c)(5)

11. Are records available which document when inspections of the storage facility are performed, by whom and the results of such inspections? Yes No

If yes, obtain copies

12. Are there any leaking PCB Articles or PCB containers in storage for disposal? Yes No

761.65(c)(5)

13. Have the contents of leaking PCB Articles or PCB Containers in storage for disposal been transferred to properly marked non-leaking containers? N/A Yes No

If no, explain why:

761.65(c)(5)

14. Have spilled or leaked materials from PCB Articles or PCB Containers in storage for disposal been immediately cleaned up using absorbents or other adequate means? N/A Yes No

If no, explain why:

761.65(c)(6)

15. Are all containers used for the storage of liquid or non-liquid PCB waste in accordance with DOT regulations (49 CFR §171-180)?

N/A Yes No

761.65(c)(7)(ii)

16. Has an SPCC plan been prepared and implemented in cases where PCB liquids are stored in containers (incl. tanks) that are larger than those specified in the DOT regulations (i.e. 55 gal drums)?

N/A Yes No

761.65(c)(8)

17. Are PCB Articles and PCB Containers dated as to when they were placed in storage? Yes No

761.65(c)(8)

18. Is storage managed so that the PCB Articles and PCB Containers can be located by the date they entered storage? Yes No

761.65(c)(8)

19. Are records available which indicate the date and quantity of each batch of PCBs either added to or removed from large (> 55 gallon) containers in storage? N/A Yes No

20. Does the facility store any bulk PCB remediation waste or PCB bulk product waste at the clean-up site or site of generation?

Yes No

If yes, answer the following questions:

761.65(c)(9)

a. Has the waste been stored for 180 days or less?

Yes No

b. Is the waste placed in a pile designed and operated to control wind dispersion? Yes No

c. Does the waste generate leachate? Yes No

d. Is the storage site provided with a liner, a cover and a run-on control system? Yes No

761.40(a)(10)

21. Is each storage area and the PCB Items stored therein for disposal properly marked with a M_L label? Yes No

If no, describe items not properly marked:

22. Does the facility utilize a temporary storage area for PCB Items? Yes No

If yes, list types of PCB Items in temporary storage and answer the following questions:

761.65(c)(1)

23. Have any PCB Items been in temporary storage in excess of 30 days? Yes No

If yes, how much in excess of 30 days?

761.65(c)(1)

24. Is there a notation on PCB Items in temporary storage indicating when the item was removed from service? Yes No

761.65(c)(1)(ii)

25. Are there any leaking PCB Articles or PCB Equipment in temporary storage which have not been placed in a non-leaking container that contains a sufficient amount of sorbent material?

Yes No

761.65(c)(1)(iv)

26. Has an SPCC plan been prepared for a temporary storage area where PCB Containers containing liquid PCBs at a concentration 50ppm are being stored? N/A Yes No

761.65(c)(1)(iv)

27. Are PCB containers containing liquid PCBs at a concentration 50 ppm in temporary storage authorized by DOT regulations (49 CFR §171-180)? N/A Yes No

761.65(c)(3)

28. Is the temporary storage area properly marked with an M_L label? Yes No

29. Does the facility store any PCB items on pallets next to a designated storage area? Yes No

If yes, list PCB Items stored at that location:

761.65(c)(2)

30. Does the storage facility have immediately available unfilled storage equal to 10 percent of the volume of PCB large, high voltage capacitors and PCB contaminated electrical equipment stored outside the facility? Yes No

761.65(c)(2)

31. Are the capacitors or other electrical equipment stored outside the facility checked for leaks at least weekly? Yes No

32. Is the facility a commercial storage facility (i.e., accepts PCB wastes from other facilities)? Yes No

If yes, answer the following:

761.65(d)(1) & (2)

a. Has the facility received final approval from EPA to operate as a commercial storage facility? Yes No

If yes, obtain evidence, including proof that it has met financial responsibility requirements and has an acceptable closure plan.

Pertinent Comments: _____

PCB ITEMS IN STORAGE FOR DISPOSAL (50 ppm)

Table 3

<i>ITEM DESCRIPTION</i>	<i>ITEM DATED? (Y) (N)</i>	<i>RECORD DATE</i>	<i>PCB M_L LABEL? (Y) (N)</i>	<i>ITEM LEAKING? (Y) (N)</i>	<i>REMARKS</i>

ITEM DESCRIPTION	ITEM DATED? (Y) (N)	RECORD DATE	PCB M _L LABEL? (Y) (N)	ITEM LEAKING? (Y) (N)	REMARKS

**III. PCB WASTE PROCESSING (EXCLUDING STORAGE), CLEAN-UP AND DISPOSAL
(Regulatory threshold = 50 ppm)**

1. Is the facility a commercial facility (i.e., accepts PCB wastes from other facilities)?
 _____ Yes _____ No

If yes, is it permitted by EPA? _____ Yes _____ No

761.60 (b) (1) (i) (B) & (b) (4)

2. Has the facility removed all free-flowing liquid from its PCB and PCB contaminated transformers through the use of a solvent for at least 18 continuous hours? _____ Yes _____ No
 _____ N/A

761.60 (b) (6) (i) & (ii)

3. Has the facility removed all free-flowing liquid from its other PCB and PCB contaminated articles?
 _____ Yes _____ No _____ N/A

761.1(a) (5)

4. Does it appear as though the facility is diluting any of its PCB waste prior to disposal?
_____ Yes _____ No _____ N/A

5. Check which of the following types of PCB waste the facility handles (state whether waste is cleaned up/decontaminated, processed, or disposed of):

a. PCB liquids _____

b. PCB transformers _____

c. PCB capacitors _____

d. Other PCB Articles _____

e. PCB Contaminated Equipment _____

f. PCB Containers _____

g. PCB Remediation Waste* (describe types & concentrations)

h. PCB Bulk Product Waste** _____

i. R & D Related PCB Waste _____

j. PCB/Radioactive Waste _____

k. Other (describe) _____

* - means waste containing PCB as a result of a spill, release, or other unauthorized disposal. It includes bulk PCB remediation waste (i.e., soil, sediment, sludge), non-porous surfaces, porous surfaces, and liquids

** - means waste derived from manufactured products containing PCBs in a non-liquid state. It includes demolition debris, material from shredding operations (i.e., fluff), coatings, insulation and fluorescent light ballasts containing PCB contaminated potting material

6. Is the facility involved with clean-up/decontamination of any PCB remediation waste?
_____Yes _____No

If yes, for each specific type of PCB remediation waste, describe its PCB concentration, the clean-up procedure employed and the level of clean-up achieved (state if it's self-implementing).

7. Does the facility perform decontamination activities on any PCB waste materials, other than PCB remediation waste, including water, organic liquids, non-porous surfaces (either coated or uncoated) or concrete? _____Yes _____No

If yes, describe the PCB concentration of the waste, decontamination procedure employed and the level of decontamination achieved (state if it's self implementing).

8. For each PCB waste identified in question 5 as being disposed of at _____ the facility, indicate below its PCB concentration and the method and _____ location of its disposal.

9. For any mixed media or multi-phase waste, does the facility use the media having the highest PCB concentration to determine the appropriate method of disposal? _____Yes _____No
_____N/A

761.50(a)

10. Indicate below if any of the following disposal prohibitions were observed at the facility?

- a. open burning of PCBs _____
- b. discharging of PCB contaminated water (3 ug/l) to treatment works or navigable streams

- c. processing liquid PCBs into non-liquid forms _____
- d. spills or other uncontrolled discharges _____

761.60

11. Describe below any other disposal of PCB items that was not in accordance with the following disposal matrix.

PCB DISPOSAL METHODS

Type of Waste	Incinerator	High Efficiency Boiler	Industrial Furnace	Chemical Waste Landfill	Approved Hazard. Waste Landfill	Permitted Solid Waste Facility	Approved Disposal Facility	RA Approved Self-Implementing Procedure
PCB Liquids (>500 ppm)	X							
PCB Liquids (50-500 ppm)	X	X						
Drained PCB Containers/Articles	X			X				
Drained PCB Contaminated Articles/Containers			X			X	X	

Large Undrained PCB Capacitors	X			X (under certain conditions)				
PCB Remediation Waste - Liquid (not decontaminated)	X	X (<500 ppm)						X
PCB Remediation Waste - Non-Liquid (not decontaminated)	X			X				X
Non-Liquid PCB-Bulk Product Waste	X			X	X	X		X
Non-Liquid PCB-Soil, Rags, Debris	X			X				
Non-Liquid PCB-Sludges, Sediment	X			X				X

Other Pertinent Comments

**IV. RECORDKEEPING AND REPORTS RELATED TO USE, STORAGE AND DISPOSAL
OF PCB**

Note: If the facility is a disposer or commercial storer of PCB waste skip to question 12

761.180(a)

1. Does the facility have in use, or in storage for future use or disposal, the following:

a. 99.4 lbs. (45 kg.) or more of PCBs in PCB Container(s)?
_____Yes _____No

b. One or more PCB Transformers? _____Yes _____No

c. 50 or more large high or low voltage PCB capacitors?
_____Yes _____No

761.180(a)

2. Has the facility developed and maintained all annual records and the annual document log as of July 1, 1991, and each year thereafter? _____Yes _____No

a. Are the annual records and the annual document log prepared on a calendar year basis? _____Yes _____No

b. Has the facility retained the annual records and the annual document logs for at least three (3) years after it no longer used or stored PCBs or PCB Items?
_____Yes _____No

3. Where are the records maintained? _____

a. How are the records compiled and by whom? _____

761.180(a)(1)(i), (ii) & (iii)

4. Do the facility's annual records contain the following:

a. All signed manifests generated by the facility during the calendar year? _____Yes _____No

b. All Certificates of Disposal that have been received by _____ the facility during the calendar year? _____Yes _____No

c. Records of inspections and clean-ups? _____Yes _____No

761.180(a)(2)(i) & (ii)

5. Does the written annual document log contain the following:

a. The name, address, and EPA identification number of the _____ facility?
_____Yes _____No

b. The calendar year covered by the annual document log?
_____Yes _____No

c. The unique manifest number of every manifest generated _____ by the
facility during the calendar year? _____Yes _____No

6. Does the written annual document log contain the following information from each manifest and for unmanifested waste that may be stored at the facility:

761.180(a)(2)(ii)(A)

Bulk PCB waste (e.g. in a tanker or truck) _____N/A

a. Its weight in kilograms? _____Yes _____No

b. The first date it was removed from service for disposal? _____Yes
_____No

c. The date it was placed into transport for off-site storage or
disposal? _____Yes _____No

d. The date of disposal, if known? _____Yes _____No

761.180(a)(2)(ii)(B)

PCB Articles (e.g. transformer or capacitor) _____N/A

a. The serial number (if available) or other means of identifying each PCB
Article? _____Yes _____No

- b. The weight in kilograms of the PCB waste in each PCB Article? _____Yes
 _____No
- c. The date it was removed from service for disposal?
 _____Yes _____No
- d. The date it was placed in transport for off-site storage or disposal?
 _____Yes _____No
- e. The date of disposal, if known? _____Yes _____No

761.180(a)(2)(ii)(C)

PCB Containers _____N/A

- a. A unique number identifying each PCB Container?
 _____Yes _____No
- b. A description of the contents of each PCB Container?
 _____Yes _____No
- c. The total weight in kilograms of the material in each PCB Container?
 _____Yes _____No
- d. The first date material was placed in each PCB Container? _____Yes
 _____No
- e. The date each container was placed in transport for off-site storage or disposal?
 _____Yes _____No
- f. The date of disposal, if known? _____Yes _____No

761.180(a)(2)(ii)(D)

PCB Article Containers _____ N/A

- a. A unique number identifying each PCB Article Container?
_____ Yes _____ No
- b. A description of the contents of each PCB Article Container? _____ Yes
_____ No
- c. The total weight in kilograms of the contents of each PCB Article Container? _____ Yes _____ No
- d. The first date a PCB Article was placed into each container? _____ Yes
_____ No
- e. The date the container was placed in transport for off-site storage or disposal? _____ Yes _____ No
- f. The date of disposal, if known? _____ Yes _____ No

761.180(a)(2)(iii)

7. Does the facility's annual document log contain the total numbers and total weights (kg.) for the following items:
- a. Total number of PCB Articles (by specific type)?
_____ Yes _____ No _____ N/A
- b. Total weight of PCBs in PCB Articles?
_____ Yes _____ No _____ N/A
- c. Total number of PCB Article Containers?
_____ Yes _____ No _____ N/A
- d. Total weight of contents of PCB Article Containers?

_____Yes _____No _____N/A

e. Total number of PCB Containers? _____Yes _____No _____N/A

f. Total weight of contents of PCB Containers?
_____Yes _____No _____N/A

g. Total weight of bulk PCB waste that was placed into storage for disposal or
disposed during the calendar year? _____Yes _____No
_____N/A

761.180(a)(2)(iv), (v) & (vi)

8. For PCBs and PCB Items remaining in service at the end of the calendar year, do records indicate the following:

a. Total number of PCB Transformers?
_____Yes _____No _____N/A

b. Total weight (kg) of PCBs in transformers?
_____Yes _____No _____N/A

c. Total number of large high or low voltage PCB Capacitors? _____Yes
_____No _____N/A

d. Total weight (kg) of PCBs and PCB Items in PCB Containers? _____Yes
_____No _____N/A

e. Identification of contents of PCB containers (liquids, capacitors,
etc.)? _____Yes _____No _____N/A

761.180(a)(2)(vii)

9. For any PCBs or PCB Items received from or shipped to another facility owned or operated by the same generator, does the annual document log contain the same information as asked in Question No. 6?

_____ Yes _____ No _____ N/A

761.180(a)(2)(viii)

10. Does the facility's annual document log contain a record of each telephone call (or other means of verification) made to each commercial storer or disposer to confirm receipt of PCB waste transported by an independent transporter?

_____ Yes _____ No _____ N/A

761.180(a)(2)(ix)

11. Does the facility's annual document log contain the name, address and telephone number of the person to whom a PCB item containing >50ppm PCB, excluding small capacitors, has been distributed in commerce for reuse along with date of transfer and the serial or internal identification number of the item? _____ Yes _____ No _____ N/A

Skip to next section of checklist

Questions for Disposer ()/Commercial Storer () Facilities (check appropriate type)

12. Has the facility developed and maintained all annual records and the annual document log as of July 1, 1991, and each year thereafter? _____ Yes _____ No

a. Are the annual records and the annual document log prepared on a calendar year basis? _____ Yes _____ No

b. Has the facility retained the annual records and the annual document logs for at least three (3) years after it no longer used or stored PCBs or PCB Items? _____ Yes _____ No

c. Has the facility prepared and submitted to the EPA Regional Administrator annual reports by July 15th for each preceding

calendar year?

_____Yes _____No

13. Where are the records maintained? _____

a. How are the records compiled and by whom? _____

761.180(b)(1)(i) & (ii)

14. Do the facility's annual records contain the following:

a. All signed manifests generated or received by the facility during the calendar year? _____Yes _____No

facility

b. All Certificates of Disposal that have been generated or received by the facility during the calendar year? _____Yes _____No

received by

c. Records of inspections and clean-ups? _____Yes _____No

761.180(b)(2)(i) & (ii)

15. Does the written annual document log contain the following:

a. The name, address, and EPA identification number of the _____Yes _____No

facility?

b. The calendar year covered by the annual document log?

_____Yes _____No

c. The unique manifest number of every manifest generated _____ or received by the facility during the calendar year and the name _____ and address of the generator?

_____Yes _____No

761.180(b)(2)(ii)(A)

16. Does the written annual document log contain the following information from each manifest and for unmanifested waste that may be stored or disposed of at the facility:

Bulk PCB waste (e.g. in a tanker or truck) _____N/A

a. Its weight in kilograms? _____Yes _____No

b. The first date it was removed from service for disposal?
_____Yes _____No

c. The date it was received at the facility? _____Yes _____No

d. The date it was placed into transport for off-site storage or disposal?
_____Yes _____No

e. The date of disposal, if known? _____Yes _____No

761.180(b)(2)(ii)(B)

PCB Articles (e.g. transformer or capacitor) _____N/A

a. The serial number (if available) or other means of identifying each PCB Article (not in a PCB Container or PCB Article Container)?
_____Yes _____No

- b. The weight in kilograms of the PCB waste in each PCB Article? _____Yes
 _____No
- c. The date it was removed from service for disposal?
 _____Yes _____No
- d. The date it was received at the facility? _____Yes _____No
- e. The date it was placed in transport for off-site storage or disposal?
 _____Yes _____No
- f. The date of disposal, if known? _____Yes _____No

761.180(b)(2)(ii)(C)

PCB Containers _____N/A

- a. A unique number identifying each PCB Container?
 _____Yes _____No
- b. A description of the contents of each PCB Container?
 _____Yes _____No
- c. The total weight in kilograms of the material in each PCB Container?
 _____Yes _____No
- d. The first date material (PCB Waste) placed in each PCB Container was removed from service for disposal? _____Yes _____No
- e. The date it was received at the facility? _____Yes _____No
- f. The date each container was placed in transport for off-site storage or disposal? _____Yes _____No

g. The date of disposal, if known? _____Yes _____No

761.180(b)(2)(ii)(D)

PCB Article Containers _____N/A

a. A unique number identifying each PCB Article Container?
_____Yes _____No

b. A description of the contents of each PCB Article Container? _____Yes
_____No

c. The total weight in kilograms of the contents (PCB Waste) of each PCB Article
Container? _____Yes _____No

d. The first date a PCB Article placed into each container was removed from
service for disposal? _____Yes _____No

e. The date it was received at the facility? _____Yes _____No

f. The date the container was placed in transport for off-site storage or disposal?
_____Yes _____No

g. The date of disposal, if known? _____Yes _____No

17. Does the facility use EPA's "PCB VOLUNTARY FORM FOR THE ANNUAL REPORT" to document the
annual report? _____Yes _____No

761.180(b)(3)(i) & (ii)

18. Does the facility's annual report contain the following information:

a. The name, address, and EPA identification number of the facility? Yes
 No

b. A list of the numbers of all signed manifests of PCB waste initiated or received by the facility during the calendar year? Yes No

761.180(b)(3)(iii), (iv), (v), & (vi)

19. Does the facility's annual report include the total weights and total numbers, by PCB waste type (bulk, transformers, capacitors, article containers, and containers) in each of the following categories:

a. In storage at the facility at the beginning of the calendar year? Yes
 No

b. Received or generated at the facility during the calendar year? Yes
 No

c. Transferred to another facility during the calendar year?
 Yes No

d. Disposed of at the facility during the calendar year?
 Yes No

e. Remaining in storage for disposal at the facility at the end of the calendar year? Yes No

(Refer to EPA's "PCB Voluntary Form For The Annual Report" as a guide to answering this question)

Pertinent Comments

**SUBPART K - PCB WASTE DISPOSAL RECORDS AND REPORTS
(40 CFR Part 761.202-761.218)**

761.205(c)(2)
20. Is the facility exempt from the EPA notification requirements because it is only a generator of PCB waste through its use, owning, servicing or processing of PCBs or PCB items but does not own or operate a designated storage for disposal area subject to the requirements of §761.65(b) or §761.65(c)(7)? Yes No

If yes, skip to question 25c

761.202(c)
21. Has the facility engaged in PCB waste handling activities on or prior to February 5, 1990?
 Yes No

761.202
22. Has the facility applied for an EPA identification number?
 Yes No

If yes, what was the date of the application and has the ID number been officially issued?

If no, does the facility already have a RCRA identification number?

Yes No

761.205(b)

If the facility has a RCRA ID number, did it notify EPA of its PCB waste activities by April 4, 1990?

Yes No

761.205(c)(2)(iii)

23. Has the generator submitted separate notifications to EPA for each PCB storage area it owns or operates on different sites or properties? Yes No N/A

761.205(f)

24. Has the facility resubmitted a notification form within 30 days from the time that its waste handling activities changed?

Yes No N/A

25. If the facility did not engage in PCB waste activities until after February 5, 1990 and has not yet received an EPA identification number or if the facility engaged in PCB waste activities on or before February 5, 1990 but has not applied for an EPA identification number have any of the following occurred:

761.202(b)(c) & (d)

a. The facility is a generator of PCB waste and processed, stored, transported or offered for transport or disposed of such PCB waste after June 4, 1990? Yes No

761.202(b)(c)&(d)

b. The facility is not a generator of PCB waste but has engaged in transporting, commercial storage or disposal of such PCB waste after June 4, 1990? Yes No

761.202(b)(c)&d)

c. The facility is a generator that offered PCB waste to transporters, commercial storers, or disposers who have not received an EPA identification number? Yes No

761.202(b)(c)&(d)

d. The facility is not a generator of PCB waste but has delivered such waste to a transporter, commercial storer or a disposer that have not received an EPA identification number? Yes No

761.207(a)

26. Has the generator prepared a manifest whenever it ships PCB waste, including drained PCB contaminated transformers off-site? Yes No N/A

If No or N/A skip to question 33

761.207(a)

27. Was the manifest prepared on EPA Form 8700-22 with a continuation sheet if necessary? Yes No

If no, describe what manifest was used.

28. Was the following information specified on the manifest

761.207(a) (1)

a. For each bulk load of PCBs, its identification, the earliest date of removal from service for disposal and its weight in kilograms?

_____ Yes _____ No _____ N/A

761.207(a) (2)

b. For each PCB container or article container, an identification number, type of PCB waste, earliest date of removal from service for disposal and its weight in kilograms?

_____ Yes _____ No _____ N/A

761.207(a) (3)

c. For each PCB article, its serial number or other identification, date of removal from service for disposal and weight in kilograms of its PCB waste? _____ Yes _____ No

_____ N/A

761.207(g)

d. An approved off-site commercial storage or disposal facility for PCB waste? _____ Yes _____ No

761.209(a)

29. Did the generator of PCB waste, transporter or the storage or disposal facility retain on file copies of the appropriate manifests?

_____ Yes _____ No

761.209(a)

30. Were the manifests properly signed? _____ yes _____ no

761.208(a) (4)

31. Did the generator receive the hand signed manifest within 35 days after the PCB waste was accepted by the transporter?

Yes No N/A

761.208(a)(4)

If yes, did the generator confirm by telephone or other means (if shipped by an independent transporter) within a day after receiving the hand-signed manifest that the commercial storer or disposer actually received the manifested waste? Yes No N/A

761.208(a)(4)

If no, did the generator telephone or communicate by other means first with the commercial storer or disposer and then, if necessary, with the transporter to determine the status of the PCB waste?

Yes No N/A

761.208(a)(4)

32. If the generator has not received a hand-signed manifest from an EPA approved facility within 10 days from the date of the telephone call to the transporter, did it submit an exception report to the EPA Regional Administrator? Yes No N/A

761.211(a)

33. Is there evidence to indicate that either a transporter or a commercial storer or disposer accepted a shipment of PCB waste after April 4, 1990 without a properly signed manifest?

Yes No N/A

761.211(c)

If yes, describe and state whether an "Unmanifested Waste Report" was submitted to the EPA Regional Administrator within 15 days after the unmanifested PCB waste was received.

761.210(a)

34. Is there evidence to indicate that a significant discrepancy regarding the amount of PCB waste stated on the manifest occurred?

_____ Yes _____ No _____ N/A

761.210(b)

If yes, describe the discrepancy and attempts to reconcile it, and state whether a letter was submitted to the EPA Regional Administrator if it is was not resolved within 15 days after the PCB waste was received

the facility is a disposer of PCB waste Answer questions 35 and 36 if

761.215(c) (1) & (2)

35. Does the disposer submit to the EPA Regional Administer, no later than 45 days from the end of the one (1) year storage for disposal date a One-year Exception Report if it receives PCB or PCB items more than 9 months after they were removed from service for disposal and, it

could not dispose of the affected PCBs or PCB items within 1 year of the date of removal from service for disposal? _____Yes _____No

761.218(a)&(b)

36. Does the disposer prepare a Certificate of Disposal for each shipment of PCB waste that it accepts and does it send a copy to the generator identified on the manifest within 30 days of the date that disposal of the PCB waste was completed? _____Yes _____No

Answer question 37 if the facility is a generator or commercial storer of PCB waste

761.215(d)(1)&(2)

37. Does the generator or commercial storer submit to the EPA Regional Administrator, no later than 45 days, a One-year Exception Report if it transferred PCB or PCB items to the disposer within 9 months after they were removed from service for disposal and it either has not received, within 13 months after removal from service for disposal, a Certificate of Disposal confirming the disposal of the affected PCBs or PCB items or it receives a Certificate of Disposal confirming disposal more than 1 year after the date of removal from service? _____Yes _____No

Pertinent Comments

Addendum to PCB Checklist

The following items are not addressed in the checklists but, if the situation warrants, they should be addressed in the inspection report.

761.20(a)

1. Were any PCBs being used in other than a totally enclosed manner?

761.20(b)

2. Were PCBs being manufactured without an exception?

761.20(c)

3. Were PCBs being processed or distributed in commerce without an exception?
4. Does the facility have any waste oil? If so, collect a sample of it for PCB analysis. Also, determine whether any waste oil containing detectable concentrations of PCBs are being used as a sealant, coating or dust control agent.

5. If the facility used PCBs in a hydraulic or heat transfer system, collect samples of sludges from drainage systems near the hydraulic or heat transfer system.
6. If there were any spills or uncontrolled discharges of PCBs in excess of 50 ppm at the facility were they cleaned up in accordance with spill cleanup policy contained in 40 CFR 761.125?