REVISIONS					
ZONE	REV	DESCRIPTION	BY	APPROVED	DATE
	01	PUMP NAMES CHANGED PER DCN 9607/10-04	HPC		

PAR RING

CONCRETE WALL

CONTROL CENTER VAULT BUILDING 410

SUPPLY

RETURN

PSP TPP-J2-3

B4C91K TPP-J5-13

PTBIS TPP-J2-13

POWER SUPPLY SYNCHROTRON INJECTION KICKER

FM

TO PUMPS 301 & 302

TO SYNCHROTRON POWER SUPPLY

V-2-3 NC

V-1-3 NO NC

V-3-3A

V-2-2 NC

V-1-2 NO NC

V-3-1A

V-2-1 NC

V-1-1 NO NC

OHM

PPRPAR INJECTION WING

PPR-LT LINAC TUNNEL

B-3-2A

PPR-SB STAND-BY

PPRKLY KLYSTRON GALLERY

V-3-3B

V-3-2B

V-3-1B

FS

POLISHERS

TE-3 PSM-7

V-4-3

V-4-1

V-4-2

TE

TO KLYSTRON GALLERY

TO LINAC TUNNEL

TO CHILLED WATER SUPPLY

TEMPORARY DI WATER COOLING PACKAGE

PB 1 & 2 TDPJ1-L-10

PAR POWER SUPPLY ROOM B105

BUILDING 412 MEZZANINE EAST

PUMPS PPR-LT,PPRKLY, PPR-SB & PPRPAR SERVING KLYSTRON GALLERY, LINAC TUNNEL AND INJECTION WING

NO SCALE

JOHNSON CONTROLS TAG

XX-X
XXX-X

NC – NORMALLY CLOSED
NO – NORMALLY OPEN

PUMP
FILTER
UV LIGHT
BUTTERFLY VALVE
BALL VALVE
CHECK VALVE
PRESSURE RELIEF VALVE
PRESS. REDUCG REG.
BALL CONTROL VALVE
3-WAY CONTROL VALVE
BUTTERFLY CONTROL VALVE
OHM RESISTIVITY METER
SENSOR – DIFF. PRESS.
PRESSURE GAGE
FLOW SWITCH
FLOW METER
ULTRASONIC FLOWMETER
HOSE CONNECTION
TE TEMPERATURE SENSOR
FLEX CONNECTOR
THERMOMETER

ITEM	DRAWING / PART NUMBER	NOMENCLATURE OR DESCRIPTION	MATERIAL / SPEC	QTY

PARTS LIST / BILL of MATERIALS

UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS ARE IN INCHES. TOLERANCES: DECIMAL ± , ANGULAR ± °. SURFACE ROUGHNESS: ✓

DRAWN BY: H.P. CZERWINSKI 04/12/96
CHECKED BY: E.SWETIN 03/13/96
ENGINEERING APPROVAL: E.SWETIN 03/13/96
DESIGN LEADER: S.SHARMA 03/13/96
APPROVED BY: DATE
APPROVED BY: DATE
APPROVED BY: DATE
MATERIAL
ELECTRONIC FILE ISSUED: A2413301

THIS DRAWING IS THE PROPERTY OF ARGONNE NATIONAL LABORATORY ADVANCED PHOTON SOURCE

TITLE: PIPING AND INSTRUMENTATION DIAGRAM LINAC TUNNEL & GALLERY PUMPS PPR-LT, P-PRKLY, PPR-SB AND PPRPAR

SIZE: E | FSCM No.: 0HRH5 | DRAWING NUMBER: 21-100200 | REV.: 01
SCALE: 1:1 | DO NOT SCALE DRAWING | SHEET: 1 of 1