#### Brubaker Biography

Kenneth J. Brubaker is currently NRECA's Manager of Safety Programs for the National Rural Electric Cooperative Association. Safety Programs is now part of the CEO's Consulting Group under NRECA VP, Monica Schmidt.

Mr. Brubaker is a Certified Utility Safety Associate, CUSA, with the National Safety Council and a Certified Loss Control Professional, CLCP, with NRECA. Kenneth holds a degree in Business Management and Safety from Columbus State Community College since 1991.

Brubaker's Cooperative career began in May of 1972 in Northwest Ohio at Tricounty REC. Brubaker has served as a Safety Instructor with the Ohio Rural Electric Cooperatives and as the Compliance and Safety Coordinator with Butler Rural Electric Cooperative.

Kenneth and his spouse, Carol, currently live and work from their home in northwestern Ohio. The Brubakers are 2006 new members of Tricounty Rural Electric Cooperative and participate in water heater load control program and the cooperative's geothermal heating and cooling incentive program.

Favorite Airports include Toledo, Ohio and Washington DC, Dulles Airport. Travel pet peeve examples are separate security lines for first class passengers and travelers who block the moving walkways. Favorite travel destinations for return trips are Ireland and Yellowstone Park. Favorite foods are Carol's wild rice soup, chicken soup, pot of chili, potato salad, and Carol's homemade lasagna. Safety Pet peeve examples are management compliance panic after an accident, making heroes out of those who violated safety rules, or safety programs built entirely on minimum compliance standards. Favorite entertainment samples are Les Miserables, Mama Mia, and Ken Burns PBS specials. Favorite occupational reading, the Washington Post, RE Magazine, Country Living, and 29 CFR 1910.269.

Kenneth J. Brubaker, CUSA, CLCP NRECA, Manager Safety Programs 703-907-6414 ken.brubaker@nreca.coop





# May 23 - 25, 1966

• "The Insurance and Employee Welfare Committee, a Standing Committee of NRECA, held a special meeting in Atlanta, GA... to discuss the possibility of developing a Rural Electric System Safety Accreditation Program to further the cause of accident prevention in rural electrification."

• John Butler, Rural Electrification, July 1966







#### <u>"Recognition of Safety Accreditation Program"</u>

- At each of the 1966 regional meetings, a resolution favoring the Safety Accreditation Program was adopted.
- At the 1967 NRECA Annual Meeting, a final resolution was adopted by the national membership.
  - John Butler, Rural Electrification, April 1967







#### **RESAP** Delegates

- NRECA Board's Education Research and Technology Committee... Mark Hofer, Central EC, SD
- NRECA's Management Issues Committee...**Meera Kohler**, AK Villages EC, AK
- RUS... Harvey Bowles, USDA Rural Utilities Service, DC
- Distribution Manager... Randy Crenshaw, Irwin REC, GA
- RESMA... Dennis Hill, NDREA, ND
- G&T Managers Assn... Garry Christopherson, Dairyland Power Coop, WI
- Insurance Carrier... Michael Bird, Federated RE Insurance Exchange, KS
- NRECA... Monica Schmidt, National Consulting Group, VA
- NUTSEA Appointed... Michael Finerfrock, Northern Neck EC, VA
- NUTSEA Appointed... Dennis Corcoran, Iowa Association of Electric Co-ops, IA (Vice Chair/Sectry 2008 + 2009)
- NUTSEA G&T Rep... Robert Richhart, Hoosier Energy, IN (@hains 2008 + 2009)











# What RESAP is, does,

- Safety and Loss Prevention standard
- Focus on typical industry hazards
- Educates system management
- Updates system management
- Compliance supportive
- Enhances business goals
- Benchmark for electric utilities
- Internal and external audit
- Prioritizes industry safety issues







	Days of								
No of	Year of	Systems			Review Period				
Systems	Report	Accredited	2001	2002	2003	2004	2005	2006	115-0
130	2004	130 *	2914	4276	4325		mployee	ins/Emplo	Act Millio
164	2005	294 *		6305	4620	5519			
180	2006	474			5385	4532	4245		
179	2007	523		Total	14330	5327	5973	5435	
				2003 Avg =	30.2	15378			
*	Incomplete				2004 Avg =	29.4			
2/20	)/2008							17	

Noof	Vear of	Systems	ays o	of Los	Review Period	9	í	4	
Sustama	Banart	Appredited	2001	2002	2003	2004	2005	2006	
Systems	Report	Accredited	2001	2002	2003	2004	2003	2000	
130	2004	130 *	4013	5204	6769				
164	2005	294 *		9793	7936	7732			
180	2006	474			9213	7920	7316		
179	2007	523		Total	23918	7681	7647	7442	
				2003 System Avg =	50.5	23333			
* 2 /20 /2	Incomplete				2004 System Avg =	44.6		10	

	Fatalities Reported Thru RESAP System = 19								
No of	Year of	Accred			Review Period				
Syste ms	Report	Sys	2001	2002	2003	2004	2005	2006	
130	2004	130 *	3	1	1				
164	2005	294 *		1	3	1			
180	2006	474			1	2	0		
179	2007	523		2003 Tot =	5	2	2	2	
					2004 Tot =	5			
* 2/20/	Incomplete 22008							19	

	Ave	OSHA - Co rage Injury	ooperative N / Illness Inc	letwork sident Rat	tes
Rate Source	Report		Incident Rate 2007	DART Rate 2007	
OSHA	General Industry	Avg =	4.5	2.3	
72 179	Random Systems 2007 Applic.	Avg = Avg =	7.3 8.6	3.3 4.0	
*2/20/20	0dincomplete				20







## NESC 410 A 3 – paragraph 1

- Effective as of January 1, 2009, the employer shall ensure that an assessment is performed to determine potential exposure to an electric arc for employees who work on or near energized parts or equipment. [Position hazard assessment]
- If the assessment determines a potential employee exposure greater than 2 cal/cm2 exists (see Neal, Bingham, and Doughty [B59]), the employer shall require employees to wear clothing or a clothing system that has an effective arc rating not less than the anticipated level of arc energy.

### NESC 410 A 3 – paragraph 2 + 3

• When exposed to an electric arc or flame, clothing made from the following materials shall not be worn: acetate, nylon, polyester, or polypropylene.

• The effective arc rating of clothing or a clothing system to be worn at voltages 1000 V and above shall be determined using Tables 410-1 and 410-2 or performing an arc hazard analysis. [Arc energy potential]

## NESC 410 A 3 – paragraph 4

- "When an arc hazard analysis is performed, it shall include a calculation of the estimated arc energy based on the available fault current, the duration of the arc (cycles), and the distance from the arc to the employee."
- ArcPro confidence over 1000 v.
- IEEE 1584 confidence under 1000 v.
  http://www.arcadvisor.com/arcflash/ieee1584.html



### NESC 410 A 3 – Exception 1:

• If the clothing required by this rule has the potential to create additional and greater hazards than the possible exposure to the heat energy of the electric arc, then clothing with an arc rating or arc thermal performance value (ATPV) less than that required by the rule can be worn.

NESC 410 A 3 – Exception 2:

• For secondary systems below 1000 V, applicable work rules required by this part and engineering controls shall be utilized to limit exposure.

• In lieu of performing an arc hazard analysis, clothing or a clothing system with a minimum effective arc rating of 4 cal/cm2 shall be required to limit the likelihood of ignition.

## NESC 410 A 3 – Note 1:

- A clothing system (multiple layers) that includes an outer layer of flame resistant material and an inner layer of non-flame resistant material has been shown to block more heat than a single layer.
- The effect of the combination of these multiple layers can be referred to as the *effective arc rating*.

### 410 A 3 – Note 2:

• It is recognized that arc energy levels can be excessive with secondary systems. Applicable work rules required by this part and engineering controls should be utilized.





# Table 410 – 1 [Gloving]

Table 410-1—Clothing and clothing<br/>systems—voltage, fault current, and<br/>maximum clearing time for voltages 1 to<br/>46 kV (See Rule 410A3.)







31

		4-cal System	8-cal System	12-cal System
Phase-to- Phase Voltage	Fault Current (kA)	Maximum Clearing	Maximum Clearing	Maximum Clearing
(KV)		Time (cycles)	Time (cycles)	Time (cycles)
1 to 15	5	46.5	93.0	139.5
	10	18.0	36.1	54.1
	15	10.0	20.1	30.1
	20	6.5	13.0	19.5
15.1 to 25	5	27.6	55.2	82.8
	10	11.4	22.7	34.1
	15	6.6	13.2	19.8
2/20/2008	20	4.4	8.8	13. <u>2</u>

















